



Wireless Security Solutions



Available for...	
<input checked="" type="checkbox"/>	GE
<input checked="" type="checkbox"/>	Honeywell
<input checked="" type="checkbox"/>	2GIG
<input checked="" type="checkbox"/>	DSC

RE213 Honeywell-Compatible Carbon Monoxide Alarm

Features

- Senses and alarms to Carbon Monoxide per UL2034
- Sleek design
- Cover tamper.
- Strong, reliable RF signal.
- 3-5 year battery life on 3 Panasonic LR6-AA batteries.
- Low Battery indication.

Key Instructions

1. Attach the mounting plate
Locate on ceiling, or wall in or near sleeping areas.
Some local codes have specifications on CO detectors.
Mounting plate removes counter-clockwise
 2. Insert batteries making sure of polarity. Close battery door.
 3. Enroll sensor in panel:
 - a) Enter Zone Programming Mode (e.g. *56)
 - b) Zone Type = 14
 - c) Input type = Supervised RF Transmitter.
 - d) When asked for a serial number, press Tamper button
 - e) Select Loop 1 for CO
 4. Testing:
 - a) Place panel in Sensor Test mode.
 - b) Press & hold TEST button until you the sounder beep.
 - c) Panel will indicate the sensor is open, and alarm will sound.
- NOTE: Using CO-in-a-Can will cause an actual CO alarm.

Operation

Situation	Sounder	LED	Wireless Signal to Panel	Recovery
Actual CO	Temporal 3 (Loud) every 8 seconds	RED (pulsing)	Wireless CO Alarm Signal sent to panel	When CO is no longer present. TEST button will silence sensor for 4 minutes.
Press & hold Test Button	2 Temporal 4 Beeps (Loud)	RED, Green, & Yellow (pulsing)	Sensor Alarm signal to panel	Sensor: Release button. Panel: Clear alarm condition.
Removing Sensor from Mount	1 Beep (Loud) once every minute	Yellow (steady)	Tamper/Trouble signal to be sent to panel.	Restore by remounting.
Low Battery	1 beep (loud) every 60 seconds	Yellow (pulsing)	Low battery	
Hourly Check			Supervisories, every hour	
Maintenance Needed	1 Chirp every minute	Yellow flash every minute	Supervisories Not Sent	Replace Unit
Low Sensitivity	1 Chirp every minute	Yellow flash twice a minute	Supervisories Not Sent	Replace Unit
End Of Life	1 Chirp every minute	Yellow flashes 4 times a minute	Supervisories Not Sent	Replace Unit


Specifications

CO Sensitivity:	(UL2034)	
	70ppm	60-120 minutes
	150ppm	10-50 minutes
	400ppm	4-15 minutes
	(EN50291)	
	50ppm	60-90 minutes
	100ppm	10-40 minutes
	150ppm	3 minutes or less

CO Sensing Technology: Electrochemical

Alarm Sound: Temporal Three
 Replacement Battery: 3 Panasonic LR6-AA
 Temperature Range: 40 to 100 F (Long Term)
 Humidity: 0 - 95% Relative Humidity
 Housing dimensions: 4.9 inch diameter, 1.4 inch high

Specifications subject to change without notice.



Opening Cover



1. Press Down On Release Button

2. Slide Battery Door Down



3. Notice Battery Polarity

Notices

Verify proper enrollment and operation, per control panel installation instructions, at installation.

CARBON MONOXIDE ALARM M330 USER'S MANUAL, which is included in device box, is an integral part of the operating information of the RE213 device.

Approved as a self-contained carbon monoxide alarm per UL2034. This represents the ability of each individual sensor to sound locally upon sensed carbon monoxide conditions.

“GE”, “Interlogix”, “Honeywell”, “2GIG”, “DSC”, “Napco” are trademarks owned by General Electric Company, UTC Fire & Security Americas Corporation, Inc., Honeywell International Inc., 2GIG Technologies Inc., Tyco Safety Products Canada LTD, Napco Security Systems respectively.

Resolution Products, Inc. products will function with one of either GE/Interlogix, Honeywell and 2GIG, DSC or Napco. However, no Resolution product is produced by, endorsed by, nor is officially associated with any of these other manufacturers. Resolution recommends verifying proper enrollment and operation, per control panel installation instructions, at installation.

Warranty

Resolution Products, Inc. will replace products that are defective in their first five (5) years.

FCC Notice

This device complies with Part 15 of the FCC rules. Operation is subject to the following two conditions:

- (1) This device may not cause harmful interference.
- (2) This device must accept any interference that may be received, including interference that may cause undesired operation.

Changes or modifications not expressly approved by the Resolution Products, Inc. could void the user's authority to operate this equipment.

FCC ID: U5X-RE213

IC Notice

This device complies with Industry Canada license-exempt RSS standard(s). Operation is subject to the following two conditions:

- (1) This device may not cause interference, and
- (2) This device must accept any interference, including interference that may cause undesired operation of the device.

Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes :

- (1) l'appareil ne doit pas produire de brouillage, et
- (2) l'utilisateur de l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.

IC: 8310A-RE213