

Supplement

In your illustrated parts list manual, please change the note on operating the generator under freezing temperatures, in the Specifications section as shown below.

Replace This:

NOTE: If operating the generator under freezing temperatures (32°F), purchase an optional cold weather package from your local servicing dealer.

With This:



TO THE INSTALLER: If operating the generator below 0°F, a battery warmer and oil heater must be installed. Both items are available at your local servicing dealer.