



DVPDT02-H2 INSTRUCTION SHEET

安裝說明 安装说明

- DeviceNet Slave Communication Module
- DeviceNet 從站通訊模組
- DeviceNet 从站通讯模块



Warning

Please read this instruction sheet carefully before use and follow this instruction to operate the device in order to prevent damages on the device or injuries to staff.
Switch off the power before wiring.
This instruction sheet only provides introductory information on electrical specification, functions, wiring, trouble-shooting and peripherals for DVPDT02-H2. Details of DeviceNet protocol are not included in this sheet. For more information on DeviceNet protocol, please refer to relevant reference or literatures.
DVPDT02-H2 is an OPEN-TYPE device and therefore should be installed in an enclosure free of airborne dust, humidity, electric shock and vibration. The enclosure should prevent non-maintenance staff from operating the device (e.g. key or specific tools are required to open the enclosure) in case danger and damage on the device may occur.
DVPDT02-H2 is to be used for controlling the operating machine and equipment. In order not to damage it, only qualified professional staff familiar with the structure and operation of it can install, operate, wire and maintain it.
DO NOT connect input AC power supply to any of the I/O terminals; otherwise serious damage may occur. Check all the wiring again before switching on the power, and DO NOT touch any terminal when the power is switched on. Make sure the ground terminal (G) is correctly grounded in order to prevent electromagnetic interference.


Introduction

Thank you for choosing Delta DVPDT02-H2 DeviceNet communication module. DVPDT02-H2 can be applied to the connection with DVP-EH2 series PLC MPU in a DeviceNet network.

Features

- Supports Group 2 only servers.
- Supports explicit connection in the pre-defined master/slave connection group.
- The length of I/O data can be freely configured through DeviceNet network configuration tool.
- Supports polling.
- Supports EDS file in DeviceNet network configuration tools.
- I/O data is extendable to 200 bytes.

Product Profile & Outline



Specifications

DeviceNet Connector	
Type	Removable connector (5.08mm)
Transmission method	CAN
Transmission cable	2 communication cables, 2 power cables, 1 shielded cable
Electrical isolation	500V DC

Communication

Message type	I/O polling: explicit
Series transmission speed	125kbps; 250kbps; 500kbps (bits per second)
Equipment type	12
Company ID	799 (Delta Electronics, Inc.)

Electrical Specifications

DeviceNet	Voltage:11 ~ 25V DC (supplied by the power cable in the network) Current: 28mA (typical), 125mA impulse current (24V DC)
-----------	---

Environment


Standards	IEC 61131-2, UL508
Storage/operation	Storage: -25°C ~ 70°C (temperature), 5 ~ 95% (humidity) Operation: 0°C ~ 55°C (temperature), 50 ~ 95% (humidity), pollution degree 2
Shock/vibration immunity	International standards: IEC 61131-2, IEC 68-2-6 (TEST Fc)/IEC 61131-2 & IEC 68-2-27 (TEST Ea)
ESD (IEC 61131-2, IEC 61000-4-2)	8KV Air Discharge
EFT (IEC 61131-2, IEC 61000-4-4)	1KV
Analog & Communication I/O: 1KV	Damped-Oscillatory Wave: Power Line: 1KV, Digital I/O: 1KV
RS (IEC 61131-2, IEC 61000-4-3): 26MHz ~ 1GHz, 10V/m	
Certificates	CE, UL

Components

DeviceNet Connector

To connect to DeviceNet network, use the connector enclosed with DVPDT02-H2 or any connectors you can buy in the store for wiring.

PIN	Signal	Color	Description
1	V-	Black	0V DC
2	CAN_L	Blue	Signal-
3	SHIELD	-	Shielded cable
4	CAN_H	White	Signal+
5	V+	Red	24V DC



Node Address Setup Rotary Switch

The two rotary MAC ID setup switches set up the node addresses on DeviceNet network in decimal form. Setup range: 00 ~ 63 (64 ~ 99 are forbidden).

Rotary switch $\times 10^1$ $\times 10^0$
Multiple $\times 10^1$ $\times 10^0$ $\times 1$



Example: If you need to set the node address of DVPDT02-H2 as 26, simply switch the corresponding rotary switch of $\times 10^1$ to "2" and the corresponding rotary switch of $\times 10^0$ to "6".

Switch setting	Description
0...63	Valid DeviceNet MAC ID
64...99	Invalid DeviceNet MAC ID

Note: The changed values on switches are only valid when DVPDT02-H2 is re-powered. When DVPDT02-H2 is operating, changing the set value of MAC ID will be invalid.

Function Setup DIP Switch

The function setup switches are for:

- Setting up I/O data holding function (IN0)
- Setting up the baud rates of DeviceNet network (DR0 ~ DR1)

DR1	DR0	Baud rate
OFF	OFF	125kbps
OFF	ON	250kbps
ON	OFF	500kbps
ON	ON	Incorrect setting




Extension Port

The extension port on DVPDT02-H2 is used for the connection to the next DVPDT02-H2 or extension modules of DVP-EH2 series PLC MPU.

Basic Operation

Connecting DVPDT02-H2 to DVP-EH2 Series PLC MPU



Switch off DVP-EH2. Open the connection port on the right hand side of DVP-EH2 and connect DVPDT02-H2 to DVP-EH2. Switch on DVP-EH2, and DVP-EH2 will supply power to DVPDT02-H2. There is no need to connect DVPDT02-H2 to an external power supply.

Install DVP-EH2 and DVPDT02-H2 on DIN Rail

- Use 35mm DIN rail.
- Open the DIN rail clips on DVP-EH2 and DVPDT02-H2. Insert DVP-EH2 and DVPDT02-H2 onto the DIN rail.
- Clip up the DIN rail clips on DVP-EH2 and DVPDT02-H2 to fix DVP-EH2 and DVPDT02-H2 on the DIN rail.

As shown in the figure.


Connecting to DeviceNet Connector

- The colors of the PINs on the DeviceNet connector match the colors of the connection cables. Make sure you connect the cable to the right PIN.
- We recommend you also apply Delta's power module in the connection.

As shown in the figure.

Installation & Wiring

- Install DVPDT02-H2 in an enclosure with sufficient space around it to allow heat dissipation (see the figure).
- DO NOT place the I/O signal wires and power supply wire in the same wiring circuit.



D>50mm

Control Register

The control registers (CR) are the registers inside DVPDT02-H2. See the table below for the definitions of all the CRs DVP-EH2 series PLC MPU can read or write the CR allowed through DFROM/DTO instructions.

CR#	Attribute	Content	High byte	Low byte
#0	Read	Model name	DVPDT02-H2	Model code ~ H0230
#1	Read	Firmware version	Displaying the current firmware version in hex, e.g. V1.12 is indicated as H0112	
#2	Read	Length of I/O data	Length of input I/O data	Length of input I/O data
#3 ~ #102	Read/write	Input data mapping	Area for storing data from DVPDT02-H2 to DeviceNet master	
#103 ~ #202	Read/write	Output data mapping	Area for storing data from DeviceNet master to DVPDT02-H2	
#203 ~ #215			Set up by the system. DO NOT use it.	
#216 ~ #250			Reserved	
#251	Read	Error	Register for storing errors. See ① for error codes.	
#252 ~ #254			Reserved	
#255	Read	MPU status	CR#255 ~ K0: MPU in STOP status	CR#255 ~ K1: MPU in RUN status

注意事項

- 使用前請務必仔細閱讀本使用手冊，並依照手冊指示進行操作，以免造成產品受損或人員受傷。
- 配線時請務必關閉電源。
- 本使用手冊提供電源規格、功能規格、安裝配線、故障檢修及開關裝置等說明，本使用說明書僅作為DVPDT02-H2 操作指南和入門參考。DeviceNet 協定的詳細內容這裏不作介紹。如果使用者想瞭解更多DeviceNet 協定的內容，請參閱相關專業書或查詢資料。
- 本機器間接連接，因此使用者應使用本機器，必須將其安裝於具防塵、防潮及免於電擊 / 衝擊意外的外殼內並進行良好的接地。
- 本產品為固態繼電器，因此使用者應使用本機器，必須將其安裝於具防塵、防潮及免於電擊 / 衝擊意外的外殼內並進行良好的接地。
- 交流電源不可連接於輸入 / 輸出信號端，否則可能造成嚴重損壞。請在上電前再次確認電源配線，且請勿在電源接通後觸摸任何端子。本機器的接地端子，請務必正確的接地，以提高產品抗干擾能力。

產品簡介

能讓您在台達 DVPDT02-H2 網路配置模組、DVPDT02-H2 定義為 DeviceNet 網路模組，可用於 DeviceNet 網路與 DVP-EH2 系列 PLC 模主機的連接。

功能特色

- 支援 Group 2 only servers
- 在預定的主上從連接主上從連接主上支援邏輯
- IO 資料可通由 DeviceNet 網路配置工具自由配置
- 支援邏輯邏..

LED Indicators & Trouble-Shooting

There are 3 LED indicators on DVPDT02-H2. POWER indicator displays the status of working power. NS indicator and MS indicator display the connection status of the communication.

NS LED

LED status	Indication	How to deal with it?
Off	No power, or DVPDT02-H2 has not completed the Dup_MAC_ID test yet.	1. Check the power of DVPDT02-H2 and see if the connection is normal. 2. Check if the node connection on the network is normal. 3. Make sure at least one or more nodes on the network are operational at the same time and the baud rate is the same as that of DVPDT02-H2. 4. Check if the baud rate of DVPDT02-H2 is the same as that of the network.
Green light flashes	DVPDT02-H2 is on-line and has passed Dup_MAC_ID test but not established connections to other nodes.	Re-download the configured data to the master and set the master PLC to be RUN status.
Green light on	DVPDT02-H2 is on-line and is normally connected to the master.	--
Red light flashes	DVPDT02-H2 is on-line, but I/O connections are timed-out.	1. Check if the network connection is normal. 2. Check if the master operates normally.
Red light on	The communication is down; MAC ID is repeated; no network power; bus-off	1. Make sure all the MAC IDs on the network are not repeated. 2. Check if the network installation is normal. 3. Check if the baud rate of DVPDT02-H2 is consistent with that of the network.

MS LED

LED status	Indication	How to deal with it?
Off	No power	Check the power of DVPDT02-H2 and see if the connection is normal.
Green light	Waiting for I/O data; no I/O data; the program of DVPDT02-H2 is being edited.	Switch DVPDT02-H2 to RUN status to start I/O data exchange.
Green light on	I/O data are normal	--
Red light flashes	Recoverable fault	Re-power DVPDT02-H2
Red light on	Hardware error	1. Find out the cause of error in CR#251. 2. Send back to the factory for repair if necessary.

NS LED + MS LED

LED status	Indication	How to deal with it?
Off	No power	Check the power of DVPDT02-H2 and see if the connection is normal.
Green light on	DVPDT02-H2 has not completed the Dup_MAC_ID test yet.	Make sure at least one or more nodes on the network are operational at the same time and the baud rate is the same as that of DVPDT02-H2 module.
Red light on	No network power	1. Check if the network cable is correctly connected to DVPDT02-H2. 2. Check if the network power works normally.
Red light on	Dup_MAC_ID test has failed; bus-off	1. Make sure DVPDT02-H2 has a unique address. 2. Re-power DVPDT02-H2.
Red light on	Working power in low voltage	Check if the power of DVPDT02-H2 and MPU is normal.
F3	Entering test mode	Re-power DVPDT02-H2
F4	BUS-OFF	Re-power DVPDT02-H2
F5	No network power detected	1. Check if the network cable works normally. 2. Check if the network power works normally.
F7	Internal error: GPIO detection error.	Send your DVPDT02-H2 back to the factory for repair.
F8	Internal error: Manufacturing error.	Send your DVPDT02-H2 back to the factory for repair.
F9	Internal error: Configured memory polling error.	Send your DVPDT02-H2 back to the factory for repair.

Error Codes

Code	Description	How to deal with it?
00	DVPDT02-H2 operates normally.	--
E2	I/O off-line	1. Check if the network connection is normal. 2. Check if the master operates normally.
F0	Dup_MAC_ID test has failed.	1. Make sure DVPDT02-H2 has a unique address. 2. Re-power DVPDT02-H2.
F2	Working power in low voltage	Check if the power of DVPDT02-H2 and MPU is normal.
F3	Entering test mode	Re-power DVPDT02-H2
F4	BUS-OFF	Re-power DVPDT02-H2
F5	No network power detected	1. Check if the network cable works normally. 2. Check if the network power works normally.
F7	Internal error: GPIO detection error.	Send your DVPDT02-H2 back to the factory for repair.
F8	Internal error: Manufacturing error.	Send your DVPDT02-H2 back to the factory for repair.
F9	Internal error: Configured memory polling error.	Send your DVPDT02-H2 back to the factory for repair.

各部分元件介紹

DeviceNet 通訊連接器

接腳	信
----	---

■ 功能設定開關 (DIP)

功能設定開關為用戶提供以下功能

- 資料保持動作的設定 (IN0)
- DeviceNet 網路通訊速率的設定 (DR0 - DR1)

DR1	DR0	通訊速率
OFF	OFF	125kbps
OFF	ON	250kbps
ON	OFF	500kbps
ON	ON	錯誤設置
IN0	OFF	當 DeviceNet 連接斷開時, 不保持緩衝區內容。
IN0	ON	當 DeviceNet 連接斷開時, 保持緩衝區內容。
IN1		保留

DIPDT02-H2

DR1

DR0

IN1

IN0

IN0

IN1

IN0

IN0

IN1

IN1