

Jackson County

|                 |         |                 |
|-----------------|---------|-----------------|
| Building Type   | County  |                 |
| Police - County | Jackson |                 |
| Street          |         |                 |
| 787 W 8th St.   |         |                 |
| City            | State   | Zip             |
| Medford         | OR      | 97501           |
| Latitude        |         | Longitude       |
| 42.32198        |         | 122.87862       |
| Tracking Code   |         | Inspection Date |
| RVS in 2006     |         | 7/6/2006        |



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | C2   | 3.6         | 0          | -0.5       | 0        | 0          | 0      | -1.2   | 0      | 1.9       |
| Secondary | C1   | 3           | 0          | -0.5       | 0        | 0          | 0      | -1     | 0      | 1.5       |
| Tertiary  |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |

Jackson County Sheriff

Final RVS Score

Final Type      Final Score

C1

1.5

FEMA-154 Collapse Potential

Moderate (>1%)



|                        |                             |                          |                    |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment             | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built  |
|                        |                             |                          | 1960               |
| Total Area (square ft) | Number of Stories           | Basement                 | Pounding Potential |
|                        | 3                           | Yes                      | No                 |

|  |  |
|--|--|
| Plan Irregularities                            | Vertical Irregularities                |
| Out of Plane Lateral-Force-Resistance Elements | Steps in Elevation View: Single Change |
| None   | None                                   |
| None   | None                                   |

|                 |                 |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None            | None            |
| None            | None            |
| None            | None            |



NW Elevation View



SE Vertical Irregularity Primary