



3. AS A GENERAL GUIDE, THE MINIMUM CLEARANCE REQUIRED FROM ANY OBSTRUCTION IS:  
 6 FEET [1.83 METERS] ON INLET  
 3 FEET [.91 METERS] ON SIDES  
 8 FEET [2.44 METERS] ON EXHAUST  
 REVIEW MANUAL FOR DETAILED INSTALLATION AND SITE CONDITIONS.

2. ALL DIMENSIONS ARE APPROX. STANDARD & [METRIC]  
 1. WEIGHT: 1100 LBS, [499 KG] APPROX

NOTES:

FOR APPLICATION ENGINEERING USAGE ONLY

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.

CE315	D	ADDED METRIC DIMS.	FACKELMANN	1/23/06	D.KOZAR
CE303	C	ADDED DIMS 36.0 & 42.0 TO EXHAUST END. ADDED GROUND STUD	J.FLAUTO	1-4-06	D.KOZAR
CD783	B	REV PER EGN	FACKELMANN	9/1/04	J.W.EMERY
CD043	A	ADDED NOTE TO "CONDUIT ENTRY AREA"	MJ	5/3/02	EMERY
EON NO.	REV LET.	CHANGE	CHG'D	CHK'D	MODEL K675A

DRAWN	J.FLAUTO	DATE	3-25-02
CHECKED	J.FLAUTO	SCALE	1/16
APPROVED	J.HUDSON		

**AVTRON** MANUFACTURING, INC.  
 INDEPENDENCE, OH

**LOAD BANK**  
 (OUTDOOR)

DRAWING NUMBER	SB3227
SHEET 1 OF 1	
OUTLINE DRAWING	