

# INMETRO Hazardous Area Approvals for Fisher® i2P-100 Electro-Pneumatic Transducer Instruction Manual (D103198X012)

This supplement provides INMETRO Hazardous Area Approval information for the i2P-100 electro-pneumatic transducer instruction manual. Use this in conjunction with information provided in the instruction manual (D103198X012).

INMETRO—National Institute of Metrology, Quality and Technology. INMETRO approval is accepted in Brazil.

Certain nameplates may carry more than one approval, and each approval may have unique installation/wiring requirements and/or conditions of “safe use”. These special instructions for “safe use” are in addition to, and may override, the standard installation procedures. Refer to the instruction manual for all other information regarding i2P-100 electro-pneumatic transducers.

---

**Note**

This information supplements the nameplate markings affixed to the product.

Always refer to the nameplate itself to identify the appropriate certification.

---

**▲ WARNING**

**Failure to follow these conditions of “safe use” could result in personal injury or property damage from fire or explosion, and area re-classification.**

---

Certificate Number: 10-IEEx-0006X

Standards Used for Certification: ABNT NBR IEC 60079-0:2013; ABNT NBR IEC 60079-1:2009;  
ABNT NBR IEC 60079-11:2013

Conditions of Safe Use (X):

- For applications of intrinsically safe version in Zone 0 (EPL Ga), considering that the equipment enclosure is aluminum, precautions must be taken to prevent ignitions caused by impact or friction.


Refer to table 1 for additional approval information and figure 1 for a typical INMETRO approval nameplate.



Table 1. Hazardous Area Classifications

Certification Obtained	Entity Rating	Temperature Code	Enclosure Rating
Intrinsically Safe Gas Ex ia IIC T3/T4/T5 Ga	$U_i \leq 30$ VDC $I_i \leq 100$ mA $P_i \leq 1.0$ W $C_i = 0$ uF $L_i = 0$ uH	T3 ( $T_{amb} \leq 85^\circ\text{C}$ ) T4 ( $T_{amb} \leq 81^\circ\text{C}$ ) T5 ( $T_{amb} \leq 46^\circ\text{C}$ )	IP64
Flameproof Gas Ex d IIC T5/T6 Gb	---	T5 ( $T_{amb} \leq 85^\circ\text{C}$ ) T6 ( $T_{amb} \leq 75^\circ\text{C}$ )	IP64

Figure 1. Typical INMETRO Approval Nameplate



Neither Emerson, Emerson Process Management, nor any of their affiliated entities assumes responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use, and maintenance of any product remains solely with the purchaser and end user.

Fisher is a mark owned by one of the companies in the Emerson Process Management business unit of Emerson Electric Co. Emerson Process Management, Emerson, and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Process Management  
 Marshalltown, Iowa 50158 USA  
 Sorocaba, 18087 Brazil  
 Chatham, Kent ME4 4QZ UK  
 Dubai, United Arab Emirates  
 Singapore 128461 Singapore

www.Fisher.com