

Installation and User Instructions for the GCS® USB-DTU

This leaflet provides user and installation instructions for the Universal Serial Bus (USB) version of the ProxiPen Data Termination Unit (DTU). The unit is equipped with both a 9-pin RS232 port and a USB port, enabling the unit to communicate with a PC running the WinDau or Top Guard software through either port.

When using the RS232 port, the unit must be powered from a separate 9Vdc power supply. When using the USB port, power is provided through the USB cable.



1 Installing the DTU

If you are using the USB interface, connect a standard A-to-B USB cable to the unit.

If you are using the RS232 interface, connect a 9-pin modem-type serial cable to the unit. When using the RS232 interface, an external 9-volt power supply must also be connected to the 2.5mm Jack socket.

2 Using the DTU

Communications between the Proxy Pen and DTU is wireless and simply requires the pen to be placed in the cradle at the top of the DTU.

To download data from the Proxy Pen, please refer to the Top Guard or WinDau software manual.

About the LEDs

Power – Lit when you connect the external 9Vdc power supply or USB cable from the PC.

Pen – Lit when the Proxy Pen is in the cradle and communicating with the DTU.

Modem – Lit if the DTU recognizes a modem connected to its RS232 port.

Data – Lit when data is being transferred from the Proxy Pen to the DTU, or vice versa.

Online – Lit when you connect the DTU to a PC. If you are connecting via the USB port, the PC must have the Top Guard or WinDau software installed for the LED to illuminate.

9600-0391. Installation and User Instructions for the USB Data Termination Unit, Issue 1.0x2 14th January 2004. © General Control Systems, 2004.

FCC Notice: This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Any unauthorized modification to this device may void the authority of the user to operate it.

All trademarks acknowledged. GCS is a trademark of General Control Systems.

Specifications

External supply (only when RS232 connection used): 9Vdc.

Input current; 30mA.

Operating temperature: 32 to 95°F (0 to 35°C).

Operating humidity: 15 to 90%, non-condensing.

Approvals: EN300 330, R&TTE.