

## Installation Manual Addendum for Meter Radio Modules

FCC IDs: OWS-NIC507, OWS-NIC508, OWS-NIC509,  
OWS-NIC511, OWS-NIC514

NOTE: For electric meters using these modules, when mounted with other meters in meter room installations, the minimum separation distance between meters and persons shall be at least 29 cm to comply with FCC and Industry Canada RF exposure requirements