

TempTrak

Liberator

Wireless Bar Code Reader
&
Temperature Sensor

Operating Instructions

Revision A

Katchall Technology Group
5800 Creek Road
Cincinnati, Ohio 45242
(800) 533-6900

Owner's Record

The serial number for the TempTrak Liberator unit is located on the side of the plastic case attached to the bottom of the bar code reader assembly. Record the serial number in the space provided below. Refer to this number whenever you call upon your Katchall dealer regarding this product.

Serial Number: TTC_____TT

Important Safety Instructions

When using the Temptrak Liberator unit, observe the following safety instructions:

1. Read and understand all instructions.
2. Unplug this product from the re-charger cable before cleaning. Wipe with a damp cloth to clean. Avoid getting moisture on the electronic connections.
3. Do not submerge the product in a liquid. Damage to the electronics will occur.
4. When storing the unit, securely place the unit onto a flat surface. Failure to do so may result in the unit falling to the ground, possibly damaging the product.
5. The unit is powered via an internal battery. Do not use the unit while the unit is re-charging.
6. Re-charge the internal battery only via the plug-in power converter provided with the unit.
7. Do not disassemble the product. Contact your Katchall dealer if problems arise in the operation of the unit.

The TempTrak Liberator unit is powered via an internal battery. Observe the following instructions to avoid injury to persons or food products:

1. Do not attempt to modify or replace the internal battery. Contact your Katchall dealer if the battery needs replacing.
2. Do not dispose of the Liberator unit in a fire. The battery within the unit may explode. Check with local codes for possible special disposal instructions.

Wireless Operation

The TempTrak Liberator unit communicates to the other devices in the TempTrak system via radio frequency (RF) energy. Careful placement of the unit is required to insure consistent RF communications with other TempTrak devices. The following general considerations apply to placement of the TempTrak Liberator unit:

1. In general, the TempTrak Liberator will communicate with a TempTrak Commander or Echo unit at ranges up to 150 feet. This range applies only to clear line-of-sight transmission in which there are no physical obstructions between the TempTrak Liberator unit and the TempTrak Commander unit. A simple way to insure line-of-sight transmission is to verify that you can physically see one unit when standing at eye level with the other unit.
2. The TempTrak Liberator unit will communicate with other TempTrak devices through walls. The range at which communication through a wall can be achieved is a function of the materials from which the wall is constructed. Any solid metallic materials greater than 1 square foot in area within the direct transmission path will block the RF transmissions. In general, the following rule

of thumb can be used for transmission ranges through interior walls (drywall construction is assumed, actual performance will vary significantly due to differences in construction material and their subsequent impact on RF transmission):

0 walls → 150 feet
1 wall → 75 feet
2 walls → 50 feet
3 walls → 35 feet
4 walls → 25 feet
5 walls → 15 feet

3. Placement of the operator's body between the TempTrak Liberator unit and the TempTrak Commander units will decrease the effective range of the unit.
4. Do not place the TempTrak Liberator unit near a cordless telephone base unit. Interference may result.
5. Operation of cordless phones and cell phones in near proximity to the TempTrak Liberator unit may result in interference.

Information To The User

NOTE: The TempTrak Liberator unit has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encourage to try to correct the interference by one or more of the following measures:

1. Reorient or relocate the receiving antenna.
2. Increase the separation between the equipment and receiver.
3. Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
4. Consult the dealer or an experienced radio/TV technician for help.

Caution To User: changes or modifications to this equipment that are not expressly approved by the party responsible for FCC compliance could void the user's authority to operate this equipment.

System Operation

Please refer to the TempTrak system operations manual for detailed instructions on how to place and integrate TempTrak Liberator units into a fully operational TempTrak system.