


METAL CAP  
BOTH ENDS




4 TAPPED HOLES Ø1/2"-13+.015 OVERSIZE  
.62 (16) MIN. FULL THREAD ON 3.0 (76) B.C.  
BOTH ENDS.

Reference	Color
084201111	LT. GRAY No. 70
084201101	BROWN

MARK  

 ANSI TR-202  
 NBA 96 kV  
 9 kN  
 YEAR - DAY



**NOTES**

- DIMENSIONS ARE INCHES (MILIMETERS)
- ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM-A153
- MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9.

**DIMENSIONS**

LEAKAGE DISTANCE, Inch (mm) 10.50 ( 267 )

**MECHANICAL VALUES**

CANTILEVER STRENGTH, pounds (kN) 2000 ( 9 )  
 TENSILE STRENGTH, pounds (kN) 7000 ( 31.1 )  
 TORSION STRENGTH, Inch-pounds (kN-m) 6000 ( 0.67 )  
 COMPRESSION STRENGTH, pounds (kN) 10000 ( 44.4 )



**ELECTRICAL VALUES**

VOLTAGE CLASS, kV 7.5  
 CRITICAL IMPULSE FLASHOVER, POS., kV 105  
 LOW FREQUENCY WET WITHSTAND, kv 30  
 IMPULSE WITHSTAND, kV 95


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV 5  
 MAXIMUM RIV AT 1000 kHz, MICROVOLTS 50

NOTE: TO PURCHASER  
 ALL SALES OF GAMMA PRODUCTS ARE  
 SUBJECT TO OUR STANDARD TERMS  
 AND CONDITIONS AND THE LIMITED  
 WARRANTIES THEREUNDER.

<b>REVISION HISTORY</b>		<b>DATE</b>	<div></div>	<div></div>	<b>PART NUMBER</b>	
DRAWING CREATED		2010-01-14			8425	
				in. (mm)	8425	
				<b>TITLE</b>		
				POST TYPE INSULATOR TR-205		
<b>REF.</b> TR-205						


METAL CAP  
BOTH ENDS



4 TAPPED HOLES Ø1/2"-13+.015 OVERSIZE  
.62 (16) MIN. FULL THREAD ON 3.0 (76) B.C.  
BOTH ENDS.

Reference	Color
084251111	LT. GRAY No. 70
084251101	BROWN

MARK



**NOTES**

1. DIMENSIONS ARE INCHES (MILIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM-A153
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9.

**DIMENSIONS**

LEAKAGE DISTANCE, Inch (mm) 15.50 (394)

**MECHANICAL VALUES**

CANTILEVER STRENGTH, pounds (kN) 2000 (9)  
TENSILE STRENGTH, pounds (kN) 8500 (37.8)  
TORSION STRENGTH, Inch-pounds (kN-m) 7000 (0.79)  
COMPRESSION STRENGTH, pounds (kN) 10000 (44.4)

**ELECTRICAL VALUES**

VOLTAGE CLASS, kV 15  
CRITICAL IMPULSE FLASHOVER, POS., kV 125  
LOW FREQUENCY WET WITHSTAND, kv 45  
IMPULSE WITHSTAND, kV 110


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV 10  
MAXIMUM RIV AT 1000 kHz, MICROVOLTS 50

NOTE: TO PURCHASER  
ALL SALES OF GAMMA PRODUCTS ARE  
SUBJECT TO OUR STANDARD TERMS  
AND CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER.

<b>REVISION HISTORY</b>	<b>DATE</b>	<b>PART NUMBER</b>
DRAWING CREATED	2010-01-14	8428
<b>GAMMA</b> corona		in. (mm)
<b>TITLE</b>		POST TYPE INSULATOR TR-208
<b>REF.</b>	TR-208	



METAL CAP  
BOTH ENDS



4 TAPPED HOLES Ø1/2"-13+.015 OVERSIZE  
.62 (16) MIN. FULL THREAD ON 3.0 (76) B.C.  
BOTH ENDS.

Reference	Color
084281111	LT. GRAY No. 70
084281101	BROWN

MARK



#### NOTES

1. DIMENSIONS ARE INCHES (MILIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM-A153
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9.

#### DIMENSIONS

LEAKAGE DISTANCE, Inch (mm) 24 (610)

#### MECHANICAL VALUES

CANTILEVER STRENGTH, pounds (kN) 2000 (9)  
TENSILE STRENGTH, pounds (kN) 10000 (44.4)  
TORSION STRENGTH, Inch-pounds (kN-m) 8000 (0.90)  
COMPRESSION STRENGTH, pounds (kN) 10000 (44.4)

#### ELECTRICAL VALUES

VOLTAGE CLASS, kV 23  
CRITICAL IMPULSE FLASHOVER, POS., kV 170  
LOW FREQUENCY WET WITHSTAND, kv 80  
IMPULSE WITHSTAND, kV 150

#### RADIO INFLUENCE VOLTAGE

TEST VOLTAGE, RMS TO GROUND, kV 15  
MAXIMUM RIV AT 1000 kHz, MICROVOLTS 100

NOTE: TO PURCHASER  
ALL SALES OF GAMMA PRODUCTS ARE  
SUBJECT TO OUR STANDARD TERMS  
AND CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER.


DWG. No. P:8428 /8428-CLIENTE


DWG. No. TYPE SALES

Autocad 2000


DWN. L.E. RINCÓN

APP. A.I.PÉREZ



<b>REVISION HISTORY</b>	<b>DATE</b>	<b>GAMMA corona</b>	<b>PART NUMBER</b>
DRAWING CREATED	2010-01-14		8435
		in. (mm)	
		<b>TITLE</b>	POST TYPE INSULATOR TR-214
<b>REF.</b>	TR-214		


METAL CAP  
BOTH ENDS



4 TAPPED HOLES Ø1/2"-13+.015 OVERSIZE  
.62 (16) MIN. FULL THREAD ON 3.0 (76) B.C.  
BOTH ENDS.

MARK

**GAMMA corona**  
ANSI TR-214  
NBA 250 kV  
9 kN  
YEAR - DAY



Reference	Color
084351111	LT. GRAY No. 70
084351101	BROWN

#### NOTES

1. DIMENSIONS ARE INCHES (MILIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM-A153
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9.

#### DIMENSIONS

LEAKAGE DISTANCE, in (mm) 43 (1092)

#### MECHANICAL VALUES

CANTILEVER STRENGTH, pounds (kN) 2000 (9)  
TENSILE STRENGTH, pounds (kN) 14000 (62.2)  
TORSION STRENGTH, in-pounds (kN-m) 12000 (1.35)  
COMPRESSION STRENGTH, pounds (kN) 15000 (66.7)

#### ELECTRICAL VALUES

VOLTAGE CLASS, kV 46  
CRITICAL IMPULSE FLASHOVER, POS., kV 280  
LOW FREQUENCY WET WITHSTAND, kv 100  
IMPULSE WITHSTAND, kV 250

#### RADIO INFLUENCE VOLTAGE

TEST VOLTAGE, RMS TO GROUND, kV 30  
MAXIMUM RIT AT 1000 kHz, MICROVOLTS 200

NOTE: TO PURCHASER  
ALL SALES OF GAMMA PRODUCTS ARE  
SUBJECT TO OUR STANDARD TERMS  
AND CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER.

DWG. No. P:8435 /8435-CLIENTE

DWG. No. TYPE SALES

Autocad 2000


DWN. L.E. RINCÓN

APP. A.I.PÉREZ

<b>REVISION HISTORY</b>		<b>DATE</b>	<b>PART NUMBER</b>	
DRAWING CREATED		2010-01-15	8436	
<b>GAMMA corona</b>		in. (mm)		
<b>TITLE</b>		POST TYPE INSULATOR TR-216		
<b>REF.</b>		TR-216		

METAL CAP BOTH ENDS

4 TAPPED HOLES Ø1/2"-13+.015 OVERSIZE  
.62 (16) MIN. FULL THREAD ON 3.0 (76) B.C.  
BOTH ENDS.



Reference	Color
084361111	LT. GRAY No. 70
084361101	BROWN

- NOTES**
1. DIMENSIONS ARE INCHES (MILIMETERS)
  2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM-A153
  3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9.

<b>DIMENSIONS</b>	
LEAKAGE DISTANCE, in (mm)	72 (1829)

<b>MECHANICAL VALUES</b>	
CANTILEVER STRENGTH, pounds (kN)	1500 (6.7)
TENSILE STRENGTH, pounds (kN)	16000 (71.2)
TORSION STRENGTH, in-pounds (kN-m)	15000 (1.69)
COMPRESSION STRENGTH, pounds (kN)	25000 (111.2)

<b>ELECTRICAL VALUES</b>	
VOLTAGE CLASS, kV	69
CRITICAL IMPULSE FLASHOVER, POS., kV	390
LOW FREQUENCY WET WITHSTAND, kv	145
IMPULSE WITHSTAND, kV	350

<b>RADIO INFLUENCE VOLTAGE</b>	
TEST VOLTAGE, RMS TO GROUND, kV	44
MAXIMUM RIT AT 1000 kHz, MICROVOLTS	200

NOTE: TO PURCHASER  
ALL SALES OF GAMMA PRODUCTS ARE  
SUBJECT TO OUR STANDARD TERMS  
AND CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER.

Technical reference number:

TR 286

BIL 550 kV



TITLE

PART NUMBER


286SU0550

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View


4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø5.0 (Ø127)



Ø6.22 (Ø158)


Ø8.46 (Ø215)



(21 Sheds) 45.0 ±0.06 (1143 ±1.6)

Ø8.46 (Ø215)

Ø6.22 (Ø158)



Bottom Flange View

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

#### Marks

**GAMMA** CERISOL EUROPE  
Year-month  
Serial number  
286SU0550  
TR286  
SC907

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom
S2907EJ	TR286 SC907	143 lb 65 kg	4 holes 5/8-11UNC 4 holes 5/8-11UNC

#### NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

#### DIMENSIONS

NOMINAL LEAKAGE DISTANCE, in (mm)	101	(2565)
MINIMUM LEAKAGE DISTANCE, in (mm)	99	(2515)

#### MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1700	(7562)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1700	(7562)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

#### ELECTRICAL VALUES

GUARANTEED VOLTAGES:	
CRITICAL IMPULSE FLASHOVER, POS., kV	610
LOW FREQUENCY WET WITHSTAND, kV	230
IMPULSE WITHSTAND, kV	550

#### RADIO INFLUENCE VOLTAGE


TEST VOLTAGE, RMS TO GROUND, kV	73
MAXIMUM RIV AT 1 MHz, µV	200

#### Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.

Shed Profile




NOTE: TO PURCHASER ALL SALES OF GAMMA PRODUCTS ARE SUBJECT TO OUR STANDARD TERMS AND CONDITIONS AND THE LIMITED WARRANTIES THEREUNDER

DWG. No.: H21286EJ | DWG. TYPE SALES | Date: 2015/07/01 | DWN: A.MEJIA A. | APP: C. JARAMILLO

Technical reference number:

TR 287

BIL 550 kV




PART NUMBER

287HU0550

TITLE

STATION POST INSULATOR. HIGH STRENGTH



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Marks	
Year-month	
Serial number	
287HU0550	
TR287	
SC914	

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom
S2914EJ	TR287 SC914	172 lb 78 kg	4 holes 5/8-11UNC 4 holes 5/8-11UNC

#### NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

#### DIMENSIONS

NOMINAL LEAKAGE DISTANCE, In (mm)	101	(2565)
MINIMUM LEAKAGE DISTANCE, In (mm)	99	(2515)

#### MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	2600	(11565)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	2600	(11565)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(112000)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

#### ELECTRICAL VALUES

GUARANTEED VOLTAGES:

CRITICAL IMPULSE FLASHOVER, POS., kV	610
LOW FREQUENCY WET WITHSTAND, kV	230
IMPULSE WITHSTAND, kV	550


#### RADIO INFLUENCE VOLTAGE

TEST VOLTAGE, RMS TO GROUND, kV	73
MAXIMUM RIV AT 1 MHz, µV	200

#### Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.



NOTE: TO PURCHASER ALL SALES OF GAMMA PRODUCTS ARE SUBJECT TO OUR STANDARD TERMS AND CONDITIONS AND THE LIMITED WARRANTIES THEREUNDER



Technical reference number:

TR 288

BIL 650 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)


TITLE

PART NUMBER

288SU0650

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View



Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.22 (Ø158)

Ø8.46 (Ø215)

(25 Sheds) 54.0 ±0.06 (1372 ±1.6)

Ø8.46 (Ø215)

Ø6.22 (Ø158)

Bottom Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)
**Marks**
**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
288SU0650  
TR288  
SC6905

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom
S26905EJ	TR288 SC6905	159 lb 72 kg	4 holes 5/8-11UNC 4 holes 5/8-11UNC

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	121	(3073)
MINIMUM LEAKAGE DISTANCE, in (mm)	116	(2946)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1400	(6227)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1400	(6227)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:

CRITICAL IMPULSE FLASHOVER, POS., kV	710
LOW FREQUENCY WET WITHSTAND, kV	275
IMPULSE WITHSTAND, kV	650


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	88
MAXIMUM RIV AT 1 MHz, µV	200

**Other characteristics:**
Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.

Shed Profile



**NOTE:** TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21288EJ

DWG: TYPE SALES

Date: 2015/07/01

DWN: A.MEJIA A.

APP: C. JARAMILLO

Technical reference number:

TR 289

BIL 650 kV



in (mm)


PART NUMBER

289HU0650

TITLE

STATION POST INSULATOR. HIGH STRENGTH

Top Flange View



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø5.0 (Ø127)

Ø6.3 (Ø160)

Ø9.06 (Ø230)

Marks	
Year-month	
Serial number	
289HU0650	
TR289	
SC913	

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom
S2913EJ	TR289 SC913	201 lb 91 kg	4 holes 5/8-11UNC 4 holes 5/8-11UNC

#### NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

#### DIMENSIONS

NOMINAL LEAKAGE DISTANCE, in (mm)	121	(3073)
MINIMUM LEAKAGE DISTANCE, in (mm)	116	(2946)

#### MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	2200	(9786)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	2200	(9786)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

#### ELECTRICAL VALUES

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	710	
LOW FREQUENCY WET WITHSTAND, kV	275	
IMPULSE WITHSTAND, kV	650	

#### RADIO INFLUENCE VOLTAGE

TEST VOLTAGE, RMS TO GROUND, kV	88	
MAXIMUM RIV AT 1 MHz, µV	200	

#### Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70


Metal parts assembled with Portland cement.

(25 Sheds) 54.0 ±0.06 (1372 ±1.6)

Ø9.06 (Ø230)

Ø6.3 (Ø160)


Bottom Flange View



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø5.0 (Ø127)

Shed Profile



NOTE: TO PURCHASER ALL SALES OF GAMMA PRODUCTS ARE SUBJECT TO OUR STANDARD TERMS AND CONDITIONS AND THE LIMITED WARRANTIES THEREUNDER

Technical reference number:

TR 291

BIL 750 kV




in (mm)

PART NUMBER

291SU0750

TITLE STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

**Marks**

**GAMMA CERISOL EUROPE**  
Year-month  
Serial number  
291SU0750  
TR291  
SC911

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom
S2911EJ	TR291 SC911	185 lb 84 kg	4 holes 5/8-11UNC 4 holes 5/8-11UNC

Ø6.22 (Ø158)

Ø8.78 (Ø223)

(27 Sheds) 62.0 ±0.09 (1575 ±2.4)

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	134	(3404)
MINIMUM LEAKAGE DISTANCE, in (mm)	132	(3353)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1200	(5338)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1200	(5338)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:	
CRITICAL IMPULSE FLASHOVER, POS., kV	810
LOW FREQUENCY WET WITHSTAND, kV	315
IMPULSE WITHSTAND, kV	750

**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	103
MAXIMUM RIV AT 1 MHz, µV	500


**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.

Ø8.78 (Ø223)


Ø6.22 (Ø158)



Bottom Flange View

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Shed Profile




**NOTE:** TO PURCHASER ALL SALES OF GAMMA PRODUCTS ARE SUBJECT TO OUR STANDARD TERMS AND CONDITIONS AND THE LIMITED WARRANTIES THEREUNDER

Technical reference number:

TR 295

BIL 750 kV



PART NUMBER

295HU0750

TITLE

STATION POST INSULATOR. HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

**Marks**

**GAMMA CERISOL EUROPE**  
Year-month  
Serial number  
295HU0750  
TR295  
SC916

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom
S2916EJ	TR295 SC916	230 lb 104 kg	4 holes 5/8-11UNC 4 holes 5/8-11UNC

Ø6.3 (Ø160)

Ø9.53 (Ø242)

(27 Sheds) 62.0 ±0.09 (1575 ±2.4)

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	134	(3404)
MINIMUM LEAKAGE DISTANCE, In (mm)	132	(3353)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1850	(8229)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1850	(8229)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:	
CRITICAL IMPULSE FLASHOVER, POS., kV	810
LOW FREQUENCY WET WITHSTAND, kV	315
IMPULSE WITHSTAND, kV	750

**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	103
MAXIMUM RIV AT 1 MHz, µV	500

**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.

Ø9.53 (Ø242)


Ø6.3 (Ø160)

Bottom Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Shed Profile



**NOTE:** TO PURCHASER ALL SALES OF GAMMA PRODUCTS ARE SUBJECT TO OUR STANDARD TERMS AND CONDITIONS AND THE LIMITED WARRANTIES THEREUNDER

Technical reference number:

TR 304

BIL 900 kV

GAMMA

CERISOL  
EUROPE

in (mm)

TITLE

PART NUMBER

304SU0900

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø5.0 (Ø127)

Ø6.22 (Ø158)

Ø8.39 (Ø213)

UNIT 1

Ø8.39 (Ø213)

Ø9.25 (Ø235)

Ø7.87 (Ø200)

Ø8.39 (Ø213)

UNIT 2

Ø8.39 (Ø213)

Ø6.22 (Ø158)

Ø5.0 (Ø127)

Bottom Flange View

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

**Marks**

GAMMA CERISOL  
EUROPE  
Year-month  
Serial number  
304SU0900  
TR304  
SC912

**Assembly:**

	Assembly:				
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S2912EJ	TR304 SC912	128 lb 58 kg	4 holes 5/8-11UNC 4xØ18xØ200	4xM16 Bolts 4xM16 Nuts 4 Washers
UNIT 2	S3912EJ	TR304 SC912	128 lb 58 kg	4xØ18xØ200 4 holes 5/8-11UNC	
Total Weight:		256 lb 116 kg			

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	171	(4343)
MINIMUM LEAKAGE DISTANCE, in (mm)	165	(4191)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	950	(4226)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	950	(4226)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1010	
LOW FREQUENCY WET WITHSTAND, kV	385	
IMPULSE WITHSTAND, kV	900	

**RADIO INFLUENCE VOLTAGE**


TEST VOLTAGE, RMS TO GROUND, kV	146
MAXIMUM RIV AT 1 MHz, µV	500

**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)



NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21304EJ

DWG: TYPE SALES

Date: 2015/07/01

DWN: A.MEJÍA A.

APP: C. JARAMILLO

Technical reference number:

TR 308

BIL 900 kV

**GAMMA** | **CERISOL**  
EUROPE



in (mm)

PART NUMBER

308HT0900

TITLE

STATION POST INSULATOR. HIGH STRENGTH



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

**Marks**

**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
308HT0900  
TR308  
SC6904

**Assembly:**

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S26904EJ	TR308 SC6904 174 lb 79 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts 4x Washers
UNIT 2	S36904EJ	TR308 SC6904 174 lb 79 kg	4 holes 5/8-11UNC 4xØ18xØ225	
Total Weight:		348 lb 158 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	170	(4318)
MINIMUM LEAKAGE DISTANCE, In (mm)	165	(4191)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1450	(6450)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1010	
LOW FREQUENCY WET WITHSTAND, kV	385	
IMPULSE WITHSTAND, kV	900	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	146	
MAXIMUM RIV AT 1 MHz, µV	500	

**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.



NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21307EJ | DWG: TYPE SALES | Date: 2015/07/07 | DWN: A.MEJÍA A. | APP: C. JARAMILLO

Technical reference number:

TR 308

BIL 900 kV

**GAMMA** | **CERISOL**  
EUROPE



in (mm)

PART NUMBER

308HU0900

TITLE

STATION POST INSULATOR. HIGH STRENGTH



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

**Marks**

**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
308HU0900  
TR308  
SC6904

**Assembly:**

Unit	Unit	Weight:	Fixation:	Galvanized
Part n°	Shed ID		Top / Bottom	Steel:
UNIT 1	S26904EJ	TR308 SC6904 174 lb 79 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts
UNIT 2	S36904EJ	TR308 SC6904 174 lb 79 kg	4xØ18xØ225 4 holes 5/8-11UNC	4x Washers
Total Weight:		348 lb 158 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	170	(4318)
MINIMUM LEAKAGE DISTANCE, in (mm)	165	(4191)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1450	(6450)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1450	(6450)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1010	
LOW FREQUENCY WET WITHSTAND, kV	385	
IMPULSE WITHSTAND, kV	900	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	146
MAXIMUM RIV AT 1 MHz, µV	500

**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

**Shed Profile (Unit 1,2)**

NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

Technical reference number:

TR 312

BIL 1050 kV

GAMMA

CERISOL  
EUROPE

in (mm)

TITLE

PART NUMBER

312ST1050

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.22 (Ø158)

Ø8.46 (Ø215)

UNIT 1

Ø8.46 (Ø215)

Ø9.25 (Ø235)

Ø7.87 (Ø200)

Ø8.46 (Ø215)

UNIT 2

Ø8.46 (Ø215)

Ø6.22 (Ø158)

Ø5.0 (Ø127)

(21 Sheds) 46.0 (1168.5)

92.0 ±0.13 (2337 ±3.2)

(21 Sheds) 46.0 (1168.5)

Bottom Flange View

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

## Marks

**GAMMA** | **CERISOL**  
**EUROPE**

Year-month  
Serial number  
312ST1050  
TR312  
SC907

## Assembly:

Assembly:					
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S3907MJ	TR312 SC907	137 lb 62 kg	4 holes 5/8-11UNC 4xØ18xØ200	4xM16 Bolts 4xM16 Nuts 4x Washers
UNIT 2	S4907MJ	TR312 SC907	137 lb 62 kg	4xØ18xØ200 4 holes 5/8-11UNC	
Total Weight:			274 lb 124 kg		

## NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

## DIMENSIONS

NOMINAL LEAKAGE DISTANCE, In (mm)	202	(5131)
MINIMUM LEAKAGE DISTANCE, In (mm)	198	(5030)

## MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	800	(3558)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

## ELECTRICAL VALUES

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1210	
LOW FREQUENCY WET WITHSTAND, kV	455	
IMPULSE WITHSTAND, kV	1050	

## RADIO INFLUENCE VOLTAGE


TEST VOLTAGE, RMS TO GROUND, kV	146	
MAXIMUM RIV AT 1 MHz, µV	500	

## Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)



NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21312EJ

DWG: TYPE SALES

Date: 2015/07/07

DWN: A.MEJÍA A.

APP: C. JARAMILLO



Technical reference number:

TR 312 U

GAMMA

CERISOL  
EUROPE

in (mm)

PART NUMBER

312SU1050

BIL 1050 kV

TITLE

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.22 (Ø158)

Ø8.46 (Ø215)

UNIT 1

Ø8.46 (Ø215)

Ø9.25 (Ø235)

Ø7.87 (Ø200)

Ø8.46 (Ø215)

UNIT 2

Ø8.46 (Ø215)

Ø6.22 (Ø158)

Ø5.0 (Ø127)

(21 Sheds) 46.0 (1168.5)

92.0 ±0.13 (2337 ±3.2)

(21 Sheds) 46.0 (1168.5)

Bottom Flange View

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

## Marks

GAMMA CERISOL  
EUROPE  
Year-month  
Serial number  
312SU1050  
TR312  
SC907

## Assembly:

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S3907MJ	TR312 SC907 137 lb 62 kg	4 holes 5/8-11UNC 4xØ18xØ200	4xM16 Bolts 4xM16 Nuts 4x Washers
UNIT 2	S4907MJ	TR312 SC907 137 lb 62 kg	4xØ18xØ200 4 holes 5/8-11UNC	
Total Weight:		274 lb 124 kg		

## NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

## DIMENSIONS

NOMINAL LEAKAGE DISTANCE, in (mm)	202	(5131)
MINIMUM LEAKAGE DISTANCE, in (mm)	198	(5030)

## MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	800	(3558)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	800	(3558)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

## ELECTRICAL VALUES

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1210	
LOW FREQUENCY WET WITHSTAND, kV	455	
IMPULSE WITHSTAND, kV	1050	

## RADIO INFLUENCE VOLTAGE


TEST VOLTAGE, RMS TO GROUND, kV	146
MAXIMUM RIV AT 1 MHz, µV	500

## Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)



NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21313EJ

DWG: TYPE SALES

Date: 2015/07/22

DWN: A.MEJÍA A.

APP: C. JARAMILLO

Technical reference number:

TR 316

BIL 1050 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)

PART NUMBER

316HT1050

TITLE

STATION POST INSULATOR. HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)

 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.22 (Ø158)

Ø8.98 (Ø228)

UNIT 1

Ø8.98 (Ø228)

Ø10.24 (Ø260)

Ø8.86 (Ø225)

Ø9.41 (Ø239)

UNIT 2

Ø9.41 (Ø239)

Ø6.3 (Ø160)

Ø5.0 (Ø127)

 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Bottom Flange View

**Marks**
**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
316HT1050  
TR316  
SC924 (Unit 1)  
SC914 (Unit 2)
**Assembly:**

	Assembly:				
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S2924EJ	TR316 SC924	155 lb 70 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts 4x Washers
UNIT 2	S4914MJ	TR316 SC914	183 lb 83 kg	4xØ18xØ225 4 holes 5/8-11UNC	
	Total Weight:		338 lb 153 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	202	(5131)
MINIMUM LEAKAGE DISTANCE, In (mm)	198	(5030)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1250	(5560)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1210	
LOW FREQUENCY WET WITHSTAND, kV	455	
IMPULSE WITHSTAND, kV	1050	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	146	
MAXIMUM RIV AT 1 MHz, µV	500	

**Other characteristics:**
 Insulating material: Al. Porcelain  
 Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
 Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)



**NOTE:** TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21316EJ | DWG: TYPE SALES | Date: 2015/07/01 | DWN: A.MEJÍA A. | APP: C. JARAMILLO

Technical reference number:

TR 316 U

BIL 1050 kV

GAMMA

CERISOL  
EUROPE

in (mm)

TITLE

PART NUMBER

316HU1050

STATION POST INSULATOR. HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.3 (Ø160)

Ø9.41 (Ø239)

UNIT 1

Ø9.41 (Ø239)

Ø10.24 (Ø260)

Ø8.86 (Ø225)

Ø9.41 (Ø239)

UNIT 2

Ø9.41 (Ø239)

Ø6.3 (Ø160)

Ø5.0 (Ø127)

Bottom Flange View

(21 Sheds) 46.0 (1168.5)

92.0 ±0.13 (2337 ±3.2)

(21 Sheds) 46.0 (1168.5)

**Marks**

GAMMA CERISOL  
EUROPE

Year-month  
Serial number  
316HU1050  
TR316  
SC914

**Assembly:**

	Assembly:				
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S3914MJ	TR316 SC914	183 lb 83 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts 4x Washers
UNIT 2	S4914MJ	TR316 SC914	183 lb 83 kg	4xØ18xØ225 4 holes 5/8-11UNC	
	Total Weight:		366 lb 166 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	202	(5131)
MINIMUM LEAKAGE DISTANCE, in (mm)	198	(5030)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1250	(5560)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1250	(5560)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1210	
LOW FREQUENCY WET WITHSTAND, kV	455	
IMPULSE WITHSTAND, kV	1050	

**RADIO INFLUENCE VOLTAGE**


TEST VOLTAGE, RMS TO GROUND, kV	146
MAXIMUM RIV AT 1 MHz, µV	500

**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)



NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21317EJ | DWG: TYPE SALES | Date: 2015/07/07 | DWN: A.MEJIA A. | APP: C. JARAMILLO

Technical reference number:

TR 324

BIL 1300 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)

PART NUMBER

324ST1300

TITLE

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View

Ø5.0 (Ø127)

 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.22 (Ø158)

Ø8.46 (Ø215)

UNIT 1

(25 Sheds) 53.15 (1350)

Ø8.46 (Ø215)

Ø10.43 (Ø265)

Ø8.86 (Ø225)

Ø9.06 (Ø230)

106.0 ±0.16 (2692 ±4)

UNIT 2

(28 Sheds) 52.83 (1342)

Ø9.06 (Ø230)

Ø6.3 (Ø160)

Ø5.0 (Ø127)

 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Bottom Flange View

**Marks**
**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
324ST1300  
TR324  
SC905 (Unit 1)  
SC915 (Unit 2)
**Assembly:**

	Assembly:				
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	SJ905PJ	TR324 SC905	166 lb 75 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts 4xB16 Washers
UNIT 2	SJ915EJ	TR324 SC915	201 lb 91 kg	4xØ18xØ225 4 holes 5/8-11UNC	
	Total Weight:		367 lb 166 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	234	(5944)
MINIMUM LEAKAGE DISTANCE, In (mm)	231	(5867)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1000	(4448)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)


**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1410	
LOW FREQUENCY WET WITHSTAND, kV	525	
IMPULSE WITHSTAND, kV	1300	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

**Other characteristics:**
 Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.


Shed Profile (Unit 1)



Shed Profile (Unit 2)

**NOTE:** TO PURCHASER ALL SALES OF GAMMA PRODUCTS ARE SUBJECT TO OUR STANDARD TERMS AND CONDITIONS AND THE LIMITED WARRANTIES THEREUNDER

Technical reference number:

TR 324 U

BIL 1300 kV

GAMMA

CERISOL  
EUROPE

in (mm)

TITLE

PART NUMBER

324SU1300

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.3 (Ø160)

Ø9.06 (Ø230)

UNIT 1

Ø9.06 (Ø230)

Ø10.43 (Ø265)

Ø8.86 (Ø225)

Ø9.06 (Ø230)

UNIT 2

Ø9.06 (Ø230)

Ø6.3 (Ø160)

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

## Marks

GAMMA CERISOL  
EUROPE

Year-month  
Serial number  
324SU1300  
TR324  
SC915

## Assembly:

		Assembly:			
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	SW915EJ	TR324 SC915	201 lb 91 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts 4x Washers
UNIT 2	SJ915EJ	TR324 SC915	201 lb 91 kg	4xØ18xØ225 4 holes 5/8-11UNC	
Total Weight:		367 lb 166 kg			

## NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

## DIMENSIONS

NOMINAL LEAKAGE DISTANCE, in (mm)	238	(6045)
MINIMUM LEAKAGE DISTANCE, in (mm)	231	(5867)

## MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1000	(4448)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1000	(4448)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

## ELECTRICAL VALUES

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1410	
LOW FREQUENCY WET WITHSTAND, kV	525	
IMPULSE WITHSTAND, kV	1300	


## RADIO INFLUENCE VOLTAGE

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

## Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.



Shed Profile

NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

Bottom Flange View

DWG. No.: H21325EJ

DWG: TYPE SALES

Date: 2015/07/07

DWN: A.MEJÍA A.

APP: C. JARAMILLO

Technical reference number:

TR 330 U

GAMMA

CERISOL  
EUROPE

in (mm)

PART NUMBER

330SU1470

BIL 1470 kV

TITLE

STATION POST INSULATOR. STANDARD STRENGTH

Top Flange View

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.3 (Ø160)

Ø9.53 (Ø242)

UNIT 1

Ø9.53 (Ø242)

Ø10.24 (Ø260)

Ø8.86 (Ø225)

Ø9.53 (Ø242)

UNIT 2

Ø9.53 (Ø242)

Ø6.3 (Ø160)

Ø5.0 (Ø127)

4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Bottom Flange View

## Marks

**GAMMA** **CERISOL EUROPE**

Year-month  
Serial number  
330SU1470  
TR330  
SC916

## Assembly:

Assembly:					
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	SM916PJ	TR330 SC916	230 lb 104 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts 4x washers
UNIT 2	SN916PJ	TR330 SC916	230 lb 104 kg	4xØ18xØ225 4 holes 5/8-11UNC	
Total Weight:			460 lb 208 kg		

## NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

## DIMENSIONS

NOMINAL LEAKAGE DISTANCE, in (mm)	267	(6782)
MINIMUM LEAKAGE DISTANCE, in (mm)	264	(6706)

## MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	900	(4003)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	900	(4003)
TENSILE BREAKING STRENGTH, pounds (N)	25000	(111200)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	90000	(10170)
COMPRESSION BREAKING STRENGTH, pounds (N)	75000	(333600)

## ELECTRICAL VALUES

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1610	
LOW FREQUENCY WET WITHSTAND, kV	590	
IMPULSE WITHSTAND, kV	1470	

## RADIO INFLUENCE VOLTAGE


TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

## Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)



NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21330EJ

DWG: TYPE SALES

Date: 2015/07/07

DWN: A.MEJÍA A.

APP: C. JARAMILLO

Technical reference number:

TR 362 U

BIL 1050 kV

GAMMA

CERISOL  
EUROPE


in (mm)

TITLE

PART NUMBER

362EU1050

STATION POST INSULATOR. EXTRA HIGH STRENGTH

**Marks**

**GAMMA** CERISOL  
EUROPE

Year-month  
Serial number  
362EU1050  
TR362  
SC8923 (UNIT1)  
SC918 (UNIT2)

**Assembly:**

Assembly:					
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S28923EJ	TR362 SC8923	256 lb 116 kg	4 holes 3/4-10UNC 8xØ18xØ254	8xM16 Bolts 8xM16 Nuts 8x washers
UNIT 2	S4918EJ	TR362 SC918	265 lb 120 kg	8xØ18xØ254 4 holes 3/4-10UNC	
Total Weight:			521 lb 236 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	202	(5131)
MINIMUM LEAKAGE DISTANCE, in (mm)	198	(5030)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	2300	(10230)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	2300	(10230)
TENSILE BREAKING STRENGTH, pounds (N)	40000	(177920)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	120000	(13560)
COMPRESSION BREAKING STRENGTH, pounds (N)	100000	(444800)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1210	
LOW FREQUENCY WET WITHSTAND, kV	455	
IMPULSE WITHSTAND, kV	1050	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	146
MAXIMUM RIV AT 1 MHz, µV	500

**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

**Shed Profile (Unit 1,2)**

NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

Technical reference number:

TR 367

BIL 1300 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)

PART NUMBER

367HT1300

TITLE

STATION POST INSULATOR. HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)

 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.22 (Ø158)

Ø8.46 (Ø215)

UNIT 1

(25 Sheds) 53.15 (1350)

Ø8.46 (Ø215)

Ø11.42 (Ø290)

Ø10.0 (Ø254)

Ø10.04 (Ø255)

106.0 ±0.16 (2692 ±4)

UNIT 2

(28 Sheds) 52.83 (1342)

Ø10.04 (Ø255)

Ø8.66 (Ø220)

Ø7.0 (Ø178)

Bottom Flange View

 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)
**Marks**
**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
367HT1300  
TR367  
SC905 (Unit 1)  
SC902 (Unit 2)
**Assembly:**

		Assembly:			
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	SJ905MJ	TR367 SC905	166 lb 75 kg	4 holes 5/8-11UNC 8xØ18xØ254	8xM16 Bolts 8xM16 Nuts 8x Washers
UNIT 2	SJ902MJ	TR367 SC902	285 lb 129 kg	8xØ18xØ254 4 holes 3/4-10UNC	
		Total Weight:	451 lb 204 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	234	(5944)
MINIMUM LEAKAGE DISTANCE, In (mm)	231	(5867)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1450	(6450)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4250)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)


**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1410	
LOW FREQUENCY WET WITHSTAND, kV	525	
IMPULSE WITHSTAND, kV	1300	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

**Other characteristics:**
 Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.


Shed Profile (Unit 1)



Shed Profile (Unit 2)

**NOTE:** TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER



Technical reference number:

TR 368

BIL 1300 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)

PART NUMBER

368EU1300

TITLE

STATION POST INSULATOR. EXTRA HIGH STRENGTH

Top Flange View

Ø7.0 (Ø178)

 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø8.66 (Ø220)

Ø10.04 (Ø255)

UNIT 1

Ø10.04 (Ø255)

Ø11.42 (Ø290)

Ø10.0 (Ø254)

Ø10.43 (Ø265)

UNIT 2

Ø10.43 (Ø265)

Ø8.66 (Ø220)

Ø7.0 (Ø178)

Bottom Flange View

 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)
**Marks**
**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
368EU1300  
TR368  
SC8922 (Unit 1)  
SC903 (Unit 2)
**Assembly:**

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S28922EJ	296 lb 134 kg	4 holes 3/4-10UNC 8xØ18xØ255	8xM16 Bolts 8xM16 Nuts 8x Washers
UNIT 2	S2903MJ	302 lb 137 kg	8xØ18xØ255 4 holes 3/4-10UNC	
Total Weight:		598 lb 271 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	234	(5944)
MINIMUM LEAKAGE DISTANCE, in (mm)	231	(5867)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	2050	(9118)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	2050	(9118)
TENSILE BREAKING STRENGTH, pounds (N)	40000	(177920)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	120000	(13560)
COMPRESSION BREAKING STRENGTH, pounds (N)	100000	(444880)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1410	
LOW FREQUENCY WET WITHSTAND, kV	525	
IMPULSE WITHSTAND, kV	1300	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

**Other characteristics:**
 Insulating material: Al. Porcelain  
 Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
 Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)


 NOTE: TO PURCHASER ALL SALES OF  
 GAMMA PRODUCTS ARE SUBJECT TO  
 OUR STANDARD TERMS AND  
 CONDITIONS AND THE LIMITED  
 WARRANTIES THEREUNDER

DWG. No.: H21368EJ

DWG: TYPE SALES

Date: 2015/07/01

DWN: A.MEJÍA A.

APP: C. JARAMILLO

Technical reference number:

TR 369

BIL 1300 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)

PART NUMBER

369ET1300

TITLE

STATION POST INSULATOR. EXTRA HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)

 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.69 (Ø170)

Ø10.04 (Ø255)

UNIT 1

Ø10.04 (Ø255)

Ø11.42 (Ø290)

Ø10.0 (Ø254)

Ø10.43 (Ø265)

UNIT 2

Ø10.43 (Ø265)

Ø8.66 (Ø220)

Ø7.0 (Ø178)

Bottom Flange View

 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)
**Marks**
**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
369ET1300  
TR369  
SC902 (Unit 1)  
SC903 (Unit 2)
**Assembly:**

Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S26902EJ	TR369 SC6902 278 lb 126 kg	4 holes 5/8-11UNC 8xØ18xØ254	8xM16 Bolts 8xM16 Nuts 8x Washers
UNIT 2	S26903EJ	TR369 SC6903 302 lb 137 kg	8xØ18xØ254 4 holes 3/4-10UNC	
Total Weight:		580 lb 263 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	234	(5944)
MINIMUM LEAKAGE DISTANCE, In (mm)	231	(5867)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	2050	(9118)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1410	
LOW FREQUENCY WET WITHSTAND, kV	525	
IMPULSE WITHSTAND, kV	1300	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

**Other characteristics:**
 Insulating material: Al. Porcelain  
 Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
 Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)



NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

Technical reference number:

TR 371

BIL 1470 kV

GAMMA

CERISOL  
EUROPE

in (mm)

TITLE

PART NUMBER

371HT1470

STATION POST INSULATOR. HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.22 (Ø158)

Ø8.78 (Ø223)

UNIT 1

Ø8.78 (Ø223)

Ø10.24 (Ø260)

Ø8.86 (Ø225)


Ø9.72 (Ø247)

UNIT 2

Ø9.72 (Ø247)

Ø8.66 (Ø220)

Ø7.0 (Ø178)



4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Bottom Flange View

## Marks

GAMMA CERISOL  
EUROPE

Year-month  
Serial number  
371HT1470  
TR371  
SC911 (UNIT1)  
SC919 (UNIT2)

## Assembly:

Assembly:					
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	SL911MJ	TR371 SC911	194 lb 88 kg	4 holes 5/8-11UNC 4xØ18xØ225	4xM16 Bolts 4xM16 Nuts 4x washers
UNIT 2	S2919EJ	TR371 SC919	267 lb 121 kg	4xØ18xØ225 4 holes 3/4-10UNC	
Total Weight:		461 lb 209 kg			

## NOTES

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

## DIMENSIONS

NOMINAL LEAKAGE DISTANCE, In (mm)	270	(6858)
MINIMUM LEAKAGE DISTANCE, In (mm)	264	(6706)

## MECHANICAL VALUES

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1170	(5204)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266800)

## ELECTRICAL VALUES

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1610	
LOW FREQUENCY WET WITHSTAND, kV	590	
IMPULSE WITHSTAND, kV	1470	


## RADIO INFLUENCE VOLTAGE

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	


## Other characteristics:

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.



Shed Profile (Unit 1)



Shed Profile (Unit 2)

NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

Technical reference number:

TR 372

BIL 1470 kV

**GAMMA** CERISOL  
EUROPE


in (mm)

PART NUMBER

372EU1470

TITLE STATION POST INSULATOR. EXTRA HIGH STRENGTH

Top Flange View

Ø7.0 (Ø178)

 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø8.66 (Ø220)

Ø10.24 (Ø260)

UNIT 1

Ø10.0 (Ø254)

Ø11.42 (Ø290)

Ø10.0 (Ø254)

Ø10.32 (Ø262)

UNIT 2

Ø8.66 (Ø220)

Ø7.0 (Ø178)

Bottom Flange View

 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)
**Marks**
**GAMMA** CERISOL  
EUROPE  
Year-month  
Serial number  
372EU1470  
TR372  
SC921 (UNIT1)  
SC920 (UNIT2)
**Assembly:**

Assembly:					
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S28921EJ	TR372 SC921	322 lb 146 kg	4 holes 3/4-10UNC 8xØ18xØ254	8xM16 Bolts 8xM16 Nuts 4x washers
UNIT 2	S2920MJ	TR372 SC920	309 lb 140 kg	8xØ18xØ254 4 holes 3/4-10UNC	
Total Weight:		631 lb 286 ka			

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, in (mm)	271	(6883)
MINIMUM LEAKAGE DISTANCE, in (mm)	264	(6706)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1750	(7784)
CANTILEVER BREAKING STRENGTH, UNDERHUNG pounds (N)	1750	(7784)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1610	
LOW FREQUENCY WET WITHSTAND, kV	590	
IMPULSE WITHSTAND, kV	1470	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

**Other characteristics:**
 Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

Shed Profile (Unit 1,2)


 NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21372EJ | DWG: TYPE SALES | Date: 2015/07/07 | DWN: A.MEJÍA A. | APP: C. JARAMILLO

Technical reference number:

TR 373

BIL 1470 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)

PART NUMBER

373ET1470

TITLE

STATION POST INSULATOR. EXTRA HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)


 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.3 (Ø160)

Ø9.53 (Ø242)

UNIT 1

Ø9.53 (Ø242)

Ø11.42 (Ø290)


Ø10.0 (Ø254)

Ø10.32 (Ø262)

UNIT 2

Ø8.66 (Ø220)

Ø7.0 (Ø178)


 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Bottom Flange View

**Marks**
 Year-month  
Serial number  
373ET1470  
TR373  
SC916 (UNIT1)  
SC920 (UNIT2)
**Assembly:**

Assembly:					
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	SP916PJ	TR373 SC916	234 lb 106 kg	4 holes 5/8-11UNC 8xØ18xØ254	8xM16 Bolts 8xM16 Nuts 4x washers
UNIT 2	S2920EJ	TR373 SC920	309 lb 140 kg	8xØ18xØ254 4 holes 3/4-10UNC	
Total Weight:			543 lb 246 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	269	(6833)
MINIMUM LEAKAGE DISTANCE, In (mm)	264	(6706)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1750	(7784)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266800)


**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1610	
LOW FREQUENCY WET WITHSTAND, kV	590	
IMPULSE WITHSTAND, kV	1470	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	220	
MAXIMUM RIV AT 1 MHz, µV	1000	

**Other characteristics:**
 Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.


Shed Profile (Unit 1)



Shed Profile (Unit 2)

**NOTE:** TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

Technical reference number:

TR 379

BIL 1550 kV

**GAMMA** | **CERISOL**  
EUROPE


in (mm)

PART NUMBER

379HT1550

TITLE

STATION POST INSULATOR. HIGH STRENGTH

Top Flange View

Ø5.0 (Ø127)

 4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Ø6.3 (Ø160)

Ø9.53 (Ø242)

UNIT 1

Ø9.53 (Ø242)

Ø11.42 (Ø290)

Ø10.0 (Ø254)

Ø10.32 (Ø262)

UNIT 2

Ø10.83 (Ø275)

Ø8.66 (Ø220)

Ø7.0 (Ø178)

 4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

Bottom Flange View

**Marks**
**GAMMA** | **CERISOL**  
EUROPE  
Year-month  
Serial number  
379HT1550  
TR379  
SC916 (Unit 1)  
SC917 (Unit 2)
**Assembly:**

Assembly:					
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	SL916MJ	TR379 SC916	230 lb 104 kg	4 holes 5/8-11UNC 8xØ18xØ254	8xM16 Bolts 8xM16 Nuts 8x Washers
UNIT 2	S2917EJ	TR379 SC917	329 lb 149 kg	8xØ18xØ254 4 holes 3/4-10UNC	
Total Weight:			559 lb 253 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	284	(7214)
MINIMUM LEAKAGE DISTANCE, In (mm)	280	(7112)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1700	(7562)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)


**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:		
CRITICAL IMPULSE FLASHOVER, POS., kV	1710	
LOW FREQUENCY WET WITHSTAND, kV	620	
IMPULSE WITHSTAND, kV	1550	


**RADIO INFLUENCE VOLTAGE**

TEST VOLTAGE, RMS TO GROUND, kV	318	
MAXIMUM RIV AT 1 MHz, µV	2000	

**Other characteristics:**
 Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70

 Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.


Shed Profile (Unit 1)



Shed Profile (Unit 2)

**NOTE:** TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

Technical reference number:

TR 391

BIL 1800 kV

**GAMMA** | **CERISOL**  
**EUROPE**



in (mm)

PART NUMBER

391ST1800


TITLE

STATION POST INSULATOR. STANDARD STRENGTH



Ø5.0 (Ø127)

Top Flange View "T"



4 Tapped Holes 5/8-11 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)

**Marks**

**GAMMA** | **CERISOL**  
**EUROPE**

Year-month  
Serial number  
391ST1800  
TR391  
SC6900 (Unit 1,2)  
SC6901 (Unit 3)

**Assembly:**

	Assembly:				
	Unit Part n°	Unit Shed ID	Weight:	Fixation: Top / Bottom	Galvanized Steel:
UNIT 1	S26900EJ	TR391 SC6900	267 lb 121 kg	4 holes 5/8-11UNC 8Ø18xØ254	16xM16 Bolts 16xM16 Nuts 16x Washers
UNIT 2	S36900EJ	TR391 SC6900	274 lb 124 kg	8xØ18xØ254 8xØ18xØ254	
UNIT 3	S26901EJ	TR391 SC6901	291 lb 132 kg	8xØ18xØ254 4 holes 3/4-10UNC	
	Total Weight:		832 lb 377 kg		

**NOTES**

1. DIMENSIONS ARE INCHES (MILLIMETERS)
2. ALL FERROUS PARTS ARE HOT DIP GALVANIZED PER ASTM A153, MALLEABLE OR SPHEROIDAL CAST IRON.
3. MEETS CHARACTERISTICS AND TOLERANCES OF ANSI C29.9 / C29.1

**DIMENSIONS**

NOMINAL LEAKAGE DISTANCE, In (mm)	330	(8382)
MINIMUM LEAKAGE DISTANCE, In (mm)	321.5	(8166)

**MECHANICAL VALUES**

CANTILEVER BREAKING STRENGTH, UPRIGHT pounds (N)	1400	(6227)
TENSILE BREAKING STRENGTH, pounds (N)	20000	(88960)
TORSIONAL BREAKING STRENGTH, in-pounds (N.m)	40000	(4520)
COMPRESSION BREAKING STRENGTH, pounds (N)	60000	(266880)

**ELECTRICAL VALUES**

GUARANTEED VOLTAGES:	
CRITICAL IMPULSE FLASHOVER, POS., kV	2000
LOW FREQUENCY WET WITHSTAND, kV	710
IMPULSE WITHSTAND, kV	1800

**RADIO INFLUENCE VOLTAGE**


TEST VOLTAGE, RMS TO GROUND, kV	318
MAXIMUM RIV AT 1 MHz, µV	2000

**Other characteristics:**

Insulating material: Al. Porcelain  
Glaze: Light Gray Munsell n° 70


Metal parts assembled with Portland cement.  
Bolts required for stack assembly are supplied.

Bottom Flange View "B"



Ø7.0 (Ø178)

4 Tapped Holes 3/4-10 UNC  
+0.015 Oversize  
Full Thread 0.87 (22)



Shed Profile  
(Unit 1,2,3)

NOTE: TO PURCHASER ALL SALES OF  
GAMMA PRODUCTS ARE SUBJECT TO  
OUR STANDARD TERMS AND  
CONDITIONS AND THE LIMITED  
WARRANTIES THEREUNDER

DWG. No.: H21391EJ | DWG. TYPE SALES | Date: 2015/07/01 | DWN: A.MEJÍA A. | APP: C. JARAMILLO

Date: March 08, 2008

**CERTIFICATE OF TESTING**

**MATERIAL TESTED: GAMMA STATION POST Insulator. TR 202**

**AISLADORES CORONA**

Carrera 49 No. 67 sur - 680

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

**DESIGN TESTS**

**1. LOW FREQUENCY WET WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.5 of ANSI C29.1-1982. Failure of any insulator to meet the rated wet withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Low Frequency Wet Withstand, kV	30	30	30	30

**Result: Satisfactory**

**2. CRITICAL IMPULSE FLASHOVER, POSITIVE**

Three insulators were randomly selected and tested in accordance with section 4.7 of ANSI C29.1-1982. Failure of the average critical – impulse flashover value of the three insulators to equal or exceed 92 percent of the rated critical – impulse flashover value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	92%
Critical Impulse Flashover, Positive, kV	120,7	119,6	120,9	120,4	105	96.6

**Result: Satisfactory**

**3. IMPULSE WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.8 of ANSI C29.1-1982. Failure of any insulator to meet the rated impulse withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Impulse Withstand, kV	95	95	95	95

**Result: Satisfactory**

**4. RADIO INFLUENCE VOLTAGE RIV**

Three insulators were randomly selected and tested in accordance with section 4.9 of ANSI C29.1-1982. If one or more insulators fail to meet the requirements given in the standard, three additional insulators shall be selected at random and tested. Failure of one or more of these additional insulators shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Rating max
RIV at 5 kV, to ground (µV)	<2,5µV	<2,5µV	<2,5µV	50 µV

**Result: Satisfactory**



## 5. THERMAL SHOCK TEST

Three insulators were randomly selected and tested for ten complete cycles in accordance with section 5.5 of ANSI C29.1-1982. The temperature of the hot water bath was approximately 150°F (66°C) and the temperature of the cold water was approximately 39°F (4°C). At the end of the tenth cycle the test specimens were checked for electrical soundness. If one insulator fails, three additional insulators shall be selected randomly and tested. Failure of more than one insulator from the first set of samples, or from the first and second set of samples combined shall constitute failure to meet the requirements of this standard.

**Three insulators were thermal shock tested in accordance to ANSI Standard, section 5.5.  
All units passed this test.**

**Result: Satisfactory**

AISLADORES CORONA

Carrera 49 No. 67 sur - 680

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

## 6. COMPRESSION STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.4 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement where applicable, or failure of any one insulator unit to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Compression Strength, pounds (*)	225.496	226.202	224.941	225.546	10.000	8500

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 7. TORSIONAL STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.2 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Torsional Strength, inches pounds	20.116	21.586	26.118	22.607	6.000	5100

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## QUALITY CONFORMANCE TESTS

### 1. VISUAL AND DIMENSIONAL TEST

Three insulators were randomly selected and checked according to section 4.2 of the standard and met the requirements. Their dimensions were verified against the manufacturing drawing.

Failure of more than one of these insulators to conform to the dimensions on the drawing shall constitute failure of the lot to meet the requirements of the standard.

**All the samples meet the conditions and dimensions.**

**Result: Satisfactory**

### 2. POROSITY TEST

Ten samples of porcelain taken from the same firing cycle as these posts were subjected to the porosity test. No porosity was observed. The test was performed in accordance with ANSI C29.9-1983, paragraph 7.3.2.

Dyer penetration:

NEGATIVE: X

POSITIVE:

**Result: Satisfactory**

### 3. GALVANIZING TEST

A galvanizing thickness test was performed on three hardware samples. The galvanizing thickness measured, equaled or exceeded the values given in the table shown in paragraph 7.3.3 of ANSI C29.9-1983.

**Result: Satisfactory**

### 4. CANTILEVER STRENGTH TEST

Three insulators were randomly selected and tested in accordance with section 5.1.4.1 of ANSI C29.1-1982. The units were tested individually. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Cantilever Strength, pounds	5.985	5.806	5.995	5.929	2000	1700

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 5. TENSILE STRENGTH TEST

Three insulators were randomly selected and tested in accordance with section 5.1.4.3 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

AISLADORES CORONA

Carrera 49 No. 67 sur - 68o

Sabaneta - Colombia


Nit: 890.900.121-4

Conmutador (574) 305 80 00

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Tensile Strength, pounds (*)	30.007	27.028	27.912	28.316	7000	5950

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**



**FRANK ESCOBAR OBANDO  
PRODUCT ENGINEER.**

Date: March 08, 2008

**CERTIFICATE OF TESTING****MATERIAL TESTED: GAMMA STATION POST Insulator. TR 205**

AISLADORES CORONA

Carrera 49 No. 67 sur - 680

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

**DESIGN TESTS****1. LOW FREQUENCY WET WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.5 of ANSI C29.1-1982. Failure of any insulator to meet the rated wet withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Low Frequency Wet Withstand, kV	45	45	45	45

**Result: Satisfactory****2. CRITICAL IMPULSE FLASHOVER, POSITIVE**

Three insulators were randomly selected and tested in accordance with section 4.7 of ANSI C29.1-1982. Failure of the average critical – impulse flashover value of the three insulators to equal or exceed 92 percent of the rated critical – impulse flashover value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	92%
Critical Impulse Flashover, Positive, kV	150,7	142,1	145,1	146,0	125	115

**Result: Satisfactory****3. IMPULSE WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.8 of ANSI C29.1-1982. Failure of any insulator to meet the rated impulse withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Impulse Withstand, kV	110	110	110	110

**Result: Satisfactory****4. RADIO INFLUENCE VOLTAGE RIV**

Three insulators were randomly selected and tested in accordance with section 4.9 of ANSI C29.1-1982. If one or more insulators fail to meet the requirements given in the standard, three additional insulators shall be selected at random and tested. Failure of one or more of these additional insulators shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Rating
RIV at 10 kV, to ground ( $\mu$ V)	<2,5 $\mu$ V	<2,5 $\mu$ V	<2,5 $\mu$ V	50 $\mu$ V max

**Result: Satisfactory**

## 5. THERMAL SHOCK TEST

Three insulators were randomly selected and tested for ten complete cycles in accordance with section 5.5 of ANSI C29.1-1982. The temperature of the hot water bath was approximately 150°F (66°C) and the temperature of the cold water was approximately 39°F (4°C). At the end of the tenth cycle the test specimens were checked for electrical soundness. If one insulator fails, three additional insulators shall be selected randomly and tested. Failure of more than one insulator from the first set of samples, or from the first and second set of samples combined shall constitute failure to meet the requirements of this standard.

**Three insulators were thermal shock tested in accordance to ANSI Standard, section 5.5. All units passed this test.**

**Result: Satisfactory**

**AISLADORES CORONA**

Carrera 49 No. 67 sur - 680

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

## 6. COMPRESSION STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.4 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement where applicable, or failure of any one insulator unit to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Compression Strength, pounds (*)	225.406	226.056	224.770	225.411	10.000	8500

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 7. TORSIONAL STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.2 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Torsional Strength, inches pounds	19.418	20.716	21.529	20.554	7.000	5950

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## QUALITY CONFORMANCE TESTS

### AISLADORES CORONA

Carrera 49 No. 67 sur - 68o

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

### 1. VISUAL AND DIMENSIONAL TEST

Three insulators were randomly selected and checked according to section 4.2 of the standard and met the requirements. Their dimensions were verified against the manufacturing drawing.

Failure of more than one of these insulators to conform to the dimensions on the drawing shall constitute failure of the lot to meet the requirements of the standard.

**All the samples meet the conditions and dimensions.**

**Result: Satisfactory**

### 2. POROSITY TEST

Ten samples of porcelain taken from the same firing cycle as these posts were subjected to a porosity test. No porosity was observed. The test was performed in accordance with ANSI C29.9-1983, paragraph 7.3.2.

Dyer penetration:

NEGATIVE: X

POSITIVE:

**Result: Satisfactory**

### 3. GALVANIZING TEST

A galvanizing thickness test was performed on three hardware samples. The galvanizing thickness measured, equaled or exceeded the values given in the table shown in paragraph 7.3.3 of ANSI C29.9-1983.

**Result: Satisfactory**

### 4. CANTILEVER STRENGTH TEST

Three insulators were randomly selected and tested according to section 5.1.4.1 of ANSI C29.1-1982. The units were tested individually. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Cantilever Strength, pounds	4.239	4.781	4.162	4.394	2000	1700

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 5. TENSILE STRENGTH TEST

Three insulators were randomly selected and tested in accordance with section 5.1.4.3 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard

AISLADORES CORONA

Carrera 49 No. 67 sur - 68o

Sabaneta - Colombia


Nit: 890.900.121-4

Conmutador (574) 305 80 00

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Tensile Strength, pounds (*)	23.692	25.763	26.058	25.171	8500	7225

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**



**FRANK ESCOBAR OBANDO**  
**PRODUCT ENGINEER.**

Date: March 08, 2008

**CERTIFICATE OF TESTING****MATERIAL TESTED: GAMMA STATION POST Insulator TR 208**

AISLADORES CORONA

Carrera 49 No. 67 sur - 680

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

**DESIGN TESTS****1. LOW FREQUENCY WET WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.5 of ANSI C29.1-1982. Failure of any insulator to meet the rated wet withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Low Frequency Wet Withstand, kV	60	60	60	60

**Result: Satisfactory****2. CRITICAL IMPULSE FLASHOVER, POSITIVE**

Three insulators were randomly selected and tested in accordance with section 4.7 of ANSI C29.1-1982. Failure of the average critical – impulse flashover value of the three insulators to equal or exceed 92 percent of the rated critical – impulse flashover value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	92%
Critical Impulse Flashover, Positive, kV	171,9	174,4	175,5	173,9	170	156.4

**Result: Satisfactory****3. IMPULSE WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.8 of ANSI C29.1-1982. Failure of any insulator to meet the rated impulse withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Impulse Withstand, kV	151	150	151	150

**Result: Satisfactory****4. RADIO INFLUENCE VOLTAGE RIV**

Three insulators were randomly selected and tested in accordance with section 4.9 of ANSI C29.1-1982. If one or more insulators fail to meet the requirements given in the standard, three additional insulators shall be selected at random and tested. Failure of one or more of these additional insulators shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Rating
RIV at 15 kV, to ground (µV)	<2,5µV	<2,5µV	<2,5µV	100 µV max

**Result: Satisfactory**



## 5. THERMAL SHOCK TEST

Three insulators were randomly selected and tested for ten complete cycles in accordance with section 5.5 of ANSI C29.1-1982. The temperature of the hot water bath was approximately 150°F (66°C) and the temperature of the cold water was approximately 39°F (4°C). At the end of the tenth cycle the test specimens were checked for electrical soundness. If one insulator fails, three additional insulators shall be selected randomly and tested. Failure of more than one insulator from the first set of samples, or from the first and second set of samples combined shall constitute failure to meet the requirements of this standard.

**Three insulators were thermal shock tested in accordance to ANSI Standard, section 5.5.  
All units passed this test.**

**Result: Satisfactory**

AISLADORES CORONA

Carrera 49 No. 67 sur - 680

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

## 6. COMPRESSION STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.4 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement where applicable, or failure of any one insulator unit to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Compression Strength, pounds (*)	225.480	225.570	225.795	225.615	10000	8500

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 7. TORSIONAL STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.2 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Torsional Strength, inches pounds	21.232	24.023	25.311	23.522	8000	6800

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## QUALITY CONFORMANCE TESTS

### 1. VISUAL AND DIMENSIONAL TEST

Three insulators were randomly selected and checked according to section 4.2 of the standard and met the requirements. Their dimensions were checked against the dimension of manufacturing drawing. Failure of more than one of these insulators to conform to the dimensions of the drawing shall constitute failure of the lot to meet the requirements of the standard.

**All the samples meet the conditions and dimensions. Result satisfactory.**

**Result: Satisfactory**

### 2. POROSITY TEST

Ten samples of porcelain taken from the same firing cycle as these posts were subjected to a porosity test. No porosity was observed. The test was performed in accordance with ANSI C29.9-1983, paragraph 7.3.2.

Dyer penetration:

NEGATIVE: X

POSITIVE:

**Result: Satisfactory**

### 3. GALVANIZING TEST

A galvanizing thickness test was performed on three hardware samples. The galvanizing thickness measured, equaled or exceeded the values given in the table shown in paragraph 7.3.3 of ANSI C29.9-1983.

**Result: Satisfactory**

### 4. CANTILEVER STRENGTH TEST

Three insulators were randomly selected and tested in accordance with section 5.1.4.1 of ANSI C29.1-1982. The units were tested individually. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Cantilever Strength, pounds	3.226	2.641	2.689	2.852	2000	1700

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 5. TENSILE STRENGTH TEST

Three insulators were randomly selected and tested in accordance with section 5.1.4.3 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

AISLADORES CORONA

Carrera 49 No. 67 sur - 68o

Sabaneta - Colombia


Nit: 890.900.121-4

Conmutador (574) 305 80 00

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Tensile Strength, pounds (*)	18.985	22.672	26.324	22.660	10000	8500

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**



**FRANK ESCOBAR OBANDO**  
**PRODUCT ENGINEER.**

Date: March 08, 2008

**CERTIFICATE OF TESTING****MATERIAL TESTED: GAMMA STATION POST Insulator. TR 210**

AISLADORES CORONA

Carrera 49 No. 67 sur - 680

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

**DESIGN TESTS****1. LOW FREQUENCY WET WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.5 of ANSI C29.1-1982. Failure of any insulator to meet the rated wet withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Low Frequency Wet Withstand, kV	80	80	80	80

**Result: Satisfactory****2. CRITICAL IMPULSE FLASHOVER, POSITIVE**

Three insulators were randomly selected and tested in accordance with section 4.7 of ANSI C29.1-1982. Failure of the average critical – impulse flashover value of the three insulators to equal or exceed 92 percent of the rated critical – impulse flashover value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	92%
Critical Impulse Flashover, Positive, kV	208,1	211,7	212	210,6	225	207

**Result: Satisfactory****3. IMPULSE WITHSTAND**

Three insulators were randomly selected and tested in accordance with section 4.8 of ANSI C29.1-1982. Failure of any insulator to meet the rated impulse withstand value, as given in the applicable table, shall constitute failure to meet the requirements of the standard.

	Unit 1	Unit 2	Unit 3	Rating
Impulse Withstand, kV	201,21	203,53	200,09	200

**Result: Satisfactory****4. RADIO INFLUENCE VOLTAGE RIV**

Three insulators were randomly selected and tested in accordance with section 4.9 of ANSI C29.1-1982. If one or more insulators fail to meet the requirements given in the standard, three additional insulators shall be selected at random and tested. Failure of one or more of these additional insulators shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Rating
RIV at 22 kV, to ground (µV)	< 2,5µV	< 2,5µV	< 2,5µV	100 µV max

**Result: Satisfactory**

## 5. THERMAL SHOCK TEST

Three insulators were randomly selected and tested for ten complete cycles in accordance with section 5.5 of ANSI C29.1-1982. The temperature of the hot water bath was approximately 150°F (66°C) and the temperature of the cold water was approximately 39°F (4°C). At the end of the tenth cycle the test specimens were checked for electrical soundness. If one insulator fails, three additional insulators shall be selected randomly and tested. Failure of more than one insulator from the first set of samples, or from the first and second set of samples combined shall constitute failure to meet the requirements of this standard.

**Three insulators were thermal shock tested in accordance to ANSI Standard, section 5.5.  
All units passed this test.**

**Result: Satisfactory**

## 6. COMPRESSION STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.4 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement where applicable, or failure of any one insulator unit to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Compression Strength, pounds (*)	140.757	131.166	215.206	162.376	15000	12750

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 7. TORSIONAL STRENGTH

Three insulators were randomly selected and tested in accordance with section 5.1.4.2 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Torsional Strength, inches pounds	25.866	25.799	25.773	25.813	10000	8500

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

**AISLADORES CORONA**

Carrera 49 No. 67 sur - 68o

Sabaneta - Colombia

Nit: 890.900.121-4

Conmutador (574) 305 80 00

## QUALITY CONFORMANCE TESTS

### 1. VISUAL AND DIMENSIONAL TEST

Three insulators were randomly selected and checked according to section 4.2 of the standard and met the requirements. Their dimensions were checked against the dimension of manufacturing drawing Failure of more than one of these insulators to conform to the dimensions of the drawing shall constitute failure of the lot to meet the requirements of the standard.

**All the samples meet the conditions and dimensions. Result satisfactory.**

**Result: Satisfactory**

### 2. POROSITY TEST

Ten samples of porcelain taken from the same firing cycle as these posts were subjected to a porosity test. No porosity was observed. The test was performed in accordance with ANSI C29.9-1983, paragraph 7.3.2.

Dyer penetration:

NEGATIVE: X

POSITIVE:

**Result: Satisfactory**

### 3. GALVANIZING TEST

A galvanizing thickness test was performed on three hardware samples. The galvanizing thickness measured, equaled or exceeded the values given in the table shown in paragraph 7.3.3 of ANSI C29.9-1983.

**Result: Satisfactory**

### 4. CANTILEVER STRENGTH TEST

Three insulators were randomly selected and tested in accordance with section 5.1.4.1 of ANSI C29.1-1982. The units were tested individually. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Cantilever Strength, pounds	3.628	3.791	3.693	3.704	2000	1700

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**

## 5. TENSILE STRENGTH TEST

Three insulators were randomly selected and tested in accordance with section 5.1.4.3 of ANSI C29.1-1982. Failure of the average strength of the three insulators to meet the strength requirements given in the tables or to meet the specified higher strength requirement, where applicable, or failure of any insulator to equal 85% of that strength requirement shall constitute failure to meet the requirements of this standard.

**AISLADORES CORONA**

Carrera 49 No. 67 sur - 68o

Sabaneta - Colombia


Nit: 890.900.121-4

Conmutador (574) 305 80 00

	Unit 1	Unit 2	Unit 3	Average	Rating	85%
Tensile Strength, pounds (*)	40.000	40.000	40.000	40.000	12000	10200

NOTE: (\*) Load released with no visible damage to the unit

**Result: Satisfactory**



**FRANK ESCOBAR OBANDO**  
**PRODUCT ENGINEER.**

## Design Test Certification

<b>Material Tested</b>	<b>GAMMA Catalog Number 8435</b>
<b>TEST OBJECT:</b>	Station Post Insulator
<b>TYPE SPECIFICATION:</b>	TR 214
<b>TEST STANDARDS:</b>	ANSI C29.9, ANSI C29.1, NEMA No. 107:1993

## SCHEDULE OF TESTS

### Design Tests, Section 7.2

<u>Page</u>	<u>Test Section</u>	<u>Description of Test</u>
-------------	---------------------	----------------------------

#### Electrical Tests

2	7.2.1	Low-frequency Wet Withstand Voltage
3	7.2.2 & 7.2.3	Critical Impulse Flashover Positive & Impulse Withstand Voltage
5	7.2.4	Radio-influence voltage tests

#### Mechanical Tests

6	7.2.5	Thermal shock test
7	7.2.6	Compression Strength
8	7.2.7	Torsional Strength

#### Quality Conformance Tests, Section 7.3

9	7.3.4	Cantilever Strength
10	7.3.5	Tensile Strength

All Electrical tests were performed per the requirements of ANSI test standard C29.9:2012, ANSI C29.1:2012, and NEMA No. 107:1993. All Mechanical tests were performed per the requirements of ANSI test standard C29.9 - 1983 (R1996), and ANSI C29.1 – 1988 (R2002).



**GAMMA Catalog 8435**  
**Design Test Certification**

**7.2.1 Low-frequency Wet Withstand Voltage**

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.1. The rated wet withstand voltage was applied on each of the tested post insulator for 10 seconds.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

**Low-frequency Wet Withstand Voltage Test Results**

	Sample No. 1	Sample No. 2	Sample No. 3
<b>b (in Hg)</b>	29.42	29.42	29.42
<b>t (°F)</b>	65.84	65.84	65.84
<b>r.i. (mm/min)</b>	5.0	5.0	5.0
<b>R<sub>W</sub> (Ωm)</b>	185.0	185.0	185.0
<b>V<sub>LW</sub> (kV) T</b>	<b>100</b>	<b>100</b>	<b>100</b>
<b>(s)</b>	10	10	10
<b>result</b>	no flashover occurred	no flashover occurred	no flashover occurred

No flashover occurred during the test at the rated wet withstand voltage 100 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. **Post type insulator TR-214, Catalog No. 8435 passed low-frequency wet withstand voltage test according to ANSI C29.9, cl. 7.2.1.**

**7.2.2 & 7.2.3 Impulse Withstand Voltage Test and Flashover Voltage**

The tests were carried out on the three post insulators according to ANSI C29.9, cl. 7.2.2 and 7.2.3. Three consecutive impulses of the rated impulse-withstand value of both polarities were applied on each of tested post insulator. The critical impulse voltages of both polarities were determined by the up and down method with 30 impulses.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

**Impulse Withstand Voltage and Flashover Voltage Test Results**

Polarity	+			-		
Test Sample No.	1	2	3	1	2	3
<b>V<sub>IW</sub> (kV)</b>	<b>250</b>	<b>250</b>	<b>250</b>	<b>250</b>	<b>250</b>	<b>250</b>
<b>Impulses</b>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>
<b>Flashovers</b>	0	0	0	0	0	0
<b>b (in Hg)</b>	29.48	29.48	29.48	29.48	29.48	29.48
<b>t (°F)</b>	67.6	67.6	67.6	67.6	67.6	67.6
<b>K<sub>h</sub></b>	1.0029	1.0029	1.0029	1.0029	1.0029	1.0029
<b>K<sub>d</sub></b>	1.0764	1.0764	1.0764	1.0663	1.0663	1.0663
<b>V<sub>CRS LI</sub> (kV)</b>	277	277	276	468	452	482
<b>V<sub>CRSA LI</sub> (kV)</b>	<b>277</b>			<b>467</b>		

No flashover occurred during the test with three impulses at the rated impulse-withstand voltage 250 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. **Post type insulator TR-214, Catalog No. 8435 passed impulse withstand voltage test according to ANSI C29.9, cl. 7.2.3.**

The rated critical-impulse flashover voltage 280 kV is specified by ANSI C29.9, Table 2. The average values of critical-impulse flashover voltages are higher than 92 percent of the rated critical-impulse flashover voltage, i.e. 258 kV. All test samples met the requirements. **Post type insulator TR-214, Catalog No. 843 passed critical-impulse flashover voltage test according to ANSI C29.9, cl. 7.2.2.**

**GAMMA Catalog 8435**  
**Design Test Certification**

**7.2.4 Radio-influence Voltage (RIV) Test**

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.4. Radio-influence voltage was measured at the frequency 1.0 MHz in accordance with circuit diagram in Figure 3 – 3a of NEMA No. 107, Section 3.

*The test arrangement was set up according to ANSI C29.1, cl. 4.9.1.*

**Radio-influence Voltage (RIV) Test Results**

	Sample No. 1	Sample No. 2	Sample No. 3
b (in Hg)	29,48	29,48	29,48
t (°F)	63,5	63,5	63,5
V <sub>T</sub> (kV)	RIV (μV)	RIV (μV)	RIV (μV)
33	4	4	4
<b>30</b>	<b>4</b>	<b>4</b>	<b>4</b>
27	4	4	4
0	4	4	4
Rated value: max. 200 μV at 30 kV/1,0 MHz			

Measured values of radio-influence voltages on post insulators at test voltage 30 kV (1 MHz) are less than 200 μV specified by ANSI C29.9, Table 2. All test samples met the requirements. **Post type insulator TR-214, Catalog No. 8435 passed radio-influence voltage test according to ANSI C29.9, cl. 7.2.4.**

**7.2.5 Thermal Shock Test**

The test was carried out on three post insulator according to ANSI C 29.9, cl 7.2.5. Each tested post insulator was first immersed in a hot water bath 150 °F (66 °C) for 10 minutes. Then it was withdrawn and immersed in a cold water bath 39 °F (4 °C) for 10 minutes. After tenth cycle each post insulator was tested for electrical soundness by low-frequency momentary flashover voltage test.

**Thermal Shock Test Results**

	10 cycles (150 °F / 10 min and 39 °F/ 10 min)	Low-frequency Momentary Flashover Voltage Test	Flashover voltage (kV)	Result
Test Sample No. 1	No failure	No failure	173	Passed
Test Sample No. 2	No failure	No failure	178	Passed
Test Sample No. 3	No failure	No failure	179	Passed

No failure occurred during the thermal shock test according to ANSI C29.9, cl. 7.2.5. All test samples met the requirements. **Post type insulator TR-214, Catalog No. 8435 passed thermal shock test according to ANSI C29.9, cl. 7.2.5.**

**GAMMA Catalog 8435**  
**Design Test Certification**

**7.2.6 Compression Strength Test**

Temperature 68 -71.6 °F (20-22 °C), Minimum failing load 14,994.76 lbs. (66.70 kN). Smooth increase in load 450 - 900 lbs. /s. (2 - 4 kN/s), smooth load up to failure, visual inspection

**Compression Strength Test Results**

Sample No.	Maximum failure load lbs. (kN)	Failure Mode	Result (MFL)
7	(3012)	Sheds	Passed
8	(2035)	Sheds	Passed
9	(3012)	Ceramic core	Passed
Average	(2686)		

**7.2.7 Torsional Strength Test**

Temperature during test + 73.4 °F (+ 23 °C), Minimum failing load (MFL) 11,948.51 lb.-in. (1.35 kNm), Smooth increase in load 265.52- 442.54 lb.-in./s (0.03 – 0.05 kNm/s), Smooth load up to failure of screws

**Torsional Strength Test Results**

Sample No.	Maximum reached torsional moment lbs. (kNm)	Failure Mode	Result (MFL)
10	>75,231.34 (8.5)	Screws failed. Insulator did not fail. Test stopped by operator.	Passed
11	> 77,001.49 (8.7)	Screws failed. Insulator did not fail. Test stopped by operator.	Passed
12	> 57,529.85 (6.5)	Insulator did not fail. Test stopped by operator	Passed

**7.3.4 Cantilever Strength Test**

Temperature during test + 71.6 °F (+ 22 °C), Minimum failing load (MFL) 2,023.28 lbs. (9 kN), Increase in load 6.74 – 13.49 lbs. /s (0.03 - 0.06 kN/s), smoothly to failure

**Cantilever Strength Test Results**

Sample No.	Maximum failing load lbs. (kN)	Failure Mode	Result (MFL)
1	3,214.77 (14.30)	Failed at bottom part of ceramic core	passed
2	2,203.13 (9.80)	Failed at bottom part of ceramic core	passed
3	3,012.44 (13.4)	Failed at bottom part of ceramic core	passed
Average	2,810.11 (12.5)		

**GAMMA Catalog 8435**  
**Design Test Certification**

**7.3.5 Tensile strength**

Temperature 68 – 69.8 °F (20-21 °C), Minimum failing load (MFL) 13,983.11 lbs. (62.2 kN), Increase in load 6.74 – 13.49 lbs./s (0.3 – 0.6 kN/s), smoothly. Smooth load up to failure, visual inspection

**Tensile Strength Test Results**

Sample No.	Maximum failure load [kN]	Way of failure	Result (MFL)
4	20,839.79 (92.7)	Ceramic core inside of metal cap	Passed
5	36,081.84 (160.5)	Ceramic core inside of metal cap	Passed
6	28,404.61 (126.35)	Ceramic core inside of metal cap	Passed
Average	28,438.33 (126.5)		

Tests performed at EGU HV Laboratory a. s., Test No. 10210/A/15, and The Klockner Institute, Report No. 129/15/AL. All test results contained in this document are held on file under drawing number reference 84351011.

---

**Frank Escobar**  
**Chief Engineer, GAMMA Insulators Corporation**

## Design Test Certification

<b>Material Tested</b>	<b>GAMMA Catalog Number 8436</b>
<b>TEST OBJECT:</b>	Station Post Insulator
<b>TYPE SPECIFICATION:</b>	TR 216
<b>TEST STANDARDS:</b>	ANSI C29.9, ANSI C29.1, NEMA No. 107:1993

## SCHEDULE OF TESTS

### Design Tests, Section 7.2

<u>Page</u>	<u>Test Section</u>	<u>Description of Test</u>
-------------	---------------------	----------------------------

#### Electrical Tests

2	7.2.1	Low-frequency Wet Withstand Voltage
3	7.2.2 & 7.2.3	Critical Impulse Flashover Positive & Impulse Withstand Voltage
5	7.2.4	Radio-influence voltage tests

#### Mechanical Tests

6	7.2.5	Thermal shock test
7	7.2.6	Compression Strength
8	7.2.7	Torsional Strength

### Quality Conformance Tests, Section 7.3

9	7.3.4	Cantilever Strength
10	7.3.5	Tensile Strength

All Electrical tests were performed per the requirements of ANSI test standard C29.9:2012, ANSI C29.1:2012, and NEMA No. 107:1993. All Mechanical tests were performed per the requirements of ANSI test standard C29.9 - 1983 (R1996), and ANSI C29.1 – 1988 (R2002).

**GAMMA Catalog 8436**  
**Design Test Certification**

**7.2.1 Low-frequency Wet Withstand Voltage**

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.1. The rated wet withstand voltage was applied on each of the tested post insulator for 10 seconds.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

**Low-frequency Wet Withstand Voltage Test Results**

	Sample No. 1	Sample No. 2	Sample No. 3
<b>b (in Hg)</b>	29.42	29.42	29.42
<b>t (°F)</b>	67.1	67.1	67.1
<b>r.i. (mm/min)</b>	5.0	5.0	5.0
<b>R<sub>W</sub> (Ωm)</b>	185.0	185.0	185.0
<b>V<sub>LW</sub> (kV)</b>	<b>145</b>	<b>145</b>	<b>145</b>
<b>T (s)</b>	10	10	10
<b>Result</b>	no flashover occurred	no flashover occurred	no flashover occurred

No flashover occurred during the test at the rated wet withstand voltage 145 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. **Post type insulator TR-216, Catalog No. 8436 passed low-frequency wet withstand voltage test according to ANSI C29.9, cl. 7.2.1.**

**7.2.2 & 7.2.3 Impulse Withstand Voltage Test and Flashover Voltage**

The tests were carried out on the three post insulators according to ANSI C29.9, cl. 7.2.2 and 7.2.3. Three consecutive impulses of the rated impulse-withstand value of both polarities were applied on each of tested post insulator. The critical impulse voltages of both polarities were determined by the up and down method with 30 impulses.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

**Impulse Withstand Voltage and Flashover Voltage Test Results**

Polarity	+			-		
Test Sample No.	1	2	3	1	2	3
<b>V<sub>IW</sub> (kV)</b>	<b>350</b>	<b>350</b>	<b>350</b>	<b>350</b>	<b>350</b>	<b>350</b>
<b>Impulses</b>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>
<b>Flashovers</b>	0	0	0	0	0	0
<b>b (in Hg)</b>	29.48	29.48	29.48	29.48	29.48	29.48
<b>t (°F)</b>	64.6	64.6	64.6	64.6	64.6	64.6
<b>K<sub>h</sub></b>	1.0088	1.0088	1.0088	1.0088	1.0088	1.0088
<b>K<sub>d</sub></b>	1.0823	1.0823	1.0823	1.0714	1.0714	1.0714
<b>V<sub>CRS LI</sub> (kV)</b>	383	386	381	630	640	617
<b>V<sub>CRSA LI</sub> (kV)</b>	<b>383</b>			<b>629</b>		

No flashover occurred during the test with three impulses at the rated impulse-withstand voltage 350 kV specified by ANSI C29.9, Table 2, All test samples met the requirements. **Post type insulator TR-216, Catalog No. 8436 passed impulse withstand voltage test according to ANSI C29.9, cl. 7.2.3.**

The rated critical-impulse flashover voltage 390 kV is specified by ANSI C29.9, Table 2. The average values of critical-impulse flashover voltages are higher than 92 percent of the rated critical-impulse flashover voltage, i.e. 359 kV. All test samples met the requirements. **Post type insulator TR-216, Catalog No. 8436 passed critical-impulse flashover voltage test according to ANSI C29.9, cl. 7.2.2.**

**GAMMA Catalog 8436**  
**Design Test Certification**

**7.2.4 Radio-influence Voltage (RIV) Test**

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.4. Radio-influence voltage was measured at the frequency 1.0 MHz in accordance with circuit diagram in Figure 3 – 3a of NEMA No. 107, Section 3.

*The test arrangement was set up according to ANSI C29.1, cl. 4.9.1.*

**Radio-influence Voltage (RIV) Test Results**

	Sample No. 1	Sample No. 2	Sample No. 3
b (in Hg)	29.48	29.48	29.48
t (°F)	63.5	63.5	63.5
V <sub>T</sub> (kV)	RIV (μV)	RIV (μV)	RIV (μV)
48	4	4	4
44	4	4	4
40	4	4	4
36	4	4	4
0	4	4	4
Rated value: max. 200 μV at 30 kV/1,0 MHz			

Measured values of radio-influence voltages on post insulators at test voltage 44 kV (1 MHz) are less than 200 μV specified by ANSI C29.9, Table 2. All test samples met the requirements. **Post type insulator TR-216, Catalog No. 8436 passed radio-influence voltage test according to ANSI C29.9, cl. 7.2.4.**

**7.2.5 Thermal Shock Test**

The test was carried out on three post insulator according to ANSI C 29.9, cl 7.2.5. Each tested post insulator was first immersed in a hot water bath 150 °F (66 °C) for 10 minutes. Then it was withdrawn and immersed in a cold water bath 39 F (4 °C) for 10 minutes. After tenth cycle each post insulator was tested for electrical soundness by low-frequency momentary flashover voltage test.

**Thermal Shock Test Results**

	10 cycles (150 °F / 10 min and 39 °F/ 10 min)	Low-frequency Momentary Flashover Voltage Test	Flashover voltage (kV)	Result
Test Sample No. 1	No failure	No failure	242	Passed
Test Sample No. 2	No failure	No failure	246	Passed
Test Sample No. 3	No failure	No failure	241	Passed

No failure occurred during the thermal shock test according to ANSI C29.9, cl. 7.2.5. All test samples met the requirements. **Post type insulator TR-216, Catalog No. 8436 passed thermal shock test according to ANSI C29.9, cl. 7.2.5.**

**GAMMA Catalog 8436**  
**Design Test Certification**

**7.2.6 Compression Strength Test**

Temperature 68 -71.6 °F (20-22 °C), Minimum failing load 24,998.75 lbs. (111.2 kN). Smooth increase in load 450 - 900 lbs./s. (2 - 4 kN/s), Smooth load up to failure, visual inspection

**Compression Strength Test Results**

Sample No.	Maximum failure load lbs. (kN)	Failure Mode	Result (MFL)
7	(3754)	Ceramic core	Passed
8	(3628)	Ceramic core	Passed
9	(3472)	Ceramic core	Passed
Average	(3618)		

**7.2.7 Torsional Strength Test**

Temperature during test + 73.4 °F (+ 23 °C), Minimum failing load (MFL) 15,002 lb.-in. (1.695 kNm), Smooth increase in load 265.52- 442.54 lb.-in./s (0.03 – 0.05 kNm/s), Smooth load up until 57,530 lb.-in. (6.5 kNm) – The limit of screws used, test stopped by operator, visual inspection.

**Torsional Strength Test Results**

Sample No.	Maximum Reached Torsional Moment lbs.-in. (kNm)	Failure Mode	Result (MFL)
10	>57,530 (6.5)	Insulator did not fail. Test stopped by operator.	Passed
11	>57,530 (6.5)	Insulator did not fail. Test stopped by operator	Passed
12	>57,530 (6.5)	Insulator did not fail. Test stopped by operator	Passed

**7.3.4 Cantilever Strength Test**

Temperature during test + 71.6 °F (+ 22 °C), Minimum failing load (MFL) 1,506.22 lbs. (6. kN), Increase in load 6.74 – 13.49 lbs./s (0.03 - 0.06 kN/s), smoothly until failure

**Cantilever Strength Test Results**

Sample No.	Maximum failing load lbs. (kN)	Failure Mode	Result (MFL)
1	2,855.07 (12.7)	Failed at bottom part of ceramic core	Passed
2	1775.99 (7.9)	Failed at bottom part of ceramic core	Passed
3	2472.90 (11.0)	Failed at bottom part of ceramic core	Passed
Average	2360.50 (10.5)		



**GAMMA Catalog 8436**  
**Design Test Certification**

**7.3.5 Tensile strength**

Temperature 68 – 69.8 °F (20-21 °C), Minimum failing load (MFL) 16,006.40 lbs. (71.2 kN), Increase in load 6.74 – 13.49 lbs./s (0.3 – 0.6 kN/s), smoothly. Smooth load up to Failure, visual inspection.

**Tensile Strength Test Results**

Sample No.	Maximum failure load lbs. (kN)	Failure Mode	Result (MFL)
4	25,628.22 (114.0)	Ceramic core inside of metal cap	Passed
5	23,649.90 (105.2)	Ceramic core inside of metal cap	Passed
6	24,661.54 (109.7)	Ceramic core inside of metal cap	Passed
Average	24,639.06 (109.6)		

Tests performed at EGU HV Laboratory a. s., Test No.10201/B/15, and The Klokner Institute, Report No. 128/15/AL.  
All test results contained in this document are held on file under drawing number reference 84361011.

---

**Frank Escobar**  
Chief Engineer, GAMMA Insulators Corporation

## Design Test Certification

<b>Material Tested</b>	<b>GAMMA-CERISOL Catalog Number 288SU0650</b>
<b>TEST OBJECT:</b>	Station Post Insulator
<b>TYPE SPECIFICATION:</b>	TR 288
<b>TEST STANDARDS:</b>	ANSI C29.9, ANSI C29.1, NEMA No. 107:1993

## SCHEDULE OF TESTS

### Design Tests, Section 7.2

<u>Page</u>	<u>Test Section</u>	<u>Description of Test</u>
-------------	---------------------	----------------------------

#### Electrical Tests

2	7.2.1	Low-frequency Wet Withstand Voltage
3	7.2.2 & 7.2.3	Critical Impulse Flashover Positive & Impulse Withstand Voltage
5	7.2.4	Radio-influence voltage tests

#### Mechanical Tests

6	7.2.5	Thermal shock test
7	7.2.6	Compression Strength
8	7.2.7	Torsional Strength

#### Quality Conformance Tests, Section 7.3

9	7.3.4	Cantilever Strength
10	7.3.5	Tensile Strength

All Electrical tests were performed per the requirements of ANSI test standard C29.9:2012, ANSI C29.1:2012, and NEMA No. 107:1993. All Mechanical tests were performed per the requirements of ANSI test standard C29.9 - 1983 (R1996), and ANSI C29.1 – 1988 (R2002).

## GAMMA-CERISOL Catalog 288SU0650

### Design Test Certification

#### 7.2.1 Low-frequency Wet Withstand Voltage

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.1. The rated wet withstand voltage was applied on each of the tested post insulator for 10 seconds.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Low-frequency Wet Withstand Voltage Test Results

Station post insulator			
	Sample No. 1	Sample No.2	Sample No.3
b (in Hg)	28.88	28.88	28.88
t (°F)	60.6	60.6	60.6
r.i. (mm/min)	5.0	5.0	5.0
R <sub>w</sub> (Ωm)	200.0	200.0	200.0
V <sub>lw</sub> (kV)	275	275	275
T (s)	10	10	10
result	No flashover occurred	No flashover occurred	No flashover occurred

No flashover occurred during the test at the rated wet withstand voltage 275 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 288, **Catalog No. 288SU0650** passed low-frequency wet withstand voltage tests according to ANSI C29.9, cl. 7.2.1.

#### 7.2.2 & 7.2.3 Impulse Withstand Voltage Test and Flashover Voltage

The tests were carried out on the three post insulators according to ANSI C29.9, cl. 7.2.2 and 7.2.3. Three consecutive impulses of the rated impulse-withstand value of both polarities were applied on each of tested post insulator. The critical impulse voltages of both polarities were determined by the up and down method with 30 impulses.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Impulse Withstand Voltage and Flashover Voltage Test Results

Polarity	+			-		
Test sample No.	1	2	3	1	2	3
V <sub>iw</sub> (kV)	650	650	650	650	650	650
Impulses	3	3	3	3	3	3
Flashovers	0	0	0	0	0	0
b (in Hg)	28.85	28.85	28.76	28.85	28.85	28.76
t (°F)	60.6	60.6	61.7	60.6	60.6	61.7
K <sub>h</sub>	1.066	1.066	1.061	1.058	1.058	1.054
K <sub>d</sub>	0.995	0.995	0.990	0.995	0.995	0.990
V <sub>CRS LI</sub> (kV)	701	711	706	863	846	829
V <sub>CRSA LI</sub> (kV)	706			846		

No flashover occurred during the test with three impulses at the rated impulse-withstand voltage 650 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 288, **Catalog No. 288SU0650** passed impulse withstand voltage tests according to ANSI C29.9, cl. 7.2.3.

The rated critical-impulse flashover voltage 710 kV is specified by ANSI C29.9, Table 2. The average values of critical-impulse flashover voltages are higher than 92 percent of the rated critical-impulse flashover voltage, i.e. 653 kV. All test samples met

the requirements. Station post insulator TR 288, **Catalog No. 288SU0650** passed critical impulse flashover voltage tests according to ANSI C29.9, cl. 7.2.2.

#### **GAMMA-CERISOL Catalog 288SU0650**

#### **Design Test Certification**

#### **7.2.4 Radio-influence Voltage (RIV) Test**

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.4. Radio-influence voltage was measured at the frequency 1.0 MHz in accordance with circuit diagram in Figure 3 – 3a of NEMA No. 107, Section 3.

*The test arrangement was set up according to ANSI C29.1, cl. 4.9.1.*

#### **Radio-influence Voltage (RIV) Test Results**

Station post insulator			
	Sample No.1	Sample No.2	Sample No. 3
<b>b (in Hg)</b>	29.03	29.03	29.03
<b>t (°F)</b>	59.5	59.7	59.7
<b>V<sub>T</sub> (kV)</b>	<b>RIV (μV)</b>	<b>RIV (μV)</b>	<b>RIV (μV)</b>
97	6	6	6
<b>88</b>	<b>6</b>	<b>6</b>	<b>6</b>
79	6	6	6
70	6	6	6
61	6	6	6
0	6	6	6
<b>Rated value: ma. 200 μV at 88 kV/1.0 MHz</b>			

Measured values of radio-influence voltages on post insulators at test voltage 88kV (1MHz) are less than 200 μV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 288, **Catalog No. 288SU0650** passed radio-influence voltage tests according to ANSI C29.9, cl. 7.2.4.

#### **7.2.5 Thermal Shock Test**

The test was carried out on three post insulator according to ANSI C 29.9, cl 7.2.5. Each tested post insulator was first immersed in a hot water bath 150 °F (66 °C) for 10 minutes. Then it was withdrawn and immersed in a cold water bath 39 °F (4 °C) for 10 minutes. After tenth cycle each post insulator was tested for electrical soundness by low-frequency momentary flashover voltage test.

#### **Thermal Shock Test Results**

	10 cycles (150 °F/ 10 min and 39 °F/ 10 min)	Low-frequency Momentary Flashover Voltage Test	Flashover voltage (kV)	Result
Test sample #1	No failure	No failure	410	Passed
Test sample #2	No failure	No failure	404	Passed
Test sample #3	No failure	No failure	413	Passed

No Failure occurred during the thermal shock test according to ANSI C29.9, cl. 7.2.5. All test samples met the requirements. Station post insulator TR 288, **Catalog No. 288SU0650** passed thermal shock test according to ANSI C29.9, cl. 7.2.5.

## GAMMA-CERISOL Catalog 288SU0650

### Design Test Certification

#### 7.2.6 Compression Strength Test

Temperature 68 -71.6 °F (20-22 °C), Minimum failing load 60,000 lbs. (266.880 kN). Smooth increase in load 450 - 900 lbs. /s. (2 - 4 kN/s), Smooth load up until 67,442.68 lbs. (300 kN), 3 sec hold on this level and unloading, visual inspection.

##### Compression Strength Test Results

Sample No.	Load 67,442.68 lbs. (300 kN) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.2.7 Torsional Strength Test

Temperature during test + 73.4 °F (+ 23 °C), Minimum failing load (MFL) 40,000 lb.-in. (4.52 kNm), Smooth increase in load 265.52- 442.54 lb.-in./s (0.03 – 0.05 kNm/s), Smooth load up until 44,253.73 lb.-in. (5 kNm), 3 sec hold on this level and unloading, visual inspection.

##### Torsional Strength Test Results

Sample No.	Torsional moment 44,253.73 lb.-in. (5 kNm) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.3.4 Cantilever Strength Test

Temperature during test + 71.6 °F (+ 22 °C), Minimum failing load (MFL) 1,400 lbs. (6.227 kN), Increase in load 6.74 – 13.49 lbs. /s (0.03 - 0.06 kN/s), smoothly until failure

##### Cantilever Strength Test Results

Sample No.	Maximum failing load lbs. (kN)	Way of failure	Result (MFL)
1	2,592.05 lbs. (11.53kN)	Failed at bottom part of ceramic core	Passed
2	2,189.64 lbs. ( 9.74kN)	Failed at bottom part of ceramic core	Passed
3	2,297.55 lbs. (10.22kN)	Failed at bottom part of ceramic core	Passed
Average	2,358.25 lbs. (10.49kN)		

## GAMMA-CERISOL Catalog 288SU0650

### Design Test Certification

#### 7.3.5 Tensile strength

Temperature 68 – 69.8 °F (20-21 °C), Minimum failing load (MFL) 20,000 lbs. (88.96 kN), Increase in load 6.74 – 13.49 lbs./s (0.3 – 0.6 kN/s), smoothly. Smooth load up until 21,356.85.07 lbs. (95 kN), 3 sec hold on this level and unloading, visual inspection.

#### Tensile Strength Test Results

Sample No.	Load 21,356.07 lbs. (95 kN) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

Tests performed at EGU HV Laboratory a. s., Test No.10060/B/14, and The Klokner Institute, Report No. 57/14/AL.

All test results contained in this document are held on file under drawing number reference H21288EJ.

---

**Frank Escobar**

**Chief Engineer, GAMMA Insulators Corporation**

## Design Test Certification

<b>Material Tested</b>	<b>GAMMA-CERISOL Catalog Number 308HU0900</b>
<b>TEST OBJECT:</b>	Station Post Insulator
<b>TYPE SPECIFICATION:</b>	TR 308
<b>TEST STANDARDS:</b>	ANSI C29.9, ANSI C29.1, NEMA No. 107:1993

## SCHEDULE OF TESTS

### Design Tests, Section 7.2

<u>Page</u>	<u>Test Section</u>	<u>Description of Test</u>
-------------	---------------------	----------------------------

#### Electrical Tests

2	7.2.1	Low-frequency Wet Withstand Voltage
3	7.2.2 & 7.2.3	Critical Impulse Flashover Positive & Impulse Withstand Voltage
5	7.2.4	Radio-influence voltage tests

#### Mechanical Tests

6	7.2.5	Thermal shock test
7	7.2.6	Compression Strength
8	7.2.7	Torsional Strength

#### Quality Conformance Tests, Section 7.3

9	7.3.4	Cantilever Strength
10	7.3.5	Tensile Strength

All Electrical tests were performed per the requirements of ANSI test standard C29.9:2012, ANSI C29.1:2012, and NEMA No. 107:1993. All Mechanical tests were performed per the requirements of ANSI test standard C29.9 - 1983 (R1996), and ANSI C29.1 – 1988 (R2002).

## GAMMA-CERISOL Catalog 308HU0900

### Design Test Certification

#### 7.2.1 Low-frequency Wet Withstand Voltage

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.1. The rated wet withstand voltage was applied on each of the tested post insulator for 10 seconds.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Low-frequency Wet Withstand Voltage Test Results

Station post insulator			
	Sample No. 1	Sample No.2	Sample No.3
b (in Hg)	28.79	28.79	28.79
t (°F)	60.6	60.6	60.6
r.i. (mm/min)	5.0	5.0	5.0
R <sub>w</sub> (Ωm)	200.0	200.0	200.0
V <sub>lw</sub> (kV)	385	385	385
T (s)	10	10	10
result	No flashover occurred	No flashover occurred	No flashover occurred

No flashover occurred during the test at the rated wet withstand voltage 385 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 308, **Catalog No. 308HU0900** passed low-frequency wet withstand voltage tests according to ANSI C29.9, cl. 7.2.1.

#### 7.2.2 & 7.2.3 Impulse Withstand Voltage Test and Flashover Voltage

The tests were carried out on the three post insulators according to ANSI C29.9, cl. 7.2.2 and 7.2.3. Three consecutive impulses of the rated impulse-withstand value of both polarities were applied on each of tested post insulator. The critical impulse voltages of both polarities were determined by the up and down method with 30 impulses.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Impulse Withstand Voltage and Flashover Voltage Test Results

Polarity	+			-		
Test Sample No.	1	2	3	1	2	3
V <sub>iw</sub> (kV)	1010	1010	1010	1010	1010	1010
Impulses	3	3	3	3	3	3
Flashovers	0	0	0	0	0	0
b (in Hg)	28.79	28.79	28.79	28.79	28.79	28.79
t (°F)	61.0	61.0	61.0	61.0	61.0	61.0
K <sub>h</sub>	1.064	1.064	1.064	1.056	1.056	1.056
K <sub>d</sub>	0.992	0.992	0.992	0.992	0.992	0.992
V <sub>CRS LI</sub> (kV)	1112	1105	1106	1277	1277	1299
V <sub>CRSA LI</sub> (kV)	1108			1284		

No flashover occurred during the test with three impulses at the rated impulse-withstand voltage 1010 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 308, **Catalog No. 308HU0900** passed impulse withstand voltage tests according to ANSI C29.9, cl. 7.2.3.

The rated critical-impulse flashover voltage 1010 kV is specified by ANSI C29.9, Table 2. The average values of critical-impulse flashover voltages are higher than 92 percent of the rated critical-impulse flashover voltage, i.e. 929 kV. All test samples met



the requirements. Station post insulator TR 308, **Catalog No. 308HU0900** passed critical impulse flashover voltage tests according to ANSI C29.9, cl. 7.2.2.

## GAMMA-CERISOL Catalog 308HU0900

### Design Test Certification

#### 7.2.4 Radio-influence Voltage (RIV) Test

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.4. Radio-influence voltage was measured at the frequency 1.0 MHz in accordance with circuit diagram in Figure 3 – 3a of NEMA No. 107, Section 3.

*The test arrangement was set up according to ANSI C29.1, cl. 4.9.1.*

#### Radio-influence Voltage (RIV) Test Results

Station post insulator			
	Sample No.1	Sample No.2	Sample No. 3
b (in Hg)	29.00	29.00	29.00
t (°F)	60.3	60.3	60.4
V <sub>T</sub> (kV)	RIV (μV)	RIV (μV)	RIV (μV)
161	141	63	100
<b>146</b>	<b>45</b>	<b>32</b>	<b>50</b>
131	10	20	14
116	6	11	9
101	6	7	6
86	6	6	6
71	6	6	6
0	6	6	6
Rated value: ma. 500 μV at 146 kV/1.0 MHz			

Measured values of radio-influence voltages on post insulators at test voltage 146kV (1MHz) are less than 500 μV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 308, **Catalog No. 308HU0900** passed radio-influence voltage tests according to ANSI C29.9, cl. 7.2.4.

#### 7.2.5 Thermal Shock Test

The test was carried out on three post insulator according to ANSI C 29.9, cl 7.2.5. Each tested post insulator was first immersed in a hot water bath 150 °F (66 °C) for 10 minutes. Then it was withdrawn and immersed in a cold water bath 39 °F (4 °C) for 10 minutes. After tenth cycle each post insulator was tested for electrical soundness by low-frequency momentary flashover voltage test.

#### Thermal Shock Test Results

	10 cycles (150 °F/ 10 min, and 39 °F/ 10 min)	Low-frequency Momentary Flashover Voltage Test	Flashover voltage (kV)	Result
Test sample #1	No failure	No failure	596	<b>Passed</b>
Test sample #2	No failure	No failure	585	<b>Passed</b>
Test sample #3	No failure	No failure	591	<b>Passed</b>

No Failure occurred during the thermal shock test according to ANSI C29.9, cl. 7.2.5. All test samples met the requirements. Station post insulator TR 308, **Catalog No. 308HU0900** passed thermal shock test according to ANSI C29.9, cl. 7.2.5.

## GAMMA-CERISOL Catalog 308HU0900

### Design Test Certification

#### 7.2.6 Compression Strength Test

Temperature 68 -71.6 °F (20-22 °C), Minimum failing load 75,000 lbs. (333.6 kN). Smooth increase in load 450 - 900 lbs. /s. (2 - 4 kN/s), Smooth load up until 89,923 lbs. (400 kN), 3 sec hold on this level and unloading, visual inspection.

##### Compression Strength Test Results

Sample No.	Load 89,923 lbs. (400kN) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.2.7 Torsional Strength Test

Temperature during test + 73.4 °F (+ 23 °C), Minimum failing load (MFL) 90,000 lb.-in. (10.17 kNm), Smooth increase in load 265.52- 442.54 lb.-in./s (0.03 – 0.05 kNm/s), Smooth load up until 92,932.83 lb.-in. (10.5 kNm), 3 sec hold on this level and unloading, visual inspection.

##### Torsional Strength Test Results

Sample No.	Torsional moment 92,932.83 lb.-in. (10.5 kNm) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.3.4 Cantilever Strength Test

Temperature during test + 71.6 °F (+ 22 °C), Minimum failing load (MFL) 1,450 lbs. (6.45 kN), Increase in load 6.74 – 13.49 lbs. /s (0.03 - 0.06 kN/s), smoothly until failure

##### Cantilever Strength Test Results

Sample No.	Maximum failing load, lbs. (kN)	Way of failure	Result (MFL)
1	1,978.32 (8.8)	Failed at bottom part of ceramic core	Passed
2	2,176.15 (9.68)	Failed at bottom part of ceramic core	Passed
3	2,000.80 (8.9)	Failed at bottom part of ceramic core	Passed
Average	2,050.26 (9.12)		

**GAMMA-CERISOL Catalog 308HU0900****Design Test Certification****7.3.5 Tensile strength**

Temperature 68 – 69.8 °F (20-21 °C), Minimum failing load (MFL) 25,000 lbs. (111.2 kN), Increase in load 6.74 – 13.49 lbs./s (0.3 – 0.6 kN/s), smoothly. Smooth load up until 26,977.07 lbs. (120 kN), 3 sec hold on this level and unloading, visual inspection.

**Tensile Strength Test Results**

Sample No.	Load 26,977.07 lbs. (120 kN) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

Tests performed at EGU HV Laboratory a. s., Test No.10060/C/14, and The Klokner Institute, Report No. 56/14/AL.  
All test results contained in this document are held on file under drawing number reference H21308EJ.

---

**Frank Escobar**  
Chief Engineer, GAMMA Insulators Corporation

## Design Test Certification

<b>Material Tested</b>	<b>GAMMA-CERISOL Catalog Number 369ET1300</b>
<b>TEST OBJECT:</b>	Station Post Insulator
<b>TYPE SPECIFICATION:</b>	TR 369
<b>TEST STANDARDS:</b>	ANSI C29.9, ANSI C29.1, NEMA No. 107:1993

## SCHEDULE OF TESTS

### Design Tests, Section 7.2

<u>Page</u>	<u>Test Section</u>	<u>Description of Test</u>
-------------	---------------------	----------------------------

#### Electrical Tests

2	7.2.1	Low-frequency Wet Withstand Voltage
3	7.2.2 & 7.2.3	Critical Impulse Flashover Positive & Impulse Withstand Voltage
5	7.2.4	Radio-influence voltage tests

#### Mechanical Tests

6	7.2.5	Thermal shock test
7	7.2.6	Compression Strength
8	7.2.7	Torsional Strength

#### Quality Conformance Tests, Section 7.3

9	7.3.4	Cantilever Strength
10	7.3.5	Tensile Strength

All Electrical tests were performed per the requirements of ANSI test standard C29.9:2012, ANSI C29.1:2012, and NEMA No. 107:1993. All Mechanical tests were performed per the requirements of ANSI test standard C29.9 - 1983 (R1996), and ANSI C29.1 – 1988 (R2002).

## GAMMA-CERISOL Catalog 369ET1300

### Design Test Certification

#### 7.2.1 Low-frequency Wet Withstand Voltage

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.1. The rated wet withstand voltage was applied on each of the tested post insulator for 10 seconds.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Low-frequency Wet Withstand Voltage Test Results

Station post insulator			
	Sample No. 1	Sample No.2	Sample No.3
b (in Hg)	28.82	28.82	28.82
t (°F)	59.4	59.4	59.4
r.i. (mm/min)	4.9	4.9	4.9
R <sub>w</sub> (Ωm)	200.0	200.0	200.0
V <sub>lw</sub> (kV)	525	525	525
T (s)	10	10	10
result	No flashover occurred	No flashover occurred	No flashover occurred

No flashover occurred during the test at the rated wet withstand voltage 525 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 369, **Catalog No. 369ET1300** passed low-frequency wet withstand voltage tests according to ANSI C29.9, cl. 7.2.1.

#### 7.2.2 & 7.2.3 Impulse Withstand Voltage Test and Flashover Voltage

The tests were carried out on the three post insulators according to ANSI C29.9, cl. 7.2.2 and 7.2.3. Three consecutive impulses of the rated impulse-withstand value of both polarities were applied on each of tested post insulator. The critical impulse voltages of both polarities were determined by the up and down method with 30 impulses.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Impulse Withstand Voltage and Flashover Voltage Test Results

Polarity	+			-		
Test sample no.	1	2	3	1	2	3
V <sub>IW</sub> (kV)	1410	1410	1410	1410	1410	1410
Impulses	3	3	3	3	3	3
Flashovers	0	0	0	0	0	0
b (in Hg)	28.82	28.88	28.82	28.82	28.88	28.82
t (°F)	60.6	60.4	60.6	60.6	60.4	60.6
K <sub>h</sub>	1.073	1.066	1.073	1.064	1.058	1.064
K <sub>d</sub>	0.994	0.996	0.994	0.994	0.996	0.994
V <sub>CRS LI</sub> (kV)	1470	1438	1446	1650	1645	1639
V <sub>CRSA LI</sub> (kV)	1451			1645		

No flashover occurred during the test with three impulses at the rated impulse-withstand voltage 1410 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 369, **Catalog No. 369ET1300** passed impulse withstand voltage tests according to ANSI C29.9, cl. 7.2.3.

The rated critical-impulse flashover voltage 1410 kV is specified by ANSI C29.9, Table 2. The average values of critical-impulse flashover voltages are higher than 92 percent of the rated critical-impulse flashover voltage, i.e. 1297 kV. All test samples met

the requirements. Station post insulator TR 369, **Catalog No. 369ET1300** passed critical impulse flashover voltage tests according to ANSI C29.9, cl. 7.2.2.

#### GAMMA-CERISOL Catalog 369ET1300

#### Design Test Certification

#### 7.2.4 Radio-influence Voltage (RIV) Test

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.4. Radio-influence voltage was measured at the frequency 1.0 MHz in accordance with circuit diagram in Figure 3 – 3a of NEMA No. 107, Section 3.

*The test arrangement was set up according to ANSI C29.1, cl. 4.9.1.*

#### Radio-influence Voltage (RIV) Test Results

Station post insulator			
	Sample No.1	Sample No.2	Sample No. 3
b (in Hg)	29.03	29.03	29.03
t (°F)	59.7	59.7	59.9
V <sub>T</sub> (kV)	RIV (μV)	RIV (μV)	RIV (μV)
242	631	794	631
<b>220</b>	<b>355</b>	<b>501</b>	<b>447</b>
198	251	316	282
176	158	224	224
154	126	126	126
132	100	100	100
110	79	7	9
88	5	5	5
66	5	5	5
0	5	5	5
Rated value: ma. 1000 μV at 220 kV/1.0 MHz			

Measured values of radio-influence voltages on post insulators at test voltage 220kV (1MHz) are less than 1000 μV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 369, catalog No. 369ET1300 **passed** radio-influence voltage tests according to ANSI C29.9, cl. 7.2.4.

#### 7.2.5 Thermal Shock Test

The test was carried out on three post insulator according to ANSI C 29.9, cl 7.2.5. Each tested post insulator was first immersed in a hot water bath 150 °F (66 °C) for 10 minutes. Then it was withdrawn and immersed in a cold water bath 39 °F (4 °C) for 10 minutes. After tenth cycle each post insulator was tested for electrical soundness by low-frequency momentary flashover voltage test.

#### Thermal Shock Test Results

	10 cycles (150 °F/ 10 min and 39 °F/ 10 min)	Low-frequency Momentary Flashover Voltage Test	Flashover voltage (kV)	Result
Test sample #1	No failure	No failure	764	<b>Passed</b>
Test sample #2	No failure	No failure	752	<b>Passed</b>
Test sample #3	No failure	No failure	760	<b>Passed</b>

No Failure occurred during the thermal shock test according to ANSI C29.9, cl. 7.2.5. All test samples met the requirements. Station post insulator TR 369, **Catalog No. 369ET1300** passed thermal shock test according to ANSI C29.9, cl. 7.2.5.

## GAMMA-CERISOL Catalog 369ET1300

### Design Test Certification

#### 7.2.6 Compression Strength Test

Temperature 68 -71.6 °F (20-22 °C), Minimum failing load 60,000 lbs. (266.880 kN). Smooth increase in load 450 - 900 lbs. /s. (2 - 4 kN/s), Smooth load up until 89,923 lbs. (400 kN), 3 sec hold on this level and unloading, visual inspection.

##### Compression Strength Test Results

Sample No.	Load 89,923 lbs. Load (400 kN) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.2.7 Torsional Strength Test

Temperature during test + 73.4 °F (+ 23 °C), Minimum failing load (MFL) 40,000 lb.-in. (4.52 kNm), Smooth increase in load 265.52- 442.54 lb.-in./s (0.03 – 0.05 kNm/s), Smooth load up until 44,253.73 lb.-in. (5 kNm), 3 sec hold on this level and unloading, visual inspection.

##### Torsional Strength Test Results

Sample No.	Torsional moment 44,248 lb.-in. (5 kNm) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.3.4 Cantilever Strength Test

Temperature during test + 71.6 °F (+ 22 °C), Minimum failing load (MFL) 2,050 lbs. (9.118 kN), Increase in load 9.0 – 15.74 lbs. /s (0.04 - 0.07 kN/s), smoothly until failure

##### Cantilever Strength Test Results

Sample No.	Maximum failing load lbs. (kN)	Way of failure	Result (MFL)
1	3,331.67 (14.82)	Failed at bottom part of ceramic core	Passed
2	3,167.56 (14.09)	Failed at bottom part of ceramic core	Passed
3	2,542.59 (11.31)	Failed at bottom part of ceramic core	Passed
Average	3,012.44 (13.4)		

## GAMMA-CERISOL Catalog 369ET1300

### Design Test Certification

#### 7.3.5 Tensile strength

Temperature 68 – 69.8 °F (20-21 °C), Minimum failing load (MFL) 20,000 lbs. (88.960 kN), Increase in load 6.74 – 13.49 lbs./s (0.3 – 0.6 kN/s), smoothly. Smooth load up until 26,977.07 lbs. (120 kN), 3 sec hold on this level and unloading, visual inspection.

#### Tensile Strength Test Results

Sample No.	Load 26,977.07 lbs. (120 kN) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

Tests performed at EGU HV Laboratory a. s., Test No.10060/D/14, and The Klokner Institute, Report No. 55/14/AL.  
All test results contained in this document are held on file under drawing number reference H21369EJ.

---

**Frank Escobar**  
Chief Engineer, GAMMA Insulators Corporation



## Design Test Certification

<b>Material Tested</b>	<b>GAMMA-CERISOL Catalog Number 391ST1800</b>
<b>TEST OBJECT:</b>	Station Post Insulator
<b>TYPE SPECIFICATION:</b>	TR 391
<b>TEST STANDARDS:</b>	ANSI C29.9, ANSI C29.1, NEMA No. 107:1993

## SCHEDULE OF TESTS

### Design Tests, Section 7.2

<u>Page</u>	<u>Test Section</u>	<u>Description of Test</u>
-------------	---------------------	----------------------------

#### Electrical Tests

2	7.2.1	Low-frequency Wet Withstand Voltage
3	7.2.2 & 7.2.3	Critical Impulse Flashover Positive & Impulse Withstand Voltage
5	7.2.4	Radio-influence voltage tests

#### Mechanical Tests

6	7.2.5	Thermal shock test
7	7.2.6	Compression Strength
8	7.2.7	Torsional Strength

#### Quality Conformance Tests, Section 7.3

9	7.3.4	Cantilever Strength
10	7.3.5	Tensile Strength

All Electrical tests were performed per the requirements of ANSI test standard C29.9:2012, ANSI C29.1:2012, and NEMA No. 107:1993. All Mechanical tests were performed per the requirements of ANSI test standard C29.9 - 1983 (R1996), and ANSI C29.1 – 1988 (R2002).

## GAMMA-CERISOL Catalog 391ST1800

### Design Test Certification

#### 7.2.1 Low-frequency Wet Withstand Voltage

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.1. The rated wet withstand voltage was applied on each of the tested post insulator for 10 seconds.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Low-frequency Wet Withstand Voltage Test Results

Station post insulator			
	Sample No. 1	Sample No.2	Sample No.3
b (in Hg)	29.4	29.4	29.4
t (°F)	59.2	59.2	59.2
r.i. (mm/min)	5.0	5.0	5.0
R <sub>w</sub> (Ωm)	200.0	200.0	200.0
V <sub>LW</sub> (kV)	<b>710</b>	<b>710</b>	<b>710</b>
T (s)	10	10	10
result	No flashover occurred	No flashover occurred	No flashover occurred

No flashover occurred during the test at the rated wet withstand voltage 230 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 391, **Catalog No. 391ST1800 passed low-frequency wet withstand voltage tests according to ANSI C29.9, cl. 7.2.1.**

#### 7.2.2 & 7.2.3 Impulse Withstand Voltage Test and Flashover Voltage

The tests were carried out on the three post insulators according to ANSI C29.9, cl. 7.2.2 and 7.2.3. Three consecutive impulses of the rated impulse-withstand value of both polarities were applied on each of tested post insulator. The critical impulse voltages of both polarities were determined by the up and down method with 30 impulses.

*The test arrangement was set up according to ANSI C29.1, cl. 3.3*

#### Impulse Withstand Voltage and Flashover Voltage Test Results

Polarity	+			-		
Test Sample No.	1	2	3	1	2	3
V <sub>IW</sub> (kV)	<b>1800</b>	<b>1800</b>	<b>1800</b>	<b>1800</b>	<b>1800</b>	<b>1800</b>
Impulses	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>
Flashovers	0	0	0	0	0	0
b (in Hg)	29.0	29.0	29.0	29.0	29.0	29.0
t (°F)	60.1	60.1	60.1	60.1	60.1	60.1
K <sub>h</sub>	1.001	1.001	1.001	1.001	1.001	1.001
K <sub>d</sub>	1.073	1.073	1.073	1.064	1.064	1.064
V <sub>CRS LI</sub> (kV)	2143	2139	2110	2316	2292	2302
V <sub>CRSA LI</sub> (kV)	<b>2131</b>			<b>2303</b>		

No flashover occurred during the test with three impulses at the rated impulse-withstand voltage 1800 kV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 391, **Catalog No. 391ST1800 passed impulse withstand voltage tests according to ANSI C29.9, cl. 7.2.3.**

The rated critical-impulse flashover voltage 2000 kV is specified by ANSI C29.9, Table 2. The average values of critical-impulse flashover voltages are higher than 92 percent of the rated critical-impulse flashover voltage, i.e. 1840 kV. All test samples met the requirements. Station post insulator TR 391, **Catalog No. 391ST1800 passed critical-impulse flashover voltage tests according to ANSI C29.9, cl. 7.2.2.**

## GAMMA-CERISOL Catalog 391ST1800

### Design Test Certification

#### 7.2.4 Radio-influence Voltage (RIV) Test

The tests were carried out on three post insulators according to ANSI C29.9, cl. 7.2.4. Radio-influence voltage was measured at the frequency 1.0 MHz in accordance with circuit diagram in Figure 3 – 3a of NEMA No. 107, Section 3.

*The test arrangement was set up according to ANSI C29.1, cl. 4.9.1.*

#### Radio-influence Voltage (RIV) Test Results

Station post insulator			
	Sample No.1	Sample No.2	Sample No. 3
<b>b (in Hg)</b>	29.03	29.03	29.03
<b>t (°F)</b>	60.1	60.1	60.1
<b>V<sub>T</sub> (kV)</b>	<b>RIV (μV)</b>	<b>RIV (μV)</b>	<b>RIV (μV)</b>
350	562	562	794
<b>318</b>	<b>100</b>	<b>112</b>	<b>89</b>
286	56	63	56
254	32	28	35
222	20	20	18
190	5	5	5
158	5	5	5
126	5	5	5
0	5	5	5
Rated value: ma. 2000 μV at 318 kV/1.0 MHz			

Measured values of radio-influence voltages on post insulators at test voltage 318kV (1MHz) are less than 2000 μV specified by ANSI C29.9, Table 2. All test samples met the requirements. Station post insulator TR 391, **Catalog No. 391ST1800 passed radio-influence voltage tests according to ANSI C29.9, cl. 7.2.4.**

#### 7.2.5 Thermal Shock Test

The test was carried out on three post insulator according to ANSI C 29.9, cl 7.2.5. Each tested post insulator was first immersed in a hot water bath 150 °F (66 °C) for 10 minutes. Then it was withdrawn and immersed in a cold water bath 39 °F (4 °C) for 10 minutes. After tenth cycle each post insulator was tested for electrical soundness by low-frequency momentary flashover voltage test.

#### Thermal Shock Test Results

	10 cycles (150 °F/ 10 min and 39 F/ 10 min)	Low-frequency Momentary Flashover Voltage Test	Flashover voltage (kV)	Result
Test sample #1	No failure	No failure	937	<b>Passed</b>
Test sample #2	No failure	No failure	945	<b>Passed</b>
Test sample #3	No failure	No failure	929	<b>Passed</b>

No Failure occurred during the thermal shock test according to ANSI C29.9, cl. 7.2.5. All test samples met the requirements. Station post insulator TR 391, **Catalog No. 391ST1800 passed thermal shock test according to ANSI C29.9, cl. 7.2.5.**

## GAMMA-CERISOL Catalog 391ST1800

### Design Test Certification

#### 7.2.6 Compression Strength Test

Temperature 68 -71.6 °F (20-22 °C), Minimum failing load 60,000 lbs. (266.880 kN). Smooth increase in load 450 - 900 lbs. /s. (2 - 4 kN/s), Smooth load up until 89,923 lbs. (400 kN), 3 sec hold on this level and unloading, visual inspection.

##### Compression Strength Test Results

Sample No.	Load 89,923 (400 kN), Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.2.7 Torsional Strength Test

Temperature during test + 73.4 °F (+ 23 °C), Minimum failing load (MFL) 40,000 lb.-in. (4.52 kNm), Smooth increase in load 265.52- 442.54 lb.-in./s (0.03 – 0.05 kNm/s), Smooth load up until 44,253.72 lb.-in. (5 kNm), 3 sec hold on this level and unloading, visual inspection.

##### Torsional Strength Test Results

Sample No.	Torsional moment 44,253.72 lb.-in (5 kNm) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

#### 7.3.4 Cantilever Strength Test

Temperature during test + 71.6 °F (+ 22 °C), Minimum failing load (MFL) 1,400 lbs. (6.227 kN), Increase in load 6.74 – 13.49 lbs. /s (0.03 - 0.06 kN/s), smoothly until failure

##### Cantilever Strength Test Results

Sample No.	Maximum failing load [kN]	Way of failure	Result (MFL)
1	9.26	Failed at bottom part of ceramic core	Passed
2	7.04	Failed at bottom part of ceramic core	Passed
3	7.84	Failed at bottom part of ceramic core	Passed
Average	8.05		

**GAMMA-CERISOL Catalog 391ST1800**  
**Design Test Certification**

**7.3.5 Tensile strength**

Temperature 68 – 69.8 °F (20-21 °C), Minimum failing load (MFL) 20,000 lbs. (88.960 kN), Increase in load 6.74 – 13.49 lbs./s (0.3 – 0.6 kN/s), smoothly. Smooth load up until 26,977.07 lbs. (120 kN), 3 sec hold on this level and unloading, visual inspection.

**Tensile Strength Test Results**

Sample No.	Load 26,977.07 lbs. (120 kN) Applied for 3 sec	Result (MFL)
1	Insulator did not fail	Passed
2	Insulator did not fail	Passed
3	Insulator did not fail	Passed

Tests performed at EGU HV Laboratory a. s., Test No.10060/E/14, and The Klokner Institute, Report No. 54/14/AL.  
 All test results contained in this document are held on file under drawing number reference H21391EJ.

---

**Frank Escobar**  
 Chief Engineer, GAMMA Insulators Corporation