



TRANE®

Cooling Performance Data

XR12

1½ – 5 Tons



Models

4TTR2018A1000A

4TTR2024A1000A

4TTR2030A1000A

4TTR2036A1000A

4TTR2042A1000A

4TTR2048A1000A

4TTR2060A1000A

PUB. NO. 22-1728-01-1201 (EN)



Contents

Cooling

MODEL NUMBER	PAGE NO.	MODEL NUMBER	PAGE NO.
4TTR2018A1 WITH 4TEE3F31A	6	4TTR2024A1 WITH TDY060R9V3+RXC025S3	15
4TTR2018A1 WITH 4TEP3F18A	6	4TTR2024A1 WITH TDY060R9V3+RXC031S3	15
4TTR2018A1 WITH 4TEP3F24A	6	4TTR2024A1 WITH TDY060R9V3+RXC036S3	15
4TTR2018A1 WITH 4TEP3F30A	6	4TTR2024A1 WITH TDY080R9V3+TXH025A4	15
4TTR2018A1 WITH RXC025S3	6	4TTR2024A1 WITH TDY080R9V3+TXH033A4	15
4TTR2018A1 WITH RXC031S3	6	4TTR2024A1 WITH TDY080R9V3+RXC025S3	15
4TTR2018A1 WITH TDD060R9V3+TXH025A4	7	4TTR2024A1 WITH TDY080R9V3+RXC031S3	16
4TTR2018A1 WITH TDD060R9V3+RXC031S3	7	4TTR2024A1 WITH TDY080R9V3+RXC036S3	16
4TTR2018A1 WITH TDY060R9V3+TXH025A4	7	4TTR2024A1 WITH TUD060R9V3+TXH025A4	16
4TTR2018A1 WITH TDY060R9V3+RXC025S3	7	4TTR2024A1 WITH TUD060R9V3+TXH033A4	16
4TTR2018A1 WITH TDY060R9V3+RXC031S3	7	4TTR2024A1 WITH TUD060R9V3+RXC025S3	16
4TTR2018A1 WITH TUD060R9V3+TXH025A4	7	4TTR2024A1 WITH TUD060R9V3+RXC031S3	16
4TTR2018A1 WITH TUD060R9V3+RXC025S3	8	4TTR2024A1 WITH TUD060R9V3+RXC036S3	17
4TTR2018A1 WITH TUD060R9V3+RXC031S3	8	4TTR2024A1 WITH TUD080R9V3+TXH025A4	17
4TTR2018A1 WITH TUY060R9V3+TXH025A4	8	4TTR2024A1 WITH TUD080R9V3+TXH033A4	17
4TTR2018A1 WITH TUY060R9V3+RXC025S3	8	4TTR2024A1 WITH TUD080R9V3+RXC025S3	17
4TTR2018A1 WITH TUY060R9V3+RXC031S3	8	4TTR2024A1 WITH TUD080R9V3+RXC031S3	17
4TTR2018A1 WITH TVF018A14	8	4TTR2024A1 WITH TUD080R9V3+RXC036S3	17
4TTR2018A1 WITH TVF024A14	9	4TTR2024A1 WITH TUY060R9V3+TXH025A4	18
4TTR2018A1 WITH TVF025A14	9	4TTR2024A1 WITH TUY060R9V3+TXH033A4	18
4TTR2018A1 WITH TVF030A14	9	4TTR2024A1 WITH TUY060R9V3+RXC025S3	18
4TTR2018A1 WITH TWE018C14	9	4TTR2024A1 WITH TUY060R9V3+RXC031S3	18
4TTR2018A1 WITH TWE024C14	9	4TTR2024A1 WITH TUY060R9V3+RXC036S3	18
4TTR2018A1 WITH TWE030C14	9	4TTR2024A1 WITH TUY080R9V3+TXH025A4	18
4TTR2018A1 WITH TXA/TXC018C4/D4	10	4TTR2024A1 WITH TUY080R9V3+TXH033A4	19
4TTR2018A1 WITH TXA/TXC024C4/D4	10	4TTR2024A1 WITH TUY080R9V3+RXC025S3	19
4TTR2018A1 WITH TXA/TXC025C4/D4	10	4TTR2024A1 WITH TUY080R9V3+RXC031S3	19
4TTR2018A1 WITH TXA/TXC030C4/D4	10	4TTR2024A1 WITH TUY080R9V3+RXC036S3	19
4TTR2018A1 WITH TXA/TXC031C4/D4	10	4TTR2024A1 WITH TVF018A14	19
4TTR2018A1 WITH TXH025A4	10	4TTR2024A1 WITH TVF024A14	19
4TTR2018A1 WITH TXH033A4	11	4TTR2024A1 WITH TVF025A14	20
4TTR2024A1 WITH 4TEE3F31A	11	4TTR2024A1 WITH TVF030A14	20
4TTR2024A1 WITH 4TEE3F37A	11	4TTR2024A1 WITH TVF036A14	20
4TTR2024A1 WITH 4TEE3F40A	11	4TTR2024A1 WITH TWE018C14	20
4TTR2024A1 WITH 4TEP3F18A	11	4TTR2024A1 WITH TWE024C14	20
4TTR2024A1 WITH 4TEP3F24A	11	4TTR2024A1 WITH TWE030C14	20
4TTR2024A1 WITH 4TEP3F30A	12	4TTR2024A1 WITH TWE036C14	21
4TTR2024A1 WITH 4TEP3F36A	12	4TTR2024A1 WITH TXA/TXC018C4/D4	21
4TTR2024A1 WITH RXC025S3	12	4TTR2024A1 WITH TXA/TXC024C4/D4	21
4TTR2024A1 WITH RXC031S3	12	4TTR2024A1 WITH TXA/TXC025C4/D4	21
4TTR2024A1 WITH RXC036S3	12	4TTR2024A1 WITH TXA/TXC030C4/D4	21
4TTR2024A1 WITH RXC037S3	12	4TTR2024A1 WITH TXA/TXC031C4/D4	21
4TTR2024A1 WITH TDD060R9V3+TXH025A4	13	4TTR2024A1 WITH TXA/TXC035C4/D4	22
4TTR2024A1 WITH TDD060R9V3+TXH033A4	13	4TTR2024A1 WITH TXA/TXC036C4/D4	22
4TTR2024A1 WITH TDD060R9V3+RXC025S3	13	4TTR2024A1 WITH TXA/TXC037C4	22
4TTR2024A1 WITH TDD060R9V3+RXC031S3	13	4TTR2024A1 WITH TXH025A4	22
4TTR2024A1 WITH TDD060R9V3+RXC036S3	13	4TTR2024A1 WITH TXH033A4	22
4TTR2024A1 WITH TDD080R9V3+TXH025A4	13	4TTR2030A1 WITH 4TEE3F31A	22
4TTR2024A1 WITH TDD080R9V3+TXH033A4	14	4TTR2030A1 WITH 4TEE3F37A	23
4TTR2024A1 WITH TDD080R9V3+RXC025S3	14	4TTR2030A1 WITH 4TEE3F40A	23
4TTR2024A1 WITH TDD080R9V3+RXC031S3	14	4TTR2030A1 WITH 4TEP3F24A	23
4TTR2024A1 WITH TDD080R9V3+RXC036S3	14	4TTR2030A1 WITH 4TEP3F30A	23
4TTR2024A1 WITH TDY060R9V3+TXH025A4	14	4TTR2030A1 WITH 4TEP3F36A	23
4TTR2024A1 WITH TDY060R9V3+TXH033A4	14	4TTR2030A1 WITH 4TEP3F42A	23

Note: Call factory for expanded performance tables on deleted models.



Contents

Cooling

MODEL NUMBER	PAGE NO.	MODEL NUMBER	PAGE NO.
4TTR2030A1 WITH RXC025S3	24	4TTR2030A1 WITH TVF030A14	33
4TTR2030A1 WITH RXC031S3	24	4TTR2030A1 WITH TVF036A14	33
4TTR2030A1 WITH RXC036S3	24	4TTR2030A1 WITH TWE024C14	33
4TTR2030A1 WITH RXC037S3	24	4TTR2030A1 WITH TWE030C14	33
4TTR2030A1 WITH TDD060R9V3+TXH025A4	24	4TTR2030A1 WITH TWE036C14	33
4TTR2030A1 WITH TDD060R9V3+TXH033A4	24	4TTR2030A1 WITH TWE042C14	33
4TTR2030A1 WITH TDD060R9V3+TXH041A4	25	4TTR2030A1 WITH TXA/TXC024C4/D4	34
4TTR2030A1 WITH TDD060R9V3+RXC025S3	25	4TTR2030A1 WITH TXA/TXC025C4/D4	34
4TTR2030A1 WITH TDD060R9V3+RXC031S3	25	4TTR2030A1 WITH TXA/TXC030C4/D4	34
4TTR2030A1 WITH TDD060R9V3+RXC036S3	25	4TTR2030A1 WITH TXA/TXC031C4/D4	34
4TTR2030A1 WITH TDD080R9V3+TXH025A4	25	4TTR2030A1 WITH TXA/TXC035C4/D4	34
4TTR2030A1 WITH TDD080R9V3+TXH033A4	25	4TTR2030A1 WITH TXA/TXC036C4/D4	34
4TTR2030A1 WITH TDD080R9V3+TXH041A4	26	4TTR2030A1 WITH TXA/TXC037C4	35
4TTR2030A1 WITH TDD080R9V3+RXC025S3	26	4TTR2030A1 WITH TXA/TXC042C4	35
4TTR2030A1 WITH TDD080R9V3+RXC031S3	26	4TTR2030A1 WITH TXA/TXC043C4	35
4TTR2030A1 WITH TDD080R9V3+RXC036S3	26	4TTR2030A1 WITH TXH025A4	35
4TTR2030A1 WITH TDY060R9V3+TXH025A4	26	4TTR2030A1 WITH TXH033A4	35
4TTR2030A1 WITH TDY060R9V3+TXH033A4	26	4TTR2030A1 WITH TXH041A4	35
4TTR2030A1 WITH TDY060R9V3+TXH041A4	27	4TTR2036A1 WITH 4TEE3F31A	36
4TTR2030A1 WITH TDY060R9V3+RXC025S3	27	4TTR2036A1 WITH 4TEE3F37A	36
4TTR2030A1 WITH TDY060R9V3+RXC031S3	27	4TTR2036A1 WITH 4TEE3F40A	36
4TTR2030A1 WITH TDY060R9V3+RXC036S3	27	4TTR2036A1 WITH 4TEE3F49A	36
4TTR2030A1 WITH TDY080R9V3+TXH025A4	27	4TTR2036A1 WITH 4TEP3F30A	36
4TTR2030A1 WITH TDY080R9V3+TXH033A4	27	4TTR2036A1 WITH 4TEP3F36A	36
4TTR2030A1 WITH TDY080R9V3+TXH041A4	28	4TTR2036A1 WITH 4TEP3F42A	37
4TTR2030A1 WITH TDY080R9V3+RXC025S3	28	4TTR2036A1 WITH 4TEP3F48A	37
4TTR2030A1 WITH TDY080R9V3+RXC031S3	28	4TTR2036A1 WITH RXC031S3	37
4TTR2030A1 WITH TDY080R9V3+RXC036S3	28	4TTR2036A1 WITH RXC036S3	37
4TTR2030A1 WITH TUD060R9V3+TXH025A4	28	4TTR2036A1 WITH RXC037S3	37
4TTR2030A1 WITH TUD060R9V3+TXH033A4	28	4TTR2036A1 WITH RXC054S3	37
4TTR2030A1 WITH TUD060R9V3+TXH041A4	29	4TTR2036A1 WITH TDD060R9V3+TXH033A4	38
4TTR2030A1 WITH TUD060R9V3+RXC025S3	29	4TTR2036A1 WITH TDD060R9V3+TXH041A4	38
4TTR2030A1 WITH TUD060R9V3+RXC031S3	29	4TTR2036A1 WITH TDD060R9V3+RXC031S3	38
4TTR2030A1 WITH TUD060R9V3+RXC036S3	29	4TTR2036A1 WITH TDD060R9V3+RXC036S3	38
4TTR2030A1 WITH TUD080R9V3+TXH025A4	29	4TTR2036A1 WITH TDD080R9V3+TXH033A4	38
4TTR2030A1 WITH TUD080R9V3+TXH033A4	29	4TTR2036A1 WITH TDD080R9V3+TXH041A4	38
4TTR2030A1 WITH TUD080R9V3+TXH041A4	30	4TTR2036A1 WITH TDD080R9V3+RXC031S3	39
4TTR2030A1 WITH TUD080R9V3+RXC025S3	30	4TTR2036A1 WITH TDD080R9V3+RXC036S3	39
4TTR2030A1 WITH TUD080R9V3+RXC031S3	30	4TTR2036A1 WITH TDD100R9V5+TXH033A4	39
4TTR2030A1 WITH TUD080R9V3+RXC036S3	30	4TTR2036A1 WITH TDD100R9V5+TXH041A4	39
4TTR2030A1 WITH TUY060R9V3+TXH025A4	30	4TTR2036A1 WITH TDD100R9V5+RXC037S3	39
4TTR2030A1 WITH TUY060R9V3+TXH033A4	30	4TTR2036A1 WITH TDY060R9V3+TXH033A4	39
4TTR2030A1 WITH TUY060R9V3+TXH041A4	31	4TTR2036A1 WITH TDY060R9V3+TXH041A4	40
4TTR2030A1 WITH TUY060R9V3+RXC025S3	31	4TTR2036A1 WITH TDY060R9V3+RXC031S3	40
4TTR2030A1 WITH TUY060R9V3+RXC031S3	31	4TTR2036A1 WITH TDY060R9V3+RXC036S3	40
4TTR2030A1 WITH TUY060R9V3+RXC036S3	31	4TTR2036A1 WITH TDY080R9V3+TXH033A4	40
4TTR2030A1 WITH TUY080R9V3+TXH025A4	31	4TTR2036A1 WITH TDY080R9V3+TXH041A4	40
4TTR2030A1 WITH TUY080R9V3+TXH033A4	31	4TTR2036A1 WITH TDY080R9V3+RXC031S3	40
4TTR2030A1 WITH TUY080R9V3+TXH041A4	32	4TTR2036A1 WITH TDY080R9V3+RXC036S3	41
4TTR2030A1 WITH TUY080R9V3+RXC025S3	32	4TTR2036A1 WITH TDY100R9V4+TXH033A4	41
4TTR2030A1 WITH TUY080R9V3+RXC031S3	32	4TTR2036A1 WITH TDY100R9V4+TXH041A4	41
4TTR2030A1 WITH TUY080R9V3+RXC036S3	32	4TTR2036A1 WITH TDY100R9V4+RXC037S3	41
4TTR2030A1 WITH TVF024A14	32	4TTR2036A1 WITH TUD060R9V3+TXH033A4	41
4TTR2030A1 WITH TVF025A14	32	4TTR2036A1 WITH TUD060R9V3+TXH041A4	41

Note: Call factory for expanded performance tables on deleted models.



Contents

Cooling

MODEL NUMBER	PAGE NO.	MODEL NUMBER	PAGE NO.
4TTR2036A1 WITH TUD060R9V3+RXC031S3	42	4TTR2042A1 WITH TUD120R9V5+TXH041A4	51
4TTR2036A1 WITH TUD060R9V3+RXC036S3	42	4TTR2042A1 WITH TUD120R9V5+TXH054A4	51
4TTR2036A1 WITH TUD080R9V3+TXH033A4	42	4TTR2042A1 WITH TVF036A14	51
4TTR2036A1 WITH TUD080R9V3+TXH041A4	42	4TTR2042A1 WITH TWE036C14	51
4TTR2036A1 WITH TUD080R9V3+RXC031S3	42	4TTR2042A1 WITH TWE042C14	51
4TTR2036A1 WITH TUD080R9V3+RXC036S3	42	4TTR2042A1 WITH TWE048C14	51
4TTR2036A1 WITH TUD100R9V5+TXH033A4	43	4TTR2042A1 WITH TXA/TXC035C4/D4	52
4TTR2036A1 WITH TUD100R9V5+TXH041A4	43	4TTR2042A1 WITH TXA/TXC036C4/D4	52
4TTR2036A1 WITH TUD100R9V5+RXC037S3	43	4TTR2042A1 WITH TXA/TXC037C4	52
4TTR2036A1 WITH TUY060R9V3+TXH033A4	43	4TTR2042A1 WITH TXA/TXC042C4	52
4TTR2036A1 WITH TUY060R9V3+TXH041A4	43	4TTR2042A1 WITH TXA/TXC043C4	52
4TTR2036A1 WITH TUY060R9V3+RXC031S3	43	4TTR2042A1 WITH TXA/TXC048C4	52
4TTR2036A1 WITH TUY060R9V3+RXC036S3	44	4TTR2042A1 WITH TXA/TXC049C4	53
4TTR2036A1 WITH TUY080R9V3+TXH033A4	44	4TTR2042A1 WITH TXA/TXC050C4	53
4TTR2036A1 WITH TUY080R9V3+TXH041A4	44	4TTR2042A1 WITH TXH041A4	53
4TTR2036A1 WITH TUY080R9V3+RXC031S3	44	4TTR2042A1 WITH TXH054A4	53
4TTR2036A1 WITH TUY080R9V3+RXC036S3	44	4TTR2048A1 WITH 4TEE3F49A	53
4TTR2036A1 WITH TUY100R9V4+TXH033A4	44	4TTR2048A1 WITH 4TEE3F65A	53
4TTR2036A1 WITH TUY100R9V4+TXH041A4	45	4TTR2048A1 WITH 4TEP3F42A	54
4TTR2036A1 WITH TUY100R9V4+RXC037S3	45	4TTR2048A1 WITH 4TEP3F48A	54
4TTR2036A1 WITH TVF030A14	45	4TTR2048A1 WITH 4TEP3F63A	54
4TTR2036A1 WITH TVF036A14	45	4TTR2048A1 WITH RXA060S3	54
4TTR2036A1 WITH TWE030C14	45	4TTR2048A1 WITH RXA/RXC061S3	54
4TTR2036A1 WITH TWE036C14	45	4TTR2048A1 WITH RXC054S3	54
4TTR2036A1 WITH TWE042C14	46	4TTR2048A1 WITH RXC065S3	55
4TTR2036A1 WITH TWE048C14	46	4TTR2048A1 WITH RXH063S3	55
4TTR2036A1 WITH TXA/TXC030C4/D4	46	4TTR2048A1 WITH TDD100R9V5+TXH041A4	55
4TTR2036A1 WITH TXA/TXC031C4/D4	46	4TTR2048A1 WITH TDD100R9V5+TXH054A4	55
4TTR2036A1 WITH TXA/TXC035C4/D4	46	4TTR2048A1 WITH TDD100R9V5+RXC037S3	55
4TTR2036A1 WITH TXA/TXC036C4/D4	46	4TTR2048A1 WITH TDD100R9V5+RXC054S3	55
4TTR2036A1 WITH TXA/TXC037C4	47	4TTR2048A1 WITH TDD100R9V5+RXH063S3	56
4TTR2036A1 WITH TXA/TXC042C4	47	4TTR2048A1 WITH TDD120R9V5+TXH041A4	56
4TTR2036A1 WITH TXA/TXC043C4	47	4TTR2048A1 WITH TDD120R9V5+TXH054A4	56
4TTR2036A1 WITH TXA/TXC048C4	47	4TTR2048A1 WITH TDD120R9V5+RXH063S3	56
4TTR2036A1 WITH TXA/TXC049C4	47	4TTR2048A1 WITH TDY100R9V4+TXH041A4	56
4TTR2036A1 WITH TXA/TXC050C4	47	4TTR2048A1 WITH TDY100R9V4+TXH054A4	56
4TTR2036A1 WITH TXH033A4	48	4TTR2048A1 WITH TDY100R9V4+RXC037S3	57
4TTR2036A1 WITH TXH041A4	48	4TTR2048A1 WITH TDY100R9V4+RXC054S3	57
4TTR2042A1 WITH 4TEE3F37A	48	4TTR2048A1 WITH TDY100R9V4+RXH063S3	57
4TTR2042A1 WITH 4TEE3F40A	48	4TTR2048A1 WITH TDY120R9V5+TXH041A4	57
4TTR2042A1 WITH 4TEE3F49A	48	4TTR2048A1 WITH TDY120R9V5+TXH054A4	57
4TTR2042A1 WITH 4TEP3F36A	48	4TTR2048A1 WITH TDY120R9V5+RXH063S3	57
4TTR2042A1 WITH 4TEP3F42A	49	4TTR2048A1 WITH TUD100R9V5+TXH041A4	58
4TTR2042A1 WITH 4TEP3F48A	49	4TTR2048A1 WITH TUD100R9V5+TXH054A4	58
4TTR2042A1 WITH RXC036S3	49	4TTR2048A1 WITH TUD100R9V5+RXC037S3	58
4TTR2042A1 WITH RXC037S3	49	4TTR2048A1 WITH TUD100R9V5+RXC054S3	58
4TTR2042A1 WITH RXC054S3	49	4TTR2048A1 WITH TUD100R9V5+RXH063S3	58
4TTR2042A1 WITH TUD080R9V3+TXH041A4	49	4TTR2048A1 WITH TUD120R9V5+TXH041A4	58
4TTR2042A1 WITH TUD080R9V3+TXH054A4	50	4TTR2048A1 WITH TUD120R9V5+TXH054A4	59
4TTR2042A1 WITH TUD080R9V3+RXC036S3	50	4TTR2048A1 WITH TUD120R9V5+RXH063S3	59
4TTR2042A1 WITH TUD100R9V5+TXH041A4	50	4TTR2048A1 WITH TUD120R9V5+RXC065S3	59
4TTR2042A1 WITH TUD100R9V5+TXH054A4	50	4TTR2048A1 WITH TUD140R9V5+TXH041A4	59
4TTR2042A1 WITH TUD100R9V5+RXC037S3	50	4TTR2048A1 WITH TUD140R9V5+TXH054A4	59
4TTR2042A1 WITH TUD100R9V5+RXC054S3	50	4TTR2048A1 WITH TUD140R9V5+RXH063S3	59

Note: Call factory for expanded performance tables on deleted models.



Contents

Cooling

MODEL NUMBER	PAGE NO.	MODEL NUMBER	PAGE NO.
4TTR2048A1 WITH TUD140R9V5+RXC065S3	60	4TTR2048A1 WITH TXH041A4	62
4TTR2048A1 WITH TUY100R9V4+TXH041A4	60	4TTR2048A1 WITH TXH054A4	63
4TTR2048A1 WITH TUY100R9V4+TXH054A4	60	4TTR2060A1 WITH 4TEE3F49A	63
4TTR2048A1 WITH TUY100R9V4+RXC037S3	60	4TTR2060A1 WITH 4TEE3F65A	63
4TTR2048A1 WITH TUY100R9V4+RXC054S3	60	4TTR2060A1 WITH 4TEP3F42A	63
4TTR2048A1 WITH TUY100R9V4+RXH063S3	60	4TTR2060A1 WITH 4TEP3F48A	63
4TTR2048A1 WITH TUY120R9V5+TXH041A4	61	4TTR2060A1 WITH 4TEP3F63A	63
4TTR2048A1 WITH TUY120R9V5+TXH054A4	61	4TTR2060A1 WITH RXA060S3	64
4TTR2048A1 WITH TUY120R9V5+RXH063S3	61	4TTR2060A1 WITH RXA/RXC061S3	64
4TTR2048A1 WITH TUY120R9V5+RXC065S3	61	4TTR2060A1 WITH RXC054S3	64
4TTR2048A1 WITH TWE042C14	61	4TTR2060A1 WITH RXC065S3	64
4TTR2048A1 WITH TWE048C14	61	4TTR2060A1 WITH RXH063S3	64
4TTR2048A1 WITH TXA/TXC042C4	62	4TTR2060A1 WITH TWE048C14	64
4TTR2048A1 WITH TXA/TXC043C4	62	4TTR2060A1 WITH TXA/TXC048C4	65
4TTR2048A1 WITH TXA/TXC048C4	62	4TTR2060A1 WITH TXA/TXC049C4	65
4TTR2048A1 WITH TXA/TXC049C4	62	4TTR2060A1 WITH TXA/TXC050C4	65
4TTR2048A1 WITH TXA/TXC050C4	62	4TTR2060A1 WITH TXH054A4	65

Note: Call factory for expanded performance tables on deleted models.



Performance Data Cooling

4TTR2018A1 WITH 4TEE3F31A AT 650 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	18.2	15.6	17.5	18.8*	19.4*	1.46
	63	20.2	13.4	15.3	17.2	18.4	1.52
	67	22.2	10.9	12.8	14.7	15.9	1.59
95	59	16.9	15.0	16.9*	17.7*	18.2*	1.57
	63	18.5	12.7	14.6	16.5	17.7	1.62
	67	20.3	10.1	12.0	13.9	15.2	1.69
105	63	16.7	11.9	13.8	15.7	16.8*	1.67
	67	18.2	9.3	11.2	13.1	14.3	1.72
	71	19.8	6.7	8.6	10.4	11.7	1.78
115	63	14.9	11.2	13.0	14.9*	15.3*	1.71
	67	16.2	8.5	10.4	12.3	13.5	1.76
	71	17.5	5.8	7.7	9.6	10.9	1.81

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	575	725	AIRFLOW	575	725
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2018A1 WITH 4TEP3F18A AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	17.4	14.5	16.2	17.7*	18.3*	1.52
	63	19.3	12.5	14.2	15.9	17.1	1.59
	67	21.3	10.2	11.9	13.7	14.8	1.65
95	59	16.0	13.9	15.6	16.6*	17.1*	1.62
	63	17.7	11.7	13.5	15.2	16.4	1.68
	67	19.4	9.4	11.1	12.9	14.1	1.75
105	63	16.0	11.0	12.8	14.5	15.7	1.72
	67	17.4	8.6	10.4	12.1	13.3	1.78
	71	19.0	6.2	7.9	9.6	10.8	1.85
115	63	14.2	10.3	12.0	13.8	14.5*	1.76
	67	15.5	7.9	9.6	11.3	12.5	1.82
	71	16.8	5.4	7.1	8.9	10.0	1.88

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.03	SENS. CAP	X0.93	X1.06

4TTR2018A1 WITH 4TEP3F24A AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	18.3	16.1	18.1	19.2*	19.7*	1.56
	63	20.3	13.7	15.7	17.7	19.1	1.62
	67	22.3	11.0	13.0	15.0	16.4	1.69
95	59	16.9	15.4	17.1*	17.9*	18.5*	1.66
	63	18.6	12.9	15.0	17.0	18.3	1.73
	67	20.3	10.2	12.2	14.2	15.6	1.79
105	63	16.7	12.2	14.2	16.2	17.0*	1.77
	67	18.2	9.4	11.4	13.4	14.7	1.83
	71	19.8	6.5	8.5	10.5	11.9	1.89
115	63	14.8	11.4	13.4	15.0*	15.4*	1.80
	67	16.1	8.5	10.6	12.6	13.9	1.86
	71	17.5	5.6	7.7	9.7	11.0	1.92

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.03	SENS. CAP	X0.92	X1.07

4TTR2018A1 WITH 4TEP3F30A AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	18.1	15.9	17.9	19.0*	19.5*	1.59
	63	20.1	13.5	15.5	17.5	18.9	1.66
	67	22.1	10.8	12.8	14.8	16.2	1.72
95	59	16.7	15.2	16.9*	17.7*	18.3*	1.69
	63	18.4	12.8	14.8	16.8	18.1	1.76
	67	20.1	10.0	12.0	14.0	15.4	1.82
105	63	16.5	12.0	14.0	16.0	16.8*	1.79
	67	18.0	9.2	11.2	13.2	14.6	1.86
	71	19.6	6.3	8.3	10.3	11.7	1.92
115	63	14.6	11.2	13.2	14.8*	15.2*	1.83
	67	15.9	8.4	10.4	12.4	13.7	1.89
	71	17.3	5.5	7.5	9.5	10.8	1.95

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.92	X1.07

4TTR2018A1 WITH RXC025S3 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	17.3	14.4	16.1	17.5*	18.0*	1.57
	63	19.2	12.6	14.2	15.8	16.9	1.64
	67	21.2	10.4	12.1	13.7	14.8	1.70
95	59	15.9	13.7	15.4	16.4*	16.9*	1.66
	63	17.5	11.8	13.4	15.1	16.2	1.73
	67	19.3	9.6	11.2	12.9	14.0	1.80
105	63	15.8	11.0	12.6	14.3	15.4	1.76
	67	17.3	8.8	10.4	12.0	13.1	1.83
	71	18.9	6.5	8.1	9.7	10.8	1.90
115	63	14.0	10.2	11.9	13.5	14.2*	1.80
	67	15.4	7.9	9.6	11.2	12.3	1.86
	71	16.7	5.6	7.3	8.9	10.0	1.93

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2018A1 WITH RXC031S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	18.1	15.9	17.9	19.0*	19.6*	1.61
	63	20.1	13.4	15.5	17.5	18.9	1.67
	67	22.2	10.7	12.7	14.8	16.2	1.74
95	59	16.7	15.2	16.9*	17.8*	18.3*	1.71
	63	18.4	12.7	14.7	16.8	18.2	1.77
	67	20.2	9.9	12.0	14.0	15.4	1.84
105	63	16.6	11.9	14.0	16.0	16.9*	1.81
	67	18.1	9.1	11.1	13.2	14.6	1.88
	71	19.7	6.2	8.2	10.3	11.7	1.94
115	63	14.7	11.2	13.2	14.9*	15.3*	1.85
	67	16.0	8.3	10.3	12.4	13.8	1.91
	71	17.3	5.4	7.4	9.5	10.8	1.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.92	X1.07

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2018A1 WITH TDD060R9V3+TXH025A4 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.8	13.8	15.4	16.4*	16.9*	1.38
	63	17.6	11.9	13.5	15.1	16.2	1.45
	67	19.5	9.8	11.4	13.0	14.1	1.51
95	59	15.5	13.6	15.2	16.1*	16.6*	1.50
	63	17.1	11.7	13.3	14.9	16.0	1.56
	67	18.9	9.6	11.2	12.8	13.9	1.62
105	63	15.6	11.0	12.6	14.3	15.3	1.60
	67	17.1	8.8	10.4	12.1	13.1	1.66
	71	18.7	6.6	8.2	9.8	10.9	1.72
115	63	14.0	10.3	12.0	13.6	14.3*	1.63
	67	15.4	8.1	9.7	11.4	12.4	1.69
	71	16.8	5.8	7.4	9.1	10.1	1.75

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2018A1 WITH TDD060R9V3+RXC031S3 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	18.0	15.0	16.8	18.3*	18.9*	1.42
	63	19.9	12.9	14.7	16.5	17.7	1.48
	67	22.0	10.6	12.4	14.2	15.4	1.55
95	59	16.6	14.4	16.1	17.2*	17.7*	1.53
	63	18.3	12.2	14.0	15.8	17.0	1.59
	67	20.0	9.8	11.6	13.4	14.6	1.65
105	63	16.5	11.5	13.3	15.1	16.2	1.63
	67	18.0	9.1	10.8	12.6	13.8	1.68
	71	19.6	6.6	8.3	10.1	11.3	1.74
115	63	14.8	10.8	12.6	14.3	15.0*	1.67
	67	16.1	8.3	10.1	11.9	13.0	1.72
	71	17.4	5.8	7.5	9.3	10.5	1.77

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.03	SENS. CAP	X0.93	X1.07

4TTR2018A1 WITH TDY060R9V3+TXH025A4 AT 550 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.5	13.2	14.7	15.8*	16.4*	1.35
	63	17.2	11.5	13.0	14.5	15.5	1.41
	67	19.1	9.5	11.0	12.5	13.5	1.47
95	59	15.2	13.0	14.5	15.6*	16.1*	1.46
	63	16.9	11.3	12.8	14.3	15.3	1.52
	67	18.6	9.3	10.8	12.3	13.3	1.59
105	63	15.3	10.6	12.1	13.6	14.6	1.57
	67	16.8	8.6	10.1	11.6	12.6	1.63
	71	18.4	6.5	8.0	9.5	10.5	1.69
115	63	13.7	9.9	11.4	12.9	13.8*	1.61
	67	15.1	7.9	9.4	10.9	11.9	1.66
	71	16.4	5.7	7.2	8.8	9.8	1.72

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	475	625	AIRFLOW	475	625
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2018A1 WITH TDY060R9V3+RXC025S3 AT 550 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.1	13.3	14.8	16.2*	16.7*	1.35
	63	18.0	11.7	13.1	14.6	15.6	1.41
	67	19.9	9.8	11.2	12.7	13.7	1.48
95	59	14.9	12.7	14.2	15.3*	15.8*	1.44
	63	16.5	11.0	12.5	13.9	14.9	1.50
	67	18.1	9.0	10.5	12.0	13.0	1.56
105	63	14.9	10.3	11.8	13.3	14.3	1.54
	67	16.3	8.3	9.8	11.2	12.2	1.59
	71	17.8	6.2	7.7	9.2	10.2	1.65
115	63	13.3	9.6	11.1	12.6	13.4*	1.57
	67	14.6	7.6	9.0	10.5	11.5	1.63
	71	15.8	5.5	6.9	8.4	9.4	1.68

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	475	625	AIRFLOW	475	625
TOTAL CAP	X0.96	X1.03	SENS. CAP	X0.93	X1.06

4TTR2018A1 WITH TDY060R9V3+RXC031S3 AT 550 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	17.5	14.2	15.9	17.5*	18.1*	1.40
	63	19.4	12.4	14.0	15.6	16.7	1.46
	67	21.4	10.3	11.9	13.5	14.6	1.52
95	59	16.2	13.7	15.3	16.6*	17.1*	1.50
	63	17.8	11.7	13.3	15.0	16.1	1.56
	67	19.6	9.5	11.2	12.8	13.9	1.62
105	63	16.2	11.0	12.6	14.3	15.4	1.60
	67	17.6	8.8	10.4	12.0	13.1	1.65
	71	19.2	6.5	8.1	9.7	10.8	1.71
115	63	14.5	10.3	11.9	13.6	14.5*	1.64
	67	15.7	8.0	9.6	11.3	12.4	1.69
	71	17.0	5.7	7.3	9.0	10.1	1.74

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	475	625	AIRFLOW	475	625
TOTAL CAP	X0.96	X1.04	SENS. CAP	X0.93	X1.07

4TTR2018A1 WITH TUD060R9V3+TXH025A4 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.8	13.8	15.4	16.4*	16.9*	1.38
	63	17.6	11.9	13.5	15.1	16.2	1.45
	67	19.5	9.8	11.4	13.0	14.1	1.51
95	59	15.5	13.6	15.2	16.1*	16.6*	1.50
	63	17.1	11.7	13.3	14.9	16.0	1.56
	67	18.9	9.6	11.2	12.8	13.9	1.62
105	63	15.6	11.0	12.6	14.3	15.3	1.60
	67	17.1	8.8	10.4	12.1	13.1	1.66
	71	18.7	6.6	8.2	9.8	10.9	1.72
115	63	14.0	10.3	12.0	13.6	14.3*	1.63
	67	15.4	8.1	9.7	11.4	12.4	1.69
	71	16.8	5.8	7.4	9.1	10.1	1.75

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2018A1 WITH TUD060R9V3+RXC025S3 AT 550 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.5	13.6	15.1	16.6*	17.1*	1.39
	63	18.3	12.0	13.5	15.0	15.9	1.45
	67	20.3	10.0	11.5	13.0	14.0	1.51
95	59	15.3	13.0	14.5	15.6*	16.1*	1.47
	63	16.9	11.3	12.8	14.3	15.3	1.53
	67	18.6	9.3	10.8	12.3	13.3	1.60
105	63	15.3	10.6	12.1	13.6	14.6	1.57
	67	16.7	8.5	10.0	11.5	12.5	1.63
	71	18.2	6.4	7.9	9.4	10.4	1.69
115	63	13.6	9.9	11.3	12.8	13.7*	1.61
	67	14.9	7.8	9.3	10.8	11.8	1.66
	71	16.2	5.7	7.2	8.7	9.7	1.72

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	475	625	AIRFLOW	475	625
TOTAL CAP	X0.96	X1.03	SENS. CAP	X0.93	X1.06

4TTR2018A1 WITH TUD060R9V3+RXC031S3 AT 650 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	17.4	14.9	16.8	18.0*	18.6*	1.46
	63	19.3	12.7	14.6	16.4	17.7	1.52
	67	21.3	10.2	12.1	14.0	15.2	1.59
95	59	16.1	14.3	16.2*	17.0*	17.4*	1.56
	63	17.7	12.0	13.9	15.8	17.0	1.62
	67	19.4	9.5	11.4	13.2	14.5	1.69
105	63	16.1	11.4	13.2	15.1	16.2*	1.67
	67	17.5	8.8	10.6	12.5	13.8	1.72
	71	18.9	6.1	8.0	9.9	11.1	1.78
115	63	14.3	10.7	12.6	14.4*	14.8*	1.71
	67	15.5	8.1	9.9	11.8	13.0	1.76
	71	16.8	5.4	7.3	9.1	10.4	1.81

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	575	725	AIRFLOW	575	725
TOTAL CAP	X0.97	X1.03	SENS. CAP	X0.94	X1.06

4TTR2018A1 WITH TUY060R9V3+TXH025A4 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.7	13.7	15.4	16.3*	16.9*	1.38
	63	17.4	11.9	13.5	15.1	16.2	1.44
	67	19.3	9.7	11.4	13.0	14.1	1.50
95	59	15.4	13.6	15.2	16.1*	16.6*	1.50
	63	17.1	11.7	13.3	15.0	16.0	1.56
	67	18.8	9.5	11.2	12.8	13.9	1.62
105	63	15.5	11.0	12.6	14.3	15.4	1.60
	67	17.1	8.8	10.4	12.1	13.1	1.66
	71	18.7	6.5	8.2	9.8	10.9	1.72
115	63	14.0	10.3	12.0	13.6	14.2*	1.64
	67	15.3	8.1	9.7	11.3	12.4	1.69
	71	16.7	5.8	7.4	9.0	10.1	1.75

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2018A1 WITH TUY060R9V3+RXC025S3 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.4	13.9	15.5	16.8*	17.3*	1.39
	63	18.3	12.1	13.7	15.3	16.3	1.45
	67	20.2	10.0	11.6	13.2	14.3	1.52
95	59	15.2	13.3	14.9	15.8*	16.3*	1.48
	63	16.8	11.4	13.0	14.6	15.7	1.54
	67	18.5	9.3	10.9	12.5	13.5	1.60
105	63	15.2	10.7	12.3	13.9	15.0	1.58
	67	16.6	8.5	10.1	11.7	12.8	1.63
	71	18.1	6.3	7.9	9.5	10.5	1.69
115	63	13.5	10.0	11.6	13.2	13.8*	1.61
	67	14.8	7.8	9.4	11.0	12.0	1.67
	71	16.0	5.5	7.1	8.7	9.7	1.72

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.03	SENS. CAP	X0.94	X1.06

4TTR2018A1 WITH TUY060R9V3+RXC031S3 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	18.0	15.0	16.8	18.3*	18.9*	1.43
	63	19.9	13.0	14.7	16.5	17.7	1.50
	67	22.0	10.6	12.4	14.2	15.4	1.56
95	59	16.6	14.4	16.2	17.2*	17.7*	1.54
	63	18.3	12.2	14.0	15.8	17.0	1.60
	67	20.0	9.8	11.6	13.4	14.6	1.66
105	63	16.5	11.5	13.3	15.1	16.2	1.64
	67	18.0	9.1	10.8	12.6	13.8	1.70
	71	19.6	6.6	8.3	10.1	11.3	1.75
115	63	14.7	10.8	12.5	14.3	15.0*	1.68
	67	16.0	8.3	10.1	11.8	13.0	1.73
	71	17.3	5.8	7.5	9.3	10.5	1.78

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.97	X1.03	SENS. CAP	X0.93	X1.07

4TTR2018A1 WITH TVF018A14 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.3	14.2	16.0	17.0*	17.6*	1.51
	63	18.1	12.1	13.9	15.7	16.9	1.57
	67	20.0	9.7	11.6	13.4	14.6	1.63
95	59	15.9	14.1	15.9	16.7*	17.2*	1.62
	63	17.6	11.9	13.7	15.5	16.7	1.68
	67	19.4	9.5	11.3	13.1	14.3	1.75
105	63	16.0	11.2	13.0	14.8	16.0*	1.72
	67	17.6	8.8	10.6	12.4	13.6	1.78
	71	19.3	6.3	8.1	9.9	11.1	1.84
115	63	14.4	10.6	12.4	14.2	14.8*	1.75
	67	15.8	8.1	9.9	11.7	12.9	1.81
	71	17.2	5.6	7.4	9.2	10.4	1.86

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2018A1 WITH TVF024A14 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.5	15.4	17.0*	17.8*	18.4*	1.61
	63	18.4	12.9	15.0	17.1	18.4*	1.67
	67	20.3	10.1	12.2	14.3	15.7	1.74
95	59	16.1	15.2	16.6*	17.5*	18.0*	1.73
	63	17.9	12.7	14.8	16.9	18.0*	1.79
	67	19.7	9.9	12.0	14.0	15.4	1.86
105	63	16.2	12.0	14.1	16.2	16.7*	1.82
	67	17.9	9.1	11.2	13.3	14.7	1.88
	71	19.5	6.2	8.3	10.4	11.8	1.94
115	63	14.6	11.3	13.4	14.9*	15.4*	1.85
	67	16.0	8.4	10.5	12.6	14.0	1.91
	71	17.5	5.5	7.6	9.7	11.1	1.96

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.07

4TTR2018A1 WITH TVF025A14 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.7	15.6	17.2*	18.0*	18.6*	1.58
	63	18.6	13.1	15.2	17.3	18.6*	1.64
	67	20.5	10.3	12.4	14.5	15.9	1.71
95	59	16.3	15.4	16.8*	17.7*	18.2*	1.70
	63	18.1	12.9	15.0	17.0	18.2*	1.76
	67	19.9	10.0	12.1	14.2	15.6	1.83
105	63	16.4	12.2	14.3	16.4	16.9*	1.79
	67	18.1	9.3	11.4	13.5	14.9	1.86
	71	19.7	6.4	8.5	10.6	12.0	1.92
115	63	14.8	11.5	13.6	15.1*	15.5*	1.82
	67	16.2	8.6	10.7	12.8	14.2	1.88
	71	17.7	5.6	7.7	9.8	11.2	1.94

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.07

4TTR2018A1 WITH TVF030A14 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.9	15.6	17.3*	18.2*	18.8*	1.63
	63	18.8	13.1	15.2	17.3	18.7	1.69
	67	20.8	10.3	12.4	14.5	15.9	1.76
95	59	16.5	15.4	17.0*	17.8*	18.3*	1.74
	63	18.2	12.8	15.0	17.1	18.3*	1.81
	67	20.1	10.0	12.1	14.2	15.6	1.88
105	63	16.6	12.2	14.3	16.4	17.0*	1.84
	67	18.2	9.3	11.4	13.5	14.9	1.90
	71	19.9	6.3	8.4	10.5	12.0	1.96
115	63	14.9	11.5	13.6	15.2*	15.6*	1.87
	67	16.3	8.5	10.7	12.8	14.2	1.92
	71	17.8	5.6	7.7	9.8	11.2	1.98

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.92	X1.07

4TTR2018A1 WITH TWE018C14 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.0	13.1	14.7	15.6*	16.2*	1.40
	63	16.8	11.3	12.9	14.5	15.5	1.46
	67	18.6	9.2	10.8	12.4	13.4	1.52
95	59	14.8	13.0	14.6	15.5*	15.9*	1.52
	63	16.4	11.1	12.7	14.3	15.4	1.58
	67	18.1	9.0	10.6	12.2	13.2	1.63
105	63	14.9	10.5	12.0	13.6	14.7	1.62
	67	16.4	8.3	9.9	11.5	12.5	1.66
	71	17.9	6.0	7.6	9.2	10.3	1.71
115	63	13.4	9.8	11.4	13.0	13.6*	1.66
	67	14.7	7.6	9.2	10.8	11.8	1.70
	71	16.0	5.3	6.9	8.5	9.6	1.74

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2018A1 WITH TWE024C14 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.3	14.0	15.6*	16.4*	16.9*	1.53
	63	17.1	11.8	13.7	15.5	16.7	1.59
	67	19.0	9.4	11.3	13.1	14.3	1.66
95	59	15.1	13.9	15.3*	16.2*	16.7*	1.65
	63	16.7	11.7	13.5	15.3	16.6	1.71
	67	18.5	9.2	11.1	12.9	14.1	1.77
105	63	15.2	11.0	12.8	14.7	15.4*	1.75
	67	16.7	8.5	10.3	12.2	13.4	1.81
	71	18.3	6.0	7.8	9.6	10.8	1.87
115	63	13.6	10.4	12.2	13.7*	14.2*	1.78
	67	14.9	7.8	9.6	11.5	12.7	1.84
	71	16.3	5.2	7.0	8.9	10.1	1.90

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2018A1 WITH TWE030C14 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.1	14.8	16.4*	17.3*	17.8*	1.60
	63	17.9	12.5	14.4	16.4	17.7	1.67
	67	19.8	9.8	11.8	13.8	15.1	1.73
95	59	15.8	14.7	16.1*	17.0*	17.5*	1.72
	63	17.5	12.3	14.3	16.2	17.5*	1.79
	67	19.3	9.6	11.6	13.6	14.9	1.85
105	63	15.9	11.6	13.6	15.6	16.3*	1.82
	67	17.5	8.9	10.9	12.9	14.2	1.88
	71	19.1	6.1	8.1	10.1	11.4	1.95
115	63	14.3	10.9	12.9	14.5*	14.9*	1.85
	67	15.7	8.2	10.2	12.1	13.5	1.91
	71	17.1	5.4	7.4	9.3	10.7	1.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2018A1 WITH TXA/TXC018C4/D4 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	14.6	12.8	14.4	15.3*	15.8*	1.48
	63	16.4	11.0	12.6	14.2	15.2	1.54
	67	18.2	9.0	10.6	12.1	13.2	1.60
95	59	14.4	12.7	14.3	15.1*	15.6*	1.59
	63	16.0	10.9	12.4	14.0	15.1	1.65
	67	17.7	8.8	10.4	11.9	13.0	1.71
105	63	14.3	10.1	11.7	13.3	14.3*	1.69
	67	15.8	8.0	9.6	11.1	12.2	1.75
	71	17.3	5.8	7.4	8.9	10.0	1.81
115	63	12.6	9.4	11.0	12.5	13.0*	1.74
	67	13.9	7.2	8.8	10.4	11.4	1.79
	71	15.2	5.0	6.6	8.1	9.2	1.85

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2018A1 WITH TXA/TXC024C4/D4 AT 600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.6	13.5	15.1	16.1*	16.7*	1.50
	63	17.3	11.6	13.2	14.9	16.0	1.56
	67	19.2	9.5	11.1	12.7	13.8	1.62
95	59	15.3	13.3	15.0	15.9*	16.4*	1.61
	63	16.9	11.4	13.1	14.7	15.8	1.67
	67	18.7	9.3	10.9	12.5	13.6	1.74
105	63	15.4	10.7	12.4	14.0	15.1	1.71
	67	16.9	8.5	10.1	11.8	12.9	1.77
	71	18.5	6.2	7.9	9.5	10.6	1.83
115	63	13.7	10.0	11.6	13.3	14.0*	1.75
	67	15.1	7.8	9.4	11.0	12.1	1.80
	71	16.5	5.5	7.1	8.7	9.8	1.86

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	525	675	AIRFLOW	525	675
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2018A1 WITH TXA/TXC025C4/D4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.1	14.8	16.4*	17.3*	17.8*	1.59
	63	17.9	12.5	14.4	16.4	17.7	1.65
	67	19.8	9.8	11.8	13.8	15.1	1.71
95	59	15.8	14.7	16.1*	17.0*	17.5*	1.71
	63	17.5	12.3	14.3	16.2	17.5*	1.77
	67	19.3	9.6	11.6	13.6	14.9	1.84
105	63	15.9	11.6	13.6	15.6	16.3*	1.80
	67	17.5	8.9	10.9	12.9	14.2	1.86
	71	19.1	6.1	8.1	10.1	11.4	1.93
115	63	14.3	10.9	12.9	14.5*	14.9*	1.84
	67	15.7	8.2	10.2	12.2	13.5	1.89
	71	17.1	5.4	7.4	9.4	10.7	1.95

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2018A1 WITH TXA/TXC030C4/D4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.3	14.9	16.6*	17.5*	18.0*	1.61
	63	18.2	12.7	14.6	16.5	17.8	1.67
	67	20.1	10.1	12.0	14.0	15.2	1.74
95	59	16.0	14.8	16.3*	17.1*	17.7*	1.72
	63	17.7	12.4	14.4	16.3	17.6	1.79
	67	19.5	9.9	11.8	13.7	15.0	1.85
105	63	16.1	11.7	13.7	15.6	16.4*	1.82
	67	17.7	9.1	11.0	13.0	14.2	1.88
	71	19.4	6.4	8.3	10.3	11.5	1.95
115	63	14.5	11.1	13.0	14.6*	15.1*	1.85
	67	15.9	8.4	10.3	12.2	13.5	1.91
	71	17.3	5.6	7.6	9.5	10.8	1.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2018A1 WITH TXA/TXC031C4/D4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.5	15.1	16.8*	17.7*	18.3*	1.61
	63	18.4	12.7	14.7	16.7	18.1	1.67
	67	20.4	10.0	12.0	14.1	15.4	1.74
95	59	16.1	14.9	16.5*	17.3*	17.9*	1.72
	63	17.9	12.5	14.5	16.5	17.9	1.79
	67	19.7	9.7	11.8	13.8	15.1	1.86
105	63	16.2	11.8	13.8	15.8	16.6*	1.82
	67	17.9	9.0	11.0	13.1	14.4	1.88
	71	19.5	6.2	8.2	10.2	11.6	1.95
115	63	14.6	11.1	13.1	14.8*	15.2*	1.85
	67	16.0	8.3	10.3	12.4	13.7	1.91
	71	17.5	5.5	7.5	9.5	10.8	1.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.07

4TTR2018A1 WITH TXH025A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	15.7	14.5	16.0*	16.9*	17.4*	1.57
	63	17.5	12.3	14.2	16.0	17.3	1.63
	67	19.4	9.8	11.7	13.6	14.8	1.70
95	59	15.4	14.4	15.8*	16.6*	17.1*	1.69
	63	17.1	12.1	14.0	15.9	17.1*	1.75
	67	18.9	9.6	11.5	13.3	14.6	1.82
105	63	15.5	11.4	13.3	15.2	15.9*	1.79
	67	17.1	8.9	10.7	12.6	13.9	1.85
	71	18.8	6.2	8.1	10.0	11.2	1.91
115	63	14.0	10.8	12.6	14.2*	14.6*	1.82
	67	15.3	8.2	10.0	11.9	13.1	1.88
	71	16.8	5.5	7.4	9.2	10.5	1.93

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.

Performance Data Cooling

4TTR2018A1 WITH TXH033A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	16.8	15.3	17.0*	17.9*	18.5*	1.62
	63	18.6	12.9	14.9	17.0	18.3	1.68
	67	20.6	10.2	12.2	14.3	15.6	1.75
95	59	16.3	15.1	16.7*	17.5*	18.1*	1.73
	63	18.1	12.7	14.7	16.7	18.1*	1.80
	67	19.9	9.9	12.0	14.0	15.3	1.87
105	63	16.4	12.0	14.0	16.0	16.8*	1.83
	67	18.0	9.2	11.2	13.2	14.6	1.89
	71	19.7	6.3	8.4	10.4	11.8	1.95
115	63	14.7	11.3	13.3	14.9*	15.4*	1.86
	67	16.1	8.4	10.5	12.5	13.9	1.91
	71	17.6	5.6	7.6	9.6	11.0	1.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH 4TEE3F31A AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.9	19.7	22.0	23.5*	24.1*	1.88
	63	24.8	16.8	19.1	21.4	22.9	1.91
	67	26.8	13.5	15.8	18.1	19.6	1.95
95	59	21.4	19.0	21.3	22.3*	22.9*	2.05
	63	23.2	16.1	18.4	20.7	22.2	2.09
	67	25.1	12.8	15.1	17.4	18.9	2.13
105	63	21.6	15.3	17.7	20.0	21.5	2.23
	67	23.3	12.1	14.4	16.7	18.2	2.27
	71	25.1	8.7	11.0	13.3	14.9	2.31
115	63	19.9	14.6	16.9	19.3	20.2*	2.37
	67	21.6	11.3	13.7	16.0	17.5	2.42
	71	23.2	8.0	10.3	12.6	14.2	2.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH 4TEE3F37A AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.1	19.9	22.3	23.7*	24.3*	1.85
	63	25.0	16.9	19.3	21.7	23.2	1.88
	67	26.9	13.6	15.9	18.3	19.9	1.92
95	59	21.5	19.2	21.6*	22.5*	23.0*	2.02
	63	23.3	16.2	18.6	20.9	22.5	2.06
	67	25.2	12.9	15.2	17.6	19.2	2.10
105	63	21.7	15.5	17.9	20.2	21.8*	2.21
	67	23.5	12.2	14.5	16.9	18.5	2.25
	71	25.3	8.8	11.1	13.5	15.1	2.29
115	63	20.1	14.8	17.2	19.6	20.5*	2.35
	67	21.8	11.5	13.9	16.2	17.8	2.39
	71	23.5	8.1	10.5	12.8	14.4	2.43

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH 4TEE3F40A AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	24.3	20.8	23.3	24.9*	25.5*	1.86
	63	26.2	17.6	20.1	22.6	24.3	1.89
	67	28.2	14.0	16.5	19.0	20.7	1.93
95	59	22.8	20.1	22.6	23.6*	24.2*	2.04
	63	24.6	16.9	19.4	21.9	23.6	2.08
	67	26.5	13.3	15.8	18.3	20.0	2.11
105	63	22.8	16.1	18.6	21.1	22.8*	2.22
	67	24.6	12.5	15.1	17.6	19.2	2.26
	71	26.4	8.9	11.4	14.0	15.6	2.30
115	63	21.0	15.3	17.9	20.4	21.3*	2.37
	67	22.6	11.8	14.3	16.8	18.5	2.41
	71	24.4	8.2	10.7	13.2	14.9	2.44

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH 4TEP3F18A AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.9	18.2	20.2	22.1*	22.7*	1.94
	63	23.8	15.6	17.6	19.7	21.1	1.98
	67	25.7	12.6	14.7	16.8	18.2	2.01
95	59	20.5	17.5	19.5	20.9*	21.5*	2.11
	63	22.3	14.9	16.9	19.0	20.4	2.15
	67	24.1	12.0	14.0	16.1	17.5	2.19
105	63	20.7	14.2	16.2	18.3	19.7	2.29
	67	22.5	11.3	13.3	15.4	16.8	2.34
	71	24.3	8.3	10.4	12.4	13.8	2.38
115	63	19.2	13.5	15.6	17.6	19.0	2.43
	67	20.8	10.6	12.6	14.7	16.1	2.48
	71	22.5	7.6	9.7	11.7	13.1	2.53

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH 4TEP3F24A AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.7	19.6	21.9	23.3*	23.9*	1.95
	63	24.6	16.6	18.9	21.3	22.8	1.99
	67	26.5	13.3	15.6	18.0	19.5	2.03
95	59	21.2	18.9	21.2*	22.1*	22.6*	2.12
	63	22.9	15.9	18.2	20.5	22.1	2.16
	67	24.8	12.6	14.9	17.2	18.8	2.20
105	63	21.3	15.2	17.5	19.8	21.3*	2.31
	67	23.1	11.9	14.2	16.5	18.1	2.35
	71	24.9	8.5	10.8	13.2	14.7	2.40
115	63	19.7	14.5	16.8	19.1	20.0*	2.45
	67	21.3	11.2	13.5	15.8	17.4	2.50
	71	23.0	7.8	10.1	12.5	14.0	2.55

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH 4TEP3F30A AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.9	20.6	23.0*	24.0*	24.6*	2.02
	63	24.8	17.3	19.9	22.4	24.2	2.06
	67	26.8	13.6	16.2	18.8	20.5	2.09
95	59	21.3	19.9	21.7*	22.7*	23.2*	2.19
	63	23.1	16.6	19.1	21.7	23.2*	2.23
	67	25.0	12.9	15.5	18.0	19.8	2.27
105	63	21.5	15.8	18.4	21.0	21.9*	2.37
	67	23.2	12.1	14.7	17.3	19.0	2.42
	71	25.0	8.4	11.0	13.6	15.3	2.47
115	63	19.8	15.1	17.7	20.0*	20.5*	2.51
	67	21.4	11.4	14.0	16.6	18.3	2.56
	71	23.1	7.7	10.3	12.9	14.6	2.62

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH 4TEP3F36A AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.6	20.3	22.7*	23.7*	24.3*	2.06
	63	24.5	16.9	19.5	22.2	23.9	2.10
	67	26.5	13.2	15.8	18.4	20.2	2.14
95	59	21.1	19.6	21.5*	22.4*	23.0*	2.23
	63	22.9	16.2	18.9	21.5	23.0*	2.27
	67	24.8	12.5	15.1	17.8	19.5	2.32
105	63	21.3	15.5	18.2	20.8	21.7*	2.41
	67	23.0	11.8	14.4	17.1	18.8	2.46
	71	24.9	8.1	10.7	13.3	15.0	2.51
115	63	19.6	14.9	17.5	19.8*	20.3*	2.55
	67	21.3	11.1	13.8	16.4	18.1	2.61
	71	23.0	7.4	10.0	12.6	14.3	2.67

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH RXC025S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.6	17.7	19.7	21.1*	21.7*	1.94
	63	22.4	15.0	17.1	19.2	20.6	1.98
	67	24.3	12.1	14.2	16.3	17.6	2.01
95	59	19.3	17.0	19.1	20.1*	20.6*	2.10
	63	21.0	14.4	16.5	18.6	20.0	2.14
	67	22.8	11.4	13.5	15.6	17.0	2.18
105	63	19.6	13.8	15.9	18.0	19.4	2.28
	67	21.3	10.8	12.9	15.0	16.4	2.32
	71	23.0	7.7	9.8	11.9	13.3	2.37
115	63	18.2	13.1	15.2	17.3	18.4*	2.41
	67	19.7	10.2	12.3	14.3	15.7	2.46
	71	21.3	7.1	9.2	11.3	12.7	2.51

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH RXC031S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.8	20.5	23.0*	23.9*	24.5*	2.06
	63	24.7	17.1	19.8	22.4	24.2	2.10
	67	26.7	13.4	16.0	18.7	20.4	2.13
95	59	21.3	19.8	21.7*	22.7*	23.2*	2.23
	63	23.1	16.4	19.1	21.7	23.2*	2.27
	67	25.0	12.7	15.3	18.0	19.7	2.31
105	63	21.4	15.7	18.4	21.0	21.9*	2.41
	67	23.2	12.0	14.6	17.2	19.0	2.46
	71	25.0	8.2	10.8	13.4	15.2	2.51
115	63	19.8	15.0	17.6	19.9*	20.5*	2.55
	67	21.4	11.3	13.9	16.5	18.3	2.60
	71	23.1	7.4	10.1	12.7	14.5	2.66

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH RXC036S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.7	21.1	23.7*	24.7*	25.3*	2.09
	63	25.6	17.6	20.3	23.0	24.8	2.12
	67	27.6	13.7	16.4	19.1	20.9	2.16
95	59	22.1	20.4	22.4*	23.4*	23.9*	2.26
	63	23.9	16.9	19.6	22.3	23.9*	2.30
	67	25.8	13.0	15.7	18.4	20.2	2.35
105	63	22.1	16.1	18.8	21.5	22.5*	2.44
	67	23.9	12.3	15.0	17.7	19.5	2.49
	71	25.7	8.3	11.0	13.7	15.5	2.54
115	63	20.3	15.3	18.0	20.4*	21.0*	2.58
	67	22.0	11.5	14.2	16.9	18.7	2.64
	71	23.7	7.6	10.3	13.0	14.8	2.69

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH RXC037S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.7	21.1	23.7*	24.7*	25.3*	2.09
	63	25.6	17.6	20.3	23.0	24.8	2.12
	67	27.6	13.7	16.4	19.1	20.9	2.16
95	59	22.1	20.4	22.4*	23.4*	23.9*	2.26
	63	23.9	16.9	19.6	22.3	23.9*	2.30
	67	25.8	13.0	15.7	18.4	20.2	2.35
105	63	22.1	16.1	18.8	21.5	22.5*	2.44
	67	23.9	12.3	15.0	17.7	19.5	2.49
	71	25.7	8.3	11.0	13.7	15.5	2.54
115	63	20.3	15.3	18.0	20.4*	21.0*	2.58
	67	22.0	11.5	14.2	16.9	18.7	2.64
	71	23.7	7.6	10.3	13.0	14.8	2.69

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.07

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data

Cooling

4TTR2024A1 WITH TDD060R9V3+TXH025A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.0	18.6	20.7	21.8*	22.4*	1.86
	63	22.8	15.9	18.0	20.2	21.6	1.90
	67	24.7	12.8	15.0	17.1	18.6	1.94
95	59	20.5	18.3	20.5	21.4*	21.9*	2.04
	63	22.3	15.6	17.8	19.9	21.4	2.08
	67	24.2	12.6	14.8	16.9	18.3	2.12
105	63	20.7	14.9	17.0	19.2	20.6	2.20
	67	22.5	11.9	14.0	16.2	17.6	2.24
	71	24.3	8.8	10.9	13.1	14.5	2.29
115	63	19.0	14.1	16.3	18.4	19.3*	2.31
	67	20.7	11.1	13.3	15.4	16.9	2.36
	71	22.5	8.1	10.2	12.4	13.8	2.41

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH TDD060R9V3+TXH033A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.3	19.7	22.1	23.1*	23.7*	1.90
	63	24.1	16.7	19.1	21.4	23.0	1.93
	67	26.0	13.4	15.7	18.1	19.7	1.97
95	59	21.6	19.4	21.7*	22.6*	23.2*	2.08
	63	23.5	16.4	18.8	21.1	22.7	2.12
	67	25.4	13.1	15.5	17.8	19.4	2.16
105	63	21.7	15.6	18.0	20.3	21.8*	2.23
	67	23.5	12.3	14.7	17.0	18.6	2.28
	71	25.4	9.0	11.3	13.7	15.2	2.32
115	63	19.9	14.9	17.2	19.6	20.3*	2.34
	67	21.6	11.6	13.9	16.3	17.8	2.39
	71	23.4	8.2	10.6	12.9	14.5	2.44

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDD060R9V3+RXC025S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.6	18.6	20.7	22.1*	22.7*	1.87
	63	23.4	15.9	18.0	20.1	21.5	1.90
	67	25.4	12.9	15.0	17.1	18.5	1.94
95	59	20.2	17.9	20.0	21.0*	21.6*	2.04
	63	22.0	15.2	17.4	19.5	20.9	2.07
	67	23.8	12.2	14.4	16.5	17.9	2.12
105	63	20.5	14.6	16.7	18.8	20.2	2.21
	67	22.2	11.6	13.7	15.8	17.2	2.26
	71	24.0	8.5	10.6	12.7	14.2	2.31
115	63	19.1	13.9	16.0	18.2	19.2*	2.35
	67	20.7	10.9	13.0	15.2	16.6	2.40
	71	22.4	7.9	10.0	12.1	13.5	2.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2024A1 WITH TDD060R9V3+RXC031S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.0	19.9	22.3	23.7*	24.3*	1.87
	63	24.9	16.9	19.2	21.6	23.2	1.90
	67	26.9	13.5	15.9	18.2	19.8	1.94
95	59	21.5	19.2	21.6*	22.5*	23.0*	2.04
	63	23.3	16.2	18.5	20.9	22.5	2.08
	67	25.2	12.8	15.2	17.5	19.1	2.12
105	63	21.7	15.5	17.8	20.2	21.7*	2.22
	67	23.5	12.1	14.5	16.8	18.4	2.26
	71	25.3	8.7	11.1	13.4	15.0	2.31
115	63	20.1	14.8	17.1	19.5	20.4*	2.37
	67	21.7	11.4	13.8	16.2	17.7	2.41
	71	23.4	8.0	10.4	12.7	14.3	2.45

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDD060R9V3+RXC036S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.6	20.2	22.6	24.2*	24.8*	1.87
	63	25.5	17.1	19.5	22.0	23.6	1.90
	67	27.5	13.7	16.1	18.5	20.2	1.94
95	59	22.1	19.5	21.9	23.0*	23.5*	2.05
	63	23.9	16.4	18.8	21.3	22.9	2.08
	67	25.8	13.0	15.4	17.8	19.4	2.12
105	63	22.2	15.7	18.1	20.5	22.1	2.23
	67	24.0	12.3	14.7	17.1	18.7	2.27
	71	25.8	8.8	11.2	13.6	15.2	2.31
115	63	20.5	15.0	17.4	19.8	20.8*	2.38
	67	22.1	11.6	14.0	16.4	18.0	2.42
	71	23.9	8.1	10.5	12.9	14.5	2.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDD080R9V3+TXH025A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.9	18.7	20.8	21.7*	22.3*	1.85
	63	22.7	15.9	18.1	20.3	21.7	1.88
	67	24.5	12.9	15.0	17.2	18.6	1.92
95	59	20.4	18.4	20.5*	21.4*	22.0*	2.03
	63	22.2	15.7	17.9	20.1	21.5	2.07
	67	24.1	12.7	14.9	17.0	18.5	2.11
105	63	20.6	15.0	17.1	19.3	20.7*	2.18
	67	22.4	11.9	14.1	16.3	17.7	2.23
	71	24.3	8.8	11.0	13.2	14.6	2.27
115	63	19.0	14.2	16.4	18.6	19.3*	2.30
	67	20.7	11.2	13.4	15.5	17.0	2.35
	71	22.4	8.1	10.3	12.4	13.9	2.40

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TDD080R9V3+TXH033A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.2	19.7	22.1	23.1*	23.6*	1.88
	63	24.0	16.7	19.1	21.4	23.0	1.92
	67	25.9	13.4	15.7	18.1	19.7	1.95
95	59	21.6	19.4	21.7*	22.6*	23.2*	2.06
	63	23.4	16.5	18.8	21.2	22.8	2.10
	67	25.3	13.1	15.5	17.9	19.4	2.14
105	63	21.6	15.7	18.0	20.4	21.7*	2.21
	67	23.4	12.4	14.7	17.1	18.7	2.26
	71	25.3	9.0	11.3	13.7	15.3	2.30
115	63	19.9	14.9	17.2	19.6	20.3*	2.33
	67	21.6	11.6	13.9	16.3	17.9	2.37
	71	23.3	8.2	10.6	12.9	14.5	2.42

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDD080R9V3+RXC025S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.6	18.8	20.9	22.2*	22.8*	1.85
	63	23.4	16.1	18.2	20.4	21.8	1.88
	67	25.4	13.1	15.2	17.4	18.8	1.91
95	59	20.2	18.1	20.2*	21.0*	21.6*	2.01
	63	21.9	15.4	17.6	19.7	21.1	2.05
	67	23.8	12.4	14.5	16.7	18.1	2.09
105	63	20.5	14.8	16.9	19.0	20.5	2.19
	67	22.2	11.7	13.9	16.0	17.4	2.23
	71	24.0	8.7	10.8	12.9	14.3	2.28
115	63	19.1	14.1	16.3	18.4	19.3*	2.33
	67	20.7	11.1	13.2	15.4	16.8	2.38
	71	22.4	8.0	10.1	12.3	13.7	2.43

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH TDD080R9V3+RXC031S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.2	20.1	22.5	23.8*	24.5*	1.86
	63	25.1	17.1	19.4	21.8	23.4	1.90
	67	27.1	13.7	16.1	18.5	20.0	1.93
95	59	21.7	19.4	21.7*	22.6*	23.2*	2.04
	63	23.5	16.4	18.7	21.1	22.7	2.08
	67	25.4	13.0	15.4	17.8	19.3	2.12
105	63	21.8	15.6	18.0	20.4	21.9*	2.22
	67	23.6	12.3	14.7	17.0	18.6	2.26
	71	25.5	8.8	11.2	13.6	15.2	2.30
115	63	20.2	14.9	17.3	19.7	20.6*	2.37
	67	21.9	11.6	14.0	16.3	17.9	2.41
	71	23.6	8.1	10.5	12.9	14.5	2.45

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDD080R9V3+RXC036S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.8	20.4	22.8	24.4*	25.0*	1.87
	63	25.7	17.3	19.7	22.1	23.7	1.90
	67	27.7	13.8	16.3	18.7	20.3	1.94
95	59	22.2	19.7	22.1	23.1*	23.7*	2.05
	63	24.0	16.6	19.0	21.4	23.0	2.08
	67	25.9	13.1	15.6	18.0	19.6	2.12
105	63	22.3	15.8	18.2	20.7	22.3	2.23
	67	24.1	12.4	14.8	17.2	18.9	2.27
	71	25.9	8.9	11.3	13.7	15.4	2.31
115	63	20.6	15.1	17.5	19.9	20.9*	2.37
	67	22.2	11.7	14.1	16.5	18.1	2.41
	71	24.0	8.2	10.6	13.0	14.6	2.45

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDY060R9V3+TXH025A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.5	17.3	19.2	20.7*	21.3*	1.81
	63	22.2	14.9	16.8	18.7	20.0	1.85
	67	24.1	12.2	14.1	16.0	17.3	1.88
95	59	20.0	17.0	18.9	20.3*	20.9*	1.99
	63	21.7	14.7	16.6	18.5	19.7	2.03
	67	23.6	12.0	13.9	15.8	17.1	2.07
105	63	20.1	13.9	15.8	17.7	19.0	2.15
	67	21.9	11.3	13.2	15.1	16.4	2.19
	71	23.8	8.6	10.5	12.4	13.7	2.24
115	63	18.6	13.2	15.1	17.0	18.3	2.27
	67	20.2	10.6	12.5	14.4	15.7	2.31
	71	22.0	7.9	9.8	11.7	12.9	2.36

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDY060R9V3+TXH033A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.9	18.5	20.6	22.2*	22.8*	1.87
	63	23.7	15.9	18.0	20.1	21.4	1.90
	67	25.6	12.9	15.0	17.1	18.5	1.94
95	59	21.3	18.2	20.3	21.7*	22.3*	2.05
	63	23.1	15.6	17.7	19.8	21.1	2.09
	67	25.0	12.7	14.7	16.8	18.2	2.13
105	63	21.3	14.8	16.9	19.0	20.4	2.20
	67	23.2	11.9	14.0	16.1	17.5	2.24
	71	25.1	8.9	11.0	13.1	14.5	2.29
115	63	19.6	14.0	16.1	18.2	19.6	2.31
	67	21.3	11.1	13.2	15.3	16.7	2.36
	71	23.1	8.2	10.2	12.3	13.7	2.41

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TDY060R9V3+RXC025S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.0	17.3	19.2	21.0*	21.6*	1.82
	63	22.8	15.0	16.9	18.7	20.0	1.85
	67	24.7	12.4	14.2	16.1	17.4	1.89
95	59	19.7	16.7	18.6	20.0*	20.5*	1.98
	63	21.4	14.4	16.2	18.1	19.3	2.02
	67	23.2	11.7	13.6	15.5	16.7	2.06
105	63	20.0	13.7	15.6	17.5	18.7	2.16
	67	21.7	11.1	13.0	14.8	16.1	2.20
	71	23.5	8.4	10.3	12.1	13.4	2.25
115	63	18.7	13.1	15.0	16.9	18.1	2.30
	67	20.3	10.5	12.4	14.2	15.5	2.35
	71	21.9	7.8	9.7	11.5	12.8	2.40

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDY060R9V3+RXC031S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.6	18.6	20.7	22.7*	23.3*	1.84
	63	24.5	16.0	18.1	20.2	21.6	1.87
	67	26.4	13.0	15.1	17.2	18.6	1.91
95	59	21.2	18.0	20.1	21.6*	22.2*	2.02
	63	22.9	15.3	17.4	19.5	20.9	2.05
	67	24.8	12.4	14.5	16.6	18.0	2.09
105	63	21.4	14.6	16.7	18.8	20.2	2.20
	67	23.1	11.7	13.8	15.9	17.3	2.24
	71	25.0	8.7	10.8	12.9	14.3	2.28
115	63	19.8	13.9	16.0	18.1	19.5	2.34
	67	21.5	11.0	13.1	15.2	16.6	2.38
	71	23.2	8.0	10.1	12.2	13.6	2.43

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TDY060R9V3+RXC036S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.0	18.8	20.9	23.0*	23.7*	1.84
	63	24.9	16.1	18.2	20.4	21.8	1.87
	67	26.8	13.1	15.2	17.4	18.8	1.91
95	59	21.5	18.1	20.3	21.9*	22.5*	2.02
	63	23.3	15.4	17.6	19.7	21.1	2.05
	67	25.2	12.4	14.6	16.7	18.1	2.09
105	63	21.7	14.7	16.9	19.0	20.4	2.20
	67	23.5	11.7	13.9	16.0	17.4	2.24
	71	25.3	8.7	10.8	12.9	14.4	2.28
115	63	20.1	14.0	16.2	18.3	19.7	2.34
	67	21.7	11.0	13.2	15.3	16.7	2.38
	71	23.4	8.0	10.1	12.2	13.7	2.42

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TDY080R9V3+TXH025A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.5	17.3	19.2	20.7*	21.3*	1.81
	63	22.2	14.9	16.8	18.7	20.0	1.85
	67	24.1	12.2	14.1	16.0	17.3	1.88
95	59	20.0	17.0	18.9	20.3*	20.9*	1.99
	63	21.7	14.7	16.6	18.5	19.7	2.03
	67	23.6	12.0	13.9	15.8	17.1	2.07
105	63	20.1	13.9	15.8	17.7	19.0	2.15
	67	21.9	11.3	13.2	15.1	16.4	2.19
	71	23.8	8.6	10.5	12.4	13.7	2.24
115	63	18.6	13.2	15.1	17.0	18.3	2.27
	67	20.2	10.6	12.5	14.4	15.7	2.31
	71	22.0	7.9	9.8	11.7	12.9	2.36

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TDY080R9V3+TXH033A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.7	18.2	20.3	22.0*	22.6*	1.86
	63	23.5	15.6	17.7	19.8	21.2	1.89
	67	25.4	12.7	14.8	16.9	18.2	1.93
95	59	21.0	17.9	20.0	21.5*	22.1*	2.04
	63	22.8	15.3	17.4	19.5	20.9	2.07
	67	24.7	12.4	14.5	16.6	18.0	2.11
105	63	21.1	14.6	16.6	18.7	20.1	2.19
	67	22.9	11.7	13.8	15.8	17.2	2.23
	71	24.8	8.7	10.8	12.9	14.3	2.28
115	63	19.4	13.8	15.9	18.0	19.4	2.30
	67	21.1	10.9	13.0	15.1	16.5	2.35
	71	22.9	8.0	10.1	12.1	13.5	2.40

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH TDY080R9V3+RXC025S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.0	17.3	19.2	21.0*	21.6*	1.81
	63	22.8	15.0	16.9	18.7	20.0	1.84
	67	24.7	12.4	14.2	16.1	17.4	1.88
95	59	19.7	16.7	18.6	20.0*	20.5*	1.98
	63	21.4	14.4	16.2	18.1	19.3	2.01
	67	23.2	11.7	13.6	15.5	16.7	2.05
105	63	20.0	13.7	15.6	17.5	18.7	2.15
	67	21.7	11.1	13.0	14.8	16.1	2.20
	71	23.5	8.4	10.3	12.1	13.4	2.24
115	63	18.7	13.1	15.0	16.9	18.1	2.29
	67	20.3	10.5	12.4	14.2	15.5	2.34
	71	21.9	7.8	9.7	11.5	12.8	2.39

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TDY080R9V3+RXC031S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.6	18.6	20.7	22.7*	23.3*	1.82
	63	24.5	16.0	18.1	20.2	21.6	1.86
	67	26.4	13.0	15.1	17.2	18.6	1.89
95	59	21.2	18.0	20.1	21.6*	22.2*	2.00
	63	22.9	15.3	17.4	19.5	20.9	2.04
	67	24.8	12.4	14.5	16.6	18.0	2.08
105	63	21.4	14.6	16.7	18.8	20.2	2.18
	67	23.1	11.7	13.8	15.9	17.3	2.22
	71	25.0	8.7	10.8	12.9	14.3	2.26
115	63	19.8	14.0	16.1	18.2	19.6	2.32
	67	21.5	11.0	13.1	15.2	16.6	2.37
	71	23.2	8.0	10.1	12.2	13.6	2.41

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TDY080R9V3+RXC036S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.0	18.8	21.0	23.0*	23.7*	1.82
	63	24.9	16.1	18.2	20.4	21.8	1.86
	67	26.8	13.1	15.3	17.4	18.8	1.89
95	59	21.6	18.2	20.3	21.9*	22.5*	2.00
	63	23.3	15.4	17.6	19.7	21.1	2.04
	67	25.2	12.5	14.6	16.7	18.1	2.07
105	63	21.7	14.7	16.9	19.0	20.4	2.18
	67	23.5	11.7	13.9	16.0	17.4	2.22
	71	25.3	8.7	10.8	12.9	14.4	2.26
115	63	20.1	14.0	16.2	18.3	19.7	2.32
	67	21.7	11.0	13.2	15.3	16.7	2.36
	71	23.4	8.0	10.1	12.2	13.7	2.40

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TUD060R9V3+TXH025A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.0	18.6	20.7	21.8*	22.4*	1.87
	63	22.8	15.9	18.0	20.2	21.6	1.91
	67	24.7	12.8	15.0	17.1	18.5	1.94
95	59	20.5	18.3	20.5	21.3*	21.9*	2.05
	63	22.3	15.6	17.8	19.9	21.4	2.09
	67	24.2	12.6	14.8	16.9	18.3	2.13
105	63	20.7	14.9	17.0	19.2	20.6	2.21
	67	22.5	11.9	14.0	16.2	17.6	2.25
	71	24.3	8.8	10.9	13.1	14.5	2.30
115	63	19.0	14.1	16.3	18.4	19.3*	2.32
	67	20.7	11.1	13.3	15.4	16.9	2.37
	71	22.5	8.1	10.2	12.4	13.8	2.43

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH TUD060R9V3+TXH033A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.3	19.7	22.1	23.1*	23.7*	1.92
	63	24.1	16.7	19.1	21.4	23.0	1.95
	67	26.0	13.4	15.7	18.1	19.6	1.99
95	59	21.6	19.4	21.7*	22.6*	23.2*	2.10
	63	23.5	16.4	18.8	21.1	22.7	2.14
	67	25.4	13.1	15.5	17.8	19.4	2.18
105	63	21.7	15.6	18.0	20.3	21.8*	2.25
	67	23.5	12.3	14.7	17.0	18.6	2.29
	71	25.4	8.9	11.3	13.7	15.2	2.34
115	63	19.9	14.8	17.2	19.6	20.3*	2.36
	67	21.6	11.6	13.9	16.3	17.8	2.41
	71	23.4	8.2	10.5	12.9	14.5	2.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TUD060R9V3+RXC025S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.6	18.6	20.7	22.1*	22.7*	1.86
	63	23.4	15.9	18.0	20.1	21.5	1.89
	67	25.4	12.9	15.0	17.1	18.5	1.93
95	59	20.2	17.9	20.0	21.0*	21.6*	2.03
	63	22.0	15.2	17.4	19.5	20.9	2.07
	67	23.8	12.3	14.4	16.5	17.9	2.11
105	63	20.5	14.6	16.7	18.8	20.2	2.21
	67	22.2	11.6	13.7	15.8	17.2	2.25
	71	24.0	8.5	10.6	12.8	14.2	2.30
115	63	19.1	13.9	16.1	18.2	19.2*	2.35
	67	20.7	10.9	13.1	15.2	16.6	2.39
	71	22.4	7.9	10.0	12.1	13.5	2.45

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2024A1 WITH TUD060R9V3+RXC031S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.9	19.7	22.1	23.5*	24.1*	1.89
	63	24.8	16.7	19.1	21.4	23.0	1.92
	67	26.8	13.4	15.7	18.1	19.6	1.96
95	59	21.5	19.0	21.4	22.3*	22.9*	2.06
	63	23.2	16.0	18.4	20.7	22.3	2.10
	67	25.1	12.7	15.0	17.4	19.0	2.14
105	63	21.6	15.3	17.7	20.0	21.6	2.24
	67	23.4	12.0	14.3	16.7	18.3	2.28
	71	25.2	8.6	10.9	13.3	14.9	2.33
115	63	20.0	14.6	17.0	19.3	20.3*	2.38
	67	21.7	11.3	13.6	16.0	17.6	2.43
	71	23.3	7.9	10.2	12.6	14.2	2.47

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data

Cooling

4TTR2024A1 WITH TUD060R9V3+RXC036S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.7	20.2	22.6	24.2*	24.9*	1.89
	63	25.6	17.1	19.5	21.9	23.6	1.93
	67	27.6	13.7	16.1	18.5	20.1	1.97
95	59	22.2	19.5	21.9	23.0*	23.6*	2.07
	63	24.0	16.4	18.8	21.2	22.9	2.11
	67	25.9	13.0	15.4	17.8	19.4	2.15
105	63	22.2	15.7	18.1	20.5	22.1	2.25
	67	24.0	12.2	14.7	17.1	18.7	2.29
	71	25.9	8.8	11.2	13.6	15.2	2.34
115	63	20.5	14.9	17.3	19.8	20.8*	2.40
	67	22.2	11.5	13.9	16.3	18.0	2.44
	71	23.9	8.0	10.4	12.9	14.5	2.48

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TUD080R9V3+TXH025A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.0	18.6	20.7	21.8*	22.4*	1.89
	63	22.8	15.9	18.0	20.2	21.6	1.93
	67	24.7	12.8	15.0	17.1	18.5	1.96
95	59	20.5	18.3	20.5	21.3*	21.9*	2.07
	63	22.3	15.6	17.8	19.9	21.4	2.11
	67	24.2	12.6	14.7	16.9	18.3	2.15
105	63	20.7	14.9	17.0	19.2	20.6	2.23
	67	22.5	11.9	14.0	16.2	17.6	2.27
	71	24.3	8.8	10.9	13.1	14.5	2.32
115	63	19.0	14.1	16.3	18.4	19.3*	2.35
	67	20.7	11.1	13.3	15.4	16.9	2.39
	71	22.5	8.0	10.2	12.3	13.8	2.44

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH TUD080R9V3+TXH033A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.3	19.7	22.1	23.1*	23.7*	1.93
	63	24.1	16.7	19.1	21.4	23.0	1.96
	67	26.0	13.4	15.7	18.1	19.6	2.00
95	59	21.6	19.4	21.7*	22.6*	23.2*	2.11
	63	23.5	16.4	18.8	21.1	22.7	2.15
	67	25.4	13.1	15.4	17.8	19.4	2.19
105	63	21.7	15.6	18.0	20.3	21.8*	2.26
	67	23.5	12.3	14.7	17.0	18.6	2.30
	71	25.4	8.9	11.3	13.6	15.2	2.35
115	63	19.9	14.8	17.2	19.5	20.3*	2.37
	67	21.6	11.5	13.9	16.3	17.8	2.42
	71	23.4	8.2	10.5	12.9	14.5	2.47

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TUD080R9V3+RXC025S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.6	18.6	20.7	22.1*	22.7*	1.87
	63	23.4	15.9	18.0	20.1	21.5	1.90
	67	25.4	12.9	15.0	17.1	18.5	1.94
95	59	20.2	17.9	20.0	21.0*	21.6*	2.04
	63	22.0	15.2	17.4	19.5	20.9	2.07
	67	23.8	12.2	14.4	16.5	17.9	2.12
105	63	20.5	14.6	16.7	18.8	20.2	2.21
	67	22.2	11.6	13.7	15.8	17.2	2.26
	71	24.0	8.5	10.6	12.7	14.2	2.31
115	63	19.1	13.9	16.0	18.2	19.2*	2.35
	67	20.7	10.9	13.0	15.2	16.6	2.40
	71	22.4	7.9	10.0	12.1	13.5	2.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2024A1 WITH TUD080R9V3+RXC031S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.0	19.9	22.3	23.7*	24.3*	1.89
	63	24.9	16.8	19.2	21.6	23.2	1.93
	67	26.9	13.5	15.9	18.2	19.8	1.96
95	59	21.5	19.2	21.5*	22.5*	23.0*	2.07
	63	23.3	16.1	18.5	20.9	22.5	2.10
	67	25.2	12.8	15.2	17.5	19.1	2.14
105	63	21.7	15.4	17.8	20.2	21.7*	2.25
	67	23.5	12.1	14.5	16.8	18.4	2.29
	71	25.3	8.7	11.0	13.4	15.0	2.33
115	63	20.1	14.7	17.1	19.5	20.4*	2.39
	67	21.7	11.4	13.8	16.1	17.7	2.44
	71	23.4	8.0	10.3	12.7	14.3	2.48

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TUD080R9V3+RXC036S3 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.8	20.3	22.7	24.3*	24.9*	1.89
	63	25.7	17.2	19.6	22.0	23.6	1.92
	67	27.7	13.8	16.2	18.6	20.2	1.96
95	59	22.3	19.6	22.0	23.1*	23.7*	2.07
	63	24.1	16.5	18.9	21.3	22.9	2.11
	67	26.0	13.1	15.5	17.9	19.5	2.14
105	63	22.3	15.7	18.2	20.6	22.2	2.25
	67	24.1	12.3	14.7	17.2	18.8	2.29
	71	26.0	8.8	11.3	13.7	15.3	2.33
115	63	20.6	15.0	17.4	19.8	20.9*	2.40
	67	22.3	11.6	14.0	16.4	18.0	2.44
	71	24.0	8.1	10.5	12.9	14.6	2.48

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TUY060R9V3+TXH025A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.6	17.3	19.2	20.8*	21.3*	1.84
	63	22.4	14.9	16.8	18.7	20.0	1.88
	67	24.2	12.2	14.1	16.0	17.3	1.91
95	59	20.0	17.0	18.9	20.4*	20.9*	2.02
	63	21.8	14.7	16.5	18.4	19.7	2.06
	67	23.7	12.0	13.9	15.8	17.1	2.10
105	63	20.2	13.9	15.8	17.7	19.0	2.18
	67	22.0	11.3	13.2	15.1	16.3	2.22
	71	23.9	8.6	10.5	12.4	13.6	2.27
115	63	18.6	13.2	15.1	17.0	18.2	2.30
	67	20.3	10.6	12.4	14.3	15.6	2.34
	71	22.1	7.9	9.8	11.6	12.9	2.39

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TUY060R9V3+TXH033A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.7	18.2	20.3	21.9*	22.5*	1.86
	63	23.5	15.6	17.7	19.7	21.1	1.90
	67	25.4	12.7	14.7	16.8	18.2	1.94
95	59	21.0	17.9	20.0	21.4*	22.0*	2.04
	63	22.8	15.3	17.4	19.4	20.8	2.08
	67	24.7	12.4	14.5	16.6	17.9	2.12
105	63	21.1	14.5	16.6	18.7	20.1	2.19
	67	22.9	11.6	13.7	15.8	17.2	2.24
	71	24.8	8.7	10.8	12.8	14.2	2.28
115	63	19.4	13.8	15.8	17.9	19.3	2.30
	67	21.1	10.9	13.0	15.0	16.4	2.35
	71	22.8	7.9	10.0	12.1	13.5	2.40

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH TUY060R9V3+RXC025S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.1	17.2	19.1	21.0	21.6*	1.84
	63	22.9	14.9	16.8	18.6	19.9	1.88
	67	24.8	12.3	14.1	16.0	17.3	1.91
95	59	19.7	16.6	18.4	20.0*	20.5*	2.01
	63	21.5	14.3	16.1	18.0	19.2	2.05
	67	23.3	11.6	13.5	15.4	16.6	2.09
105	63	20.1	13.6	15.5	17.4	18.6	2.19
	67	21.8	11.0	12.9	14.7	16.0	2.23
	71	23.6	8.3	10.2	12.0	13.3	2.28
115	63	18.7	13.0	14.9	16.7	18.0	2.32
	67	20.3	10.4	12.3	14.1	15.4	2.38
	71	22.0	7.7	9.6	11.4	12.7	2.43

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TUY060R9V3+RXC031S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.4	18.5	20.6	22.5*	23.1*	1.85
	63	24.3	15.8	17.9	20.0	21.4	1.88
	67	26.2	12.9	15.0	17.1	18.5	1.92
95	59	21.0	17.8	19.9	21.4*	22.0*	2.02
	63	22.8	15.1	17.2	19.3	20.7	2.06
	67	24.6	12.2	14.3	16.4	17.8	2.10
105	63	21.2	14.5	16.6	18.7	20.0	2.20
	67	22.9	11.5	13.6	15.7	17.1	2.25
	71	24.7	8.5	10.6	12.7	14.1	2.29
115	63	19.7	13.8	15.9	18.0	19.4	2.35
	67	21.3	10.9	12.9	15.0	16.4	2.39
	71	23.0	7.8	9.9	12.0	13.4	2.44

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TUY060R9V3+RXC036S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.0	18.8	20.9	23.0*	23.6*	1.86
	63	24.9	16.1	18.2	20.4	21.8	1.90
	67	26.8	13.1	15.2	17.4	18.8	1.93
95	59	21.5	18.1	20.3	21.9*	22.5*	2.04
	63	23.3	15.4	17.5	19.7	21.1	2.08
	67	25.2	12.4	14.5	16.7	18.1	2.12
105	63	21.7	14.7	16.8	19.0	20.4	2.22
	67	23.4	11.7	13.8	16.0	17.4	2.26
	71	25.3	8.6	10.8	12.9	14.3	2.30
115	63	20.1	14.0	16.1	18.3	19.7	2.36
	67	21.7	11.0	13.1	15.3	16.7	2.41
	71	23.4	7.9	10.1	12.2	13.6	2.45

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TUY080R9V3+TXH025A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.5	17.3	19.2	20.7*	21.3*	1.81
	63	22.2	14.9	16.8	18.7	20.0	1.85
	67	24.1	12.2	14.1	16.0	17.3	1.88
95	59	20.0	17.0	18.9	20.3*	20.9*	1.99
	63	21.7	14.7	16.6	18.5	19.7	2.03
	67	23.6	12.0	13.9	15.8	17.1	2.07
105	63	20.1	13.9	15.8	17.7	19.0	2.15
	67	21.9	11.3	13.2	15.1	16.4	2.19
	71	23.8	8.6	10.5	12.4	13.7	2.24
115	63	18.6	13.2	15.1	17.0	18.3	2.27
	67	20.2	10.6	12.5	14.4	15.7	2.31
	71	22.0	7.9	9.8	11.7	12.9	2.36

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TUY080R9V3+TXH033A4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.9	18.5	20.5	22.2*	22.8*	1.86
	63	23.7	15.8	17.9	20.0	21.4	1.90
	67	25.6	12.9	15.0	17.1	18.4	1.94
95	59	21.2	18.1	20.2	21.7*	22.3*	2.04
	63	23.0	15.5	17.6	19.7	21.1	2.08
	67	24.9	12.6	14.7	16.8	18.2	2.12
105	63	21.3	14.7	16.8	18.9	20.3	2.20
	67	23.1	11.8	13.9	16.0	17.4	2.24
	71	25.0	8.9	11.0	13.0	14.4	2.29
115	63	19.6	14.0	16.1	18.2	19.5	2.31
	67	21.3	11.1	13.2	15.3	16.7	2.36
	71	23.1	8.1	10.2	12.3	13.7	2.41

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH TUY080R9V3+RXC025S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.0	17.3	19.2	21.0*	21.6*	1.81
	63	22.8	15.0	16.9	18.7	20.0	1.84
	67	24.7	12.4	14.2	16.1	17.4	1.88
95	59	19.7	16.7	18.6	20.0*	20.5*	1.98
	63	21.4	14.4	16.2	18.1	19.3	2.01
	67	23.2	11.7	13.6	15.5	16.7	2.05
105	63	20.0	13.7	15.6	17.5	18.7	2.15
	67	21.7	11.1	13.0	14.8	16.1	2.20
	71	23.5	8.4	10.3	12.1	13.4	2.24
115	63	18.7	13.1	15.0	16.9	18.1	2.29
	67	20.3	10.5	12.4	14.2	15.5	2.34
	71	21.9	7.8	9.7	11.5	12.8	2.39

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TUY080R9V3+RXC031S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.6	18.6	20.7	22.7*	23.3*	1.84
	63	24.5	16.0	18.1	20.2	21.6	1.87
	67	26.4	13.0	15.1	17.2	18.6	1.91
95	59	21.2	18.0	20.1	21.6*	22.2*	2.02
	63	22.9	15.3	17.4	19.5	20.9	2.05
	67	24.8	12.4	14.5	16.6	18.0	2.09
105	63	21.4	14.6	16.7	18.8	20.2	2.20
	67	23.1	11.7	13.8	15.9	17.3	2.24
	71	25.0	8.7	10.8	12.9	14.3	2.28
115	63	19.8	13.9	16.0	18.1	19.5	2.34
	67	21.5	11.0	13.1	15.2	16.6	2.38
	71	23.2	8.0	10.1	12.2	13.6	2.43

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TUY080R9V3+RXC036S3 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	23.0	18.8	20.9	23.0*	23.7*	1.84
	63	24.9	16.1	18.2	20.4	21.8	1.87
	67	26.8	13.1	15.2	17.4	18.8	1.91
95	59	21.5	18.1	20.3	21.9*	22.5*	2.02
	63	23.3	15.4	17.6	19.7	21.1	2.05
	67	25.2	12.4	14.6	16.7	18.1	2.09
105	63	21.7	14.7	16.9	19.0	20.4	2.20
	67	23.5	11.7	13.9	16.0	17.4	2.24
	71	25.3	8.7	10.8	12.9	14.4	2.28
115	63	20.1	14.0	16.2	18.3	19.7	2.34
	67	21.7	11.0	13.2	15.3	16.7	2.38
	71	23.4	8.0	10.1	12.2	13.7	2.42

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TVF018A14 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.9	17.9	20.1	21.4*	22.0*	2.01
	63	22.7	15.2	17.3	19.5	20.9	2.04
	67	24.6	12.2	14.3	16.5	17.9	2.08
95	59	20.4	17.7	19.8	21.0*	21.6*	2.19
	63	22.2	15.0	17.1	19.3	20.7	2.23
	67	24.1	12.0	14.1	16.3	17.7	2.27
105	63	20.5	14.2	16.4	18.5	20.0	2.34
	67	22.4	11.2	13.4	15.5	17.0	2.39
	71	24.3	8.2	10.3	12.5	13.9	2.43
115	63	18.9	13.5	15.6	17.8	19.0*	2.46
	67	20.6	10.5	12.7	14.8	16.3	2.51
	71	22.4	7.5	9.6	11.8	13.2	2.56

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH TVF024A14 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.3	19.2	21.4*	22.3*	22.9*	2.05
	63	23.1	16.1	18.5	20.9	22.5	2.09
	67	25.0	12.6	15.1	17.5	19.1	2.12
95	59	20.7	18.9	21.0*	21.9*	22.5*	2.23
	63	22.6	15.8	18.3	20.7	22.3	2.27
	67	24.5	12.4	14.9	17.3	18.9	2.32
105	63	20.8	15.1	17.5	19.9	21.1*	2.39
	67	22.7	11.7	14.1	16.5	18.2	2.43
	71	24.6	8.2	10.6	13.1	14.7	2.48
115	63	19.1	14.3	16.8	19.1*	19.7*	2.50
	67	20.9	10.9	13.4	15.8	17.4	2.55
	71	22.7	7.5	9.9	12.3	14.0	2.60

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TVF025A14 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.4	19.2	21.5*	22.4*	23.0*	2.02
	63	23.3	16.1	18.5	21.0	22.6	2.05
	67	25.2	12.7	15.1	17.6	19.2	2.09
95	59	20.9	18.9	21.0*	22.0*	22.6*	2.20
	63	22.7	15.9	18.3	20.7	22.3	2.24
	67	24.6	12.5	14.9	17.3	18.9	2.28
105	63	21.0	15.1	17.5	20.0	21.2*	2.35
	67	22.8	11.7	14.2	16.6	18.2	2.39
	71	24.7	8.3	10.7	13.1	14.7	2.44
115	63	19.2	14.4	16.8	19.2	19.8*	2.46
	67	21.0	11.0	13.4	15.9	17.5	2.51
	71	22.8	7.6	10.0	12.4	14.0	2.56

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TVF030A14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.3	20.8	22.7*	23.7*	24.3*	2.09
	63	24.1	17.2	20.0	22.7	24.3*	2.12
	67	26.1	13.4	16.1	18.8	20.7	2.16
95	59	21.6	20.5	22.2*	23.1*	23.7*	2.27
	63	23.5	17.0	19.7	22.4	23.7*	2.31
	67	25.4	13.1	15.8	18.6	20.4	2.35
105	63	21.6	16.2	18.9	21.7*	22.2*	2.42
	67	23.5	12.3	15.1	17.8	19.6	2.47
	71	25.4	8.4	11.1	13.9	15.7	2.51
115	63	19.8	15.4	18.2	20.2*	20.7*	2.53
	67	21.6	11.6	14.3	17.1	18.9	2.58
	71	23.4	7.6	10.4	13.1	15.0	2.63

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TVF036A14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.3	20.7	22.7*	23.7*	24.3*	2.17
	63	24.2	17.1	19.9	22.7	24.3*	2.20
	67	26.1	13.2	16.0	18.7	20.6	2.24
95	59	21.6	20.4	22.2*	23.1*	23.7*	2.35
	63	23.5	16.8	19.6	22.3	23.7*	2.39
	67	25.4	12.9	15.7	18.4	20.3	2.43
105	63	21.6	16.0	18.8	21.6	22.2*	2.50
	67	23.5	12.1	14.9	17.7	19.5	2.54
	71	25.4	8.2	10.9	13.7	15.6	2.59
115	63	19.8	15.3	18.0	20.1*	20.7*	2.61
	67	21.6	11.4	14.2	16.9	18.8	2.66
	71	23.4	7.4	10.2	13.0	14.8	2.71

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.07

4TTR2024A1 WITH TWE018C14 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	19.5	16.6	18.5	19.9*	20.4*	1.90
	63	21.3	14.2	16.1	18.0	19.3	1.93
	67	23.1	11.6	13.5	15.4	16.6	1.97
95	59	19.1	16.4	18.3	19.6*	20.1*	2.08
	63	20.9	14.1	16.0	17.9	19.1	2.12
	67	22.7	11.4	13.3	15.2	16.5	2.16
105	63	19.3	13.4	15.3	17.2	18.4	2.24
	67	21.1	10.7	12.6	14.5	15.8	2.28
	71	22.9	8.0	9.9	11.8	13.1	2.31
115	63	17.8	12.7	14.6	16.5	17.7	2.36
	67	19.4	10.0	11.9	13.8	15.1	2.40
	71	21.1	7.3	9.2	11.1	12.4	2.44

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TWE024C14 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.2	17.6	19.7	20.9*	21.5*	1.98
	63	22.0	15.0	17.1	19.2	20.6	2.02
	67	23.9	12.0	14.1	16.2	17.6	2.05
95	59	19.7	17.4	19.5	20.5*	21.1*	2.16
	63	21.5	14.7	16.8	18.9	20.3	2.20
	67	23.4	11.8	13.9	16.0	17.4	2.24
105	63	19.9	14.0	16.1	18.2	19.6	2.32
	67	21.7	11.1	13.2	15.3	16.7	2.36
	71	23.6	8.1	10.2	12.3	13.7	2.41
115	63	18.3	13.3	15.4	17.5	18.5*	2.44
	67	20.0	10.4	12.5	14.6	16.0	2.48
	71	21.8	7.4	9.5	11.6	13.0	2.53

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH TWE030C14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.3	19.6	21.6*	22.5*	23.1*	2.06
	63	23.1	16.4	18.9	21.4	23.1*	2.10
	67	25.0	12.8	15.3	17.8	19.5	2.14
95	59	20.7	19.3	21.1*	22.0*	22.6*	2.24
	63	22.5	16.1	18.6	21.2	22.6*	2.28
	67	24.4	12.5	15.1	17.6	19.3	2.32
105	63	20.8	15.4	17.9	20.4	21.2*	2.40
	67	22.6	11.8	14.3	16.8	18.5	2.44
	71	24.5	8.2	10.7	13.2	14.9	2.49
115	63	19.1	14.6	17.1	19.3*	19.8*	2.51
	67	20.8	11.1	13.6	16.1	17.8	2.56
	71	22.6	7.4	10.0	12.5	14.2	2.61

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TWE036C14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.4	20.1	21.8*	22.8*	23.4*	2.09
	63	23.2	16.7	19.3	21.9	23.4*	2.13
	67	25.1	13.0	15.6	18.2	20.0	2.16
95	59	20.8	19.8	21.4*	22.3*	22.9*	2.27
	63	22.7	16.5	19.1	21.7	22.9*	2.31
	67	24.6	12.8	15.4	18.0	19.7	2.35
105	63	21.0	15.7	18.3	21.0	21.6*	2.43
	67	22.8	12.0	14.7	17.3	19.0	2.47
	71	24.7	8.3	10.9	13.5	15.3	2.52
115	63	19.3	15.0	17.6	19.6*	20.2*	2.54
	67	21.0	11.3	13.9	16.6	18.3	2.59
	71	22.8	7.6	10.2	12.8	14.6	2.64

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TXA/TXC018C4/D4 AT 700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	19.1	16.4	18.2	19.5*	20.1*	1.94
	63	20.9	14.1	15.9	17.8	19.0	1.98
	67	22.7	11.5	13.3	15.2	16.4	2.01
95	59	18.7	16.2	18.0	19.2*	19.8*	2.12
	63	20.5	13.9	15.8	17.6	18.9	2.16
	67	22.3	11.3	13.2	15.1	16.3	2.20
105	63	18.9	13.2	15.1	16.9	18.1	2.29
	67	20.7	10.6	12.5	14.3	15.6	2.33
	71	22.5	8.0	9.8	11.7	12.9	2.37
115	63	17.4	12.5	14.3	16.2	17.4*	2.41
	67	19.1	9.9	11.8	13.6	14.9	2.46
	71	20.8	7.3	9.1	11.0	12.2	2.50

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	600	800	AIRFLOW	600	800
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2024A1 WITH TXA/TXC024C4/D4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	19.8	17.5	19.6	20.6*	21.2*	2.01
	63	21.6	14.8	17.0	19.1	20.5	2.05
	67	23.5	11.8	14.0	16.1	17.5	2.08
95	59	19.4	17.3	19.4*	20.2*	20.8*	2.19
	63	21.2	14.6	16.8	18.9	20.3	2.23
	67	23.0	11.7	13.8	15.9	17.3	2.27
105	63	19.6	13.9	16.0	18.2	19.6	2.35
	67	21.3	10.9	13.1	15.2	16.6	2.39
	71	23.1	7.9	10.0	12.1	13.5	2.44
115	63	18.0	13.2	15.3	17.5	18.3*	2.46
	67	19.6	10.2	12.4	14.5	15.9	2.51
	71	21.3	7.2	9.3	11.4	12.8	2.56

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH TXA/TXC025C4/D4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.8	18.4	20.7	21.7*	22.3*	2.04
	63	22.7	15.5	17.8	20.0	21.6	2.07
	67	24.5	12.3	14.5	16.8	18.3	2.11
95	59	20.3	18.1	20.3*	21.2*	21.8*	2.22
	63	22.1	15.2	17.5	19.8	21.3	2.26
	67	24.0	12.0	14.3	16.6	18.1	2.30
105	63	20.4	14.5	16.8	19.1	20.5*	2.37
	67	22.2	11.3	13.6	15.9	17.4	2.41
	71	24.1	8.0	10.3	12.6	14.1	2.46
115	63	18.7	13.8	16.0	18.3	19.1*	2.48
	67	20.4	10.6	12.9	15.1	16.7	2.53
	71	22.2	7.3	9.6	11.9	13.4	2.58

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2024A1 WITH TXA/TXC030C4/D4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.5	19.7	21.7*	22.6*	23.2*	2.11
	63	23.3	16.5	19.0	21.4	23.1	2.14
	67	25.2	13.0	15.4	17.9	19.6	2.18
95	59	20.8	19.3	21.2*	22.1*	22.7*	2.28
	63	22.7	16.2	18.7	21.1	22.7*	2.32
	67	24.6	12.7	15.2	17.6	19.3	2.37
105	63	20.9	15.4	17.9	20.4	21.3*	2.44
	67	22.8	12.0	14.4	16.9	18.5	2.48
	71	24.7	8.4	10.9	13.3	15.0	2.53
115	63	19.2	14.7	17.1	19.3*	19.9*	2.55
	67	20.9	11.2	13.7	16.1	17.8	2.60
	71	22.7	7.7	10.1	12.6	14.2	2.65

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TXA/TXC031C4/D4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.7	19.9	22.0*	22.9*	23.5*	2.11
	63	23.5	16.6	19.2	21.8	23.5	2.15
	67	25.4	12.9	15.5	18.1	19.8	2.18
95	59	21.0	19.6	21.5*	22.4*	23.0*	2.29
	63	22.9	16.3	18.9	21.5	23.0*	2.33
	67	24.8	12.6	15.2	17.8	19.5	2.37
105	63	21.1	15.5	18.1	20.7	21.5*	2.44
	67	22.9	11.9	14.5	17.1	18.8	2.49
	71	24.8	8.1	10.7	13.3	15.1	2.53
115	63	19.3	14.8	17.4	19.5*	20.1*	2.55
	67	21.1	11.1	13.7	16.3	18.0	2.60
	71	22.9	7.4	10.0	12.6	14.3	2.65

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2024A1 WITH TXA/TXC035C4/D4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.5	19.7	21.7*	22.6*	23.2*	2.11
	63	23.3	16.5	19.0	21.4	23.1	2.14
	67	25.2	13.0	15.4	17.9	19.6	2.18
95	59	20.8	19.3	21.2*	22.1*	22.7*	2.28
	63	22.7	16.2	18.7	21.1	22.7*	2.32
	67	24.6	12.7	15.2	17.6	19.3	2.37
105	63	20.9	15.4	17.9	20.4	21.3*	2.44
	67	22.8	12.0	14.4	16.9	18.5	2.48
	71	24.7	8.4	10.9	13.3	15.0	2.53
115	63	19.2	14.7	17.1	19.3*	19.9*	2.55
	67	20.9	11.2	13.7	16.1	17.8	2.60
	71	22.7	7.7	10.1	12.6	14.2	2.65

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2024A1 WITH TXA/TXC036C4/D4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.9	20.1	22.2*	23.1*	23.7*	2.13
	63	23.7	16.7	19.3	22.0	23.7*	2.17
	67	25.6	13.0	15.6	18.2	20.0	2.20
95	59	21.2	19.8	21.6*	22.6*	23.2*	2.31
	63	23.1	16.4	19.1	21.7	23.2*	2.35
	67	25.0	12.7	15.3	18.0	19.7	2.39
105	63	21.3	15.7	18.3	21.0	21.8*	2.46
	67	23.2	12.0	14.6	17.2	19.0	2.51
	71	25.1	8.2	10.8	13.5	15.2	2.56
115	63	19.5	14.9	17.6	19.8*	20.3*	2.58
	67	21.3	11.2	13.9	16.5	18.3	2.63
	71	23.1	7.5	10.1	12.7	14.5	2.68

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH TXA/TXC037C4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	21.9	20.1	22.2*	23.1*	23.7*	2.13
	63	23.7	16.7	19.3	22.0	23.7*	2.17
	67	25.6	13.0	15.6	18.2	20.0	2.20
95	59	21.2	19.8	21.6*	22.6*	23.2*	2.31
	63	23.1	16.4	19.1	21.7	23.2*	2.35
	67	25.0	12.7	15.3	18.0	19.7	2.39
105	63	21.3	15.7	18.3	21.0	21.8*	2.46
	67	23.2	12.0	14.6	17.2	19.0	2.51
	71	25.1	8.2	10.8	13.5	15.2	2.56
115	63	19.5	14.9	17.6	19.8*	20.3*	2.58
	67	21.3	11.2	13.9	16.5	18.3	2.63
	71	23.1	7.5	10.1	12.7	14.5	2.68

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2024A1 WITH TXH025A4 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	20.4	18.0	20.1	21.2*	21.8*	2.02
	63	22.2	15.3	17.4	19.6	21.0	2.06
	67	24.1	12.2	14.4	16.5	18.0	2.09
95	59	19.9	17.7	19.9	20.8*	21.4*	2.20
	63	21.7	15.1	17.2	19.3	20.8	2.24
	67	23.6	12.0	14.2	16.3	17.7	2.28
105	63	20.1	14.3	16.4	18.6	20.0	2.36
	67	21.9	11.3	13.4	15.6	17.0	2.40
	71	23.7	8.2	10.4	12.5	13.9	2.45
115	63	18.4	13.6	15.7	17.9	18.7*	2.47
	67	20.1	10.6	12.7	14.9	16.3	2.52
	71	21.9	7.5	9.6	11.8	13.2	2.57

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2024A1 WITH TXH033A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	22.1	20.4	22.4*	23.4*	24.0*	2.14
	63	23.9	17.0	19.7	22.3	24.0*	2.17
	67	25.9	13.3	15.9	18.6	20.3	2.21
95	59	21.4	20.1	21.9*	22.8*	23.4*	2.32
	63	23.3	16.7	19.4	22.0	23.4*	2.36
	67	25.2	13.0	15.6	18.3	20.0	2.40
105	63	21.4	15.9	18.6	21.2	21.9*	2.47
	67	23.3	12.2	14.9	17.5	19.2	2.51
	71	25.2	8.5	11.1	13.7	15.5	2.56
115	63	19.6	15.1	17.8	19.9*	20.4*	2.58
	67	21.4	11.5	14.1	16.7	18.5	2.63
	71	23.2	7.7	10.3	12.9	14.7	2.68

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH 4TEE3F31A AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.9	23.7	26.5	27.7*	28.4*	2.33
	63	28.9	19.9	22.8	25.6	27.5	2.35
	67	30.9	15.8	18.6	21.4	23.3	2.37
95	59	25.9	23.2	25.9*	26.9*	27.5*	2.59
	63	27.8	19.4	22.3	25.1	27.0	2.62
	67	29.8	15.3	18.1	21.0	22.9	2.64
105	63	26.4	18.8	21.6	24.5	26.4*	2.91
	67	28.3	14.7	17.5	20.3	22.2	2.94
	71	30.2	10.4	13.3	16.1	18.0	2.97
115	63	25.0	18.2	21.0	23.9	25.2*	3.20
	67	26.8	14.0	16.9	19.7	21.6	3.24
	71	28.7	9.8	12.7	15.5	17.4	3.28

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH 4TEE3F37A AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.3	24.1	27.0	28.3*	28.9*	2.26
	63	29.3	20.3	23.2	26.1	28.0	2.28
	67	31.4	16.1	19.0	21.9	23.8	2.30
95	59	26.3	23.6	26.4*	27.4*	28.0*	2.52
	63	28.2	19.8	22.7	25.6	27.6	2.55
	67	30.2	15.6	18.5	21.4	23.3	2.57
105	63	26.8	19.2	22.1	25.0	26.9*	2.84
	67	28.7	15.0	17.9	20.8	22.7	2.87
	71	30.7	10.7	13.6	16.5	18.4	2.90
115	63	25.5	18.6	21.5	24.4	25.7*	3.14
	67	27.3	14.4	17.3	20.2	22.2	3.17
	71	29.2	10.1	13.0	15.9	17.9	3.21

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH 4TEE3F40A AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	28.7	25.2	28.4	29.7*	30.3*	2.28
	63	30.7	21.1	24.2	27.3	29.4	2.30
	67	32.8	16.5	19.7	22.8	24.9	2.32
95	59	27.6	24.7	27.7*	28.7*	29.3*	2.55
	63	29.5	20.6	23.7	26.8	28.9	2.57
	67	31.6	16.0	19.2	22.3	24.4	2.60
105	63	28.0	19.9	23.0	26.2	28.1*	2.87
	67	29.9	15.4	18.5	21.6	23.7	2.90
	71	31.9	10.8	13.9	17.0	19.1	2.92
115	63	26.4	19.3	22.4	25.5	26.8*	3.17
	67	28.3	14.7	17.9	21.0	23.1	3.20
	71	30.2	10.2	13.3	16.4	18.5	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH 4TEP3F24A AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.1	22.1	24.7	26.5*	27.2*	2.40
	63	28.0	18.7	21.3	23.9	25.6	2.42
	67	30.1	14.9	17.5	20.1	21.9	2.44
95	59	25.1	21.7	24.2	25.7*	26.4*	2.66
	63	27.0	18.3	20.8	23.4	25.2	2.68
	67	29.0	14.5	17.1	19.7	21.4	2.71
105	63	25.6	17.6	20.2	22.8	24.6	2.98
	67	27.5	13.9	16.5	19.1	20.8	3.01
	71	29.5	10.0	12.6	15.2	17.0	3.04
115	63	24.3	17.0	19.6	22.2	23.9	3.27
	67	26.1	13.3	15.9	18.5	20.2	3.31
	71	27.9	9.4	12.0	14.6	16.4	3.35

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH 4TEP3F30A AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.4	22.2	24.8	26.8*	27.4*	2.38
	63	28.4	18.8	21.4	24.0	25.7	2.40
	67	30.4	15.1	17.6	20.2	21.9	2.42
95	59	25.4	21.7	24.3	25.9*	26.6*	2.64
	63	27.3	18.3	20.9	23.5	25.2	2.67
	67	29.3	14.6	17.2	19.7	21.5	2.69
105	63	25.9	17.7	20.3	22.9	24.6	2.96
	67	27.8	14.0	16.5	19.1	20.8	2.99
	71	29.8	10.2	12.7	15.3	17.0	3.03
115	63	24.5	17.1	19.7	22.3	24.0	3.25
	67	26.3	13.4	15.9	18.5	20.2	3.29
	71	28.2	9.6	12.1	14.7	16.4	3.34

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH 4TEP3F36A AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.9	24.5	27.1*	28.2*	28.8*	2.50
	63	28.8	20.3	23.4	26.6	28.7	2.52
	67	30.9	15.7	18.8	22.0	24.1	2.54
95	59	25.8	24.0	26.2*	27.2*	27.9*	2.77
	63	27.7	19.8	23.0	26.1	27.9*	2.79
	67	29.7	15.2	18.4	21.5	23.6	2.82
105	63	26.3	19.2	22.4	25.5	26.7*	3.09
	67	28.3	14.6	17.8	20.9	23.0	3.12
	71	30.3	10.0	13.1	16.3	18.4	3.15
115	63	24.9	18.6	21.8	24.9	25.5*	3.38
	67	26.8	14.0	17.2	20.3	22.4	3.42
	71	28.7	9.4	12.5	15.7	17.8	3.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH 4TEP3F42A AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.5	24.9	27.7*	28.7*	29.4*	2.51
	63	29.5	20.6	23.8	27.1	29.2	2.53
	67	31.6	15.9	19.1	22.3	24.5	2.55
95	59	26.4	24.4	26.8*	27.8*	28.5*	2.78
	63	28.3	20.1	23.3	26.6	28.5*	2.80
	67	30.4	15.4	18.6	21.9	24.0	2.83
105	63	26.9	19.5	22.7	25.9	27.2*	3.10
	67	28.8	14.8	18.0	21.2	23.4	3.13
	71	30.8	10.0	13.2	16.5	18.6	3.16
115	63	25.4	18.8	22.1	25.3	25.9*	3.39
	67	27.2	14.2	17.4	20.6	22.8	3.43
	71	29.1	9.4	12.6	15.9	18.0	3.47

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data

Cooling

4TTR2030A1 WITH RXC025S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.0	20.9	23.3	25.2*	25.8*	2.42
	63	26.9	17.9	20.2	22.6	24.1	2.44
	67	28.9	14.5	16.8	19.1	20.7	2.46
95	59	24.0	20.4	22.8	24.4*	25.0*	2.68
	63	25.8	17.4	19.7	22.1	23.6	2.70
	67	27.8	14.0	16.3	18.7	20.2	2.73
105	63	24.6	16.8	19.2	21.5	23.1	3.00
	67	26.5	13.4	15.8	18.1	19.7	3.03
	71	28.5	9.9	12.3	14.6	16.2	3.06
115	63	23.4	16.3	18.6	21.0	22.5	3.29
	67	25.3	12.9	15.2	17.6	19.1	3.33
	71	27.1	9.4	11.7	14.1	15.6	3.37

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH RXC031S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.7	23.5	26.4	27.7*	28.3*	2.45
	63	28.7	19.7	22.6	25.5	27.4	2.47
	67	30.8	15.4	18.3	21.2	23.2	2.49
95	59	25.7	23.0	25.8*	26.8*	27.4*	2.72
	63	27.6	19.2	22.1	25.0	26.9	2.74
	67	29.6	14.9	17.8	20.8	22.7	2.77
105	63	26.2	18.6	21.5	24.4	26.2*	3.03
	67	28.1	14.3	17.2	20.2	22.1	3.07
	71	30.1	10.0	12.9	15.8	17.8	3.10
115	63	24.8	18.0	20.9	23.8	25.1*	3.32
	67	26.7	13.7	16.6	19.6	21.5	3.37
	71	28.5	9.4	12.3	15.3	17.2	3.41

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH RXC036S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.7	25.1	27.9*	29.0*	29.6*	2.51
	63	29.7	20.7	24.0	27.2	29.4	2.53
	67	31.8	16.0	19.2	22.5	24.6	2.55
95	59	26.6	24.5	27.0*	28.0*	28.6*	2.77
	63	28.5	20.2	23.5	26.7	28.6*	2.79
	67	30.5	15.5	18.7	22.0	24.2	2.82
105	63	27.0	19.6	22.8	26.1	27.4*	3.09
	67	28.9	14.9	18.1	21.4	23.5	3.12
	71	30.9	10.1	13.3	16.6	18.7	3.15
115	63	25.5	18.9	22.2	25.4	26.1*	3.38
	67	27.4	14.2	17.5	20.7	22.9	3.42
	71	29.3	9.4	12.7	15.9	18.1	3.47

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH RXC037S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.7	25.1	27.9*	29.0*	29.6*	2.51
	63	29.7	20.7	24.0	27.2	29.4	2.53
	67	31.8	16.0	19.2	22.5	24.6	2.55
95	59	26.6	24.5	27.0*	28.0*	28.6*	2.77
	63	28.5	20.2	23.5	26.7	28.6*	2.79
	67	30.5	15.5	18.7	22.0	24.2	2.82
105	63	27.0	19.6	22.8	26.1	27.4*	3.09
	67	28.9	14.9	18.1	21.4	23.5	3.12
	71	30.9	10.1	13.3	16.6	18.7	3.15
115	63	25.5	18.9	22.2	25.4	26.1*	3.38
	67	27.4	14.2	17.5	20.7	22.9	3.42
	71	29.3	9.4	12.7	15.9	18.1	3.47

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TDD060R9V3+TXH025A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.6	22.7	25.3	26.4*	27.1*	2.30
	63	27.5	19.3	21.9	24.5	26.2	2.32
	67	29.5	15.4	18.0	20.6	22.4	2.34
95	59	25.1	22.4	25.0	26.0*	26.6*	2.56
	63	27.0	19.0	21.6	24.2	26.0	2.59
	67	29.0	15.2	17.8	20.4	22.1	2.61
105	63	25.4	18.3	20.9	23.5	25.3	2.86
	67	27.4	14.5	17.1	19.7	21.4	2.89
	71	29.3	10.6	13.2	15.8	17.5	2.92
115	63	23.9	17.6	20.2	22.8	24.1*	3.13
	67	25.7	13.8	16.4	19.0	20.7	3.17
	71	27.6	9.9	12.5	15.1	16.9	3.21

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TDD060R9V3+TXH033A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.3	24.3	27.2	28.2*	28.9*	2.35
	63	29.2	20.5	23.4	26.2	28.2	2.37
	67	31.3	16.2	19.1	22.0	23.9	2.39
95	59	26.6	24.0	26.7*	27.7*	28.3*	2.62
	63	28.6	20.2	23.1	26.0	27.9	2.65
	67	30.6	15.9	18.8	21.7	23.7	2.67
105	63	26.8	19.4	22.3	25.2	26.9*	2.92
	67	28.8	15.2	18.1	21.0	22.9	2.95
	71	30.8	10.9	13.8	16.7	18.6	2.98
115	63	25.1	18.6	21.5	24.4	25.5*	3.19
	67	26.9	14.4	17.3	20.2	22.1	3.23
	71	28.9	10.1	13.0	15.9	17.9	3.27

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TDD060R9V3+TXH041A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.8	24.7	27.7	28.8*	29.4*	2.34
	63	29.8	20.8	23.7	26.7	28.7	2.36
	67	31.8	16.4	19.4	22.4	24.4	2.38
95	59	27.2	24.4	27.3*	28.3*	28.9*	2.62
	63	29.1	20.5	23.5	26.5	28.4	2.64
	67	31.2	16.1	19.1	22.1	24.1	2.67
105	63	27.5	19.7	22.7	25.7	27.5*	2.91
	67	29.4	15.4	18.4	21.4	23.4	2.94
	71	31.5	11.0	14.0	17.0	19.0	2.98
115	63	25.8	19.0	22.0	25.0	26.1*	3.19
	67	27.7	14.7	17.7	20.7	22.7	3.22
	71	29.6	10.3	13.3	16.3	18.3	3.26

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TDD060R9V3+RXC025S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.6	22.3	24.8	26.2*	26.9*	2.32
	63	27.5	18.9	21.5	24.1	25.8	2.34
	67	29.6	15.2	17.7	20.3	22.0	2.36
95	59	24.6	21.8	24.3	25.4*	26.0*	2.58
	63	26.4	18.4	21.0	23.6	25.3	2.60
	67	28.4	14.7	17.2	19.8	21.5	2.63
105	63	25.2	17.9	20.4	23.0	24.7	2.90
	67	27.1	14.1	16.7	19.2	20.9	2.93
	71	29.0	10.3	12.8	15.4	17.1	2.96
115	63	24.0	17.3	19.9	22.4	24.0*	3.19
	67	25.8	13.6	16.1	18.7	20.4	3.23
	71	27.7	9.7	12.3	14.9	16.6	3.27

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TDD060R9V3+RXC031S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.3	24.1	27.0	28.3*	28.9*	2.32
	63	29.3	20.2	23.1	26.1	28.0	2.34
	67	31.4	16.0	18.9	21.8	23.8	2.36
95	59	26.3	23.6	26.3*	27.4*	28.0*	2.59
	63	28.2	19.7	22.7	25.6	27.5	2.61
	67	30.2	15.5	18.4	21.3	23.3	2.64
105	63	26.8	19.1	22.0	25.0	26.8*	2.91
	67	28.7	14.9	17.8	20.7	22.7	2.94
	71	30.7	10.6	13.5	16.4	18.3	2.97
115	63	25.4	18.5	21.4	24.4	25.7*	3.20
	67	27.2	14.3	17.2	20.1	22.1	3.24
	71	29.2	10.0	12.9	15.8	17.8	3.28

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TDD060R9V3+RXC036S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.9	24.5	27.5	28.8*	29.5*	2.32
	63	29.9	20.5	23.5	26.5	28.5	2.34
	67	32.0	16.2	19.1	22.1	24.1	2.36
95	59	26.9	24.0	26.9*	27.9*	28.5*	2.58
	63	28.8	20.0	23.0	26.0	28.0	2.61
	67	30.8	15.7	18.7	21.6	23.6	2.63
105	63	27.3	19.4	22.4	25.3	27.3*	2.90
	67	29.2	15.0	18.0	21.0	23.0	2.93
	71	31.2	10.6	13.6	16.6	18.6	2.96
115	63	25.8	18.7	21.7	24.7	26.1*	3.20
	67	27.7	14.4	17.4	20.4	22.4	3.23
	71	29.6	10.0	13.0	16.0	18.0	3.27

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TDD080R9V3+TXH025A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.7	23.1	25.7*	26.7*	27.3*	2.30
	63	27.7	19.6	22.3	24.9	26.7	2.32
	67	29.7	15.7	18.4	21.0	22.8	2.34
95	59	25.3	22.9	25.3*	26.3*	26.9*	2.57
	63	27.2	19.4	22.1	24.7	26.5	2.59
	67	29.2	15.5	18.2	20.8	22.6	2.61
105	63	25.6	18.7	21.3	24.0	25.7*	2.86
	67	27.6	14.8	17.5	20.1	21.9	2.90
	71	29.6	10.9	13.5	16.2	17.9	2.93
115	63	24.1	18.0	20.6	23.3	24.4*	3.14
	67	25.9	14.1	16.8	19.4	21.2	3.18
	71	27.9	10.2	12.8	15.5	17.2	3.22

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TDD080R9V3+TXH033A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.2	24.5	27.3*	28.2*	28.9*	2.33
	63	29.1	20.6	23.5	26.5	28.4	2.35
	67	31.2	16.4	19.3	22.2	24.1	2.37
95	59	26.6	24.2	26.8*	27.8*	28.5*	2.61
	63	28.6	20.4	23.3	26.2	28.2	2.63
	67	30.6	16.1	19.0	22.0	23.9	2.66
105	63	26.9	19.6	22.5	25.4	27.0*	2.90
	67	28.8	15.3	18.3	21.2	23.1	2.94
	71	30.8	11.0	13.9	16.9	18.8	2.97
115	63	25.1	18.8	21.7	24.6	25.6*	3.17
	67	27.0	14.6	17.5	20.4	22.4	3.21
	71	28.9	10.3	13.2	16.1	18.1	3.25

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TDD080R9V3+TXH041A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.5	24.7	27.6*	28.6*	29.3*	2.32
	63	29.5	20.7	23.7	26.7	28.7	2.34
	67	31.5	16.4	19.4	22.4	24.4	2.36
95	59	27.0	24.5	27.2*	28.2*	28.8*	2.60
	63	29.0	20.5	23.5	26.5	28.5	2.62
	67	31.0	16.2	19.2	22.2	24.2	2.65
105	63	27.3	19.8	22.8	25.8	27.5*	2.90
	67	29.3	15.4	18.4	21.4	23.4	2.93
	71	31.3	11.0	14.0	17.0	19.0	2.96
115	63	25.6	19.0	22.0	25.0	26.1*	3.17
	67	27.5	14.7	17.7	20.7	22.7	3.20
	71	29.5	10.3	13.3	16.3	18.3	3.24

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TDD080R9V3+RXC025S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.4	21.2	23.5	25.6*	26.2*	2.28
	63	27.4	18.1	20.5	22.8	24.3	2.30
	67	29.4	14.7	17.1	19.4	20.9	2.32
95	59	24.4	20.7	23.0	24.8*	25.4*	2.54
	63	26.3	17.7	20.0	22.3	23.9	2.57
	67	28.3	14.3	16.6	18.9	20.5	2.59
105	63	25.1	17.1	19.4	21.7	23.3	2.86
	67	27.0	13.7	16.0	18.4	19.9	2.89
	71	28.9	10.2	12.6	14.9	16.4	2.93
115	63	23.9	16.5	18.9	21.2	22.7	3.15
	67	25.7	13.2	15.5	17.8	19.4	3.19
	71	27.5	9.7	12.0	14.3	15.9	3.24

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TDD080R9V3+RXC031S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.9	22.7	25.3	27.3*	28.0*	2.28
	63	28.9	19.2	21.9	24.5	26.3	2.30
	67	30.9	15.4	18.0	20.7	22.4	2.32
95	59	25.9	22.2	24.9	26.5*	27.1*	2.54
	63	27.8	18.8	21.4	24.0	25.8	2.57
	67	29.8	14.9	17.6	20.2	22.0	2.59
105	63	26.5	18.2	20.8	23.4	25.2	2.86
	67	28.4	14.3	17.0	19.6	21.4	2.89
	71	30.3	10.4	13.1	15.7	17.5	2.93
115	63	25.1	17.6	20.2	22.8	24.6	3.16
	67	26.9	13.8	16.4	19.0	20.8	3.20
	71	28.8	9.9	12.5	15.1	16.9	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TDD080R9V3+RXC036S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.5	23.1	25.8	27.9*	28.5*	2.27
	63	29.5	19.5	22.2	24.9	26.7	2.29
	67	31.6	15.6	18.3	21.0	22.8	2.31
95	59	26.5	22.6	25.3	27.0*	27.7*	2.53
	63	28.4	19.0	21.7	24.4	26.2	2.55
	67	30.4	15.1	17.8	20.5	22.3	2.58
105	63	27.0	18.4	21.1	23.8	25.6	2.85
	67	28.9	14.5	17.2	19.9	21.7	2.88
	71	30.8	10.5	13.2	15.9	17.7	2.91
115	63	25.5	17.8	20.5	23.2	25.0	3.15
	67	27.3	13.9	16.6	19.3	21.1	3.18
	71	29.2	9.9	12.6	15.3	17.1	3.21

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TDY060R9V3+TXH025A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.3	21.8	24.2	25.8*	26.4*	2.27
	63	27.2	18.7	21.1	23.5	25.1	2.29
	67	29.2	15.1	17.5	19.9	21.5	2.31
95	59	24.8	21.5	23.9	25.4*	26.0*	2.54
	63	26.7	18.4	20.8	23.2	24.8	2.56
	67	28.7	14.9	17.3	19.7	21.3	2.58
105	63	25.2	17.7	20.1	22.5	24.1	2.83
	67	27.1	14.2	16.6	19.0	20.6	2.86
	71	29.1	10.6	13.1	15.5	17.1	2.89
115	63	23.7	17.0	19.4	21.8	23.4	3.11
	67	25.5	13.5	15.9	18.3	19.9	3.14
	71	27.4	10.0	12.4	14.8	16.4	3.18

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TDY060R9V3+TXH033A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.8	23.1	25.7	27.3*	28.0*	2.30
	63	28.7	19.6	22.3	24.9	26.7	2.32
	67	30.8	15.8	18.4	21.0	22.8	2.34
95	59	26.2	22.8	25.4	26.9*	27.5*	2.57
	63	28.1	19.3	22.0	24.6	26.4	2.59
	67	30.2	15.5	18.2	20.8	22.6	2.62
105	63	26.4	18.6	21.2	23.8	25.6	2.86
	67	28.4	14.7	17.4	20.0	21.8	2.89
	71	30.4	10.8	13.5	16.1	17.9	2.93
115	63	24.7	17.8	20.4	23.1	24.8*	3.13
	67	26.6	14.0	16.6	19.3	21.0	3.17
	71	28.5	10.1	12.7	15.4	17.1	3.21

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.

Performance Data

Cooling

4TTR2030A1 WITH TDY060R9V3+TXH041A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.1	23.3	26.1	27.7*	28.4*	2.30
	63	29.1	19.8	22.5	25.2	27.0	2.32
	67	31.1	15.8	18.5	21.2	23.1	2.34
95	59	26.6	23.1	25.8	27.3*	28.0*	2.57
	63	28.6	19.5	22.3	25.0	26.8	2.60
	67	30.6	15.6	18.3	21.0	22.8	2.62
105	63	26.9	18.8	21.5	24.2	26.0	2.87
	67	28.9	14.9	17.6	20.3	22.1	2.90
	71	30.9	10.9	13.6	16.3	18.1	2.93
115	63	25.3	18.1	20.8	23.5	25.3*	3.14
	67	27.1	14.2	16.9	19.6	21.4	3.18
	71	29.1	10.2	12.9	15.6	17.4	3.22

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TDY060R9V3+RXC025S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.3	21.4	23.8	25.6*	26.2*	2.28
	63	27.2	18.4	20.7	23.1	24.6	2.30
	67	29.3	14.9	17.3	19.6	21.2	2.32
95	59	24.3	20.9	23.3	24.8*	25.4*	2.54
	63	26.2	17.8	20.2	22.6	24.1	2.56
	67	28.1	14.4	16.8	19.1	20.7	2.59
105	63	25.0	17.3	19.7	22.0	23.6	2.86
	67	26.8	13.9	16.2	18.6	20.1	2.89
	71	28.8	10.3	12.7	15.1	16.6	2.92
115	63	23.8	16.7	19.1	21.5	23.0	3.15
	67	25.6	13.3	15.7	18.0	19.6	3.19
	71	27.4	9.8	12.2	14.5	16.1	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TDY060R9V3+RXC031S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.0	23.0	25.6	27.5*	28.1*	2.28
	63	29.0	19.5	22.1	24.8	26.6	2.30
	67	31.0	15.6	18.3	20.9	22.7	2.32
95	59	26.0	22.5	25.1	26.6*	27.3*	2.55
	63	27.9	19.0	21.7	24.3	26.1	2.57
	67	29.9	15.1	17.8	20.5	22.2	2.59
105	63	26.5	18.4	21.0	23.7	25.5	2.87
	67	28.5	14.5	17.2	19.9	21.6	2.90
	71	30.5	10.6	13.3	15.9	17.7	2.93
115	63	25.2	17.8	20.4	23.1	24.9	3.16
	67	27.0	13.9	16.6	19.3	21.0	3.20
	71	28.9	10.0	12.7	15.3	17.1	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TDY060R9V3+RXC036S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.4	23.2	25.9	27.9*	28.5*	2.27
	63	29.4	19.6	22.3	25.0	26.8	2.29
	67	31.5	15.7	18.4	21.1	22.9	2.31
95	59	26.4	22.7	25.4	27.0*	27.7*	2.54
	63	28.3	19.1	21.8	24.5	26.4	2.56
	67	30.3	15.2	17.9	20.6	22.4	2.59
105	63	26.9	18.5	21.2	23.9	25.7	2.86
	67	28.8	14.6	17.3	20.0	21.8	2.89
	71	30.8	10.6	13.3	16.0	17.8	2.92
115	63	25.5	17.9	20.6	23.3	25.1	3.15
	67	27.3	14.0	16.7	19.4	21.2	3.19
	71	29.2	10.0	12.7	15.4	17.2	3.22

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TDY080R9V3+TXH025A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.3	21.6	24.0	25.7*	26.3*	2.32
	63	27.2	18.5	20.9	23.3	24.9	2.34
	67	29.2	15.0	17.4	19.8	21.4	2.36
95	59	24.7	21.4	23.7	25.3*	25.9*	2.58
	63	26.7	18.3	20.6	23.0	24.6	2.60
	67	28.7	14.8	17.2	19.6	21.1	2.62
105	63	25.1	17.5	19.9	22.3	23.9	2.87
	67	27.0	14.1	16.5	18.8	20.4	2.91
	71	29.0	10.5	12.9	15.3	16.9	2.94
115	63	23.6	16.8	19.2	21.6	23.2	3.15
	67	25.4	13.4	15.8	18.1	19.7	3.19
	71	27.3	9.8	12.2	14.6	16.2	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TDY080R9V3+TXH033A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.7	22.9	25.6	27.2*	27.9*	2.34
	63	28.7	19.5	22.1	24.7	26.5	2.36
	67	30.7	15.6	18.3	20.9	22.6	2.38
95	59	26.1	22.6	25.3	26.7*	27.4*	2.61
	63	28.0	19.2	21.8	24.4	26.2	2.63
	67	30.1	15.3	18.0	20.6	22.4	2.66
105	63	26.3	18.4	21.0	23.7	25.4	2.90
	67	28.3	14.6	17.2	19.8	21.6	2.93
	71	30.3	10.7	13.3	16.0	17.7	2.97
115	63	24.6	17.6	20.3	22.9	24.6*	3.17
	67	26.5	13.8	16.5	19.1	20.8	3.21
	71	28.4	10.0	12.6	15.2	17.0	3.25

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TDY080R9V3+TXH041A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.1	23.2	25.9	27.7*	28.3*	2.33
	63	29.1	19.6	22.4	25.1	26.9	2.35
	67	31.1	15.7	18.4	21.1	22.9	2.37
95	59	26.5	22.9	25.6	27.2*	27.8*	2.60
	63	28.5	19.4	22.1	24.8	26.6	2.62
	67	30.5	15.4	18.1	20.9	22.7	2.65
105	63	26.8	18.6	21.3	24.0	25.8	2.89
	67	28.8	14.7	17.4	20.1	21.9	2.93
	71	30.8	10.7	13.4	16.1	17.9	2.96
115	63	25.2	17.9	20.6	23.3	25.1	3.17
	67	27.0	14.0	16.7	19.4	21.2	3.20
	71	29.0	10.0	12.7	15.4	17.2	3.24

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TDY080R9V3+RXC025S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.3	21.4	23.8	25.6*	26.2*	2.33
	63	27.2	18.3	20.7	23.0	24.6	2.35
	67	29.3	14.9	17.2	19.6	21.2	2.37
95	59	24.3	20.9	23.2	24.8*	25.4*	2.59
	63	26.1	17.8	20.2	22.5	24.1	2.61
	67	28.1	14.4	16.7	19.1	20.7	2.64
105	63	24.9	17.3	19.6	22.0	23.6	2.91
	67	26.8	13.8	16.2	18.5	20.1	2.94
	71	28.8	10.3	12.7	15.0	16.6	2.97
115	63	23.7	16.7	19.1	21.4	23.0	3.20
	67	25.6	13.3	15.6	18.0	19.6	3.24
	71	27.4	9.7	12.1	14.5	16.1	3.29

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TDY080R9V3+RXC031S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.8	22.8	25.5	27.3*	27.9*	2.30
	63	28.8	19.3	22.0	24.6	26.4	2.32
	67	30.8	15.4	18.1	20.8	22.5	2.34
95	59	25.8	22.3	25.0	26.4*	27.1*	2.56
	63	27.7	18.8	21.5	24.1	25.9	2.59
	67	29.7	15.0	17.6	20.3	22.1	2.61
105	63	26.3	18.2	20.9	23.5	25.3	2.88
	67	28.2	14.4	17.0	19.7	21.5	2.91
	71	30.2	10.4	13.1	15.8	17.5	2.94
115	63	25.0	17.6	20.3	22.9	24.7	3.17
	67	26.8	13.8	16.4	19.1	20.9	3.21
	71	28.7	9.9	12.5	15.2	17.0	3.25

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TDY080R9V3+RXC036S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.4	23.2	25.9	27.9*	28.5*	2.30
	63	29.4	19.6	22.3	25.0	26.8	2.31
	67	31.5	15.6	18.4	21.1	22.9	2.34
95	59	26.4	22.7	25.4	27.0*	27.7*	2.56
	63	28.3	19.1	21.8	24.5	26.3	2.58
	67	30.3	15.2	17.9	20.6	22.4	2.61
105	63	26.9	18.5	21.2	23.9	25.7	2.88
	67	28.8	14.5	17.3	20.0	21.8	2.91
	71	30.8	10.5	13.2	16.0	17.8	2.94
115	63	25.4	17.8	20.6	23.3	25.1	3.17
	67	27.3	13.9	16.6	19.3	21.2	3.21
	71	29.2	9.9	12.6	15.4	17.2	3.24

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TUD060R9V3+TXH025A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.6	22.6	25.3	26.4*	27.0*	2.36
	63	27.5	19.2	21.8	24.5	26.2	2.38
	67	29.5	15.4	18.0	20.6	22.3	2.40
95	59	25.1	22.4	25.0	26.0*	26.6*	2.62
	63	27.0	19.0	21.6	24.2	25.9	2.65
	67	29.0	15.1	17.8	20.4	22.1	2.67
105	63	25.4	18.2	20.9	23.5	25.2	2.92
	67	27.4	14.4	17.0	19.7	21.4	2.95
	71	29.4	10.5	13.1	15.8	17.5	2.98
115	63	23.9	17.5	20.1	22.8	24.1*	3.19
	67	25.7	13.7	16.3	19.0	20.7	3.23
	71	27.6	9.8	12.5	15.1	16.8	3.27

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TUD060R9V3+TXH033A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.1	24.1	27.0	28.0*	28.7*	2.38
	63	29.0	20.3	23.2	26.1	28.0	2.40
	67	31.1	16.0	18.9	21.8	23.8	2.42
95	59	26.4	23.8	26.5*	27.5*	28.2*	2.65
	63	28.4	20.0	22.9	25.8	27.7	2.68
	67	30.4	15.8	18.7	21.5	23.5	2.70
105	63	26.6	19.2	22.1	25.0	26.7*	2.95
	67	28.6	15.0	17.9	20.8	22.7	2.98
	71	30.6	10.7	13.6	16.5	18.4	3.01
115	63	24.9	18.4	21.3	24.2	25.3*	3.21
	67	26.8	14.2	17.1	20.0	22.0	3.25
	71	28.7	10.0	12.9	15.8	17.7	3.29

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data

Cooling

4TTR2030A1 WITH TUD060R9V3+TXH041A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.6	24.5	27.5	28.6*	29.2*	2.37
	63	29.6	20.6	23.6	26.5	28.5	2.39
	67	31.6	16.2	19.2	22.2	24.2	2.41
95	59	27.0	24.2	27.1*	28.1*	28.7*	2.64
	63	29.0	20.3	23.3	26.3	28.3	2.67
	67	31.0	16.0	19.0	21.9	23.9	2.70
105	63	27.3	19.6	22.5	25.5	27.3*	2.94
	67	29.2	15.2	18.2	21.2	23.2	2.97
	71	31.3	10.8	13.8	16.8	18.8	3.01
115	63	25.6	18.8	21.8	24.8	26.0*	3.21
	67	27.5	14.5	17.5	20.5	22.5	3.25
	71	29.4	10.1	13.1	16.1	18.1	3.29

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TUD060R9V3+RXC025S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.4	22.1	24.6	26.1*	26.7*	2.37
	63	27.3	18.7	21.3	23.9	25.6	2.38
	67	29.3	15.0	17.5	20.1	21.8	2.40
95	59	24.4	21.6	24.2	25.2*	25.8*	2.62
	63	26.2	18.2	20.8	23.4	25.1	2.65
	67	28.2	14.5	17.0	19.6	21.3	2.67
105	63	25.0	17.7	20.2	22.8	24.5	2.94
	67	26.9	13.9	16.5	19.1	20.8	2.97
	71	28.8	10.1	12.7	15.2	16.9	3.00
115	63	23.8	17.1	19.7	22.3	23.9*	3.23
	67	25.6	13.4	15.9	18.5	20.2	3.27
	71	27.5	9.5	12.1	14.7	16.4	3.31

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TUD060R9V3+RXC031S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.5	25.3	27.8*	28.8*	29.5*	2.40
	63	29.5	21.1	24.3	27.5	29.5*	2.42
	67	31.5	16.4	19.6	22.8	24.9	2.44
95	59	26.4	24.8	26.9*	27.9*	28.6*	2.66
	63	28.4	20.6	23.8	27.0	28.6*	2.68
	67	30.4	15.9	19.1	22.3	24.4	2.71
105	63	26.9	19.9	23.1	26.3	27.4*	2.98
	67	28.9	15.3	18.5	21.7	23.8	3.01
	71	30.9	10.5	13.7	17.0	19.1	3.05
115	63	25.5	19.3	22.5	25.6*	26.2*	3.27
	67	27.3	14.7	17.9	21.1	23.2	3.31
	71	29.3	9.9	13.1	16.3	18.5	3.36

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TUD060R9V3+RXC036S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.9	24.3	27.3	28.7*	29.4*	2.35
	63	29.9	20.4	23.4	26.3	28.3	2.37
	67	31.9	16.0	19.0	22.0	24.0	2.39
95	59	26.8	23.8	26.8*	27.8*	28.4*	2.62
	63	28.7	19.9	22.9	25.8	27.8	2.64
	67	30.7	15.5	18.5	21.5	23.5	2.67
105	63	27.2	19.2	22.2	25.2	27.2	2.94
	67	29.2	14.9	17.9	20.9	22.9	2.97
	71	31.2	10.5	13.5	16.5	18.5	3.00
115	63	25.8	18.6	21.6	24.6	26.0*	3.24
	67	27.6	14.3	17.3	20.2	22.2	3.27
	71	29.5	9.9	12.9	15.9	17.8	3.31

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TUD080R9V3+TXH025A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.6	22.7	25.3	26.4*	27.1*	2.31
	63	27.5	19.2	21.9	24.5	26.2	2.33
	67	29.5	15.4	18.0	20.6	22.4	2.35
95	59	25.1	22.4	25.0	26.0*	26.6*	2.58
	63	27.0	19.0	21.6	24.2	26.0	2.60
	67	29.0	15.2	17.8	20.4	22.1	2.62
105	63	25.4	18.3	20.9	23.5	25.2	2.87
	67	27.4	14.5	17.1	19.7	21.4	2.90
	71	29.3	10.6	13.2	15.8	17.5	2.93
115	63	23.9	17.6	20.2	22.8	24.1*	3.14
	67	25.7	13.8	16.4	19.0	20.7	3.18
	71	27.6	9.9	12.5	15.1	16.9	3.22

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TUD080R9V3+TXH033A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.1	24.1	27.0	28.0*	28.7*	2.35
	63	29.0	20.3	23.2	26.1	28.0	2.36
	67	31.1	16.1	19.0	21.8	23.8	2.39
95	59	26.4	23.8	26.5*	27.5*	28.2*	2.62
	63	28.4	20.0	22.9	25.8	27.7	2.64
	67	30.4	15.8	18.7	21.6	23.5	2.67
105	63	26.6	19.2	22.1	25.0	26.7*	2.91
	67	28.6	15.0	17.9	20.8	22.7	2.94
	71	30.6	10.8	13.6	16.5	18.5	2.97
115	63	24.9	18.5	21.4	24.2	25.3*	3.18
	67	26.8	14.3	17.2	20.1	22.0	3.22
	71	28.7	10.0	12.9	15.8	17.7	3.26

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TUD080R9V3+TXH041A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.6	24.5	27.5	28.6*	29.2*	2.35
	63	29.6	20.6	23.6	26.6	28.5	2.37
	67	31.6	16.2	19.2	22.2	24.2	2.39
95	59	27.0	24.3	27.1*	28.1*	28.7*	2.62
	63	29.0	20.3	23.3	26.3	28.3	2.65
	67	31.0	16.0	19.0	22.0	23.9	2.67
105	63	27.3	19.6	22.6	25.5	27.4*	2.92
	67	29.2	15.3	18.3	21.2	23.2	2.95
	71	31.3	10.9	13.9	16.8	18.8	2.98
115	63	25.6	18.9	21.8	24.8	26.0*	3.19
	67	27.5	14.6	17.5	20.5	22.5	3.23
	71	29.4	10.2	13.2	16.1	18.1	3.27

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TUD080R9V3+RXC025S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.6	22.3	24.8	26.2*	26.9*	2.32
	63	27.5	18.9	21.5	24.1	25.8	2.34
	67	29.5	15.2	17.7	20.3	22.0	2.36
95	59	24.6	21.8	24.3	25.4*	26.0*	2.58
	63	26.4	18.4	21.0	23.6	25.3	2.60
	67	28.4	14.7	17.2	19.8	21.5	2.63
105	63	25.2	17.9	20.4	23.0	24.7	2.90
	67	27.1	14.1	16.7	19.2	21.0	2.93
	71	29.0	10.3	12.8	15.4	17.1	2.96
115	63	24.0	17.3	19.9	22.4	24.0*	3.19
	67	25.8	13.6	16.1	18.7	20.4	3.23
	71	27.7	9.7	12.3	14.9	16.6	3.27

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TUD080R9V3+RXC031S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.3	24.1	27.0	28.3*	28.9*	2.33
	63	29.3	20.2	23.1	26.1	28.0	2.35
	67	31.4	16.0	18.9	21.8	23.8	2.37
95	59	26.3	23.6	26.3*	27.4*	28.0*	2.60
	63	28.2	19.7	22.7	25.6	27.5	2.62
	67	30.2	15.5	18.4	21.3	23.3	2.65
105	63	26.8	19.1	22.0	25.0	26.8*	2.92
	67	28.7	14.9	17.8	20.7	22.7	2.95
	71	30.7	10.6	13.5	16.4	18.3	2.98
115	63	25.4	18.5	21.4	24.3	25.7*	3.22
	67	27.2	14.3	17.2	20.1	22.1	3.25
	71	29.2	10.0	12.9	15.8	17.8	3.29

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TUD080R9V3+RXC036S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.9	24.5	27.5	28.8*	29.5*	2.31
	63	29.9	20.5	23.5	26.5	28.5	2.33
	67	32.0	16.2	19.1	22.1	24.1	2.35
95	59	26.9	24.0	26.9*	27.9*	28.5*	2.57
	63	28.8	20.0	23.0	26.0	28.0	2.60
	67	30.8	15.7	18.7	21.6	23.6	2.62
105	63	27.3	19.4	22.4	25.3	27.3*	2.89
	67	29.2	15.0	18.0	21.0	23.0	2.92
	71	31.2	10.6	13.6	16.6	18.6	2.95
115	63	25.8	18.7	21.7	24.7	26.1*	3.19
	67	27.7	14.4	17.4	20.4	22.4	3.22
	71	29.6	10.0	13.0	16.0	18.0	3.25

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TUY060R9V3+TXH025A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.3	21.7	24.1	25.7*	26.3*	2.29
	63	27.2	18.6	21.0	23.3	24.9	2.31
	67	29.2	15.1	17.4	19.8	21.4	2.33
95	59	24.8	21.4	23.8	25.3*	25.9*	2.55
	63	26.7	18.3	20.7	23.1	24.7	2.58
	67	28.7	14.8	17.2	19.6	21.2	2.60
105	63	25.2	17.6	20.0	22.4	24.0	2.85
	67	27.1	14.1	16.5	18.9	20.5	2.88
	71	29.1	10.6	13.0	15.4	17.0	2.92
115	63	23.6	16.9	19.3	21.7	23.3	3.13
	67	25.5	13.4	15.8	18.2	19.8	3.16
	71	27.4	9.9	12.3	14.7	16.3	3.20

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TUY060R9V3+TXH033A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.7	23.0	25.6	27.3*	28.0*	2.32
	63	28.7	19.5	22.2	24.8	26.6	2.34
	67	30.7	15.7	18.3	21.0	22.7	2.36
95	59	26.1	22.7	25.4	26.8*	27.5*	2.59
	63	28.1	19.3	21.9	24.5	26.3	2.61
	67	30.1	15.4	18.1	20.7	22.5	2.64
105	63	26.4	18.5	21.1	23.8	25.5	2.88
	67	28.3	14.7	17.3	19.9	21.7	2.91
	71	30.3	10.8	13.4	16.0	17.8	2.95
115	63	24.7	17.7	20.3	23.0	24.7*	3.15
	67	26.5	13.9	16.5	19.2	20.9	3.19
	71	28.4	10.0	12.7	15.3	17.1	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TUY060R9V3+TXH041A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.1	23.3	26.0	27.7*	28.3*	2.31
	63	29.1	19.7	22.4	25.2	27.0	2.33
	67	31.1	15.8	18.5	21.2	23.0	2.35
95	59	26.6	23.1	25.8	27.2*	27.9*	2.58
	63	28.5	19.5	22.2	24.9	26.7	2.60
	67	30.6	15.6	18.3	21.0	22.8	2.63
105	63	26.9	18.7	21.5	24.2	26.0	2.88
	67	28.8	14.8	17.5	20.3	22.1	2.91
	71	30.9	10.8	13.5	16.3	18.1	2.94
115	63	25.2	18.0	20.7	23.4	25.2*	3.15
	67	27.1	14.1	16.8	19.5	21.3	3.19
	71	29.0	10.1	12.8	15.6	17.4	3.22

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TUY060R9V3+RXC025S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.3	21.4	23.8	25.6*	26.2*	2.30
	63	27.2	18.3	20.7	23.1	24.6	2.32
	67	29.3	14.9	17.2	19.6	21.2	2.34
95	59	24.3	20.9	23.2	24.8*	25.4*	2.56
	63	26.1	17.8	20.2	22.5	24.1	2.59
	67	28.1	14.4	16.7	19.1	20.7	2.61
105	63	25.0	17.3	19.6	22.0	23.6	2.88
	67	26.8	13.8	16.2	18.6	20.1	2.91
	71	28.8	10.3	12.7	15.0	16.6	2.94
115	63	23.8	16.7	19.1	21.4	23.0	3.17
	67	25.6	13.3	15.6	18.0	19.6	3.21
	71	27.4	9.8	12.1	14.5	16.1	3.25

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TUY060R9V3+RXC031S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.8	22.8	25.5	27.3*	27.9*	2.29
	63	28.8	19.3	22.0	24.6	26.4	2.31
	67	30.8	15.4	18.1	20.8	22.5	2.33
95	59	25.8	22.3	25.0	26.4*	27.1*	2.55
	63	27.7	18.8	21.5	24.1	25.9	2.58
	67	29.7	15.0	17.6	20.3	22.1	2.60
105	63	26.3	18.2	20.9	23.5	25.3	2.87
	67	28.2	14.4	17.0	19.7	21.5	2.90
	71	30.2	10.5	13.1	15.8	17.5	2.93
115	63	25.0	17.6	20.3	23.0	24.7	3.16
	67	26.8	13.8	16.5	19.1	20.9	3.20
	71	28.7	9.9	12.5	15.2	17.0	3.24

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TUY060R9V3+RXC036S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.4	23.2	25.9	27.9*	28.5*	2.28
	63	29.4	19.6	22.3	25.0	26.8	2.30
	67	31.5	15.7	18.4	21.1	22.9	2.32
95	59	26.4	22.7	25.4	27.0*	27.7*	2.55
	63	28.3	19.1	21.8	24.5	26.3	2.57
	67	30.3	15.2	17.9	20.6	22.4	2.60
105	63	26.9	18.5	21.2	23.9	25.7	2.87
	67	28.8	14.5	17.3	20.0	21.8	2.90
	71	30.8	10.5	13.3	16.0	17.8	2.93
115	63	25.4	17.8	20.6	23.3	25.1	3.16
	67	27.3	13.9	16.6	19.4	21.2	3.20
	71	29.2	9.9	12.7	15.4	17.2	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TUY080R9V3+TXH025A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.4	21.9	24.4	25.9*	26.5*	2.27
	63	27.3	18.8	21.2	23.6	25.2	2.29
	67	29.3	15.3	17.7	20.1	21.7	2.31
95	59	24.9	21.7	24.1	25.5*	26.1*	2.53
	63	26.8	18.6	21.0	23.4	25.0	2.55
	67	28.8	15.1	17.5	19.9	21.5	2.58
105	63	25.3	17.9	20.3	22.7	24.3	2.83
	67	27.2	14.4	16.8	19.2	20.8	2.86
	71	29.2	10.8	13.2	15.6	17.2	2.89
115	63	23.7	17.1	19.6	22.0	23.6	3.10
	67	25.6	13.7	16.1	18.5	20.1	3.14
	71	27.5	10.1	12.5	14.9	16.5	3.18

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TUY080R9V3+TXH033A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.6	23.0	25.7	27.2*	27.9*	2.28
	63	28.6	19.6	22.2	24.9	26.6	2.29
	67	30.6	15.7	18.4	21.0	22.8	2.31
95	59	26.1	22.8	25.4	26.8*	27.5*	2.55
	63	28.0	19.3	22.0	24.6	26.4	2.57
	67	30.1	15.5	18.1	20.8	22.5	2.60
105	63	26.3	18.5	21.2	23.8	25.6	2.84
	67	28.3	14.7	17.4	20.0	21.8	2.87
	71	30.3	10.8	13.5	16.1	17.9	2.90
115	63	24.6	17.8	20.4	23.1	24.7*	3.11
	67	26.5	14.0	16.6	19.3	21.0	3.14
	71	28.4	10.1	12.7	15.4	17.1	3.18

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TUY080R9V3+TXH041A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.2	23.5	26.2	27.8*	28.5*	2.29
	63	29.1	19.9	22.6	25.4	27.2	2.31
	67	31.2	15.9	18.7	21.4	23.2	2.33
95	59	26.7	23.3	26.0	27.4*	28.1*	2.57
	63	28.6	19.7	22.4	25.1	27.0	2.59
	67	30.7	15.7	18.5	21.2	23.0	2.62
105	63	27.0	18.9	21.7	24.4	26.2	2.86
	67	28.9	15.0	17.7	20.5	22.3	2.89
	71	31.0	11.0	13.7	16.4	18.3	2.92
115	63	25.3	18.2	20.9	23.6	25.4*	3.14
	67	27.2	14.3	17.0	19.7	21.5	3.17
	71	29.1	10.3	13.0	15.7	17.6	3.21

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TUY080R9V3+RXC025S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.5	21.6	24.0	25.8*	26.4*	2.27
	63	27.4	18.5	20.9	23.2	24.8	2.29
	67	29.5	15.1	17.4	19.8	21.4	2.31
95	59	24.5	21.1	23.4	25.0*	25.6*	2.53
	63	26.3	18.0	20.4	22.7	24.3	2.56
	67	28.3	14.6	16.9	19.3	20.9	2.58
105	63	25.1	17.5	19.8	22.2	23.8	2.85
	67	27.0	14.0	16.4	18.7	20.3	2.88
	71	29.0	10.5	12.8	15.2	16.8	2.92
115	63	23.9	16.9	19.3	21.6	23.2	3.14
	67	25.8	13.5	15.8	18.2	19.8	3.18
	71	27.6	9.9	12.3	14.7	16.2	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TUY080R9V3+RXC031S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.9	22.9	25.6	27.4*	28.0*	2.27
	63	28.8	19.4	22.1	24.7	26.5	2.29
	67	30.9	15.5	18.2	20.9	22.7	2.31
95	59	25.9	22.4	25.1	26.5*	27.2*	2.53
	63	27.8	19.0	21.6	24.3	26.1	2.56
	67	29.8	15.1	17.8	20.4	22.2	2.58
105	63	26.4	18.3	21.0	23.7	25.4	2.85
	67	28.3	14.5	17.1	19.8	21.6	2.88
	71	30.3	10.6	13.2	15.9	17.7	2.91
115	63	25.0	17.7	20.4	23.1	24.8	3.14
	67	26.9	13.9	16.6	19.2	21.0	3.18
	71	28.8	10.0	12.6	15.3	17.1	3.22

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TUY080R9V3+RXC036S3 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.5	23.3	26.0	27.9*	28.6*	2.28
	63	29.5	19.7	22.4	25.1	26.9	2.30
	67	31.6	15.8	18.5	21.2	23.0	2.32
95	59	26.5	22.8	25.5	27.1*	27.7*	2.54
	63	28.4	19.2	21.9	24.6	26.5	2.57
	67	30.4	15.3	18.0	20.7	22.5	2.59
105	63	27.0	18.6	21.3	24.0	25.8	2.86
	67	28.9	14.6	17.4	20.1	21.9	2.89
	71	30.9	10.6	13.4	16.1	17.9	2.92
115	63	25.5	17.9	20.7	23.4	25.2	3.16
	67	27.4	14.0	16.7	19.5	21.3	3.19
	71	29.3	10.0	12.7	15.5	17.3	3.23

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TVF024A14 AT 800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.3	21.1	23.6	25.6*	26.2*	2.40
	63	27.3	17.9	20.4	22.8	24.4	2.42
	67	29.3	14.4	16.9	19.3	20.9	2.44
95	59	24.8	20.9	23.3	25.2*	25.8*	2.66
	63	26.8	17.7	20.1	22.6	24.2	2.69
	67	28.8	14.2	16.7	19.1	20.7	2.71
105	63	25.1	17.0	19.4	21.8	23.5	2.96
	67	27.1	13.5	15.9	18.4	20.0	2.99
	71	29.1	9.9	12.4	14.8	16.4	3.02
115	63	23.5	16.3	18.7	21.1	22.7	3.23
	67	25.4	12.8	15.2	17.7	19.3	3.27
	71	27.2	9.2	11.7	14.1	15.7	3.31

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	700	900	AIRFLOW	700	900
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TVF025A14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.9	22.3	25.0	26.5*	27.2*	2.45
	63	27.8	18.8	21.5	24.2	26.0	2.47
	67	29.8	14.9	17.6	20.3	22.1	2.49
95	59	25.2	22.1	24.8	26.0*	26.7*	2.72
	63	27.2	18.5	21.2	23.9	25.7	2.74
	67	29.2	14.6	17.3	20.0	21.8	2.77
105	63	25.6	17.8	20.5	23.2	25.0	3.02
	67	27.5	13.9	16.6	19.3	21.1	3.05
	71	29.5	9.9	12.6	15.3	17.1	3.08
115	63	23.9	17.1	19.8	22.5	24.1*	3.29
	67	25.8	13.2	15.9	18.6	20.4	3.32
	71	27.7	9.3	12.0	14.7	16.5	3.36

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TVF030A14 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.9	24.0	26.9*	27.9*	28.6*	2.49
	63	28.8	20.0	23.0	26.0	28.0	2.51
	67	30.9	15.6	18.6	21.6	23.6	2.53
95	59	26.2	23.7	26.4*	27.4*	28.0*	2.76
	63	28.2	19.7	22.7	25.7	27.7	2.78
	67	30.2	15.3	18.3	21.3	23.4	2.81
105	63	26.5	19.0	22.0	25.0	26.6*	3.06
	67	28.4	14.6	17.6	20.6	22.6	3.09
	71	30.4	10.1	13.2	16.2	18.2	3.12
115	63	24.8	18.2	21.2	24.3	25.2*	3.33
	67	26.7	13.9	16.9	19.9	21.9	3.36
	71	28.6	9.4	12.5	15.5	17.5	3.40

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TVF036A14 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.4	25.3	27.8*	28.8*	29.5*	2.59
	63	29.4	20.8	24.2	27.5	29.5*	2.61
	67	31.4	16.0	19.3	22.6	24.9	2.63
95	59	26.7	25.0	27.2*	28.3*	28.9*	2.87
	63	28.7	20.5	23.9	27.2	28.9*	2.89
	67	30.7	15.7	19.0	22.4	24.6	2.92
105	63	27.0	19.8	23.1	26.5	27.5*	3.16
	67	28.9	15.0	18.3	21.6	23.9	3.20
	71	31.0	10.0	13.4	16.7	19.0	3.23
115	63	25.3	19.1	22.4	25.4*	26.0*	3.43
	67	27.1	14.3	17.6	20.9	23.2	3.47
	71	29.1	9.4	12.7	16.0	18.3	3.51

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2030A1 WITH TWE024C14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	24.4	20.6	22.9	24.7*	25.3*	2.38
	63	26.3	17.5	19.9	22.2	23.8	2.40
	67	28.3	14.1	16.5	18.8	20.3	2.42
95	59	23.9	20.3	22.6	24.3*	24.9*	2.64
	63	25.8	17.3	19.6	22.0	23.5	2.66
	67	27.8	13.9	16.2	18.6	20.1	2.68
105	63	24.3	16.6	18.9	21.3	22.8	2.94
	67	26.2	13.2	15.6	17.9	19.5	2.97
	71	28.2	9.8	12.1	14.4	16.0	3.00
115	63	22.8	15.9	18.3	20.6	22.1	3.21
	67	24.6	12.6	14.9	17.2	18.8	3.25
	71	26.5	9.1	11.5	13.8	15.3	3.28

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TWE030C14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.5	21.6	24.1	25.9*	26.6*	2.40
	63	27.4	18.3	20.8	23.4	25.0	2.42
	67	29.5	14.6	17.1	19.7	21.4	2.44
95	59	24.9	21.3	23.8	25.4*	26.1*	2.66
	63	26.8	18.0	20.5	23.1	24.8	2.69
	67	28.8	14.3	16.9	19.4	21.1	2.71
105	63	25.2	17.3	19.8	22.3	24.0	2.96
	67	27.1	13.6	16.2	18.7	20.4	2.99
	71	29.0	9.9	12.4	14.9	16.6	3.02
115	63	23.5	16.6	19.1	21.6	23.3	3.23
	67	25.3	12.9	15.4	18.0	19.7	3.27
	71	27.2	9.2	11.7	14.3	15.9	3.31

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TWE036C14 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.3	24.6	26.8*	27.8*	28.4*	2.52
	63	28.3	20.4	23.5	26.7	28.4*	2.54
	67	30.3	15.8	18.9	22.1	24.2	2.56
95	59	25.8	24.3	26.3*	27.3*	28.0*	2.79
	63	27.7	20.1	23.3	26.4	28.0*	2.82
	67	29.7	15.6	18.7	21.8	23.9	2.84
105	63	26.1	19.4	22.6	25.7	26.6*	3.09
	67	28.1	14.9	18.0	21.1	23.2	3.12
	71	30.1	10.2	13.4	16.5	18.6	3.15
115	63	24.5	18.7	21.9	24.7*	25.3*	3.36
	67	26.4	14.2	17.3	20.5	22.5	3.40
	71	28.3	9.6	12.7	15.8	17.9	3.44

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TWE042C14 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.0	24.9	27.3*	28.4*	29.0*	2.55
	63	28.9	20.6	23.8	27.0	29.0*	2.56
	67	31.0	16.0	19.2	22.3	24.5	2.59
95	59	26.3	24.6	26.8*	27.8*	28.5*	2.82
	63	28.3	20.4	23.5	26.7	28.5*	2.84
	67	30.3	15.7	18.9	22.1	24.2	2.87
105	63	26.6	19.6	22.8	26.0	27.1*	3.11
	67	28.6	15.0	18.2	21.4	23.5	3.15
	71	30.6	10.3	13.5	16.7	18.8	3.18
115	63	25.0	18.9	22.1	25.1*	25.7*	3.38
	67	26.9	14.3	17.5	20.7	22.8	3.42
	71	28.8	9.6	12.8	16.0	18.1	3.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TXA/TXC024C4/D4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	24.6	21.0	23.4	25.1*	25.7*	2.41
	63	26.6	17.9	20.3	22.7	24.2	2.43
	67	28.6	14.5	16.8	19.2	20.8	2.45
95	59	24.1	20.7	23.1	24.6*	25.2*	2.67
	63	26.0	17.7	20.0	22.4	24.0	2.69
	67	28.0	14.2	16.6	18.9	20.5	2.72
105	63	24.5	17.0	19.3	21.7	23.3	2.97
	67	26.4	13.5	15.9	18.3	19.8	3.00
	71	28.4	10.0	12.4	14.7	16.3	3.03
115	63	23.0	16.3	18.6	21.0	22.6	3.24
	67	24.8	12.8	15.2	17.6	19.2	3.28
	71	26.7	9.3	11.7	14.1	15.6	3.32

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TXA/TXC025C4/D4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	25.4	21.7	24.2	25.9*	26.6*	2.44
	63	27.3	18.3	20.9	23.4	25.1	2.46
	67	29.4	14.6	17.2	19.7	21.4	2.48
95	59	24.9	21.4	23.9	25.5*	26.1*	2.71
	63	26.8	18.1	20.6	23.2	24.9	2.73
	67	28.8	14.4	16.9	19.5	21.2	2.76
105	63	25.1	17.3	19.9	22.4	24.1	3.00
	67	27.1	13.7	16.2	18.8	20.5	3.03
	71	29.1	9.9	12.5	15.0	16.7	3.07
115	63	23.5	16.6	19.1	21.7	23.4	3.27
	67	25.3	12.9	15.5	18.0	19.7	3.31
	71	27.2	9.2	11.8	14.3	16.0	3.35

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TXA/TXC030C4/D4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.0	22.8	25.5	26.8*	27.5*	2.49
	63	28.0	19.3	22.0	24.7	26.5	2.51
	67	30.0	15.3	18.0	20.7	22.5	2.53
95	59	25.4	22.5	25.2	26.3*	27.0*	2.76
	63	27.4	19.0	21.7	24.4	26.2	2.79
	67	29.4	15.0	17.7	20.4	22.2	2.81
105	63	25.7	18.2	20.9	23.6	25.4	3.06
	67	27.7	14.3	17.0	19.7	21.5	3.09
	71	29.7	10.3	13.0	15.7	17.5	3.12
115	63	24.1	17.5	20.2	22.9	24.3*	3.33
	67	25.9	13.5	16.2	18.9	20.7	3.37
	71	27.9	9.5	12.2	14.9	16.7	3.41

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2030A1 WITH TXA/TXC031C4/D4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.3	23.1	25.9	27.1*	27.8*	2.49
	63	28.2	19.3	22.2	25.0	26.9	2.51
	67	30.3	15.1	18.0	20.8	22.7	2.53
95	59	25.6	22.7	25.6	26.6*	27.3*	2.76
	63	27.6	19.0	21.9	24.7	26.6	2.78
	67	29.6	14.9	17.7	20.6	22.5	2.81
105	63	25.9	18.3	21.1	24.0	25.9	3.05
	67	27.9	14.2	17.0	19.8	21.7	3.08
	71	29.9	9.9	12.8	15.6	17.5	3.11
115	63	24.3	17.6	20.4	23.2	24.5*	3.32
	67	26.1	13.4	16.3	19.1	21.0	3.36
	71	28.0	9.3	12.1	15.0	16.9	3.40

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TXA/TXC035C4/D4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.2	23.8	26.4*	27.4*	28.0*	2.53
	63	28.2	19.9	22.9	25.8	27.7	2.55
	67	30.2	15.6	18.5	21.5	23.4	2.57
95	59	25.6	23.5	25.9*	26.9*	27.5*	2.80
	63	27.6	19.7	22.6	25.5	27.5	2.82
	67	29.6	15.3	18.3	21.2	23.2	2.85
105	63	25.9	18.9	21.8	24.8	26.2*	3.09
	67	27.9	14.6	17.5	20.5	22.4	3.12
	71	29.9	10.2	13.2	16.1	18.1	3.16
115	63	24.3	18.2	21.1	24.0	24.8*	3.36
	67	26.1	13.9	16.8	19.8	21.7	3.40
	71	28.1	9.5	12.5	15.4	17.3	3.44

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TXA/TXC036C4/D4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.8	24.4	27.0*	28.0*	28.7*	2.54
	63	28.7	20.2	23.3	26.5	28.6	2.56
	67	30.8	15.6	18.7	21.9	24.0	2.58
95	59	26.2	24.1	26.5*	27.5*	28.2*	2.81
	63	28.1	19.9	23.1	26.2	28.2*	2.84
	67	30.1	15.3	18.5	21.6	23.7	2.86
105	63	26.5	19.2	22.4	25.5	26.8*	3.11
	67	28.4	14.6	17.8	20.9	23.0	3.14
	71	30.4	10.0	13.1	16.3	18.4	3.17
115	63	24.8	18.5	21.7	24.8*	25.4*	3.38
	67	26.7	13.9	17.1	20.3	22.4	3.42
	71	28.6	9.3	12.5	15.6	17.7	3.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.

* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)

TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2030A1 WITH TXA/TXC037C4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.8	24.4	27.0*	28.0*	28.7*	2.54
	63	28.7	20.2	23.3	26.5	28.6	2.56
	67	30.8	15.6	18.7	21.9	24.0	2.58
95	59	26.2	24.1	26.5*	27.5*	28.2*	2.81
	63	28.1	19.9	23.1	26.2	28.2*	2.84
	67	30.1	15.3	18.5	21.6	23.7	2.86
105	63	26.5	19.2	22.4	25.5	26.8*	3.11
	67	28.4	14.6	17.8	20.9	23.0	3.14
	71	30.4	10.0	13.1	16.3	18.4	3.17
115	63	24.8	18.5	21.7	24.8*	25.4*	3.38
	67	26.7	13.9	17.1	20.3	22.4	3.42
	71	28.6	9.3	12.5	15.6	17.7	3.46

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TXA/TXC042C4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.2	24.7	27.4*	28.4*	29.1*	2.56
	63	29.1	20.4	23.6	26.8	29.0	2.58
	67	31.2	15.8	19.0	22.2	24.3	2.60
95	59	26.5	24.4	26.9*	27.9*	28.5*	2.84
	63	28.5	20.2	23.4	26.5	28.5*	2.86
	67	30.5	15.5	18.7	21.9	24.0	2.89
105	63	26.8	19.4	22.6	25.8	27.1*	3.13
	67	28.8	14.8	18.0	21.2	23.3	3.16
	71	30.8	10.1	13.3	16.5	18.6	3.20
115	63	25.1	18.7	21.9	25.1	25.7*	3.40
	67	27.0	14.1	17.3	20.5	22.6	3.44
	71	29.0	9.4	12.6	15.8	17.9	3.48

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TXA/TXC043C4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.2	24.7	27.4*	28.4*	29.1*	2.56
	63	29.1	20.4	23.6	26.8	29.0	2.58
	67	31.2	15.8	19.0	22.2	24.3	2.60
95	59	26.5	24.4	26.9*	27.9*	28.5*	2.84
	63	28.5	20.2	23.4	26.5	28.5*	2.86
	67	30.5	15.5	18.7	21.9	24.0	2.89
105	63	26.8	19.4	22.6	25.8	27.1*	3.13
	67	28.8	14.8	18.0	21.2	23.3	3.16
	71	30.8	10.1	13.3	16.5	18.6	3.20
115	63	25.1	18.7	21.9	25.1	25.7*	3.40
	67	27.0	14.1	17.3	20.5	22.6	3.44
	71	29.0	9.4	12.6	15.8	17.9	3.48

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2030A1 WITH TXH025A4 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	24.8	21.1	23.5	25.2*	25.8*	2.42
	63	26.7	18.0	20.4	22.8	24.4	2.44
	67	28.7	14.5	16.9	19.3	20.9	2.46
95	59	24.3	20.9	23.2	24.8*	25.4*	2.68
	63	26.2	17.8	20.2	22.5	24.1	2.70
	67	28.2	14.3	16.7	19.1	20.7	2.72
105	63	24.7	17.1	19.4	21.8	23.4	2.97
	67	26.6	13.6	16.0	18.4	20.0	3.00
	71	28.6	10.0	12.4	14.8	16.4	3.03
115	63	23.1	16.4	18.7	21.1	22.7	3.24
	67	25.0	12.9	15.3	17.7	19.3	3.28
	71	26.9	9.4	11.8	14.1	15.7	3.32

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TXH033A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	26.7	23.7	26.6	27.6*	28.3*	2.51
	63	28.6	19.9	22.8	25.7	27.6	2.53
	67	30.7	15.6	18.5	21.4	23.4	2.55
95	59	26.0	23.4	26.1*	27.1*	27.7*	2.78
	63	28.0	19.6	22.5	25.4	27.3	2.80
	67	30.0	15.4	18.3	21.1	23.1	2.83
105	63	26.2	18.8	21.7	24.6	26.3*	3.07
	67	28.2	14.6	17.5	20.4	22.3	3.11
	71	30.2	10.3	13.2	16.1	18.0	3.14
115	63	24.5	18.0	20.9	23.8	24.9*	3.34
	67	26.4	13.8	16.7	19.6	21.6	3.38
	71	28.3	9.6	12.5	15.4	17.3	3.42

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2030A1 WITH TXH041A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	27.6	25.3	27.9*	28.9*	29.6*	2.58
	63	29.6	21.0	24.2	27.5	29.6*	2.60
	67	31.6	16.2	19.5	22.7	24.9	2.62
95	59	26.9	25.0	27.3*	28.4*	29.0*	2.86
	63	28.9	20.7	23.9	27.2	29.0*	2.88
	67	30.9	15.9	19.2	22.4	24.6	2.91
105	63	27.2	19.9	23.2	26.4	27.6*	3.16
	67	29.2	15.2	18.4	21.7	23.9	3.19
	71	31.2	10.4	13.7	16.9	19.1	3.22
115	63	25.5	19.2	22.4	25.5*	26.1*	3.43
	67	27.4	14.5	17.7	21.0	23.1	3.47
	71	29.3	9.7	13.0	16.2	18.4	3.51

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH 4TEE3F31A AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.9	27.9	31.2	32.9*	33.7*	2.80
	63	34.4	23.5	26.9	30.2	32.4	2.82
	67	36.9	18.7	22.0	25.3	27.6	2.84
95	59	30.6	27.2	30.6*	31.7*	32.5*	3.10
	63	32.9	22.9	26.2	29.5	31.8	3.13
	67	35.3	18.0	21.3	24.7	26.9	3.15
105	63	31.2	22.1	25.4	28.8	31.0	3.49
	67	33.5	17.3	20.6	23.9	26.1	3.52
	71	35.9	12.3	15.6	19.0	21.2	3.56
115	63	29.5	21.4	24.7	28.0	29.8*	3.85
	67	31.7	16.5	19.8	23.2	25.4	3.89
	71	34.0	11.6	14.9	18.2	20.5	3.93

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2036A1 WITH 4TEE3F37A AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.3	29.1	32.5	34.1*	34.8*	2.69
	63	35.4	24.4	27.8	31.2	33.5	2.71
	67	37.5	19.2	22.7	26.1	28.4	2.73
95	59	31.9	28.4	31.8	32.9*	33.6*	3.00
	63	33.9	23.7	27.1	30.6	32.9	3.02
	67	35.9	18.6	22.0	25.4	27.7	3.04
105	63	32.2	23.0	26.4	29.8	32.1	3.39
	67	34.2	17.8	21.3	24.7	27.0	3.42
	71	36.2	12.6	16.0	19.5	21.8	3.44
115	63	30.6	22.2	25.7	29.1	30.8*	3.75
	67	32.4	17.1	20.5	24.0	26.3	3.79
	71	34.3	11.9	15.3	18.8	21.0	3.82

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH 4TEE3F40A AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	35.0	30.3	34.0	35.8*	36.5*	2.67
	63	37.0	25.2	28.9	32.6	35.1	2.69
	67	39.2	19.7	23.4	27.1	29.5	2.71
95	59	33.6	29.7	33.4	34.6*	35.2*	2.99
	63	35.5	24.6	28.3	32.0	34.4	3.01
	67	37.6	19.0	22.7	26.4	28.9	3.03
105	63	33.6	23.8	27.5	31.2	33.6*	3.37
	67	35.6	18.2	21.9	25.6	28.1	3.40
	71	37.6	12.6	16.3	20.0	22.5	3.43
115	63	31.7	22.9	26.7	30.4	32.0*	3.74
	67	33.6	17.4	21.1	24.8	27.3	3.77
	71	35.5	11.8	15.6	19.3	21.7	3.79

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH 4TEE3F49A AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	35.4	30.5	34.2	36.2*	36.9*	2.67
	63	37.5	25.3	29.1	32.8	35.3	2.69
	67	39.6	19.8	23.5	27.2	29.7	2.71
95	59	33.9	29.8	33.6	34.9*	35.6*	2.98
	63	35.9	24.7	28.4	32.2	34.7	3.00
	67	38.0	19.1	22.9	26.6	29.1	3.03
105	63	34.0	23.9	27.6	31.4	33.8	3.37
	67	36.0	18.3	22.1	25.8	28.3	3.40
	71	38.0	12.7	16.4	20.2	22.7	3.42
115	63	32.1	23.1	26.8	30.6	32.4*	3.74
	67	34.0	17.6	21.3	25.0	27.5	3.77
	71	35.9	11.9	15.7	19.4	21.9	3.80

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH 4TEP3F30A AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.3	24.6	27.1	29.7	31.4*	2.70
	63	33.4	21.1	23.6	26.2	27.9	2.72
	67	35.5	17.2	19.8	22.3	24.0	2.74
95	59	30.0	23.9	26.5	29.1	30.3*	3.00
	63	32.0	20.4	23.0	25.6	27.3	3.03
	67	34.0	16.6	19.1	21.7	23.4	3.05
105	63	30.4	19.7	22.3	24.8	26.6	3.39
	67	32.3	15.8	18.4	21.0	22.7	3.42
	71	34.3	11.9	14.5	17.0	18.8	3.45
115	63	28.8	19.0	21.6	24.1	25.8	3.75
	67	30.7	15.1	17.7	20.3	22.0	3.79
	71	32.5	11.2	13.8	16.3	18.1	3.83

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH 4TEP3F36A AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.6	28.0	31.4	33.2*	34.0*	2.86
	63	34.6	23.4	26.8	30.2	32.4	2.88
	67	36.8	18.3	21.7	25.1	27.3	2.90
95	59	31.2	27.4	30.8	32.1*	32.8*	3.16
	63	33.2	22.8	26.1	29.5	31.8	3.19
	67	35.2	17.7	21.1	24.4	26.7	3.21
105	63	31.5	22.0	25.4	28.8	31.1	3.55
	67	33.4	17.0	20.3	23.7	26.0	3.59
	71	35.5	11.8	15.2	18.6	20.8	3.62
115	63	29.8	21.3	24.7	28.1	30.0*	3.92
	67	31.7	16.2	19.6	23.0	25.3	3.96
	71	33.6	11.1	14.5	17.9	20.1	4.00

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH 4TEP3F42A AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.9	31.2	34.2*	35.4*	36.1*	2.94
	63	36.0	25.6	29.7	33.7	36.1*	2.96
	67	38.1	19.6	23.6	27.6	30.3	2.98
95	59	32.5	30.5	33.0*	34.1*	34.8*	3.25
	63	34.5	25.0	29.0	33.0	34.8*	3.27
	67	36.5	18.9	23.0	27.0	29.7	3.30
105	63	32.6	24.2	28.2	32.3	33.2*	3.64
	67	34.6	18.2	22.2	26.2	28.9	3.67
	71	36.6	12.0	16.1	20.1	22.8	3.70
115	63	30.8	23.4	27.4	31.0*	31.6*	4.00
	67	32.7	17.4	21.4	25.4	28.1	4.04
	71	34.6	11.3	15.3	19.3	22.0	4.08

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH 4TEP3F48A AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	34.5	31.7	35.0*	36.1*	36.8*	2.83
	63	36.6	25.9	30.2	34.4	36.8*	2.85
	67	38.8	19.5	23.8	28.1	30.9	2.87
95	59	33.2	31.1	33.8*	34.8*	35.5*	3.13
	63	35.1	25.3	29.5	33.8	35.5*	3.16
	67	37.1	18.9	23.2	27.5	30.3	3.18
105	63	33.2	24.5	28.8	33.0	33.8*	3.51
	67	35.1	18.1	22.4	26.7	29.5	3.54
	71	37.1	11.7	16.0	20.2	23.1	3.57
115	63	31.3	23.7	28.0	31.5*	32.1*	3.87
	67	33.1	17.4	21.6	25.9	28.8	3.90
	71	34.9	10.9	15.2	19.5	22.3	3.93

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.93	X1.06

4TTR2036A1 WITH RXC031S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.5	27.2	30.4	32.9*	33.6*	2.83
	63	34.6	22.9	26.0	29.2	31.3	2.85
	67	36.7	18.1	21.3	24.4	26.6	2.87
95	59	31.2	26.6	29.7	31.7*	32.4*	3.13
	63	33.1	22.2	25.4	28.6	30.7	3.16
	67	35.2	17.5	20.6	23.8	25.9	3.18
105	63	31.5	21.5	24.7	27.8	29.9	3.52
	67	33.4	16.7	19.9	23.1	25.2	3.55
	71	35.4	11.9	15.1	18.2	20.4	3.58
115	63	29.8	20.8	23.9	27.1	29.2	3.88
	67	31.7	16.0	19.2	22.4	24.5	3.92
	71	33.6	11.2	14.4	17.5	19.6	3.96

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH RXC036S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.5	28.8	32.4	34.2*	35.0*	2.86
	63	35.6	24.0	27.5	31.0	33.4	2.88
	67	37.7	18.7	22.2	25.8	28.1	2.90
95	59	32.2	28.2	31.7	33.1*	33.8*	3.17
	63	34.1	23.4	26.9	30.4	32.7	3.19
	67	36.2	18.1	21.6	25.1	27.5	3.22
105	63	32.3	22.6	26.1	29.6	32.0	3.56
	67	34.3	17.3	20.8	24.3	26.7	3.59
	71	36.3	12.0	15.5	19.0	21.3	3.62
115	63	30.5	21.8	25.3	28.8	30.7*	3.92
	67	32.4	16.6	20.1	23.6	25.9	3.95
	71	34.3	11.2	14.7	18.3	20.6	3.99

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH RXC037S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.5	28.8	32.4	34.2*	35.0*	2.86
	63	35.6	24.0	27.5	31.0	33.4	2.88
	67	37.7	18.7	22.2	25.8	28.1	2.90
95	59	32.2	28.2	31.7	33.1*	33.8*	3.17
	63	34.1	23.4	26.9	30.4	32.7	3.19
	67	36.2	18.1	21.6	25.1	27.5	3.22
105	63	32.3	22.6	26.1	29.6	32.0	3.56
	67	34.3	17.3	20.8	24.3	26.7	3.59
	71	36.3	12.0	15.5	19.0	21.3	3.62
115	63	30.5	21.8	25.3	28.8	30.7*	3.92
	67	32.4	16.6	20.1	23.6	25.9	3.95
	71	34.3	11.2	14.7	18.3	20.6	3.99

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH RXC054S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	34.1	30.9	34.3*	35.5*	36.2*	2.94
	63	36.2	25.3	29.4	33.4	36.1	2.96
	67	38.3	19.3	23.3	27.4	30.1	2.98
95	59	32.7	30.3	33.1*	34.2*	34.9*	3.25
	63	34.7	24.7	28.8	32.8	34.9*	3.28
	67	36.7	18.7	22.7	26.7	29.4	3.30
105	63	32.8	23.9	28.0	32.0	33.2*	3.64
	67	34.7	17.9	21.9	26.0	28.7	3.67
	71	36.8	11.8	15.8	19.8	22.5	3.70
115	63	30.9	23.1	27.2	31.0*	31.6*	4.00
	67	32.7	17.1	21.1	25.2	27.9	4.04
	71	34.6	11.0	15.0	19.1	21.8	4.08

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TDD060R9V3+TXH033A4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.6	28.7	32.1	33.4*	34.2*	2.79
	63	34.6	24.0	27.4	30.8	33.1	2.81
	67	36.7	18.9	22.3	25.7	28.0	2.83
95	59	31.9	28.3	31.7	32.9*	33.6*	3.11
	63	33.9	23.7	27.1	30.5	32.8	3.13
	67	36.0	18.6	22.0	25.4	27.7	3.16
105	63	31.8	22.8	26.2	29.6	31.8*	3.45
	67	33.8	17.7	21.1	24.5	26.7	3.49
	71	35.9	12.5	15.9	19.3	21.6	3.52
115	63	29.7	21.8	25.2	28.6	30.0*	3.78
	67	31.6	16.8	20.2	23.6	25.8	3.81
	71	33.6	11.6	15.0	18.4	20.7	3.85

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2036A1 WITH TDD060R9V3+TXH041A4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.5	29.4	32.9	34.4*	35.1*	2.80
	63	35.5	24.6	28.1	31.6	33.9	2.82
	67	37.6	19.3	22.8	26.3	28.6	2.84
95	59	32.8	29.1	32.6	33.8*	34.5*	3.12
	63	34.9	24.3	27.8	31.3	33.6	3.15
	67	37.0	19.0	22.5	26.0	28.4	3.18
105	63	32.9	23.4	26.9	30.4	32.7	3.48
	67	34.9	18.1	21.6	25.2	27.5	3.51
	71	37.0	12.8	16.3	19.8	22.2	3.54
115	63	30.8	22.5	26.0	29.5	31.1*	3.81
	67	32.8	17.3	20.8	24.3	26.6	3.85
	71	34.8	12.0	15.5	19.0	21.3	3.89

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TDD060R9V3+RXC031S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.2	28.7	32.1	33.9*	34.6*	2.80
	63	35.3	24.0	27.4	30.9	33.2	2.82
	67	37.4	18.8	22.3	25.7	28.0	2.84
95	59	31.8	28.0	31.5	32.7*	33.4*	3.10
	63	33.7	23.3	26.8	30.2	32.5	3.13
	67	35.8	18.2	21.6	25.1	27.3	3.15
105	63	32.1	22.6	26.0	29.5	31.7	3.49
	67	34.0	17.4	20.9	24.3	26.6	3.52
	71	36.0	12.2	15.7	19.1	21.4	3.56
115	63	30.4	21.9	25.3	28.7	30.5*	3.86
	67	32.2	16.7	20.1	23.6	25.9	3.90
	71	34.1	11.5	14.9	18.4	20.7	3.94

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TDD060R9V3+RXC036S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.9	29.2	32.7	34.6*	35.4*	2.77
	63	36.0	24.4	27.9	31.4	33.8	2.79
	67	38.2	19.1	22.6	26.1	28.5	2.81
95	59	32.6	28.6	32.1	33.5*	34.1*	3.08
	63	34.5	23.7	27.3	30.8	33.1	3.10
	67	36.6	18.5	22.0	25.5	27.8	3.13
105	63	32.7	23.0	26.5	30.0	32.3	3.47
	67	34.7	17.7	21.2	24.7	27.1	3.50
	71	36.7	12.3	15.9	19.4	21.7	3.53
115	63	30.9	22.2	25.7	29.2	31.1*	3.83
	67	32.8	16.9	20.4	24.0	26.3	3.87
	71	34.7	11.6	15.1	18.6	21.0	3.90

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDD080R9V3+TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.3	27.5	30.6	32.8*	33.5*	2.74
	63	34.4	23.2	26.3	29.5	31.5	2.76
	67	36.5	18.5	21.6	24.7	26.8	2.78
95	59	31.6	27.1	30.2	32.2*	32.9*	3.05
	63	33.6	22.9	26.0	29.1	31.2	3.08
	67	35.7	18.2	21.3	24.4	26.5	3.10
105	63	31.5	21.9	25.0	28.2	30.2	3.40
	67	33.5	17.2	20.4	23.5	25.6	3.43
	71	35.6	12.5	15.6	18.7	20.8	3.46
115	63	29.4	21.0	24.1	27.2	29.3	3.72
	67	31.3	16.3	19.4	22.6	24.7	3.76
	71	33.3	11.6	14.7	17.8	19.9	3.80

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDD080R9V3+TXH041A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.2	28.0	31.3	33.6*	34.3*	2.74
	63	35.2	23.6	26.8	30.1	32.2	2.76
	67	37.3	18.8	22.0	25.2	27.3	2.78
95	59	32.5	27.7	30.9	33.0*	33.7*	3.06
	63	34.5	23.3	26.5	29.7	31.9	3.09
	67	36.6	18.5	21.7	24.9	27.0	3.11
105	63	32.5	22.4	25.6	28.8	31.0	3.42
	67	34.5	17.6	20.8	24.0	26.2	3.45
	71	36.6	12.7	15.9	19.1	21.3	3.48
115	63	30.5	21.5	24.7	28.0	30.1	3.75
	67	32.4	16.7	20.0	23.2	25.3	3.78
	71	34.4	11.9	15.1	18.3	20.5	3.82

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TDD080R9V3+RXC031S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.9	27.5	30.7	33.2*	33.9*	2.72
	63	34.9	23.2	26.4	29.5	31.6	2.74
	67	37.1	18.4	21.6	24.8	26.9	2.76
95	59	31.5	26.9	30.0	32.0*	32.7*	3.03
	63	33.5	22.5	25.7	28.9	31.0	3.05
	67	35.5	17.8	21.0	24.1	26.2	3.08
105	63	31.8	21.8	25.0	28.1	30.3	3.42
	67	33.8	17.1	20.2	23.4	25.5	3.45
	71	35.8	12.2	15.4	18.6	20.7	3.48
115	63	30.2	21.1	24.3	27.4	29.5	3.78
	67	32.0	16.3	19.5	22.7	24.8	3.82
	71	33.9	11.5	14.7	17.9	20.0	3.85

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDD080R9V3+RXC036S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.6	28.0	31.2	33.9*	34.6*	2.69
	63	35.7	23.5	26.8	30.0	32.2	2.71
	67	37.8	18.7	21.9	25.1	27.3	2.73
95	59	32.2	27.3	30.6	32.7*	33.4*	3.00
	63	34.2	22.9	26.1	29.4	31.5	3.02
	67	36.3	18.0	21.3	24.5	26.7	3.05
105	63	32.5	22.1	25.4	28.6	30.8	3.39
	67	34.4	17.3	20.5	23.7	25.9	3.42
	71	36.4	12.3	15.6	18.8	21.0	3.45
115	63	30.7	21.4	24.6	27.8	30.0	3.75
	67	32.5	16.5	19.8	23.0	25.2	3.79
	71	34.4	11.6	14.8	18.1	20.2	3.82

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDD100R9V5+TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.3	27.4	30.6	32.8*	33.4*	2.74
	63	34.3	23.2	26.3	29.4	31.5	2.76
	67	36.4	18.5	21.6	24.7	26.8	2.78
95	59	31.6	27.1	30.2	32.1*	32.8*	3.05
	63	33.6	22.8	25.9	29.1	31.2	3.07
	67	35.7	18.1	21.2	24.4	26.5	3.10
105	63	31.5	21.9	25.0	28.1	30.2	3.40
	67	33.5	17.2	20.3	23.5	25.5	3.43
	71	35.5	12.5	15.6	18.7	20.8	3.46
115	63	29.4	21.0	24.1	27.2	29.3	3.72
	67	31.3	16.3	19.4	22.5	24.6	3.76
	71	33.3	11.6	14.7	17.8	19.9	3.80

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDD100R9V5+TXH041A4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.7	29.6	33.1	34.6*	35.3*	2.71
	63	35.7	24.8	28.3	31.8	34.1	2.73
	67	37.8	19.5	23.0	26.5	28.8	2.75
95	59	33.0	29.3	32.8	34.0*	34.7*	3.04
	63	35.1	24.5	28.0	31.5	33.8	3.06
	67	37.2	19.2	22.7	26.2	28.6	3.09
105	63	33.1	23.6	27.1	30.6	32.9	3.39
	67	35.1	18.4	21.9	25.4	27.7	3.42
	71	37.2	13.0	16.5	20.0	22.4	3.45
115	63	31.1	22.7	26.2	29.7	31.3*	3.72
	67	33.0	17.5	21.0	24.5	26.8	3.76
	71	35.0	12.2	15.7	19.2	21.5	3.79

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TDD100R9V5+RXC037S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	34.2	29.6	33.1	34.9*	35.7*	2.65
	63	36.3	24.7	28.3	31.8	34.1	2.67
	67	38.4	19.4	23.0	26.5	28.8	2.69
95	59	32.8	28.9	32.5	33.8*	34.4*	2.96
	63	34.8	24.1	27.6	31.1	33.5	2.99
	67	36.9	18.8	22.3	25.9	28.2	3.01
105	63	33.0	23.3	26.8	30.4	32.7	3.35
	67	35.0	18.0	21.6	25.1	27.4	3.38
	71	37.0	12.7	16.2	19.7	22.1	3.40
115	63	31.2	22.5	26.1	29.6	31.4*	3.72
	67	33.1	17.3	20.8	24.3	26.7	3.74
	71	35.0	11.9	15.5	19.0	21.3	3.77

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY060R9V3+TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.0	27.4	30.6	32.6*	33.3*	2.72
	63	34.1	23.2	26.3	29.4	31.5	2.74
	67	36.2	18.4	21.6	24.7	26.8	2.76
95	59	31.4	27.1	30.3	32.0*	32.7*	3.04
	63	33.4	22.9	26.0	29.1	31.2	3.06
	67	35.5	18.1	21.3	24.4	26.5	3.09
105	63	31.3	21.9	25.1	28.2	30.3	3.38
	67	33.3	17.2	20.4	23.5	25.6	3.42
	71	35.4	12.4	15.6	18.7	20.8	3.45
115	63	29.3	21.0	24.1	27.3	29.3*	3.70
	67	31.2	16.3	19.5	22.6	24.7	3.74
	71	33.1	11.6	14.7	17.8	19.9	3.78

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TDY060R9V3+TXH041A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.0	28.1	31.4	33.5*	34.2*	2.74
	63	35.0	23.7	27.0	30.2	32.4	2.76
	67	37.1	18.8	22.1	25.3	27.5	2.78
95	59	32.4	27.9	31.1	33.0*	33.7*	3.06
	63	34.4	23.4	26.7	29.9	32.1	3.09
	67	36.6	18.6	21.8	25.1	27.2	3.11
105	63	32.4	22.5	25.8	29.0	31.2	3.42
	67	34.5	17.7	20.9	24.2	26.4	3.45
	71	36.6	12.8	16.0	19.3	21.4	3.48
115	63	30.4	21.7	24.9	28.1	30.3	3.75
	67	32.4	16.8	20.1	23.3	25.5	3.78
	71	34.4	11.9	15.2	18.4	20.6	3.82

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY060R9V3+RXC031S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.8	27.6	30.7	33.1*	33.9*	2.73
	63	34.8	23.2	26.4	29.6	31.7	2.75
	67	37.0	18.4	21.6	24.8	26.9	2.77
95	59	31.4	26.9	30.1	32.0*	32.7*	3.03
	63	33.4	22.6	25.7	28.9	31.0	3.06
	67	35.4	17.8	21.0	24.1	26.3	3.08
105	63	31.7	21.8	25.0	28.2	30.3	3.42
	67	33.7	17.1	20.2	23.4	25.5	3.45
	71	35.7	12.2	15.4	18.6	20.7	3.48
115	63	30.1	21.1	24.3	27.5	29.6	3.78
	67	32.0	16.4	19.5	22.7	24.8	3.82
	71	33.9	11.5	14.7	17.9	20.0	3.86

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY060R9V3+RXC036S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.6	28.1	31.3	33.9*	34.6*	2.71
	63	35.7	23.6	26.9	30.1	32.3	2.73
	67	37.8	18.7	22.0	25.2	27.4	2.76
95	59	32.2	27.4	30.7	32.7*	33.4*	3.02
	63	34.2	23.0	26.2	29.5	31.6	3.05
	67	36.3	18.1	21.3	24.6	26.8	3.07
105	63	32.5	22.2	25.5	28.7	30.9	3.41
	67	34.4	17.3	20.6	23.8	26.0	3.44
	71	36.4	12.4	15.6	18.9	21.0	3.47
115	63	30.7	21.4	24.7	27.9	30.1	3.78
	67	32.6	16.6	19.8	23.1	25.2	3.81
	71	34.5	11.6	14.9	18.1	20.3	3.84

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY080R9V3+TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.0	27.3	30.4	32.5*	33.1*	2.78
	63	34.0	23.0	26.1	29.3	31.3	2.80
	67	36.1	18.3	21.4	24.5	26.6	2.82
95	59	31.3	26.9	30.1	31.9*	32.6*	3.09
	63	33.3	22.7	25.8	28.9	31.0	3.12
	67	35.4	18.0	21.1	24.2	26.3	3.15
105	63	31.2	21.7	24.9	28.0	30.1	3.44
	67	33.2	17.1	20.2	23.3	25.4	3.47
	71	35.3	12.3	15.4	18.5	20.6	3.51
115	63	29.2	20.8	23.9	27.1	29.2	3.76
	67	31.1	16.1	19.3	22.4	24.5	3.80
	71	33.0	11.4	14.5	17.7	19.8	3.84

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TDY080R9V3+TXH041A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.9	27.9	31.2	33.4*	34.1*	2.79
	63	34.9	23.5	26.7	30.0	32.1	2.81
	67	37.0	18.6	21.8	25.1	27.2	2.83
95	59	32.2	27.6	30.8	32.8*	33.5*	3.11
	63	34.3	23.2	26.4	29.7	31.8	3.14
	67	36.4	18.3	21.6	24.8	27.0	3.17
105	63	32.3	22.3	25.5	28.8	30.9	3.47
	67	34.3	17.5	20.7	23.9	26.1	3.50
	71	36.4	12.6	15.8	19.0	21.2	3.53
115	63	30.3	21.4	24.6	27.9	30.0	3.79
	67	32.2	16.6	19.8	23.1	25.2	3.84
	71	34.2	11.7	15.0	18.2	20.4	3.88

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY080R9V3+RXC031S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.7	27.6	30.8	33.2*	33.9*	2.78
	63	34.8	23.3	26.5	29.7	31.8	2.80
	67	37.0	18.5	21.7	24.9	27.0	2.82
95	59	31.3	27.0	30.2	32.0*	32.7*	3.08
	63	33.3	22.6	25.8	29.0	31.1	3.11
	67	35.4	17.8	21.0	24.2	26.3	3.13
105	63	31.7	21.9	25.1	28.3	30.4	3.47
	67	33.6	17.1	20.3	23.5	25.6	3.50
	71	35.7	12.2	15.4	18.6	20.7	3.54
115	63	30.0	21.1	24.3	27.5	29.7	3.83
	67	31.9	16.4	19.6	22.8	24.9	3.87
	71	33.8	11.5	14.7	17.9	20.0	3.91

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TDY080R9V3+RXC036S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.3	27.9	31.2	33.7*	34.4*	2.76
	63	35.4	23.5	26.7	30.0	32.2	2.78
	67	37.5	18.6	21.8	25.1	27.3	2.80
95	59	31.9	27.3	30.5	32.5*	33.2*	3.07
	63	33.9	22.8	26.1	29.3	31.5	3.09
	67	36.0	17.9	21.2	24.5	26.6	3.12
105	63	32.2	22.1	25.3	28.6	30.8	3.46
	67	34.2	17.2	20.4	23.7	25.9	3.49
	71	36.2	12.2	15.5	18.7	20.9	3.52
115	63	30.5	21.3	24.6	27.8	30.0	3.82
	67	32.3	16.4	19.7	23.0	25.1	3.86
	71	34.2	11.5	14.7	18.0	20.2	3.89

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY100R9V4+TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.1	27.7	30.8	32.7*	33.4*	2.72
	63	34.1	23.4	26.5	29.7	31.8	2.74
	67	36.3	18.6	21.8	24.9	27.0	2.76
95	59	31.5	27.4	30.5	32.2*	32.9*	3.04
	63	33.5	23.1	26.2	29.4	31.5	3.06
	67	35.7	18.3	21.5	24.7	26.8	3.09
105	63	31.5	22.1	25.3	28.5	30.6	3.39
	67	33.5	17.4	20.6	23.7	25.8	3.42
	71	35.5	12.6	15.8	18.9	21.0	3.45
115	63	29.4	21.2	24.4	27.5	29.5*	3.71
	67	31.3	16.5	19.7	22.8	24.9	3.75
	71	33.3	11.7	14.9	18.0	20.1	3.78

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY100R9V4+TXH041A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.9	28.1	31.4	33.4*	34.1*	2.71
	63	34.9	23.7	26.9	30.2	32.4	2.74
	67	37.0	18.8	22.0	25.3	27.5	2.76
95	59	32.3	27.9	31.1	32.9*	33.7*	3.04
	63	34.3	23.4	26.7	29.9	32.1	3.06
	67	36.5	18.6	21.8	25.1	27.2	3.09
105	63	32.4	22.5	25.8	29.0	31.2	3.39
	67	34.4	17.7	20.9	24.2	26.4	3.42
	71	36.5	12.8	16.0	19.3	21.4	3.45
115	63	30.4	21.7	24.9	28.2	30.3	3.72
	67	32.3	16.8	20.1	23.3	25.5	3.75
	71	34.3	11.9	15.2	18.4	20.6	3.79

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TDY100R9V4+RXC037S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.7	28.3	31.6	34.1*	34.8*	2.70
	63	35.8	23.8	27.1	30.4	32.6	2.72
	67	37.9	18.9	22.2	25.5	27.6	2.74
95	59	32.3	27.7	30.9	32.9*	33.6*	3.01
	63	34.3	23.2	26.5	29.7	31.9	3.03
	67	36.4	18.3	21.5	24.8	27.0	3.06
105	63	32.6	22.4	25.7	29.0	31.1	3.40
	67	34.6	17.5	20.8	24.1	26.2	3.43
	71	36.6	12.5	15.8	19.1	21.3	3.46
115	63	30.9	21.7	24.9	28.2	30.4	3.77
	67	32.7	16.8	20.0	23.3	25.5	3.80
	71	34.7	11.8	15.1	18.4	20.5	3.83

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TUD060R9V3+TXH033A4 AT 1300 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.5	29.7	32.8*	33.8*	34.5*	2.89
	63	34.6	24.7	28.4	32.0	34.5	2.91
	67	36.7	19.2	22.9	26.5	29.0	2.93
95	59	31.8	29.4	32.2*	33.3*	33.9*	3.21
	63	33.9	24.4	28.1	31.7	33.9*	3.24
	67	36.0	18.9	22.6	26.2	28.7	3.26
105	63	31.8	23.5	27.1	30.8	32.1*	3.56
	67	33.8	18.0	21.6	25.3	27.7	3.59
	71	35.8	12.4	16.1	19.7	22.2	3.62
115	63	29.7	22.5	26.2	29.7*	30.3*	3.88
	67	31.6	17.0	20.7	24.4	26.8	3.92
	71	33.5	11.5	15.2	18.8	21.3	3.96

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1125	1475	AIRFLOW	1125	1475
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUD060R9V3+TXH041A4 AT 1300 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.4	30.4	33.6*	34.7*	35.4*	2.88
	63	35.4	25.2	29.0	32.8	35.3	2.90
	67	37.5	19.5	23.3	27.1	29.6	2.92
95	59	32.8	30.1	33.1*	34.2*	34.9*	3.21
	63	34.8	25.0	28.7	32.5	34.9*	3.24
	67	37.0	19.3	23.1	26.9	29.4	3.27
105	63	32.8	24.1	27.8	31.6	33.2*	3.57
	67	34.9	18.4	22.2	26.0	28.5	3.60
	71	36.9	12.7	16.4	20.2	22.8	3.63
115	63	30.8	23.2	26.9	30.7	31.4*	3.90
	67	32.7	17.5	21.3	25.1	27.6	3.94
	71	34.7	11.8	15.6	19.4	21.9	3.98

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1125	1475	AIRFLOW	1125	1475
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COOP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TUD060R9V3+RXC031S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.0	28.5	32.0	33.7*	34.4*	2.81
	63	35.0	23.8	27.3	30.7	33.0	2.83
	67	37.2	18.7	22.1	25.5	27.8	2.85
95	59	31.6	27.9	31.3	32.5*	33.2*	3.11
	63	33.6	23.2	26.6	30.0	32.3	3.14
	67	35.6	18.0	21.5	24.9	27.2	3.16
105	63	31.9	22.4	25.9	29.3	31.6	3.50
	67	33.8	17.3	20.7	24.2	26.4	3.53
	71	35.8	12.1	15.5	18.9	21.2	3.57
115	63	30.2	21.7	25.1	28.6	30.4*	3.86
	67	32.0	16.6	20.0	23.4	25.7	3.90
	71	33.9	11.4	14.8	18.2	20.5	3.94

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUD060R9V3+RXC036S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.7	29.0	32.6	34.4*	35.2*	2.79
	63	35.8	24.2	27.7	31.2	33.6	2.81
	67	37.9	18.9	22.4	26.0	28.3	2.84
95	59	32.4	28.4	31.9	33.3*	34.0*	3.10
	63	34.3	23.6	27.1	30.6	32.9	3.13
	67	36.4	18.3	21.8	25.3	27.7	3.15
105	63	32.5	22.8	26.3	29.8	32.2	3.49
	67	34.5	17.5	21.0	24.6	26.9	3.52
	71	36.5	12.2	15.7	19.2	21.5	3.55
115	63	30.7	22.0	25.5	29.0	30.9*	3.85
	67	32.6	16.8	20.3	23.8	26.1	3.89
	71	34.5	11.4	14.9	18.5	20.8	3.92

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TUD060R9V3+TXH033A4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.4	28.5	31.9	33.3*	34.0*	2.80
	63	34.4	23.9	27.3	30.6	32.9	2.82
	67	36.5	18.8	22.1	25.5	27.8	2.84
95	59	31.7	28.2	31.6	32.7*	33.4*	3.12
	63	33.7	23.6	26.9	30.3	32.6	3.14
	67	35.8	18.5	21.9	25.2	27.5	3.17
105	63	31.6	22.6	26.0	29.4	31.6*	3.46
	67	33.6	17.5	20.9	24.3	26.6	3.50
	71	35.7	12.4	15.8	19.2	21.4	3.53
115	63	29.5	21.7	25.1	28.5	29.9*	3.78
	67	31.4	16.6	20.0	23.4	25.7	3.82
	71	33.4	11.5	14.9	18.3	20.5	3.86

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2036A1 WITH TUD080R9V3+TXH041A4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.3	29.2	32.7	34.2*	34.9*	2.81
	63	35.3	24.4	27.9	31.4	33.7	2.83
	67	37.4	19.1	22.6	26.1	28.5	2.85
95	59	32.7	28.9	32.4	33.6*	34.3*	3.13
	63	34.7	24.1	27.6	31.1	33.4	3.16
	67	36.8	18.8	22.4	25.9	28.2	3.19
105	63	32.7	23.2	26.7	30.2	32.5	3.49
	67	34.7	18.0	21.5	25.0	27.3	3.52
	71	36.8	12.7	16.2	19.7	22.0	3.55
115	63	30.7	22.3	25.8	29.3	30.9*	3.82
	67	32.6	17.1	20.6	24.1	26.5	3.86
	71	34.6	11.8	15.3	18.8	21.2	3.90

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUD080R9V3+RXC031S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.2	28.7	32.1	33.9*	34.6*	2.81
	63	35.3	24.0	27.4	30.9	33.2	2.83
	67	37.4	18.8	22.3	25.7	28.0	2.85
95	59	31.8	28.0	31.5	32.7*	33.4*	3.12
	63	33.7	23.3	26.8	30.2	32.5	3.14
	67	35.8	18.2	21.6	25.0	27.3	3.17
105	63	32.0	22.6	26.0	29.5	31.7	3.51
	67	34.0	17.4	20.9	24.3	26.6	3.54
	71	36.0	12.2	15.6	19.1	21.4	3.57
115	63	30.4	21.8	25.3	28.7	30.5*	3.87
	67	32.2	16.7	20.1	23.6	25.9	3.91
	71	34.1	11.5	14.9	18.4	20.6	3.95

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUD080R9V3+RXC036S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.7	29.0	32.6	34.4*	35.2*	2.81
	63	35.8	24.2	27.7	31.2	33.6	2.83
	67	37.9	18.9	22.4	26.0	28.3	2.85
95	59	32.4	28.4	31.9	33.3*	34.0*	3.12
	63	34.3	23.6	27.1	30.6	32.9	3.14
	67	36.4	18.3	21.8	25.3	27.7	3.17
105	63	32.5	22.8	26.3	29.8	32.2	3.50
	67	34.5	17.5	21.0	24.5	26.9	3.53
	71	36.5	12.2	15.7	19.2	21.5	3.57
115	63	30.7	22.0	25.5	29.0	30.9*	3.87
	67	32.6	16.7	20.3	23.8	26.1	3.90
	71	34.5	11.4	14.9	18.4	20.8	3.94

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY - SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TUD100R9V5+TXH033A4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.8	28.9	32.3	33.6*	34.4*	2.73
	63	34.8	24.2	27.6	31.0	33.3	2.76
	67	36.9	19.1	22.5	25.9	28.2	2.78
95	59	32.1	28.5	31.9	33.1*	33.8*	3.06
	63	34.1	23.9	27.3	30.7	33.0	3.08
	67	36.2	18.8	22.2	25.6	27.9	3.11
105	63	32.0	23.0	26.4	29.8	32.0*	3.41
	67	34.0	17.9	21.3	24.7	26.9	3.44
	71	36.1	12.7	16.1	19.5	21.8	3.47
115	63	29.9	22.0	25.4	28.8	30.2*	3.73
	67	31.8	17.0	20.4	23.8	26.0	3.77
	71	33.8	11.8	15.2	18.6	20.9	3.81

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUD100R9V5+TXH041A4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.5	29.4	32.9	34.4*	35.1*	2.72
	63	35.5	24.6	28.1	31.6	33.9	2.74
	67	37.6	19.3	22.8	26.3	28.7	2.76
95	59	32.9	29.1	32.6	33.8*	34.5*	3.05
	63	34.9	24.3	27.8	31.3	33.7	3.07
	67	37.0	19.1	22.6	26.1	28.4	3.10
105	63	32.9	23.4	26.9	30.4	32.8	3.40
	67	34.9	18.2	21.7	25.2	27.5	3.43
	71	37.0	12.9	16.4	19.9	22.2	3.46
115	63	30.9	22.5	26.0	29.5	31.2*	3.73
	67	32.8	17.3	20.8	24.3	26.7	3.76
	71	34.8	12.1	15.6	19.1	21.4	3.80

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUD100R9V5+RXC037S3 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	35.1	30.3	33.8	35.8*	36.6*	2.74
	63	37.2	25.4	28.9	32.5	34.9	2.76
	67	39.4	20.0	23.6	27.1	29.5	2.79
95	59	33.7	29.6	33.1	34.6*	35.3*	3.06
	63	35.7	24.7	28.3	31.8	34.2	3.09
	67	37.8	19.3	22.9	26.5	28.8	3.11
105	63	33.8	23.9	27.4	31.0	33.4	3.46
	67	35.8	18.5	22.1	25.7	28.0	3.49
	71	37.9	13.1	16.7	20.3	22.6	3.52
115	63	31.9	23.0	26.6	30.2	32.1*	3.84
	67	33.9	17.7	21.3	24.9	27.2	3.87
	71	35.9	12.4	15.9	19.5	21.9	3.90

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TUY060R9V3+TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.1	27.5	30.7	32.6*	33.3*	2.74
	63	34.1	23.2	26.4	29.5	31.6	2.76
	67	36.2	18.5	21.6	24.8	26.9	2.78
95	59	31.4	27.2	30.3	32.1*	32.8*	3.05
	63	33.5	22.9	26.1	29.2	31.3	3.08
	67	35.5	18.2	21.3	24.5	26.6	3.10
105	63	31.4	22.0	25.1	28.3	30.4	3.40
	67	33.4	17.3	20.4	23.6	25.7	3.43
	71	35.4	12.5	15.6	18.8	20.9	3.47
115	63	29.3	21.0	24.2	27.3	29.3*	3.72
	67	31.2	16.3	19.5	22.6	24.7	3.76
	71	33.2	11.6	14.7	17.9	20.0	3.80

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TUY060R9V3+TXH041A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.6	26.7	29.7	32.6*	33.3*	2.68
	63	34.7	22.7	25.7	28.6	30.6	2.70
	67	36.7	18.2	21.2	24.2	26.1	2.72
95	59	31.9	26.4	29.4	32.1*	32.7*	2.99
	63	34.0	22.4	25.3	28.3	30.3	3.02
	67	36.1	18.0	20.9	23.9	25.8	3.04
105	63	32.0	21.5	24.5	27.4	29.4	3.35
	67	34.0	17.1	20.0	23.0	25.0	3.38
	71	36.1	12.6	15.6	18.5	20.5	3.41
115	63	30.0	20.6	23.6	26.5	28.5	3.67
	67	32.0	16.2	19.2	22.2	24.1	3.71
	71	33.9	11.8	14.7	17.7	19.7	3.75

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUY060R9V3+RXC031S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.8	27.7	30.9	33.2*	33.9*	2.72
	63	34.8	23.3	26.5	29.7	31.8	2.74
	67	37.0	18.5	21.7	24.9	27.0	2.76
95	59	31.3	27.0	30.2	32.0*	32.7*	3.03
	63	33.3	22.6	25.8	29.0	31.2	3.05
	67	35.4	17.9	21.0	24.2	26.4	3.08
105	63	31.7	21.9	25.1	28.3	30.4	3.41
	67	33.7	17.1	20.3	23.5	25.6	3.44
	71	35.7	12.3	15.5	18.7	20.8	3.48
115	63	30.1	21.2	24.4	27.6	29.7	3.78
	67	31.9	16.4	19.6	22.8	24.9	3.81
	71	33.8	11.6	14.8	18.0	20.1	3.85

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TUY060R9V3+RXC036S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.5	28.1	31.4	33.9*	34.6*	2.71
	63	35.6	23.7	26.9	30.2	32.4	2.73
	67	37.7	18.8	22.0	25.3	27.5	2.75
95	59	32.1	27.5	30.7	32.7*	33.4*	3.02
	63	34.1	23.0	26.3	29.5	31.7	3.04
	67	36.2	18.1	21.4	24.6	26.8	3.07
105	63	32.4	22.2	25.5	28.8	31.0	3.41
	67	34.4	17.4	20.6	23.9	26.1	3.43
	71	36.4	12.4	15.7	18.9	21.1	3.46
115	63	30.7	21.5	24.8	28.0	30.2	3.77
	67	32.5	16.6	19.9	23.1	25.3	3.80
	71	34.5	11.7	14.9	18.2	20.4	3.84

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TUY080R9V3+TXH033A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.6	26.1	29.0	31.7*	32.3*	2.67
	63	33.6	22.2	25.1	28.0	29.9	2.69
	67	35.7	17.9	20.8	23.6	25.6	2.71
95	59	30.9	25.8	28.7	31.1*	31.8*	2.98
	63	32.9	21.9	24.8	27.6	29.6	3.00
	67	35.0	17.6	20.5	23.3	25.2	3.03
105	63	30.9	21.0	23.8	26.7	28.6	3.33
	67	32.9	16.7	19.6	22.4	24.3	3.36
	71	34.9	12.3	15.2	18.1	20.0	3.39
115	63	28.9	20.1	22.9	25.8	27.7	3.65
	67	30.7	15.8	18.7	21.5	23.4	3.69
	71	32.7	11.4	14.3	17.2	19.1	3.73

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUY080R9V3+TXH041A4 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.6	26.7	29.7	32.6*	33.3*	2.68
	63	34.7	22.7	25.7	28.6	30.6	2.70
	67	36.7	18.2	21.2	24.2	26.1	2.72
95	59	31.9	26.4	29.4	32.1*	32.7*	2.99
	63	34.0	22.4	25.3	28.3	30.3	3.02
	67	36.1	18.0	20.9	23.9	25.8	3.04
105	63	32.0	21.5	24.5	27.4	29.4	3.35
	67	34.0	17.1	20.0	23.0	25.0	3.38
	71	36.1	12.6	15.6	18.5	20.5	3.41
115	63	30.0	20.6	23.6	26.5	28.5	3.67
	67	32.0	16.2	19.2	22.2	24.1	3.71
	71	33.9	11.8	14.7	17.7	19.7	3.75

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUY080R9V3+RXC031S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.3	26.2	29.1	32.0	32.9*	2.67
	63	34.4	22.2	25.1	28.0	30.0	2.69
	67	36.5	17.9	20.8	23.7	25.6	2.71
95	59	31.0	25.6	28.4	31.1*	31.8*	2.97
	63	33.0	21.6	24.5	27.4	29.3	3.00
	67	35.0	17.2	20.1	23.0	25.0	3.02
105	63	31.4	20.9	23.8	26.7	28.6	3.36
	67	33.3	16.5	19.4	22.3	24.3	3.39
	71	35.3	12.1	15.0	17.9	19.8	3.42
115	63	29.8	20.2	23.1	26.0	27.9	3.72
	67	31.6	15.8	18.7	21.6	23.6	3.75
	71	33.5	11.4	14.3	17.2	19.1	3.79

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2036A1 WITH TUY080R9V3+RXC036S3 AT 1000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.1	26.7	29.6	32.6	33.6*	2.67
	63	35.1	22.6	25.6	28.5	30.5	2.69
	67	37.3	18.1	21.1	24.1	26.0	2.71
95	59	31.8	26.0	29.0	31.8*	32.5*	2.98
	63	33.7	22.0	24.9	27.9	29.9	3.00
	67	35.8	17.5	20.5	23.4	25.4	3.02
105	63	32.0	21.2	24.2	27.2	29.1	3.36
	67	34.0	16.8	19.7	22.7	24.7	3.39
	71	36.0	12.2	15.2	18.2	20.2	3.42
115	63	30.3	20.5	23.4	26.4	28.4	3.73
	67	32.2	16.0	19.0	22.0	23.9	3.76
	71	34.1	11.5	14.5	17.5	19.4	3.79

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	875	1125	AIRFLOW	875	1125
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TUY100R9V4+TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.1	27.7	30.8	32.7*	33.4*	2.68
	63	34.2	23.4	26.5	29.7	31.8	2.70
	67	36.3	18.6	21.8	24.9	27.1	2.72
95	59	31.5	27.4	30.6	32.2*	32.9*	3.00
	63	33.6	23.1	26.3	29.4	31.5	3.02
	67	35.7	18.4	21.5	24.7	26.8	3.05
105	63	31.5	22.2	25.3	28.5	30.6	3.34
	67	33.5	17.5	20.6	23.8	25.9	3.37
	71	35.5	12.7	15.8	19.0	21.1	3.41
115	63	29.4	21.2	24.4	27.5	29.5*	3.67
	67	31.3	16.5	19.7	22.9	25.0	3.70
	71	33.3	11.8	14.9	18.1	20.2	3.74

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.

Performance Data

Cooling

4TTR2036A1 WITH TUY100R9V4+TXH041A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.1	28.3	31.6	33.6*	34.3*	2.69
	63	35.1	23.9	27.1	30.4	32.5	2.71
	67	37.2	19.0	22.2	25.5	27.6	2.73
95	59	32.5	28.0	31.3	33.1*	33.9*	3.02
	63	34.5	23.6	26.9	30.1	32.3	3.04
	67	36.7	18.7	22.0	25.2	27.4	3.07
105	63	32.5	22.7	26.0	29.2	31.4	3.37
	67	34.6	17.9	21.1	24.4	26.5	3.40
	71	36.7	12.9	16.2	19.4	21.6	3.43
115	63	30.6	21.8	25.1	28.3	30.5	3.70
	67	32.5	17.0	20.3	23.5	25.7	3.73
	71	34.5	12.1	15.3	18.6	20.8	3.77

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TUY100R9V4+RXC037S3 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.9	28.4	31.7	34.2*	35.0*	2.63
	63	36.0	24.0	27.2	30.5	32.7	2.65
	67	38.1	19.1	22.3	25.6	27.8	2.68
95	59	32.5	27.8	31.1	33.1*	33.8*	2.95
	63	34.5	23.3	26.6	29.9	32.0	2.97
	67	36.6	18.4	21.7	25.0	27.2	2.99
105	63	32.8	22.6	25.8	29.1	31.3	3.34
	67	34.7	17.7	20.9	24.2	26.4	3.36
	71	36.8	12.7	16.0	19.2	21.4	3.39
115	63	31.0	21.8	25.1	28.3	30.5	3.70
	67	32.9	16.9	20.2	23.5	25.6	3.73
	71	34.8	12.0	15.2	18.5	20.7	3.76

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TVF030A14 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.1	27.3	30.6	32.7*	33.4*	2.90
	63	34.1	22.8	26.1	29.4	31.6	2.92
	67	36.2	17.9	21.2	24.5	26.7	2.94
95	59	31.4	27.0	30.3	32.1*	32.8*	3.21
	63	33.4	22.5	25.8	29.1	31.3	3.24
	67	35.5	17.6	20.9	24.2	26.4	3.26
105	63	31.4	21.6	24.9	28.2	30.4	3.57
	67	33.4	16.7	20.0	23.3	25.5	3.60
	71	35.4	11.8	15.1	18.3	20.5	3.63
115	63	29.3	20.7	24.0	27.3	29.4*	3.89
	67	31.3	15.9	19.2	22.4	24.6	3.93
	71	33.2	10.9	14.2	17.5	19.7	3.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TVF036A14 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.8	28.8	32.4	33.7*	34.4*	2.95
	63	34.8	23.8	27.4	31.0	33.4	2.97
	67	36.9	18.4	22.0	25.6	28.0	2.99
95	59	32.1	28.4	32.1	33.2*	33.8*	3.27
	63	34.1	23.5	27.1	30.7	33.1	3.30
	67	36.2	18.1	21.7	25.4	27.8	3.32
105	63	32.1	22.6	26.2	29.9	32.1*	3.62
	67	34.1	17.3	20.9	24.5	26.9	3.65
	71	36.1	11.8	15.4	19.1	21.5	3.69
115	63	30.0	21.8	25.4	29.0	30.4*	3.95
	67	32.0	16.4	20.0	23.6	26.1	3.99
	71	33.9	11.0	14.6	18.2	20.6	4.02

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TWE030C14 AT 900 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	29.7	23.5	26.0	28.5	29.9*	2.69
	63	31.7	20.1	22.6	25.1	26.8	2.71
	67	33.8	16.4	18.9	21.4	23.1	2.73
95	59	29.1	23.2	25.7	28.2	29.4*	2.99
	63	31.0	19.8	22.3	24.8	26.5	3.01
	67	33.1	16.1	18.6	21.1	22.8	3.04
105	63	29.2	19.0	21.5	24.0	25.7	3.34
	67	31.1	15.2	17.7	20.3	21.9	3.37
	71	33.2	11.4	13.9	16.4	18.1	3.41
115	63	27.3	18.1	20.6	23.2	24.8	3.67
	67	29.2	14.4	16.9	19.4	21.1	3.71
	71	31.1	10.6	13.1	15.6	17.3	3.75

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	775	1025	AIRFLOW	775	1025
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TWE036C14 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.6	28.1	31.4	32.6*	33.3*	2.88
	63	33.7	23.5	26.8	30.2	32.5	2.90
	67	35.8	18.4	21.7	25.1	27.4	2.92
95	59	31.1	27.8	31.1*	32.1*	32.8*	3.19
	63	33.1	23.2	26.6	30.0	32.2	3.22
	67	35.2	18.1	21.5	24.9	27.1	3.24
105	63	31.2	22.3	25.7	29.1	31.2*	3.55
	67	33.2	17.3	20.7	24.0	26.3	3.58
	71	35.3	12.1	15.5	18.9	21.2	3.61
115	63	29.3	21.5	24.9	28.2	29.6*	3.88
	67	31.2	16.5	19.8	23.2	25.5	3.92
	71	33.2	11.3	14.7	18.1	20.4	3.96

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TWE042C14 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.7	30.9	33.3*	34.4*	35.1*	3.00
	63	34.7	25.4	29.4	33.4	35.1*	3.02
	67	36.9	19.4	23.4	27.4	30.0	3.04
95	59	32.2	30.6	32.8*	33.9*	34.6*	3.32
	63	34.2	25.2	29.1	33.1	34.6*	3.35
	67	36.3	19.2	23.2	27.2	29.8	3.38
105	63	32.2	24.3	28.3	32.2*	32.9*	3.68
	67	34.2	18.3	22.3	26.3	28.9	3.71
	71	36.3	12.3	16.3	20.3	22.9	3.74
115	63	30.2	23.4	27.4	30.5*	31.2*	4.01
	67	32.2	17.5	21.5	25.4	28.1	4.05
	71	34.2	11.5	15.4	19.4	22.1	4.09

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TWE048C14 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.1	31.2	33.7*	34.8*	35.5*	3.05
	63	35.2	25.6	29.7	33.7	35.5*	3.07
	67	37.3	19.4	23.5	27.6	30.3	3.09
95	59	32.5	30.9	33.2*	34.3*	35.0*	3.38
	63	34.6	25.3	29.4	33.5	35.0*	3.40
	67	36.7	19.2	23.3	27.4	30.1	3.43
105	63	32.6	24.4	28.5	32.6*	33.3*	3.73
	67	34.6	18.4	22.4	26.5	29.2	3.77
	71	36.7	12.2	16.3	20.4	23.1	3.80
115	63	30.6	23.6	27.6	30.9*	31.5*	4.06
	67	32.5	17.5	21.6	25.7	28.4	4.10
	71	34.6	11.4	15.5	19.5	22.3	4.14

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXA/TXC030C4/D4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.1	26.1	29.0	31.4*	32.0*	2.84
	63	33.1	22.1	25.0	28.0	29.9	2.86
	67	35.2	17.7	20.6	23.5	25.5	2.88
95	59	30.5	25.8	28.7	30.9*	31.5*	3.15
	63	32.5	21.8	24.8	27.7	29.6	3.18
	67	34.6	17.4	20.3	23.3	25.2	3.20
105	63	30.6	20.9	23.9	26.8	28.7	3.51
	67	32.6	16.5	19.5	22.4	24.3	3.54
	71	34.6	12.1	15.0	17.9	19.9	3.57
115	63	28.6	20.1	23.0	25.9	27.8	3.83
	67	30.6	15.7	18.6	21.5	23.5	3.87
	71	32.5	11.2	14.2	17.1	19.0	3.92

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXA/TXC031C4/D4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.3	26.4	29.4	31.7*	32.4*	2.83
	63	33.3	22.1	25.2	28.3	30.4	2.85
	67	35.4	17.5	20.6	23.7	25.7	2.87
95	59	30.7	26.1	29.2	31.2*	31.9*	3.14
	63	32.7	21.9	25.0	28.1	30.1	3.17
	67	34.8	17.2	20.3	23.4	25.5	3.19
105	63	30.7	21.0	24.1	27.2	29.2	3.49
	67	32.7	16.4	19.5	22.6	24.6	3.52
	71	34.8	11.7	14.8	17.9	19.9	3.56
115	63	28.8	20.1	23.2	26.3	28.4	3.81
	67	30.7	15.5	18.6	21.7	23.8	3.85
	71	32.6	10.9	13.9	17.0	19.1	3.89

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXA/TXC035C4/D4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.1	26.1	29.0	31.4*	32.0*	2.84
	63	33.1	22.1	25.0	28.0	29.9	2.86
	67	35.2	17.7	20.6	23.5	25.5	2.88
95	59	30.5	25.8	28.7	30.9*	31.5*	3.15
	63	32.5	21.8	24.8	27.7	29.6	3.18
	67	34.6	17.4	20.3	23.3	25.2	3.20
105	63	30.6	20.9	23.9	26.8	28.7	3.51
	67	32.6	16.5	19.5	22.4	24.3	3.54
	71	34.6	12.1	15.0	17.9	19.9	3.57
115	63	28.6	20.1	23.0	25.9	27.8	3.83
	67	30.6	15.7	18.6	21.5	23.5	3.87
	71	32.5	11.2	14.2	17.1	19.0	3.92

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXA/TXC036C4/D4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.1	27.9	31.3	32.9*	33.6*	2.90
	63	34.1	23.2	26.6	30.0	32.3	2.92
	67	36.2	18.1	21.5	24.9	27.2	2.94
95	59	31.5	27.6	31.0	32.4*	33.1*	3.21
	63	33.5	22.9	26.4	29.8	32.0	3.24
	67	35.6	17.8	21.2	24.7	26.9	3.27
105	63	31.5	22.1	25.5	28.9	31.2	3.57
	67	33.5	17.0	20.4	23.8	26.1	3.60
	71	35.6	11.8	15.2	18.7	20.9	3.63
115	63	29.5	21.2	24.6	28.0	29.8*	3.89
	67	31.5	16.2	19.6	23.0	25.3	3.93
	71	33.5	11.0	14.4	17.8	20.1	3.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TXA/TXC037C4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.1	27.9	31.3	32.9*	33.6*	2.90
	63	34.1	23.2	26.6	30.0	32.3	2.92
	67	36.2	18.1	21.5	24.9	27.2	2.94
95	59	31.5	27.6	31.0	32.4*	33.1*	3.21
	63	33.5	22.9	26.4	29.8	32.0	3.24
	67	35.6	17.8	21.2	24.7	26.9	3.27
105	63	31.5	22.1	25.5	28.9	31.2	3.57
	67	33.5	17.0	20.4	23.8	26.1	3.60
	71	35.6	11.8	15.2	18.7	20.9	3.63
115	63	29.5	21.2	24.6	28.0	29.8*	3.89
	67	31.5	16.2	19.6	23.0	25.3	3.93
	71	33.5	11.0	14.4	17.8	20.1	3.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXA/TXC042C4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	32.5	28.2	31.6	33.3*	34.0*	2.91
	63	34.5	23.4	26.9	30.3	32.6	2.93
	67	36.6	18.3	21.7	25.2	27.4	2.95
95	59	31.8	27.9	31.3	32.8*	33.4*	3.24
	63	33.9	23.2	26.6	30.1	32.4	3.26
	67	36.0	18.0	21.4	24.9	27.2	3.29
105	63	31.9	22.3	25.7	29.2	31.5	3.59
	67	33.9	17.1	20.6	24.0	26.3	3.62
	71	36.0	11.9	15.4	18.8	21.1	3.65
115	63	29.9	21.4	24.9	28.3	30.1*	3.92
	67	31.8	16.3	19.8	23.2	25.5	3.96
	71	33.8	11.1	14.6	18.0	20.3	4.00

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXA/TXC043C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.0	30.5	33.4*	34.5*	35.2*	3.01
	63	35.0	25.1	29.0	33.0	35.2*	3.03
	67	37.1	19.1	23.1	27.1	29.7	3.05
95	59	32.4	30.2	32.9*	34.0*	34.7*	3.34
	63	34.4	24.8	28.8	32.8	34.7*	3.37
	67	36.5	18.9	22.8	26.8	29.5	3.39
105	63	32.4	23.9	27.9	31.9	32.9*	3.70
	67	34.4	18.0	22.0	26.0	28.6	3.73
	71	36.5	12.0	16.0	19.9	22.6	3.76
115	63	30.3	23.1	27.0	30.5*	31.2*	4.03
	67	32.3	17.2	21.1	25.1	27.8	4.07
	71	34.3	11.2	15.2	19.1	21.8	4.11

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXA/TXC048C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.6	31.0	34.0*	35.1*	35.8*	3.03
	63	35.6	25.4	29.5	33.5	35.8*	3.05
	67	37.7	19.3	23.4	27.4	30.1	3.07
95	59	32.9	30.7	33.4*	34.6*	35.3*	3.37
	63	35.0	25.2	29.2	33.3	35.3*	3.39
	67	37.1	19.1	23.1	27.2	29.9	3.42
105	63	32.9	24.3	28.3	32.4	33.5*	3.72
	67	35.0	18.2	22.3	26.3	29.0	3.76
	71	37.1	12.1	16.2	20.2	22.9	3.79
115	63	30.8	23.4	27.4	31.0*	31.7*	4.05
	67	32.8	17.4	21.4	25.5	28.2	4.09
	71	34.8	11.3	15.3	19.4	22.1	4.13

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TXA/TXC049C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.6	31.0	34.0*	35.1*	35.8*	3.03
	63	35.6	25.4	29.5	33.5	35.8*	3.05
	67	37.7	19.3	23.4	27.4	30.1	3.07
95	59	32.9	30.7	33.4*	34.6*	35.3*	3.37
	63	35.0	25.2	29.2	33.3	35.3*	3.39
	67	37.1	19.1	23.1	27.2	29.9	3.42
105	63	32.9	24.3	28.3	32.4	33.5*	3.72
	67	35.0	18.2	22.3	26.3	29.0	3.76
	71	37.1	12.1	16.2	20.2	22.9	3.79
115	63	30.8	23.4	27.4	31.0*	31.7*	4.05
	67	32.8	17.4	21.4	25.5	28.2	4.09
	71	34.8	11.3	15.3	19.4	22.1	4.13

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

4TTR2036A1 WITH TXA/TXC050C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.6	31.0	34.0*	35.1*	35.8*	3.03
	63	35.6	25.4	29.5	33.5	35.8*	3.05
	67	37.7	19.3	23.4	27.4	30.1	3.07
95	59	32.9	30.7	33.4*	34.6*	35.3*	3.37
	63	35.0	25.2	29.2	33.3	35.3*	3.39
	67	37.1	19.1	23.1	27.2	29.9	3.42
105	63	32.9	24.3	28.3	32.4	33.5*	3.72
	67	35.0	18.2	22.3	26.3	29.0	3.76
	71	37.1	12.1	16.2	20.2	22.9	3.79
115	63	30.8	23.4	27.4	31.0*	31.7*	4.05
	67	32.8	17.4	21.4	25.5	28.2	4.09
	71	34.8	11.3	15.3	19.4	22.1	4.13

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2036A1 WITH TXH033A4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	31.7	26.9	30.0	32.2*	32.9*	2.84
	63	33.8	22.7	25.8	28.9	31.0	2.86
	67	35.9	17.9	21.1	24.2	26.3	2.88
95	59	31.0	26.6	29.7	31.6*	32.3*	3.15
	63	33.0	22.3	25.4	28.6	30.6	3.17
	67	35.1	17.6	20.7	23.9	25.9	3.20
105	63	31.0	21.4	24.5	27.6	29.7	3.50
	67	32.9	16.7	19.8	23.0	25.0	3.53
	71	35.0	12.0	15.1	18.2	20.3	3.56
115	63	28.9	20.5	23.6	26.7	28.8	3.82
	67	30.8	15.8	18.9	22.0	24.1	3.85
	71	32.7	11.1	14.2	17.3	19.4	3.89

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2036A1 WITH TXH041A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	33.4	31.3	33.9*	35.0*	35.7*	3.02
	63	35.4	25.7	29.8	33.8	35.7*	3.04
	67	37.5	19.6	23.7	27.7	30.4	3.06
95	59	32.8	31.0	33.4*	34.5*	35.2*	3.35
	63	34.8	25.5	29.5	33.5	35.2*	3.37
	67	36.9	19.4	23.4	27.5	30.2	3.40
105	63	32.8	24.5	28.6	32.6	33.4*	3.70
	67	34.8	18.5	22.6	26.6	29.3	3.74
	71	36.9	12.4	16.4	20.5	23.2	3.77
115	63	30.7	23.7	27.7	31.0*	31.6*	4.03
	67	32.7	17.6	21.7	25.7	28.4	4.07
	71	34.7	11.5	15.6	19.6	22.3	4.11

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH 4TEE3F37A AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	37.8	33.3	37.3	39.0*	39.9*	3.40
	63	40.6	28.1	32.0	36.0	38.6	3.43
	67	43.4	22.3	26.3	30.2	32.8	3.47
95	59	36.2	32.6	36.3*	37.7*	38.6*	3.81
	63	38.9	27.4	31.3	35.3	37.9	3.85
	67	41.7	21.6	25.5	29.5	32.1	3.89
105	63	37.1	26.5	30.5	34.4	37.1	4.30
	67	39.8	20.7	24.7	28.7	31.3	4.36
	71	42.6	14.9	18.8	22.8	25.4	4.42
115	63	35.3	25.7	29.7	33.6	35.6*	4.75
	67	37.8	19.9	23.9	27.8	30.5	4.82
	71	40.5	14.1	18.0	22.0	24.6	4.90

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2042A1 WITH 4TEE3F40A AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	40.0	35.0	39.3	41.3*	42.2*	3.41
	63	42.8	29.3	33.6	37.9	40.8	3.45
	67	45.7	23.0	27.3	31.6	34.5	3.48
95	59	38.4	34.2	38.4*	39.9*	40.7*	3.83
	63	41.1	28.5	32.8	37.1	40.0	3.87
	67	43.9	22.2	26.5	30.8	33.7	3.92
105	63	39.0	27.6	31.9	36.2	39.0*	4.33
	67	41.7	21.3	25.6	29.9	32.8	4.38
	71	44.5	15.0	19.3	23.6	26.5	4.44
115	63	36.9	26.7	31.0	35.3	37.3*	4.78
	67	39.5	20.4	24.8	29.1	31.9	4.84
	71	42.2	14.1	18.4	22.7	25.6	4.91

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2042A1 WITH 4TEE3F49A AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	40.1	35.0	39.3	41.3*	42.2*	3.38
	63	42.9	29.2	33.5	37.9	40.7	3.41
	67	45.8	22.8	27.2	31.5	34.4	3.45
95	59	38.5	34.2	38.5*	39.9*	40.8*	3.79
	63	41.2	28.4	32.8	37.1	40.0	3.83
	67	44.0	22.1	26.5	30.8	33.7	3.88
105	63	39.1	27.5	31.9	36.2	39.1*	4.28
	67	41.8	21.2	25.6	29.9	32.8	4.33
	71	44.6	14.8	19.2	23.5	26.4	4.39
115	63	37.0	26.7	31.0	35.3	37.4*	4.73
	67	39.6	20.4	24.7	29.0	31.9	4.79
	71	42.2	14.0	18.3	22.6	25.5	4.86

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2042A1 WITH 4TEP3F36A AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	36.7	32.1	36.0	37.9*	38.8*	3.54
	63	39.5	27.0	30.9	34.8	37.4	3.57
	67	42.4	21.3	25.2	29.1	31.7	3.61
95	59	35.2	31.4	35.3*	36.6*	37.5*	3.94
	63	37.9	26.3	30.2	34.1	36.7	3.99
	67	40.7	20.6	24.5	28.4	31.0	4.03
105	63	36.1	25.5	29.4	33.3	35.9	4.44
	67	38.8	19.8	23.7	27.6	30.2	4.49
	71	41.5	13.9	17.8	21.8	24.4	4.55
115	63	34.3	24.7	28.6	32.5	34.6*	4.88
	67	36.9	19.0	22.9	26.8	29.4	4.95
	71	39.5	13.2	17.1	21.0	23.6	5.03

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2042A1 WITH 4TEP3F42A AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.1	33.1	37.2	39.1*	40.1*	3.50
	63	40.9	27.8	31.8	35.8	38.5	3.54
	67	43.8	21.9	25.9	29.9	32.6	3.57
95	59	36.5	32.4	36.4	37.9*	38.8*	3.91
	63	39.2	27.1	31.1	35.1	37.8	3.96
	67	42.0	21.2	25.2	29.2	31.9	4.00
105	63	37.3	26.2	30.2	34.2	36.9	4.40
	67	39.9	20.3	24.3	28.4	31.0	4.46
	71	42.7	14.3	18.3	22.4	25.1	4.52
115	63	35.3	25.3	29.4	33.4	35.5*	4.85
	67	37.9	19.5	23.5	27.5	30.2	4.92
	71	40.5	13.5	17.5	21.5	24.2	4.99

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2042A1 WITH 4TEP3F48A AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	39.3	36.2	39.8*	41.3*	42.2*	3.49
	63	42.1	29.7	34.6	39.4	42.2*	3.52
	67	45.0	22.6	27.5	32.3	35.6	3.56
95	59	37.7	35.5	38.5*	39.9*	40.8*	3.89
	63	40.3	29.0	33.8	38.7	40.8*	3.93
	67	43.1	21.9	26.7	31.6	34.8	3.97
105	63	38.3	28.1	33.0	37.8	39.0*	4.37
	67	40.9	21.0	25.9	30.8	34.0	4.42
	71	43.6	13.8	18.7	23.6	26.8	4.47
115	63	36.3	27.3	32.1	36.4*	37.3*	4.80
	67	38.7	20.2	25.1	29.9	33.2	4.86
	71	41.2	13.0	17.9	22.7	26.0	4.92

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

4TTR2042A1 WITH RXC036S3 AT 1300 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.1	32.2	36.0	38.7*	39.7*	3.47
	63	40.9	27.2	31.0	34.8	37.4	3.51
	67	43.8	21.6	25.5	29.3	31.8	3.54
95	59	36.6	31.5	35.3	37.5*	38.4*	3.88
	63	39.3	26.5	30.3	34.1	36.6	3.93
	67	42.1	20.9	24.8	28.6	31.1	3.97
105	63	37.4	25.6	29.4	33.2	35.8	4.38
	67	40.1	20.1	23.9	27.7	30.2	4.43
	71	42.8	14.4	18.2	22.1	24.6	4.49
115	63	35.4	24.8	28.6	32.4	34.9	4.82
	67	38.0	19.2	23.0	26.9	29.4	4.89
	71	40.7	13.6	17.4	21.2	23.8	4.96

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1125	1475	AIRFLOW	1125	1475
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2042A1 WITH RXC037S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.2	33.3	37.4	39.3*	40.3*	3.50
	63	41.0	27.9	32.0	36.1	38.8	3.54
	67	43.9	22.0	26.1	30.1	32.8	3.57
95	59	36.7	32.6	36.7	38.1*	39.0*	3.92
	63	39.4	27.2	31.3	35.4	38.1	3.96
	67	42.2	21.3	25.3	29.4	32.1	4.00
105	63	37.5	26.4	30.4	34.5	37.2	4.41
	67	40.1	20.4	24.5	28.6	31.3	4.46
	71	42.9	14.4	18.4	22.5	25.2	4.52
115	63	35.5	25.5	29.6	33.7	35.8*	4.85
	67	38.1	19.6	23.6	27.7	30.4	4.92
	71	40.7	13.5	17.6	21.7	24.4	5.00

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH RXC054S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.7	35.0	39.0*	40.4*	41.4*	3.58
	63	41.5	28.9	33.5	38.1	41.1	3.61
	67	44.4	22.3	26.8	31.4	34.4	3.65
95	59	37.1	34.3	37.6*	39.1*	40.0*	3.99
	63	39.8	28.2	32.8	37.3	40.0*	4.03
	67	42.6	21.6	26.1	30.7	33.7	4.08
105	63	37.8	27.4	31.9	36.5	38.3*	4.48
	67	40.4	20.7	25.3	29.8	32.9	4.53
	71	43.2	13.9	18.5	23.1	26.1	4.59
115	63	35.7	26.5	31.1	35.6	36.5*	4.92
	67	38.3	19.9	24.4	29.0	32.0	4.99
	71	40.9	13.1	17.7	22.2	25.3	5.06

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TUD080R9V3+TXH041A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	37.8	33.3	37.4	39.0*	39.9*	3.53
	63	40.5	28.0	32.0	36.1	38.8	3.57
	67	43.3	22.1	26.1	30.1	32.8	3.60
95	59	36.9	33.0	37.0*	38.3*	39.2*	3.96
	63	39.7	27.6	31.7	35.7	38.4	4.00
	67	42.5	21.7	25.8	29.8	32.5	4.05
105	63	37.4	26.6	30.6	34.7	37.4	4.41
	67	40.1	20.7	24.8	28.8	31.5	4.46
	71	42.9	14.7	18.8	22.8	25.5	4.52
115	63	35.1	25.6	29.6	33.7	35.5*	4.81
	67	37.7	19.7	23.8	27.8	30.5	4.87
	71	40.4	13.7	17.8	21.8	24.5	4.94

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data

Cooling

4TTR2042A1 WITH TUD080R9V3+TXH054A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.7	34.4	38.7	40.2*	41.1*	3.60
	63	41.5	28.6	33.0	37.3	40.2	3.63
	67	44.4	22.3	26.7	31.0	33.9	3.67
95	59	37.9	34.0	38.0*	39.5*	40.4*	4.04
	63	40.6	28.3	32.6	36.9	39.8	4.08
	67	43.5	22.0	26.3	30.6	33.5	4.12
105	63	38.4	27.3	31.6	35.9	38.5*	4.48
	67	41.2	21.0	25.3	29.7	32.5	4.53
	71	44.0	14.7	19.0	23.3	26.2	4.59
115	63	36.2	26.3	30.6	35.0	36.7*	4.88
	67	38.8	20.1	24.4	28.7	31.6	4.95
	71	41.5	13.7	18.0	22.4	25.2	5.01

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2042A1 WITH TUD080R9V3+RXC036S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.6	33.4	37.5	39.6*	40.5*	3.54
	63	41.4	28.0	32.1	36.2	38.9	3.58
	67	44.3	22.1	26.2	30.2	32.9	3.61
95	59	37.0	32.7	36.8	38.3*	39.2*	3.96
	63	39.7	27.3	31.4	35.4	38.2	4.00
	67	42.5	21.4	25.4	29.5	32.2	4.05
105	63	37.7	26.4	30.5	34.6	37.3	4.46
	67	40.4	20.5	24.6	28.6	31.3	4.51
	71	43.2	14.5	18.5	22.6	25.3	4.57
115	63	35.7	25.6	29.6	33.7	35.9*	4.91
	67	38.3	19.6	23.7	27.8	30.5	4.98
	71	41.0	13.6	17.7	21.8	24.5	5.05

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TUD100R9V5+TXH041A4 AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.8	35.4	39.1*	40.6*	41.5*	3.50
	63	41.6	29.6	34.0	38.3	41.2	3.53
	67	44.5	23.3	27.6	31.9	34.8	3.57
95	59	38.0	35.0	38.4*	39.9*	40.8*	3.93
	63	40.8	29.3	33.6	37.9	40.8*	3.98
	67	43.6	22.9	27.3	31.6	34.5	4.02
105	63	38.4	28.2	32.6	36.9	38.8*	4.38
	67	41.2	21.9	26.2	30.6	33.5	4.44
	71	44.1	15.5	19.8	24.1	27.0	4.50
115	63	36.1	27.2	31.5	35.9	36.9*	4.79
	67	38.8	20.9	25.2	29.6	32.5	4.86
	71	41.6	14.5	18.8	23.2	26.1	4.94

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2042A1 WITH TUD100R9V5+TXH054A4 AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	39.3	36.2	39.8*	41.3*	42.2*	3.53
	63	42.1	30.0	34.6	39.3	42.2*	3.56
	67	45.0	23.3	27.9	32.5	35.6	3.60
95	59	38.6	35.8	39.1*	40.6*	41.5*	3.97
	63	41.3	29.7	34.3	38.9	41.5*	4.02
	67	44.2	22.9	27.5	32.2	35.3	4.06
105	63	39.1	28.7	33.3	37.9	39.6*	4.42
	67	41.8	22.0	26.6	31.2	34.3	4.47
	71	44.7	15.1	19.8	24.4	27.5	4.53
115	63	36.8	27.7	32.3	36.9*	37.8*	4.81
	67	39.5	21.0	25.6	30.3	33.4	4.88
	71	42.2	14.2	18.8	23.5	26.5	4.96

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.93	X1.06

4TTR2042A1 WITH TUD100R9V5+RXC037S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.6	33.5	37.5	39.6*	40.6*	3.45
	63	41.4	28.1	32.2	36.2	38.9	3.49
	67	44.2	22.2	26.2	30.3	33.0	3.52
95	59	37.0	32.7	36.8	38.3*	39.2*	3.87
	63	39.7	27.4	31.4	35.5	38.2	3.91
	67	42.5	21.4	25.5	29.6	32.3	3.95
105	63	37.7	26.5	30.6	34.6	37.3	4.36
	67	40.4	20.6	24.6	28.7	31.4	4.41
	71	43.2	14.6	18.6	22.7	25.4	4.47
115	63	35.8	25.7	29.7	33.8	36.0*	4.80
	67	38.3	19.7	23.8	27.9	30.6	4.88
	71	41.0	13.7	17.8	21.8	24.5	4.95

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TUD100R9V5+RXC054S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.6	33.1	37.2	39.5*	40.4*	3.44
	63	41.3	27.8	31.8	35.9	38.6	3.47
	67	44.2	21.9	25.9	29.9	32.6	3.51
95	59	37.0	32.4	36.5	38.2*	39.1*	3.85
	63	39.7	27.1	31.1	35.1	37.8	3.89
	67	42.5	21.1	25.2	29.2	31.9	3.94
105	63	37.7	26.2	30.2	34.3	37.0	4.34
	67	40.4	20.3	24.3	28.4	31.1	4.40
	71	43.2	14.3	18.3	22.4	25.1	4.45
115	63	35.7	25.3	29.4	33.4	35.9*	4.79
	67	38.3	19.5	23.5	27.6	30.3	4.86
	71	40.9	13.5	17.5	21.6	24.3	4.93

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2042A1 WITH TUD120R9V5+TXH041A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.7	34.3	38.3	40.0*	40.9*	3.38
	63	41.5	28.9	33.0	37.0	39.7	3.42
	67	44.3	22.9	27.0	31.1	33.8	3.45
95	59	37.9	33.9	37.9*	39.3*	40.2*	3.81
	63	40.6	28.5	32.6	36.6	39.3	3.86
	67	43.5	22.6	26.6	30.7	33.4	3.90
105	63	38.3	27.5	31.5	35.6	38.3	4.26
	67	41.1	21.6	25.6	29.7	32.4	4.32
	71	43.9	15.6	19.6	23.7	26.4	4.38
115	63	36.0	26.4	30.5	34.5	36.4*	4.67
	67	38.7	20.6	24.6	28.7	31.4	4.74
	71	41.4	14.6	18.6	22.7	25.4	4.81

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TUD120R9V5+TXH054A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	39.7	35.3	39.7	41.2*	42.1*	3.44
	63	42.5	29.6	33.9	38.2	41.1	3.48
	67	45.4	23.2	27.6	31.9	34.8	3.51
95	59	38.8	34.9	39.0*	40.4*	41.3*	3.88
	63	41.6	29.2	33.5	37.8	40.7	3.93
	67	44.5	22.9	27.2	31.5	34.4	3.97
105	63	39.3	28.2	32.5	36.8	39.5*	4.33
	67	42.1	21.9	26.2	30.6	33.5	4.39
	71	45.0	15.5	19.8	24.2	27.1	4.45
115	63	37.1	27.2	31.5	35.9	37.6*	4.74
	67	39.8	20.9	25.3	29.6	32.5	4.81
	71	42.5	14.6	18.9	23.2	26.1	4.88

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2042A1 WITH TVF036A14 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	37.4	33.4	37.5*	38.9*	39.8*	3.67
	63	40.1	27.8	32.0	36.2	39.0	3.70
	67	43.0	21.7	25.9	30.1	32.9	3.74
95	59	36.6	33.0	36.8*	38.2*	39.1*	4.10
	63	39.3	27.4	31.6	35.8	38.6	4.14
	67	42.2	21.3	25.5	29.7	32.5	4.19
105	63	37.0	26.4	30.6	34.8	37.2*	4.55
	67	39.8	20.3	24.5	28.7	31.5	4.60
	71	42.6	14.1	18.3	22.5	25.3	4.66
115	63	34.8	25.4	29.6	33.8	35.3*	4.95
	67	37.4	19.4	23.6	27.8	30.6	5.02
	71	40.1	13.2	17.4	21.6	24.6	5.09

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TWE036C14 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	35.7	32.2	35.9*	37.2*	38.1*	3.55
	63	38.4	27.1	31.0	34.9	37.5	3.59
	67	41.3	21.4	25.3	29.2	31.8	3.62
95	59	35.1	31.9	35.4*	36.7*	37.6*	3.97
	63	37.8	26.8	30.7	34.6	37.2	4.01
	67	40.7	21.1	25.0	28.9	31.5	4.06
105	63	35.7	25.8	29.8	33.7	35.9*	4.43
	67	38.4	20.2	24.1	28.0	30.6	4.48
	71	41.2	14.4	18.3	22.2	24.8	4.54
115	63	33.6	24.9	28.8	32.7	34.2*	4.84
	67	36.2	19.2	23.1	27.0	29.6	4.90
	71	38.9	13.4	17.3	21.2	23.8	4.97

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2042A1 WITH TWE042C14 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	37.2	33.1	37.0	38.5*	39.4*	3.56
	63	39.9	27.8	31.8	35.7	38.4	3.60
	67	42.8	21.9	25.9	29.9	32.6	3.63
95	59	36.4	32.7	36.5*	37.9*	38.8*	3.99
	63	39.2	27.4	31.4	35.4	38.1	4.03
	67	42.0	21.6	25.6	29.6	32.2	4.08
105	63	36.9	26.4	30.4	34.4	37.0*	4.44
	67	39.7	20.6	24.6	28.6	31.2	4.50
	71	42.5	14.7	18.7	22.7	25.3	4.55
115	63	34.7	25.4	29.4	33.4	35.2*	4.85
	67	37.4	19.7	23.6	27.6	30.3	4.92
	71	40.1	13.8	17.7	21.7	24.4	4.99

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2042A1 WITH TWE048C14 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.2	35.8	38.9*	40.4*	41.3*	3.70
	63	41.0	29.6	34.3	38.9	41.3*	3.74
	67	43.9	22.9	27.5	32.1	35.2	3.77
95	59	37.4	35.4	38.2*	39.7*	40.6*	4.14
	63	40.2	29.3	33.9	38.5	40.6*	4.18
	67	43.1	22.5	27.1	31.8	34.8	4.23
105	63	38.0	28.3	32.9	37.5	38.7*	4.59
	67	40.8	21.6	26.2	30.8	33.9	4.65
	71	43.6	14.7	19.3	24.0	27.0	4.70
115	63	35.8	27.3	31.9	36.0*	36.9*	4.99
	67	38.5	20.6	25.2	29.8	32.9	5.06
	71	41.2	13.8	18.4	23.0	26.1	5.14

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2042A1 WITH TXA/TXC035C4/D4 AT 1100 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	34.4	27.7	30.7	33.6	34.8*	3.34
	63	37.0	24.0	26.9	29.8	31.8	3.38
	67	39.8	19.7	22.6	25.5	27.5	3.41
95	59	33.6	27.4	30.3	33.2	34.2*	3.74
	63	36.2	23.6	26.5	29.4	31.4	3.78
	67	39.0	19.3	22.3	25.2	27.1	3.82
105	63	34.1	22.6	25.5	28.4	30.4	4.19
	67	36.7	18.3	21.3	24.2	26.1	4.24
	71	39.4	14.0	16.9	19.8	21.8	4.30
115	63	31.9	21.6	24.5	27.4	29.4	4.60
	67	34.4	17.3	20.3	23.2	25.1	4.67
	71	37.0	13.0	15.9	18.9	20.8	4.73

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	950	1250	AIRFLOW	950	1250
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TXA/TXC036C4/D4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	35.8	29.7	33.2	36.1*	36.9*	3.42
	63	38.5	25.3	28.7	32.1	34.4	3.45
	67	41.3	20.3	23.7	27.1	29.4	3.49
95	59	35.0	29.4	32.8	35.5*	36.4*	3.83
	63	37.7	24.9	28.3	31.8	34.0	3.87
	67	40.5	20.0	23.4	26.8	29.1	3.91
105	63	35.5	23.9	27.4	30.8	33.1	4.28
	67	38.2	19.0	22.4	25.8	28.1	4.33
	71	40.9	13.9	17.3	20.8	23.0	4.38
115	63	33.3	23.0	26.4	29.8	32.1	4.69
	67	35.9	18.0	21.4	24.9	27.1	4.75
	71	38.5	13.0	16.4	19.8	22.1	4.81

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2042A1 WITH TXA/TXC037C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	36.9	32.5	36.5	38.1*	39.0*	3.55
	63	39.6	27.3	31.2	35.2	37.8	3.58
	67	42.4	21.5	25.4	29.4	32.0	3.62
95	59	36.1	32.1	36.1*	37.5*	38.4*	3.97
	63	38.8	26.9	30.9	34.9	37.5	4.01
	67	41.7	21.2	25.1	29.1	31.7	4.05
105	63	36.6	25.9	29.9	33.9	36.5	4.42
	67	39.3	20.2	24.1	28.1	30.7	4.48
	71	42.2	14.3	18.3	22.2	24.9	4.53
115	63	34.4	24.9	28.9	32.9	34.7*	4.83
	67	37.0	19.2	23.2	27.1	29.8	4.90
	71	39.7	13.4	17.3	21.3	23.9	4.96

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2042A1 WITH TXA/TXC042C4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	36.3	30.1	33.5	36.5*	37.4*	3.44
	63	39.0	25.5	29.0	32.5	34.8	3.47
	67	41.8	20.5	23.9	27.4	29.7	3.51
95	59	35.5	29.7	33.2	35.9*	36.8*	3.86
	63	38.2	25.2	28.6	32.1	34.4	3.90
	67	41.0	20.2	23.6	27.1	29.4	3.94
105	63	36.0	24.2	27.6	31.1	33.4	4.31
	67	38.6	19.2	22.6	26.1	28.4	4.36
	71	41.4	14.0	17.5	21.0	23.3	4.42
115	63	33.7	23.2	26.6	30.1	32.4	4.71
	67	36.3	18.2	21.7	25.1	27.4	4.78
	71	38.9	13.1	16.6	20.0	22.3	4.85

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TXA/TXC043C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	37.3	32.6	36.6	38.4*	39.3*	3.55
	63	40.0	27.3	31.3	35.3	37.9	3.58
	67	42.9	21.5	25.5	29.4	32.1	3.62
95	59	36.4	32.2	36.2	37.7*	38.6*	3.97
	63	39.2	26.9	30.9	34.9	37.6	4.01
	67	42.0	21.1	25.1	29.1	31.7	4.06
105	63	36.9	25.9	29.9	33.9	36.5	4.42
	67	39.6	20.1	24.1	28.1	30.8	4.47
	71	42.4	14.2	18.2	22.2	24.9	4.53
115	63	34.6	24.9	28.9	32.9	34.9*	4.82
	67	37.2	19.2	23.1	27.1	29.8	4.89
	71	39.9	13.3	17.3	21.2	23.9	4.95

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TXA/TXC048C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	37.9	33.1	37.2	39.1*	40.0*	3.57
	63	40.7	27.8	31.8	35.9	38.6	3.61
	67	43.6	21.8	25.9	29.9	32.6	3.65
95	59	37.1	32.7	36.8	38.4*	39.3*	4.01
	63	39.8	27.4	31.4	35.5	38.2	4.05
	67	42.7	21.4	25.5	29.6	32.3	4.09
105	63	37.6	26.4	30.4	34.5	37.2	4.46
	67	40.3	20.5	24.5	28.6	31.3	4.51
	71	43.2	14.5	18.5	22.6	25.3	4.57
115	63	35.3	25.4	29.4	33.5	35.6*	4.86
	67	38.0	19.5	23.6	27.6	30.3	4.93
	71	40.7	13.5	17.6	21.6	24.3	5.00

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2042A1 WITH TXA/TXC049C4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.3	35.2	38.8*	40.2*	41.1*	3.66
	63	41.1	29.1	33.7	38.2	41.1*	3.70
	67	44.0	22.4	27.0	31.5	34.6	3.73
95	59	37.5	34.8	38.0*	39.5*	40.4*	4.10
	63	40.2	28.7	33.3	37.8	40.4*	4.14
	67	43.1	22.0	26.6	31.2	34.2	4.19
105	63	37.9	27.7	32.3	36.8	38.5*	4.54
	67	40.7	21.1	25.6	30.2	33.2	4.60
	71	43.5	14.3	18.9	23.4	26.5	4.65
115	63	35.7	26.7	31.3	35.7*	36.6*	4.94
	67	38.3	20.1	24.7	29.2	32.3	5.01
	71	41.0	13.4	17.9	22.5	25.5	5.08

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TXA/TXC050C4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	38.3	35.2	38.8*	40.2*	41.1*	3.66
	63	41.1	29.1	33.7	38.2	41.1*	3.70
	67	44.0	22.4	27.0	31.5	34.6	3.73
95	59	37.5	34.8	38.0*	39.5*	40.4*	4.10
	63	40.2	28.7	33.3	37.8	40.4*	4.14
	67	43.1	22.0	26.6	31.2	34.2	4.19
105	63	37.9	27.7	32.3	36.8	38.5*	4.54
	67	40.7	21.1	25.6	30.2	33.2	4.60
	71	43.5	14.3	18.9	23.4	26.5	4.65
115	63	35.7	26.7	31.3	35.7*	36.6*	4.94
	67	38.3	20.1	24.7	29.2	32.3	5.01
	71	41.0	13.4	17.9	22.5	25.5	5.08

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2042A1 WITH TXH041A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	37.7	33.3	37.4	39.0*	39.9*	3.57
	63	40.5	28.0	32.0	36.1	38.7	3.60
	67	43.3	22.0	26.1	30.1	32.8	3.64
95	59	36.9	32.9	36.9*	38.3*	39.2*	4.00
	63	39.7	27.6	31.6	35.7	38.4	4.04
	67	42.5	21.7	25.7	29.8	32.5	4.09
105	63	37.4	26.6	30.6	34.6	37.3	4.45
	67	40.1	20.7	24.7	28.8	31.5	4.50
	71	42.9	14.7	18.7	22.8	25.5	4.56
115	63	35.1	25.6	29.6	33.6	35.5*	4.85
	67	37.7	19.7	23.7	27.8	30.5	4.92
	71	40.4	13.7	17.7	21.8	24.5	4.99

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2042A1 WITH TXH054A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	39.3	36.9	40.0*	41.5*	42.4*	3.69
	63	42.0	30.4	35.3	40.2	42.4*	3.72
	67	44.9	23.2	28.1	33.0	36.3	3.76
95	59	38.4	36.6	39.3*	40.8*	41.7*	4.14
	63	41.2	30.0	34.9	39.8	41.7*	4.18
	67	44.1	22.9	27.8	32.7	36.0	4.22
105	63	39.0	29.1	34.0	38.9	39.8*	4.58
	67	41.7	22.0	26.8	31.7	35.0	4.63
	71	44.6	14.7	19.6	24.5	27.8	4.69
115	63	36.7	28.1	33.0	37.0*	37.9*	4.98
	67	39.4	21.0	25.9	30.8	34.1	5.05
	71	42.1	13.8	18.7	23.6	26.9	5.12

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH 4TEE3F49A AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.6	38.8	43.4	46.5*	47.6*	3.82
	63	48.8	32.6	37.2	41.9	45.0	3.86
	67	52.1	25.8	30.5	35.1	38.2	3.90
95	59	43.8	37.9	42.6	45.0*	46.0*	4.29
	63	46.8	31.7	36.4	41.0	44.1	4.34
	67	50.0	25.0	29.6	34.2	37.3	4.39
105	63	44.6	30.8	35.4	40.1	43.1	4.82
	67	47.6	24.0	28.6	33.3	36.4	4.88
	71	50.8	17.1	21.8	26.4	29.5	4.94
115	63	42.4	29.8	34.5	39.1	42.2	5.30
	67	45.3	23.1	27.7	32.3	35.4	5.37
	71	48.3	16.2	20.8	25.5	28.6	5.45

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.93	X1.06

4TTR2048A1 WITH 4TEE3F65A AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	46.6	40.2	45.2	47.8*	48.9*	3.95
	63	49.8	33.6	38.5	43.5	46.8	3.99
	67	53.1	26.3	31.3	36.2	39.5	4.03
95	59	44.6	39.3	44.3	46.1*	47.2*	4.42
	63	47.7	32.7	37.6	42.6	45.9	4.47
	67	50.9	25.4	30.4	35.3	38.6	4.52
105	63	45.4	31.7	36.6	41.6	44.9	4.95
	67	48.4	24.4	29.4	34.4	37.7	5.01
	71	51.6	17.1	22.0	27.0	30.3	5.08
115	63	43.1	30.7	35.7	40.6	43.3*	5.43
	67	46.0	23.5	28.4	33.4	36.7	5.51
	71	49.0	16.1	21.1	26.0	29.4	5.59

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH 4TEP3F42A AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.7	37.9	42.5	44.8*	45.9*	4.10
	63	46.8	31.9	36.4	41.0	44.1	4.14
	67	50.1	25.2	29.7	34.3	37.3	4.18
95	59	41.9	37.1	41.7	43.3*	44.4*	4.57
	63	45.0	31.0	35.6	40.2	43.2	4.62
	67	48.1	24.3	28.9	33.5	36.5	4.67
105	63	42.8	30.1	34.6	39.2	42.2	5.11
	67	45.9	23.4	27.9	32.5	35.6	5.17
	71	49.0	18.6	21.1	25.7	28.7	5.24
115	63	40.7	29.1	33.7	38.3	40.9*	5.59
	67	43.6	22.4	27.0	31.6	34.6	5.67
	71	46.6	15.6	20.2	24.8	27.8	5.76

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH 4TEP3F48A AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.2	38.4	43.3	45.6*	46.6*	3.98
	63	47.3	31.9	36.8	41.7	44.9	4.02
	67	50.6	24.8	29.7	34.6	37.8	4.06
95	59	42.4	37.6	42.4*	44.0*	45.0*	4.44
	63	45.4	31.1	36.0	40.9	44.1	4.48
	67	48.5	24.0	28.8	33.7	37.0	4.53
105	63	43.2	30.2	35.1	39.9	43.2	4.95
	67	46.2	23.0	27.9	32.8	36.1	5.01
	71	49.2	15.8	20.7	25.6	28.8	5.07
115	63	41.1	29.3	34.1	39.0	41.4*	5.42
	67	43.8	22.1	27.0	31.9	35.1	5.49
	71	46.7	14.9	19.8	24.6	27.9	5.56

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH 4TEP3F63A AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	46.3	41.9	46.6*	48.3*	49.4*	4.35
	63	49.5	34.4	40.0	45.6	49.3	4.39
	67	52.8	26.3	31.8	37.4	41.1	4.43
95	59	44.2	41.0	44.9*	46.5*	47.6*	4.82
	63	47.3	33.5	39.1	44.6	47.6*	4.87
	67	50.5	25.4	30.9	36.5	40.2	4.93
105	63	44.9	32.5	38.1	43.6	45.6*	5.36
	67	48.0	24.4	29.9	35.5	39.2	5.42
	71	51.2	16.1	21.7	27.3	31.0	5.49
115	63	42.5	31.5	37.1	42.6*	43.6*	5.83
	67	45.5	23.4	29.0	34.5	38.2	5.92
	71	48.5	15.2	20.7	26.3	30.0	6.01

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH RXA060S3 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.1	38.6	43.4	45.5*	46.6*	4.10
	63	47.3	32.2	37.0	41.8	45.0	4.13
	67	50.5	25.1	29.9	34.7	37.9	4.17
95	59	42.3	37.7	42.4*	44.0*	45.0*	4.56
	63	45.3	31.3	36.1	41.0	44.2	4.61
	67	48.5	24.3	29.1	33.9	37.1	4.66
105	63	43.2	30.4	35.2	40.1	43.3*	5.10
	67	46.3	23.4	28.2	33.0	36.2	5.17
	71	49.4	16.2	21.0	25.8	29.0	5.24
115	63	41.2	29.5	34.4	39.2	41.5*	5.58
	67	44.1	22.5	27.3	32.1	35.3	5.67
	71	47.1	15.3	20.1	25.0	28.2	5.76

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH RXA/RXC061S3 AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.6	40.4	44.9*	46.6*	47.7*	4.12
	63	47.8	33.6	38.7	43.9	47.3	4.16
	67	51.1	26.0	31.1	36.3	39.7	4.20
95	59	42.8	39.6	43.4*	45.0*	46.0*	4.59
	63	45.8	32.7	37.8	43.0	46.0*	4.64
	67	49.0	25.1	30.3	35.4	38.8	4.69
105	63	43.7	31.8	36.9	42.1	44.2*	5.12
	67	46.7	24.2	29.4	34.5	37.9	5.19
	71	49.9	16.5	21.7	26.8	30.3	5.25
115	63	41.6	30.8	36.0	41.1	42.4*	5.60
	67	44.5	23.3	28.4	33.6	37.0	5.69
	71	47.5	15.6	20.8	25.9	29.4	5.77

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH RXC054S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.6	37.3	41.9	44.6*	45.7*	4.01
	63	46.7	31.3	35.8	40.4	43.4	4.05
	67	50.0	24.6	29.1	33.7	36.7	4.09
95	59	41.8	36.5	41.1	43.2*	44.1*	4.47
	63	44.9	30.4	35.0	39.6	42.6	4.52
	67	48.0	23.8	28.3	32.9	35.9	4.57
105	63	42.7	29.5	34.1	38.6	41.7	5.00
	67	45.7	22.8	27.4	32.0	35.0	5.07
	71	48.8	16.0	20.6	25.2	28.2	5.13
115	63	40.6	28.6	33.2	37.7	40.6*	5.47
	67	43.4	21.9	26.5	31.0	34.1	5.56
	71	46.4	15.1	19.7	24.3	27.3	5.65

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH RXC065S3 AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.6	40.5	45.0*	46.6*	47.7*	4.12
	63	47.8	33.5	38.7	43.9	47.4	4.16
	67	51.1	25.8	31.0	36.3	39.7	4.20
95	59	42.8	39.6	43.4*	45.0*	46.0*	4.59
	63	45.8	32.6	37.9	43.1	46.0*	4.64
	67	49.0	25.0	30.2	35.4	38.9	4.69
105	63	43.8	31.8	37.0	42.2	44.3*	5.12
	67	46.8	24.1	29.3	34.5	38.0	5.19
	71	50.0	16.3	21.6	26.8	30.3	5.25
115	63	41.7	30.9	36.1	41.3	42.6*	5.60
	67	44.6	23.2	28.5	33.7	37.2	5.69
	71	47.6	15.5	20.7	25.9	29.4	5.77

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH RXH063S3 AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	46.2	42.1	46.6*	48.3*	49.4*	4.15
	63	49.4	34.7	40.2	45.7	49.4	4.19
	67	52.7	26.6	32.1	37.6	41.3	4.23
95	59	44.2	41.2	45.0*	46.6*	47.6*	4.62
	63	47.3	33.8	39.3	44.8	47.6*	4.67
	67	50.5	25.8	31.3	36.8	40.4	4.72
105	63	45.0	32.8	38.3	43.8	45.7*	5.15
	67	48.1	24.8	30.3	35.8	39.5	5.22
	71	51.3	16.7	22.2	27.7	31.3	5.28
115	63	42.8	31.9	37.4	42.8*	43.8*	5.63
	67	45.7	23.9	29.4	34.9	38.5	5.71
	71	48.7	15.7	21.2	26.7	30.4	5.80

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDD100R9V5+TXH041A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.8	38.5	43.0	45.1*	46.1*	3.99
	63	46.9	32.4	37.0	41.5	44.5	4.02
	67	50.1	25.7	30.3	34.8	37.8	4.06
95	59	42.7	37.9	42.5	44.2*	45.2*	4.46
	63	45.8	31.9	36.4	41.0	44.0	4.51
	67	49.0	25.2	29.8	34.3	37.4	4.56
105	63	43.3	30.8	35.3	39.9	42.9	4.95
	67	46.4	24.1	28.7	33.2	36.2	5.02
	71	49.6	17.3	21.9	26.4	29.5	5.08
115	63	40.8	29.6	34.2	38.7	41.1*	5.40
	67	43.8	23.0	27.6	32.1	35.1	5.47
	71	46.8	16.3	20.8	25.4	28.4	5.56

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TDD100R9V5+TXH054A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.8	39.7	44.6	46.3*	47.4*	4.09
	63	47.9	33.1	38.0	42.9	46.2	4.12
	67	51.1	25.9	30.8	35.7	39.0	4.16
95	59	43.7	39.1	43.8*	45.4*	46.4*	4.57
	63	46.8	32.6	37.5	42.4	45.7	4.62
	67	50.0	25.5	30.4	35.3	38.5	4.67
105	63	44.3	31.5	36.4	41.3	44.4*	5.06
	67	47.4	24.4	29.3	34.2	37.5	5.13
	71	50.6	17.1	22.0	26.9	30.2	5.19
115	63	41.8	30.5	35.4	40.2	42.3*	5.50
	67	44.8	23.3	28.2	33.1	36.4	5.58
	71	47.9	16.1	21.0	25.9	29.2	5.66

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDD100R9V5+RXC037S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.1	38.1	42.7	45.2*	46.3*	3.96
	63	47.2	32.1	36.6	41.2	44.3	4.00
	67	50.5	25.3	29.9	34.5	37.5	4.04
95	59	42.3	37.3	41.9	43.7*	44.7*	4.42
	63	45.3	31.2	35.8	40.4	43.4	4.47
	67	48.5	24.5	29.1	33.6	36.7	4.52
105	63	43.2	30.3	34.8	39.4	42.5	4.96
	67	46.2	23.5	28.1	32.7	35.7	5.02
	71	49.3	16.7	21.3	25.9	28.9	5.08
115	63	41.0	29.3	33.9	38.5	41.2*	5.43
	67	43.9	22.6	27.2	31.8	34.8	5.51
	71	46.9	15.8	20.3	24.9	28.0	5.60

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TDD100R9V5+RXC054S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.1	37.7	42.3	45.0*	46.1*	3.96
	63	47.2	31.6	36.2	40.7	43.8	4.00
	67	50.5	24.9	29.5	34.0	37.1	4.04
95	59	42.3	36.9	41.4	43.6*	44.6*	4.42
	63	45.3	30.8	35.4	39.9	43.0	4.47
	67	48.5	24.1	28.7	33.2	36.3	4.52
105	63	43.1	29.8	34.4	39.0	42.0	4.96
	67	46.2	23.2	27.7	32.3	35.3	5.02
	71	49.3	16.4	20.9	25.5	28.5	5.09
115	63	41.0	28.9	33.5	38.0	41.0*	5.44
	67	43.8	22.2	26.8	31.4	34.4	5.52
	71	46.8	15.4	20.0	24.6	27.6	5.60

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH TDD100R9V5+RXH063S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.7	39.7	44.6	47.0*	48.0*	3.96
	63	48.8	33.1	38.0	43.0	46.2	4.00
	67	52.1	25.9	30.8	35.8	39.0	4.04
95	59	43.8	38.8	43.7	45.4*	46.4*	4.42
	63	46.8	32.3	37.2	42.1	45.4	4.47
	67	50.0	25.1	30.0	34.9	38.2	4.52
105	63	44.6	31.3	36.2	41.1	44.4	4.95
	67	47.6	24.1	29.0	33.9	37.2	5.02
	71	50.8	16.8	21.7	26.7	29.9	5.09
115	63	42.3	30.3	35.3	40.2	42.7*	5.43
	67	45.2	23.2	28.1	33.0	36.3	5.51
	71	48.2	15.9	20.8	25.7	29.0	5.60

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDD120R9V5+TXH041A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.8	38.5	43.0	45.1*	46.1*	3.94
	63	46.9	32.4	37.0	41.5	44.6	3.98
	67	50.1	25.8	30.3	34.8	37.9	4.02
95	59	42.7	37.9	42.5	44.2*	45.2*	4.42
	63	45.8	31.9	36.5	41.0	44.0	4.47
	67	49.0	25.3	29.8	34.3	37.4	4.52
105	63	43.3	30.8	35.3	39.9	42.9	4.91
	67	46.4	24.2	28.7	33.2	36.3	4.97
	71	49.6	17.4	21.9	26.5	29.5	5.04
115	63	40.8	29.7	34.2	38.8	41.1*	5.35
	67	43.8	23.1	27.6	32.2	35.2	5.43
	71	46.8	16.3	20.9	25.4	28.4	5.52

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TDD120R9V5+TXH054A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.8	39.7	44.6	46.4*	47.4*	4.00
	63	47.9	33.2	38.1	42.9	46.2	4.04
	67	51.1	26.0	30.9	35.8	39.0	4.08
95	59	43.7	39.2	43.8*	45.4*	46.5*	4.49
	63	46.8	32.7	37.6	42.5	45.7	4.54
	67	50.0	25.5	30.4	35.3	38.6	4.59
105	63	44.3	31.6	36.5	41.4	44.4*	4.97
	67	47.4	24.5	29.4	34.3	37.5	5.04
	71	50.6	17.2	22.1	27.0	30.3	5.10
115	63	41.9	30.5	35.4	40.3	42.4*	5.41
	67	44.8	23.4	28.3	33.2	36.5	5.49
	71	47.9	16.2	21.1	26.0	29.2	5.57

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDD120R9V5+RXH063S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	46.1	40.0	44.9	47.4*	48.4*	3.89
	63	49.3	33.5	38.4	43.3	46.6	3.93
	67	52.6	26.3	31.2	36.1	39.4	3.97
95	59	44.2	39.2	44.1	45.8*	46.8*	4.36
	63	47.3	32.6	37.5	42.4	45.7	4.41
	67	50.5	25.4	30.3	35.2	38.5	4.46
105	63	45.0	31.6	36.5	41.4	44.7	4.90
	67	48.1	24.4	29.4	34.3	37.5	4.96
	71	51.2	17.1	22.1	27.0	30.3	5.02
115	63	42.8	30.7	35.6	40.5	43.1*	5.38
	67	45.7	23.5	28.4	33.3	36.6	5.45
	71	48.7	16.2	21.1	26.0	29.3	5.53

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDY100R9V4+TXH041A4 AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	42.9	37.0	41.4	43.9*	45.0*	4.01
	63	46.0	31.3	35.7	40.0	42.8	4.04
	67	49.3	25.0	29.3	33.6	36.5	4.08
95	59	41.9	36.6	40.9	43.1*	44.1*	4.48
	63	45.0	30.9	35.2	39.5	42.4	4.53
	67	48.2	24.6	28.9	33.2	36.1	4.57
105	63	42.5	29.7	34.0	38.4	41.2	4.97
	67	45.6	23.4	27.8	32.1	34.9	5.03
	71	48.8	17.0	21.3	25.6	28.5	5.10
115	63	40.1	28.6	32.9	37.2	40.1*	5.41
	67	43.0	22.3	26.7	31.0	33.8	5.49
	71	46.1	15.9	20.3	24.6	27.4	5.57

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TDY100R9V4+TXH054A4 AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.9	38.1	42.8	45.1*	46.1*	4.05
	63	47.0	32.0	36.6	41.2	44.3	4.09
	67	50.3	25.2	29.8	34.5	37.5	4.13
95	59	42.9	37.7	42.3	44.3*	45.3*	4.53
	63	46.0	31.5	36.2	40.8	43.9	4.58
	67	49.2	24.8	29.4	34.0	37.1	4.63
105	63	43.6	30.4	35.1	39.7	42.8	5.02
	67	46.7	23.7	28.3	33.0	36.0	5.08
	71	49.9	16.9	21.5	26.1	29.2	5.14
115	63	41.1	29.4	34.0	38.6	41.3*	5.45
	67	44.1	22.7	27.3	31.9	35.0	5.53
	71	47.1	15.8	20.5	25.1	28.2	5.61

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH TDY100R9V4+RXC037S3 AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.8	37.2	41.6	44.5*	45.6*	4.00
	63	46.9	31.5	35.8	40.2	43.1	4.04
	67	50.2	25.1	29.4	33.8	36.7	4.08
95	59	42.0	36.4	40.7	43.1*	44.1*	4.47
	63	45.1	30.6	35.0	39.3	42.2	4.52
	67	48.3	24.2	28.6	32.9	35.8	4.57
105	63	42.9	29.6	34.0	38.4	41.3	5.01
	67	46.0	23.3	27.6	32.0	34.9	5.07
	71	49.2	16.8	21.1	25.5	28.4	5.14
115	63	40.8	28.7	33.0	37.4	40.3	5.49
	67	43.7	22.3	26.7	31.0	33.9	5.57
	71	46.8	15.9	20.2	24.6	27.5	5.67

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TDY100R9V4+RXC054S3 AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.2	36.3	40.7	43.9*	44.9*	3.96
	63	46.4	30.6	34.9	39.3	42.1	4.00
	67	49.7	24.3	28.6	32.9	35.8	4.04
95	59	41.5	35.5	39.9	42.5*	43.5*	4.42
	63	44.6	29.8	34.1	38.5	41.3	4.47
	67	47.7	23.5	27.8	32.1	35.0	4.52
105	63	42.5	28.9	33.2	37.5	40.4	4.96
	67	45.5	22.6	26.9	31.2	34.1	5.02
	71	48.6	16.1	20.5	24.8	27.7	5.08
115	63	40.3	28.0	32.3	36.6	39.5	5.43
	67	43.2	21.7	26.0	30.3	33.2	5.51
	71	46.2	15.2	19.6	23.9	26.8	5.60

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDY100R9V4+RXH063S3 AT 1500 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.4	38.6	43.2	46.2*	47.3*	3.98
	63	48.6	32.4	37.0	41.7	44.8	4.01
	67	51.9	25.6	30.2	34.9	38.0	4.05
95	59	43.5	37.7	42.3	44.7*	45.7*	4.44
	63	46.6	31.5	36.1	40.8	43.9	4.49
	67	49.8	24.7	29.3	34.0	37.1	4.54
105	63	44.4	30.5	35.2	39.8	42.9	4.97
	67	47.4	23.7	28.4	33.0	36.1	5.04
	71	50.6	16.8	21.5	26.1	29.2	5.11
115	63	42.1	29.6	34.2	38.9	42.0	5.45
	67	45.1	22.8	27.4	32.1	35.2	5.54
	71	48.1	15.9	20.6	25.2	28.3	5.63

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1300	1700	AIRFLOW	1300	1700
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDY120R9V5+TXH041A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	42.8	35.8	39.8	43.2*	44.1*	3.91
	63	45.9	30.5	34.5	38.5	41.2	3.95
	67	49.1	24.5	28.6	32.6	35.3	3.99
95	59	41.7	35.2	39.3	42.3*	43.3*	4.38
	63	44.8	30.0	34.0	38.0	40.7	4.43
	67	48.0	24.1	28.1	32.1	34.8	4.48
105	63	42.3	28.8	32.8	36.9	39.5	4.88
	67	45.3	23.0	27.0	31.0	33.7	4.94
	71	48.5	17.0	21.0	25.0	27.7	5.00
115	63	39.8	27.7	31.7	35.7	38.4	5.32
	67	42.7	21.8	25.9	29.9	32.6	5.40
	71	45.8	15.9	19.9	23.9	26.6	5.48

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TDY120R9V5+TXH054A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.7	36.8	41.1	44.3*	45.4*	3.95
	63	46.8	31.1	35.4	39.7	42.5	3.99
	67	50.0	24.8	29.1	33.4	36.2	4.03
95	59	42.7	36.3	40.6	43.4*	44.5*	4.43
	63	45.7	30.6	34.9	39.2	42.1	4.48
	67	48.9	24.3	28.6	32.9	35.8	4.53
105	63	43.3	29.5	33.8	38.1	41.0	4.92
	67	46.4	23.2	27.5	31.9	34.7	4.98
	71	49.5	16.8	21.2	25.5	28.3	5.04
115	63	40.8	28.4	32.7	37.0	39.9	5.36
	67	43.8	22.2	26.5	30.8	33.7	5.43
	71	46.8	15.8	20.1	24.4	27.3	5.51

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TDY120R9V5+RXH063S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.1	37.3	41.7	45.4*	46.5*	3.89
	63	48.3	31.5	35.9	40.2	43.1	3.93
	67	51.5	25.2	29.5	33.9	36.8	3.97
95	59	43.2	36.4	40.8	43.9*	44.9*	4.36
	63	46.3	30.7	35.0	39.3	42.2	4.41
	67	49.5	24.3	28.7	33.0	35.9	4.46
105	63	44.1	29.7	34.0	38.4	41.3	4.89
	67	47.1	23.4	27.7	32.1	35.0	4.95
	71	50.3	16.9	21.3	25.6	28.5	5.02
115	63	41.9	28.7	33.1	37.4	40.3	5.37
	67	44.8	22.4	26.8	31.1	34.0	5.45
	71	47.8	16.0	20.3	24.7	27.6	5.54

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH TUD100R9V5+TXH041A4 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.8	39.5	44.0*	45.6*	46.6*	4.08
	63	46.9	33.1	37.9	42.7	46.0	4.11
	67	50.2	26.0	30.8	35.6	38.8	4.15
95	59	42.8	39.0	43.1*	44.7*	45.8*	4.56
	63	45.9	32.6	37.4	42.3	45.5	4.61
	67	49.1	25.6	30.4	35.2	38.4	4.66
105	63	43.4	31.5	36.3	41.1	43.7*	5.05
	67	46.5	24.5	29.3	34.1	37.3	5.11
	71	49.7	17.3	22.1	26.9	30.1	5.18
115	63	40.9	30.4	35.2	40.0	41.6*	5.49
	67	43.9	23.4	28.2	33.0	36.2	5.57
	71	47.0	16.2	21.0	25.8	29.0	5.65

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TUD100R9V5+TXH054A4 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.9	40.9	45.3*	46.9*	48.0*	4.13
	63	48.0	34.0	39.2	44.4	47.8	4.17
	67	51.3	26.4	31.6	36.8	40.2	4.21
95	59	43.8	40.4	44.4*	46.0*	47.1*	4.62
	63	46.9	33.5	38.7	43.9	47.1*	4.67
	67	50.2	25.9	31.1	36.3	39.8	4.72
105	63	44.5	32.4	37.6	42.8	45.0*	5.11
	67	47.6	24.9	30.1	35.3	38.7	5.17
	71	50.8	17.2	22.4	27.6	31.0	5.23
115	63	42.0	31.4	36.6	41.7	42.9*	5.54
	67	45.0	23.8	29.0	34.2	37.7	5.62
	71	48.1	16.1	21.3	26.5	30.0	5.70

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUD100R9V5+RXCO37S3 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.2	39.4	44.2	45.8*	46.9*	4.02
	63	47.4	32.9	37.7	42.6	45.8	4.06
	67	50.7	25.8	30.6	35.5	38.7	4.10
95	59	42.4	38.5	42.7*	44.3*	45.3*	4.49
	63	45.5	32.0	36.9	41.7	45.0	4.54
	67	48.6	24.9	29.8	34.6	37.8	4.59
105	63	43.3	31.1	35.9	40.8	43.5*	5.02
	67	46.3	24.0	28.8	33.7	36.9	5.08
	71	49.5	16.7	21.6	26.4	29.6	5.15
115	63	41.2	30.1	35.0	39.8	41.7*	5.49
	67	44.0	23.0	27.9	32.7	36.0	5.58
	71	47.0	15.8	20.6	25.5	28.7	5.67

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TUD100R9V5+RXCO54S3 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.2	38.8	43.6	45.7*	46.7*	4.07
	63	47.4	32.4	37.2	42.0	45.3	4.10
	67	50.7	25.3	30.1	34.9	38.2	4.14
95	59	42.4	38.0	42.5*	44.1*	45.1*	4.53
	63	45.5	31.5	36.4	41.2	44.4	4.58
	67	48.6	24.4	29.3	34.1	37.3	4.63
105	63	43.3	30.6	35.4	40.2	43.3*	5.06
	67	46.3	23.5	28.3	33.2	36.4	5.13
	71	49.4	16.3	21.1	25.9	29.2	5.20
115	63	41.1	29.6	34.5	39.3	41.5*	5.54
	67	44.0	22.5	27.4	32.2	35.4	5.63
	71	47.0	15.3	20.2	25.0	28.3	5.71

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUD100R9V5+RXH063S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.7	39.7	44.6	47.0*	48.0*	4.04
	63	48.8	33.1	38.0	42.9	46.2	4.08
	67	52.1	25.9	30.8	35.7	39.0	4.12
95	59	43.8	38.8	43.7	45.4*	46.4*	4.51
	63	46.8	32.2	37.1	42.0	45.3	4.56
	67	50.0	25.0	29.9	34.8	38.1	4.61
105	63	44.6	31.2	36.1	41.1	44.4	5.04
	67	47.6	24.0	29.0	33.9	37.2	5.11
	71	50.8	16.7	21.7	26.6	29.9	5.17
115	63	42.3	30.3	35.2	40.1	42.6*	5.52
	67	45.2	23.1	28.0	32.9	36.2	5.60
	71	48.2	15.6	20.7	25.6	28.9	5.69

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUD120R9V5+TXH041A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.8	38.3	42.8	45.0*	46.0*	3.97
	63	46.9	32.3	36.8	41.3	44.4	4.01
	67	50.1	25.6	30.1	34.7	37.7	4.05
95	59	42.6	37.8	42.3	44.0*	45.1*	4.44
	63	45.7	31.8	36.3	40.8	43.8	4.49
	67	48.9	25.1	29.6	34.2	37.2	4.54
105	63	43.2	30.6	35.2	39.7	42.7	4.94
	67	46.3	24.0	28.5	33.1	36.1	5.00
	71	49.5	17.2	21.8	26.3	29.3	5.07
115	63	40.7	29.5	34.1	38.6	41.0*	5.37
	67	43.7	22.9	27.4	32.0	35.0	5.46
	71	46.8	16.2	20.7	25.2	28.3	5.55

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY).
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.

Performance Data

Cooling

4TTR2048A1 WITH TUD120R9V5+TXH054A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.2	40.0	44.9	46.7*	47.8*	4.05
	63	48.4	33.4	38.3	43.2	46.5	4.09
	67	51.6	26.2	31.1	36.0	39.3	4.13
95	59	44.1	39.4	44.1*	45.8*	46.8*	4.54
	63	47.2	32.9	37.8	42.7	45.9	4.59
	67	50.4	25.7	30.6	35.5	38.8	4.64
105	63	44.7	31.8	36.7	41.6	44.7*	5.03
	67	47.8	24.7	29.5	34.4	37.7	5.09
	71	51.0	17.4	22.3	27.2	30.5	5.16
115	63	42.2	30.7	35.6	40.5	42.7*	5.46
	67	45.2	23.6	28.5	33.4	36.6	5.55
	71	48.3	16.4	21.3	26.2	29.4	5.63

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUD120R9V5+RXH063S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	46.1	40.0	44.9	47.4*	48.4*	3.93
	63	49.3	33.4	38.3	43.3	46.5	3.97
	67	52.6	26.2	31.1	36.1	39.3	4.01
95	59	44.2	39.1	44.0	45.8*	46.8*	4.40
	63	47.3	32.6	37.5	42.4	45.7	4.45
	67	50.5	25.4	30.3	35.2	38.5	4.50
105	63	45.0	31.6	36.5	41.4	44.7	4.93
	67	48.1	24.4	29.3	34.2	37.5	5.00
	71	51.2	17.1	22.0	26.9	30.2	5.06
115	63	42.8	30.6	35.5	40.5	43.1*	5.42
	67	45.7	23.5	28.4	33.3	36.6	5.50
	71	48.7	16.2	21.1	26.0	29.3	5.58

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUD120R9V5+RXC065S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.5	38.6	43.2	45.7*	46.8*	3.90
	63	47.7	32.3	37.0	41.7	44.8	3.94
	67	51.0	25.4	30.1	34.8	37.9	3.98
95	59	42.7	37.7	42.4	44.2*	45.2*	4.36
	63	45.8	31.5	36.2	40.8	44.0	4.41
	67	48.9	24.6	29.3	34.0	37.1	4.46
105	63	43.7	30.6	35.3	40.0	43.1	4.90
	67	46.8	23.7	28.4	33.1	36.2	4.96
	71	49.9	16.8	21.5	26.1	29.3	5.03
115	63	41.7	29.7	34.4	39.1	41.9*	5.37
	67	44.6	22.9	27.6	32.2	35.4	5.46
	71	47.6	15.9	20.6	25.3	28.4	5.55

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TUD140R9V5+TXH041A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.8	38.5	43.0	45.1*	46.1*	3.96
	63	46.9	32.4	37.0	41.5	44.6	4.00
	67	50.1	25.7	30.3	34.8	37.9	4.04
95	59	42.7	37.9	42.5	44.2*	45.2*	4.44
	63	45.8	31.9	36.5	41.0	44.0	4.49
	67	49.0	25.3	29.8	34.3	37.4	4.54
105	63	43.3	30.8	35.3	39.9	42.9	4.93
	67	46.4	24.1	28.7	33.2	36.3	5.00
	71	49.6	17.4	21.9	26.5	29.5	5.06
115	63	40.8	29.7	34.2	38.8	41.1*	5.37
	67	43.8	23.1	27.6	32.1	35.2	5.45
	71	46.8	16.3	20.8	25.4	28.4	5.54

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TUD140R9V5+TXH054A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.8	39.7	44.6	46.3*	47.4*	4.02
	63	47.9	33.2	38.1	42.9	46.2	4.06
	67	51.1	26.0	30.9	35.8	39.0	4.10
95	59	43.7	39.2	43.8*	45.4*	46.4*	4.51
	63	46.8	32.7	37.6	42.5	45.7	4.56
	67	50.0	25.5	30.4	35.3	38.6	4.61
105	63	44.3	31.6	36.5	41.4	44.4*	5.00
	67	47.4	24.5	29.4	34.2	37.5	5.06
	71	50.6	17.2	22.1	27.0	30.3	5.13
115	63	41.9	30.5	35.4	40.3	42.4*	5.43
	67	44.8	23.4	28.3	33.2	36.5	5.51
	71	47.9	16.2	21.1	26.0	29.2	5.60

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUD140R9V5+RXC063S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	46.2	40.1	45.1	47.5*	48.5*	3.92
	63	49.3	33.6	38.5	43.4	46.7	3.96
	67	52.6	26.3	31.3	36.2	39.5	4.00
95	59	44.2	39.3	44.2	45.8*	46.9*	4.39
	63	47.3	32.7	37.6	42.5	45.8	4.44
	67	50.5	25.5	30.4	35.3	38.6	4.49
105	63	45.0	31.7	36.6	41.6	44.8	4.92
	67	48.1	24.5	29.4	34.4	37.6	4.99
	71	51.3	17.2	22.1	27.0	30.3	5.05
115	63	42.8	30.7	35.7	40.6	43.1*	5.40
	67	45.7	23.5	28.5	33.4	36.7	5.48
	71	48.7	16.2	21.2	26.1	29.4	5.57

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH TUD140R9V5+RXC065S3 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.1	37.4	42.1	44.4*	45.4*	3.77
	63	46.2	31.3	35.9	40.6	43.7	3.81
	67	49.5	24.5	29.2	33.8	36.9	3.85
95	59	41.5	36.7	41.3	43.0*	43.9*	4.22
	63	44.4	30.5	35.2	39.8	42.9	4.27
	67	47.5	23.8	28.4	33.0	36.1	4.32
105	63	42.5	29.7	34.4	39.0	42.1	4.74
	67	45.4	22.9	27.6	32.2	35.3	4.80
	71	48.4	16.0	20.7	25.3	28.4	4.86
115	63	40.6	28.9	33.5	38.2	40.8*	5.21
	67	43.4	22.1	26.8	31.4	34.5	5.28
	71	46.2	15.2	19.8	24.5	27.6	5.36

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUY100R9V4+TXH041A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	42.8	35.7	39.7	43.1*	44.1*	3.93
	63	45.9	30.4	34.4	38.4	41.1	3.97
	67	49.1	24.5	28.5	32.5	35.2	4.01
95	59	41.6	35.1	39.1	42.2*	43.2*	4.39
	63	44.7	29.8	33.9	37.9	40.6	4.44
	67	47.9	24.0	28.0	32.0	34.7	4.49
105	63	42.2	28.7	32.7	36.7	39.4	4.89
	67	45.3	22.9	26.9	30.9	33.6	4.95
	71	48.4	16.9	20.9	24.9	27.6	5.02
115	63	39.7	27.6	31.6	35.6	38.3	5.33
	67	42.7	21.8	25.8	29.8	32.5	5.42
	71	45.7	15.8	19.8	23.8	26.5	5.50

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TUY100R9V4+TXH054A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.7	36.7	41.0	44.3*	45.4*	3.97
	63	46.8	31.0	35.3	39.6	42.5	4.01
	67	50.0	24.7	29.0	33.3	36.2	4.05
95	59	42.6	36.2	40.5	43.4*	44.4*	4.44
	63	45.7	30.5	34.8	39.1	42.0	4.49
	67	48.9	24.2	28.5	32.8	35.7	4.54
105	63	43.2	29.4	33.7	38.0	40.9	4.93
	67	46.3	23.1	27.5	31.8	34.6	4.99
	71	49.4	16.8	21.1	25.4	28.2	5.05
115	63	40.8	28.3	32.6	36.9	39.8	5.37
	67	43.7	22.1	26.4	30.7	33.6	5.44
	71	46.7	15.7	20.0	24.3	27.2	5.52

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUY100R9V4+RXC037S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.4	35.8	39.9	43.6*	44.6*	3.91
	63	46.5	30.4	34.5	38.5	41.2	3.94
	67	49.8	24.5	28.5	32.6	35.3	3.98
95	59	41.7	35.0	39.0	42.2*	43.2*	4.37
	63	44.7	29.6	33.6	37.7	40.4	4.42
	67	47.8	23.6	27.7	31.8	34.5	4.47
105	63	42.6	28.6	32.7	36.8	39.5	4.90
	67	45.6	22.7	26.8	30.8	33.5	4.97
	71	48.7	16.7	20.7	24.8	27.5	5.03
115	63	40.5	27.7	31.8	35.8	38.5	5.39
	67	43.4	21.8	25.8	29.9	32.6	5.47
	71	46.4	15.7	19.8	23.9	26.6	5.55

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TUY100R9V4+RXC054S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.4	35.4	39.5	43.5*	44.5*	3.91
	63	46.5	30.1	34.1	38.2	40.9	3.94
	67	49.8	24.1	28.2	32.2	35.0	3.98
95	59	41.7	34.6	38.7	42.0*	43.1*	4.37
	63	44.7	29.3	33.3	37.4	40.1	4.42
	67	47.8	23.3	27.4	31.4	34.1	4.47
105	63	42.6	28.3	32.4	36.4	39.1	4.91
	67	45.6	22.4	26.5	30.5	33.2	4.97
	71	48.7	16.4	20.4	24.5	27.2	5.04
115	63	40.5	27.4	31.5	35.5	38.2	5.39
	67	43.4	21.5	25.5	29.6	32.3	5.47
	71	46.4	15.5	19.5	23.6	26.3	5.56

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TUY100R9V4+RXH063S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.0	37.2	41.5	45.3*	46.4*	3.90
	63	48.2	31.4	35.7	40.1	42.9	3.94
	67	51.5	25.0	29.4	33.7	36.8	3.98
95	59	43.2	36.3	40.6	43.8*	44.8*	4.37
	63	46.2	30.5	34.9	39.2	42.1	4.42
	67	49.4	24.2	28.5	32.9	35.8	4.47
105	63	44.0	29.6	33.9	38.2	41.1	4.90
	67	47.1	23.2	27.6	31.9	34.8	4.97
	71	50.2	16.8	21.2	25.5	28.4	5.04
115	63	41.8	28.6	33.0	37.3	40.2	5.38
	67	44.8	22.3	26.6	31.0	33.9	5.47
	71	47.8	15.9	20.2	24.6	27.5	5.56

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH TUY120R9V5+TXH041A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	42.8	35.9	39.9	43.2*	44.2*	3.88
	63	45.9	30.5	34.6	38.6	41.3	3.92
	67	49.1	24.6	28.7	32.7	35.4	3.96
95	59	41.7	35.3	39.4	42.3*	43.3*	4.35
	63	44.8	30.0	34.1	38.1	40.8	4.39
	67	48.0	24.2	28.2	32.2	34.9	4.44
105	63	42.3	28.9	32.9	37.0	39.6	4.84
	67	45.4	23.0	27.1	31.1	33.8	4.90
	71	48.6	17.0	21.1	25.1	27.8	4.97
115	63	39.8	27.8	31.8	35.8	38.5	5.28
	67	42.8	21.9	26.0	30.0	32.7	5.37
	71	45.8	16.0	20.0	24.0	26.7	5.45

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TUY120R9V5+TXH054A4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.2	37.2	41.5	44.7*	45.8*	3.95
	63	47.3	31.4	35.7	40.0	42.9	3.99
	67	50.5	25.1	29.4	33.7	36.6	4.03
95	59	43.1	36.6	40.9	43.8*	44.9*	4.43
	63	46.2	30.9	35.2	39.5	42.4	4.47
	67	49.4	24.6	28.9	33.2	36.1	4.52
105	63	43.7	29.8	34.1	38.4	41.3	4.92
	67	46.8	23.5	27.8	32.2	35.0	4.98
	71	50.0	17.1	21.5	25.8	28.6	5.05
115	63	41.2	28.7	33.0	37.3	40.2	5.36
	67	44.2	22.5	26.8	31.1	34.0	5.44
	71	47.3	16.1	20.4	24.7	27.6	5.52

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUY120R9V5+RXH063S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	45.1	37.3	41.7	45.4*	46.5*	3.87
	63	48.3	31.5	35.9	40.2	43.1	3.91
	67	51.6	25.2	29.5	33.9	36.8	3.95
95	59	43.3	36.4	40.8	43.9*	45.0*	4.34
	63	46.3	30.7	35.0	39.4	42.3	4.39
	67	49.5	24.3	28.7	33.0	35.9	4.44
105	63	44.2	29.7	34.1	38.4	41.3	4.88
	67	47.2	23.4	27.7	32.1	35.0	4.94
	71	50.3	17.0	21.3	25.6	28.5	5.01
115	63	42.0	28.8	33.1	37.5	40.4	5.36
	67	44.9	22.5	26.8	31.2	34.0	5.44
	71	47.9	16.0	20.4	24.7	27.6	5.53

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.06

4TTR2048A1 WITH TUY120R9V5+RXC065S3 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.0	36.4	40.6	44.3*	45.4*	3.84
	63	47.2	30.9	35.1	39.2	42.0	3.88
	67	50.4	24.8	29.0	33.1	35.9	3.92
95	59	42.3	35.6	39.7	42.9*	43.9*	4.31
	63	45.3	30.1	34.2	38.4	41.2	4.36
	67	48.5	24.0	28.2	32.3	35.1	4.41
105	63	43.4	29.2	33.4	37.5	40.3	4.85
	67	46.4	23.1	27.3	31.5	34.2	4.91
	71	49.6	16.9	21.1	25.3	28.0	4.98
115	63	41.4	28.3	32.5	36.6	39.4	5.33
	67	44.3	22.3	26.4	30.6	33.4	5.42
	71	47.4	16.1	20.3	24.4	27.2	5.51

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TWE042C14 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	41.9	37.0	41.5	43.3*	44.3*	4.13
	63	45.0	31.1	35.6	40.1	43.0	4.17
	67	48.2	24.6	29.0	33.5	36.5	4.20
95	59	40.8	36.5	40.9*	42.4*	43.5*	4.59
	63	43.9	30.6	35.1	39.6	42.5	4.64
	67	47.1	24.1	28.6	33.0	36.0	4.69
105	63	41.5	29.5	34.0	38.5	41.4	5.08
	67	44.5	23.0	27.5	31.9	34.9	5.15
	71	47.7	16.3	20.8	25.3	28.2	5.21
115	63	39.1	28.4	32.9	37.4	39.5*	5.53
	67	42.0	21.9	26.4	30.8	33.8	5.61
	71	45.0	15.3	19.7	24.2	27.2	5.69

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TWE048C14 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.2	38.1	42.7	44.6*	45.6*	4.13
	63	46.3	32.0	36.6	41.2	44.2	4.17
	67	49.5	25.2	29.8	34.4	37.5	4.21
95	59	42.2	37.6	42.2*	43.7*	44.8*	4.61
	63	45.3	31.5	36.1	40.7	43.8	4.66
	67	48.5	24.8	29.4	34.0	37.0	4.71
105	63	42.8	30.4	35.0	39.6	42.7	5.10
	67	45.9	23.7	28.3	32.9	35.9	5.17
	71	49.1	16.8	21.4	26.0	29.1	5.23
115	63	40.4	29.3	33.9	38.5	40.7*	5.55
	67	43.4	22.6	27.2	31.8	34.9	5.63
	71	46.5	15.8	20.4	25.0	28.0	5.71

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH TXA/TXC042C4 AT 1200 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	40.3	32.0	35.4	38.9	40.7*	3.85
	63	43.4	27.5	30.9	34.4	36.7	3.89
	67	46.5	22.4	25.9	29.4	31.7	3.93
95	59	39.3	31.5	34.9	38.4	39.9*	4.30
	63	42.4	27.0	30.5	33.9	36.2	4.35
	67	45.5	22.0	25.5	28.9	31.2	4.40
105	63	39.9	25.9	29.3	32.8	35.1	4.81
	67	42.9	20.9	24.4	27.8	30.1	4.87
	71	46.0	15.8	19.3	22.7	25.0	4.93
115	63	37.5	24.8	28.2	31.7	34.0	5.26
	67	40.4	19.8	23.3	26.7	29.0	5.34
	71	43.3	14.7	18.2	21.6	23.9	5.41

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1050	1350	AIRFLOW	1050	1350
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TXA/TXC043C4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	42.3	36.8	41.3	43.5*	44.5*	4.06
	63	45.4	30.9	35.4	39.9	42.8	4.09
	67	48.6	24.4	28.8	33.3	36.3	4.13
95	59	41.3	36.4	40.9	42.7*	43.8*	4.53
	63	44.4	30.5	35.0	39.4	42.4	4.57
	67	47.6	24.0	28.4	32.9	35.9	4.62
105	63	41.9	29.4	33.9	38.3	41.3	5.02
	67	45.0	22.9	27.3	31.8	34.8	5.08
	71	48.2	16.2	20.7	25.2	28.1	5.15
115	63	39.4	28.3	32.8	37.2	39.7*	5.46
	67	42.4	21.8	26.3	30.7	33.7	5.54
	71	45.4	15.2	19.6	24.1	27.1	5.62

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2048A1 WITH TXA/TXC048C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	42.0	34.9	39.0	42.4*	43.4*	3.96
	63	45.1	29.6	33.6	37.7	40.4	4.00
	67	48.3	23.7	27.7	31.8	34.5	4.04
95	59	41.0	34.5	38.5	41.6*	42.6*	4.43
	63	44.1	29.2	33.2	37.3	40.0	4.48
	67	47.3	23.3	27.3	31.4	34.1	4.53
105	63	41.6	28.0	32.1	36.1	38.8	4.92
	67	44.7	22.2	26.2	30.3	33.0	4.98
	71	47.8	16.2	20.2	24.2	26.9	5.05
115	63	39.1	26.9	31.0	35.0	37.7	5.36
	67	42.0	21.1	25.1	29.2	31.9	5.44
	71	45.0	15.1	19.1	23.2	25.9	5.52

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TXA/TXC049C4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.3	37.5	42.1	44.4*	45.5*	4.09
	63	46.4	31.4	36.0	40.5	43.6	4.13
	67	49.6	24.7	29.3	33.8	36.9	4.17
95	59	42.2	37.0	41.5	43.5*	44.6*	4.57
	63	45.3	30.9	35.5	40.1	43.1	4.61
	67	48.5	24.3	28.8	33.4	36.4	4.66
105	63	42.7	29.8	34.4	38.9	42.0	5.06
	67	45.8	23.2	27.7	32.3	35.3	5.12
	71	49.0	16.4	20.9	25.5	28.5	5.18
115	63	40.2	28.7	33.3	37.8	40.4*	5.49
	67	43.2	22.1	26.6	31.2	34.2	5.57
	71	46.2	15.3	19.9	24.4	27.5	5.65

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TXA/TXC050C4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.3	37.5	42.1	44.4*	45.5*	4.09
	63	46.4	31.4	36.0	40.5	43.6	4.13
	67	49.6	24.7	29.3	33.8	36.9	4.17
95	59	42.2	37.0	41.5	43.5*	44.6*	4.57
	63	45.3	30.9	35.5	40.1	43.1	4.61
	67	48.5	24.3	28.8	33.4	36.4	4.66
105	63	42.7	29.8	34.4	38.9	42.0	5.06
	67	45.8	23.2	27.7	32.3	35.3	5.12
	71	49.0	16.4	20.9	25.5	28.5	5.18
115	63	40.2	28.7	33.3	37.8	40.4*	5.49
	67	43.2	22.1	26.6	31.2	34.2	5.57
	71	46.2	15.3	19.9	24.4	27.5	5.65

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2048A1 WITH TXH041A4 AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	43.4	38.2	42.7	44.7*	45.8*	4.10
	63	46.5	32.1	36.7	41.2	44.3	4.14
	67	49.7	25.4	29.9	34.5	37.5	4.18
95	59	42.3	37.6	42.2	43.8*	44.9*	4.57
	63	45.4	31.6	36.1	40.7	43.7	4.62
	67	48.6	24.9	29.5	34.0	37.1	4.67
105	63	42.9	30.5	35.0	39.6	42.6	5.07
	67	46.0	23.8	28.3	32.9	35.9	5.13
	71	49.2	17.0	21.5	26.1	29.1	5.20
115	63	40.4	29.3	33.9	38.4	40.7*	5.51
	67	43.4	22.7	27.2	31.8	34.8	5.59
	71	46.4	15.9	20.5	25.0	28.1	5.68

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2048A1 WITH TXH054A4 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	44.7	40.6	45.1*	46.7*	47.8*	4.17
	63	47.9	33.7	38.9	44.0	47.5	4.21
	67	51.1	26.1	31.3	36.4	39.9	4.25
95	59	43.7	40.1	44.2*	45.8*	46.8*	4.66
	63	46.8	33.2	38.4	43.5	46.8*	4.71
	67	50.0	25.6	30.8	36.0	39.4	4.76
105	63	44.3	32.1	37.3	42.5	44.8*	5.15
	67	47.4	24.6	29.7	34.9	38.4	5.21
	71	50.6	16.9	22.1	27.3	30.7	5.28
115	63	41.8	31.0	36.2	41.4	42.7*	5.58
	67	44.8	23.5	28.7	33.9	37.3	5.66
	71	47.9	15.9	21.1	26.2	29.7	5.74

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2060A1 WITH 4TEE3F49A AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	55.5	46.4	52.0	56.2*	57.5*	5.00
	63	59.3	39.0	44.6	50.1	53.8	5.06
	67	63.3	30.9	36.4	42.0	45.6	5.12
95	59	53.0	45.3	50.8	54.1*	55.4*	5.59
	63	56.7	37.9	43.4	48.9	52.6	5.66
	67	60.5	29.8	35.3	40.8	44.5	5.73
105	63	54.1	36.8	42.3	47.8	51.5	6.23
	67	57.8	28.7	34.2	39.7	43.4	6.31
	71	61.5	20.4	25.9	31.5	35.1	6.40
115	63	51.5	35.6	41.1	46.7	50.3	6.79
	67	55.0	27.6	33.1	38.6	42.3	6.89
	71	58.6	19.3	24.8	30.4	34.0	6.99

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2060A1 WITH 4TEE3F65A AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	56.5	47.2	52.8	57.1*	58.5*	4.91
	63	60.4	39.7	45.3	50.9	54.6	4.97
	67	64.3	31.5	37.1	42.7	46.4	5.03
95	59	54.0	46.0	51.6	55.0*	56.3*	5.49
	63	57.7	38.5	44.1	49.7	53.4	5.57
	67	61.5	30.3	35.9	41.5	45.2	5.64
105	63	55.0	37.4	42.9	48.5	52.2	6.12
	67	58.7	29.2	34.8	40.3	44.1	6.22
	71	62.5	20.9	26.4	32.0	35.7	6.32
115	63	52.3	36.2	41.8	47.4	51.1	6.67
	67	55.8	28.0	33.6	39.2	42.9	6.79
	71	59.5	19.7	25.3	30.9	34.6	6.92

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2060A1 WITH 4TEP3F42A AT 1600 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	52.0	41.9	46.5	51.0	52.8*	4.88
	63	55.7	35.9	40.4	45.0	48.0	4.94
	67	59.6	29.2	33.7	38.3	41.3	5.00
95	59	49.8	40.8	45.4	49.8*	51.0*	5.46
	63	53.4	34.8	39.4	43.9	46.9	5.53
	67	57.2	28.1	32.7	37.2	40.2	5.60
105	63	51.0	33.7	38.3	42.8	45.8	6.09
	67	54.7	27.0	31.6	36.1	39.2	6.18
	71	58.4	20.2	24.7	29.3	32.3	6.27
115	63	48.7	32.6	37.2	41.7	44.8	6.65
	67	52.1	25.9	30.5	35.1	38.1	6.76
	71	55.7	19.1	23.7	28.2	31.3	6.87

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1400	1800	AIRFLOW	1400	1800
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2060A1 WITH 4TEP3F48A AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	54.0	45.2	50.7	54.7*	56.0*	4.86
	63	57.8	37.9	43.4	48.9	52.5	4.91
	67	61.7	29.9	35.4	40.8	44.5	4.97
95	59	51.7	44.2	49.6	52.9*	54.1*	5.43
	63	55.3	36.9	42.3	47.8	51.4	5.50
	67	59.0	28.8	34.3	39.8	43.4	5.57
105	63	52.8	35.8	41.2	46.7	50.3	6.05
	67	56.3	27.8	33.2	38.7	42.3	6.12
	71	60.0	19.6	25.1	30.5	34.2	6.21
115	63	50.3	34.7	40.2	45.6	49.3	6.59
	67	53.7	26.7	32.2	37.6	41.3	6.68
	71	57.1	18.6	24.0	29.5	33.1	6.78

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.05

4TTR2060A1 WITH 4TEP3F63A AT 2000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	56.1	48.6	54.8	57.7*	59.0*	5.28
	63	60.0	40.4	46.5	52.7	56.8	5.34
	67	64.0	31.3	37.5	43.6	47.7	5.40
95	59	53.5	47.4	53.5*	55.5*	56.7*	5.86
	63	57.2	39.2	45.3	51.5	55.5	5.93
	67	61.0	30.1	36.3	42.4	46.5	6.01
105	63	54.5	38.0	44.1	50.3	54.4	6.48
	67	58.1	29.0	35.1	41.3	45.4	6.58
	71	61.9	19.8	25.9	32.1	36.2	6.68
115	63	51.7	36.8	43.0	49.1	52.2*	7.03
	67	55.2	27.8	34.0	40.1	44.2	7.15
	71	58.8	18.7	24.8	31.0	35.1	7.27

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1750	2250	AIRFLOW	1750	2250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



Performance Data Cooling

4TTR2060A1 WITH RXA060S3 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	52.8	42.7	47.6	52.4	53.8*	4.88
	63	56.6	36.3	41.2	46.0	49.2	4.94
	67	60.5	29.2	34.0	38.9	42.1	5.00
95	59	50.6	41.7	46.5	50.8*	52.0*	5.46
	63	54.2	35.3	40.1	44.9	48.1	5.53
	67	58.0	28.2	33.0	37.8	41.0	5.60
105	63	51.9	34.2	39.1	43.9	47.1	6.10
	67	55.5	27.2	32.0	36.8	40.0	6.18
	71	59.3	19.9	24.8	29.6	32.8	6.27
115	63	49.6	33.2	38.0	42.9	46.1	6.66
	67	53.1	26.1	31.0	35.8	39.0	6.76
	71	56.7	18.9	23.8	28.6	31.8	6.87

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2060A1 WITH RXA/RXC061S3 AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	53.9	44.9	50.0	54.4*	55.6*	4.95
	63	57.7	38.0	43.2	48.3	51.8	5.00
	67	61.6	30.4	35.6	40.7	44.1	5.06
95	59	51.5	43.7	48.9	52.4*	53.7*	5.53
	63	55.2	36.9	42.0	47.2	50.6	5.60
	67	59.0	29.3	34.4	39.6	43.0	5.67
105	63	52.8	35.8	41.0	46.1	49.5	6.17
	67	56.5	28.2	33.4	38.5	42.0	6.26
	71	60.3	20.5	25.6	30.8	34.2	6.34
115	63	50.4	34.7	39.9	45.0	48.5	6.73
	67	53.9	27.2	32.3	37.5	40.9	6.84
	71	57.6	19.5	24.6	29.8	33.2	6.94

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

4TTR2060A1 WITH RXC054S3 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	52.9	42.9	47.7	52.6	54.0*	4.88
	63	56.6	36.5	41.3	46.2	49.4	4.94
	67	60.6	29.3	34.2	39.0	42.3	5.00
95	59	50.6	41.8	46.6	50.9*	52.1*	5.46
	63	54.2	35.4	40.2	45.1	48.3	5.53
	67	58.0	28.3	33.1	38.0	41.2	5.60
105	63	51.7	34.3	39.1	44.0	47.2	6.09
	67	55.4	27.2	32.0	36.9	40.1	6.18
	71	59.1	19.9	24.8	29.6	32.8	6.27
115	63	49.3	33.2	38.0	42.9	46.1	6.65
	67	52.8	26.1	30.9	35.8	39.0	6.76
	71	56.4	18.9	23.7	28.5	31.8	6.87

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2060A1 WITH RXC065S3 AT 2000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	55.0	47.6	53.4	56.4*	57.7*	5.04
	63	58.8	39.9	45.7	51.4	55.3	5.10
	67	62.8	31.4	37.1	42.9	46.8	5.16
95	59	52.5	46.4	52.2	54.3*	55.5*	5.62
	63	56.2	38.7	44.5	50.3	54.1	5.70
	67	60.0	30.2	36.0	41.8	45.6	5.77
105	63	53.8	37.7	43.4	49.2	53.1	6.26
	67	57.5	29.2	35.0	40.7	44.6	6.35
	71	61.3	20.5	26.3	32.1	35.9	6.44
115	63	51.4	36.6	42.4	48.2	51.6*	6.83
	67	55.0	28.2	33.9	39.7	43.5	6.93
	71	58.6	19.5	25.3	31.1	34.9	7.04

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1750	2250	AIRFLOW	1750	2250
TOTAL CAP	X0.99	X1.01	SENS. CAP	X0.95	X1.05

4TTR2060A1 WITH RXH063S3 AT 2000 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	56.6	49.2	55.3	58.2*	59.5*	5.07
	63	60.4	41.1	47.1	53.2	57.3	5.13
	67	64.4	32.1	38.2	44.3	48.3	5.19
95	59	54.0	48.0	54.0*	56.0*	57.2*	5.65
	63	57.7	39.8	45.9	52.0	56.1	5.72
	67	61.5	30.9	37.0	43.1	47.1	5.80
105	63	55.0	38.7	44.8	50.9	54.9	6.28
	67	58.7	29.8	35.9	41.9	46.0	6.38
	71	62.5	20.7	26.8	32.9	36.9	6.48
115	63	52.4	37.6	43.6	49.7	52.8*	6.83
	67	55.9	28.7	34.7	40.8	44.9	6.95
	71	59.6	19.6	25.7	31.8	35.8	7.08

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1750	2250	AIRFLOW	1750	2250
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.94	X1.06

4TTR2060A1 WITH TWE048C14 AT 1800 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	52.5	44.6	49.7	53.3*	54.5*	5.21
	63	56.2	37.7	42.9	48.0	51.4	5.27
	67	60.1	30.2	35.3	40.4	43.8	5.33
95	59	51.4	44.0	49.1	52.4*	53.6*	5.84
	63	55.1	37.2	42.3	47.5	50.9	5.91
	67	59.0	29.7	34.8	39.9	43.3	5.99
105	63	52.1	35.8	41.0	46.1	49.5	6.49
	67	55.9	28.4	33.5	38.6	42.0	6.58
	71	59.8	20.7	25.8	30.9	34.3	6.68
115	63	49.1	34.5	39.6	44.7	48.1	7.06
	67	52.8	27.0	32.1	37.2	40.7	7.17
	71	56.5	19.4	24.5	29.6	33.0	7.29

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1575	2025	AIRFLOW	1575	2025
TOTAL CAP	X0.98	X1.01	SENS. CAP	X0.95	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
* DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.

Performance Data Cooling

4TTR2060A1 WITH TXA/TXC048C4 AT 1400 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	50.0	38.9	42.9	47.0	49.7	4.82
	63	53.7	33.5	37.6	41.6	44.3	4.87
	67	57.5	27.6	31.6	35.7	38.4	4.93
95	59	48.9	38.3	42.3	46.4	49.0*	5.41
	63	52.6	33.0	37.1	41.1	43.8	5.49
	67	56.4	27.1	31.2	35.2	37.9	5.56
105	63	50.0	31.8	35.9	39.9	42.6	6.00
	67	53.7	26.0	30.0	34.1	36.7	6.08
	71	57.5	19.9	24.0	28.0	30.7	6.17
115	63	47.4	30.6	34.7	38.7	41.4	6.50
	67	50.9	24.8	28.8	32.9	35.6	6.61
	71	54.6	18.8	22.8	26.9	29.6	6.72

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1225	1575	AIRFLOW	1225	1575
TOTAL CAP	X0.97	X1.02	SENS. CAP	X0.95	X1.05

4TTR2060A1 WITH TXA/TXC049C4 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	52.3	42.9	47.8	52.4*	53.6*	5.07
	63	56.0	36.5	41.3	46.2	49.4	5.12
	67	59.9	29.4	34.2	39.0	42.3	5.18
95	59	51.0	42.3	47.2	51.4*	52.6*	5.69
	63	54.8	36.0	40.8	45.6	48.8	5.76
	67	58.6	28.9	33.7	38.5	41.7	5.84
105	63	51.8	34.6	39.4	44.2	47.5	6.32
	67	55.5	27.5	32.4	37.2	40.4	6.42
	71	59.4	20.3	25.2	30.0	33.2	6.51
115	63	48.8	33.3	38.1	42.9	46.1	6.88
	67	52.4	26.2	31.1	35.9	39.1	7.00
	71	56.1	19.1	23.9	28.7	31.9	7.12

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2060A1 WITH TXA/TXC050C4 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	52.3	42.9	47.8	52.4*	53.6*	5.07
	63	56.0	36.5	41.3	46.2	49.4	5.12
	67	59.9	29.4	34.2	39.0	42.3	5.18
95	59	51.0	42.3	47.2	51.4*	52.6*	5.69
	63	54.8	36.0	40.8	45.6	48.8	5.76
	67	58.6	28.9	33.7	38.5	41.7	5.84
105	63	51.8	34.6	39.4	44.2	47.5	6.32
	67	55.5	27.5	32.4	37.2	40.4	6.42
	71	59.4	20.3	25.2	30.0	33.2	6.51
115	63	48.8	33.3	38.1	42.9	46.1	6.88
	67	52.4	26.2	31.1	35.9	39.1	7.00
	71	56.1	19.1	23.9	28.7	31.9	7.12

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

4TTR2060A1 WITH TXH054A4 AT 1700 CFM

O.D. D.B.	I.D. W.B.	TOT CAP.	SENS. CAP. AT ENTERING D.B. TEMP				TOTAL KW
			72	75	78	80	
85	59	54.1	45.2	50.3	54.6*	55.8*	5.17
	63	57.9	38.2	43.4	48.6	52.0	5.23
	67	61.8	30.6	35.8	40.9	44.4	5.29
95	59	52.8	44.5	49.7	53.6*	54.9*	5.81
	63	56.6	37.6	42.8	48.0	51.4	5.88
	67	60.5	30.1	35.2	40.4	43.9	5.96
105	63	53.6	36.3	41.4	46.6	50.1	6.48
	67	57.3	28.7	33.9	39.1	42.5	6.57
	71	61.2	21.0	26.2	31.4	34.8	6.66
115	63	50.5	34.9	40.1	45.3	48.7	7.06
	67	54.2	27.4	32.6	37.7	41.2	7.18
	71	57.9	19.7	24.9	30.1	33.5	7.29

CORRECTION FACTORS - OTHER AIRFLOWS (MULTIPLY OR ADD AS INDICATED)

AIRFLOW	1475	1925	AIRFLOW	1475	1925
TOTAL CAP	X0.98	X1.02	SENS. CAP	X0.94	X1.05

NOTE: ALL TABLES ABOVE ARE AT ARI RATING CONDITIONS RATED WITH 25 FEET OF REFRIGERANT LINES.
 * DRY COIL CONDITION (TOTAL CAPACITY = SENSIBLE CAPACITY)
 TOTAL CAPACITY, COMP. KW AND APP. DEW PT. ARE VALID ONLY FOR WET COIL. ALL TEMPERATURES IN DEGREES F.



The Trane Company
An American Standard Company
www.trane.com

Since The Trane Company has a policy of continuous product and product data improvement, it reserves the right to change design and specifications without notice.