



- NOTES:
1. ALL WIRE IS 10 AWG UNLESS NOTED OTHERWISE.
 2. VR2 REQUIRES A MOV INSULATOR KIT.
 3. LINE 2 IS THE NEUTRAL FOR INTERNATIONAL SYSTEMS USING 220 VAC HOT AND NEUTRAL.

ADDED TRAY IDENTIFICATION AT CB2 THRU CB4. (SAK)			
A0	20005471	2/9/99	RE
CHANGED 44R02-4111-150 TO 44R02-4111-250. (RFB)			
2	9250	2/31/97	RE
A1 P/N WAS 44R02-4121-150.			
1	8101	7/17/96	RE

ADC Telecommunications THIS PRINT IS THE PROPERTY OF ADC. IT SHALL NOT BE COPIED WITHOUT PERMISSION.		TITLE INTERCONNECT, AC DISTRIBUTION PANEL, NARROW (1265-1600)			
		MATERIAL -----	DWN SJM 5/9/96	DWG. NO. 1265-8600	REV A0
FINISH -----	CHK RE 5/10/96	REL RE 5/10/96	C SCALE ---	SHEET 1 OF 1	

