

How To Create Scenarios

Network Master Pro MT1000A

Network Master Flex MT1100A

Scenario Edit Environment Kit (SEEK) MX100003A

Contents

1	Introduction	2
1.1	ABOUT THIS NOTE	2
1.2	DIFFICULTY OF SCENARIO CREATION	2
2	Considerations for Creating Scenarios	4
2.1	TESTING MANAGER AND TESTING FIELD TECHNICIAN	4
2.2	PREPARING FOR CREATING SCENARIOS.....	4
2.3	HANDLING VARIABLE PARAMETERS AND THRESHOLD VALUES	6
2.4	UPDATING SCENARIOS.....	7
3	Sample Scenarios	8
3.1	ERROR-FREE COMMUNICATIONS TEST	9
3.2	COMMUNICATIONS TEST WITH ERROR INSERTION	13
3.3	AUTOMATING LONG-TERM CONTINUOUS MEASUREMENT.....	18
3.4	TESTING CATEGORY 5 CABLE.....	21

1 Introduction

1.1 About This Note

This note describes the procedures and knowledge required for end users to create scenarios to automate tests using the MT1000A and MT1100A (Network Master hereafter). Readers with a good understanding of the contents will be able to create scenarios for controlling the Network Master.

This note explains the following:

- General procedures and knowledge to prepare for creating and maintaining scenarios
- Detailed explanations of sample scenarios

This note does not explain the following items; refer to the appended instruction manual for explanation of these items.

- | | |
|---|---|
| • How to operate network master | → Refer to MT1000A or MT1100A instruction manual. |
| • SCPI command reference | → Refer to remote scripting instruction manual. |
| • How to use MX100003A Scenario Editing Kit | → Refer to MX100003A instruction manual. |
| • Scripts syntax and commands reference | → Refer to MX100003A instruction manual. |

1.2 Difficulty of Scenario Creation

The MX100003A Scenario Editing Kit (SEEK) is a tool to support automating tests. Implementing automatic testing using general measuring instruments without SEEK requires deep knowledge, skills, and experience in the following areas.

- Knowledge about command-line-based user interfaces called SCPI supported by measuring instruments
- Knowledge and experience of software programming using languages, such as C/C++, Visual Basic, Python, Ruby, etc.

Using these types of knowledge for programming automation objectives is a strength. Conversely, sections performing and managing testing must secure staff with the necessary software development skills.

The SEEK has been developed to implement automation using a drag and drop GUI without the need for the above-described knowledge and experience. The SEEK GUI is used to create scenarios on-screen based on operation sequences and pass/fail evaluation standards to be automated.

Scenario descriptions are simple to create using general GUI operations, but on the other hand, there may be limits to the descriptions. Descriptions created using programming languages have no limits, but on the other hand, can be extremely hard to use. SEEK eliminates this trade-off by introducing a unique scripting language in addition to GUI operations. It is easy to obtain this scripting language due to its small size. This combination of sequence description using a GUI and scripting language offers users the best balance of both methods.

The necessity to use scripting language when creating scenarios by the SEEK depends on what kind of pass/fail evaluation standards are used. The following table shows the relationship between pass/fail evaluation standards and the difficulty of scenario creation.

Table 1.2-1 Relationship between pass/fail evaluation standards and scenario creation difficulty

Pass/fail evaluation standards	Scenario creation difficulty
Network Master pass/fail evaluation (threshold setting)	No need to use scripting language Scenarios created easily using GUI operation only
Other than above	Requires programming using scripting language Difficulty of scenario creation depends on complexity of evaluation standards Simple example: The difference between the measured maximum and minimum throughput for a frame length of 64 bytes is evaluated as pass if it is 10% or less of the wire rate, but fail under other conditions. Complex example: If no frame loss is detected at a frame length of 64 bytes, it is evaluated as pass. If frame loss is detected, the frame length is set to 1500 bytes and measurement is performed over. If the frame loss rate result of the second measurement is improved by at least 50% compared to the first measurement, it is evaluated as pass. If this improvement is not achieved, it is evaluated as fail.

2 Considerations for Creating Scenarios

This section explains some general considerations and recommended procedures for creating scenarios.

2.1 Testing Manager and Testing Field Technician

There are two positions to consider when automating tests: the testing manager (in the office), and the field technician onsite. The testing manager (or office) creates the scenarios, while the field technician loads scenarios into the Network Master and runs the field tests. Technicians performing multiple tests can be based at different locations, and sometimes the testing manager and field technician may be the same person.

The role of the testing manager is to create the scenarios and distribute them to the field technicians. Sometimes, following distribution of the scenarios, it may be necessary to change these scenarios due to differences in the network operation policy, and testing environment. In this case, the testing manager must be able to change/revise scenarios and will also have to redistribute them so that field technicians will run the revised scenarios.




Fig. 2.1-1 Testing manager and field technician

This important work requires careful consideration of how the testing manager distributes the completed created test scenarios so that field technicians can perform operations and maintenance. If the testing manager and field technician are located at the same person, this is not a problem.

2.2 Preparing for Creating Scenarios

The first thing to do before creating scenarios is to clearly document the test procedure. For example, it is best to clarify the following four points.

2.2.1 Defining Network Master Initial Conditions at Test Start

To assure measurement repeatability, it is important to define the initial conditions. When the next test is performed under the some conditions which precious test made, if the measurement results change without changing anything about the device/network under the test, it indicates that a problem has occurred.

After defining the initial conditions, set and operate the Network Master under these conditions, which can be saved as a settings or configuration (.cfg) file defining the initial conditions of the Network Master. Loading this

configuration file before the scenario assures testing under the same conditions every time. If no Network Master is available, this settings or configuration file can be created on a PC using the MX100001A software, which can be downloaded free-of-charge from the Anritsu website.

2.2.2 Examining Parameters

What settings cannot be determined at scenario creation? As an example, the IP address of the equipment to which the Network Master will be connected changes at each measurement site and cannot be determined until actual testing starts. Occasionally, a scenario may be created in which all measurement sites have a common fixed IP address, but this usage may change with time.

So how do we examine these variable parameters and clarify the reasons and changes at fault conditions? It is best to consider them from various viewpoints, such as changes with time, changes with location, changes due to unknown factors (accuracy), changes due to test frequency (quarterly measurements, etc.). It is also good to describe items that can change simultaneously.

2.2.3 Visualizing Test Procedure

Visualize the test procedure using a flowchart. It is best to start from powering-up the device to be tested (DUT) and the Network Master. It is important to be clear about manual operation procedures before and after connecting cables. When powering-up equipment before and after connecting cables, there may be differences in the obtained measurement results.

It is important to understand complex flow procedures when there are many alternative conditions. When describing these types of procedure using one scenario, the scenario can become extremely complex, making post-testing maintenance difficult. In these cases, it is better to re-examine the procedure and split the scenario into several scenarios.

2.2.4 Defining Pass/Fail Standards

This section explains the basics of a passing test.

The Network Master has a pass/fail evaluation function using standard counter items. This tutorial first explains use of this function, which simplifies scenario creation. Select “Summary” at the GUI and read section 3.4.7.8 *Judge* of the MX100003A instruction manual for an explanation.

If the pass/fail evaluation is complex, consider whether it can be simplified.

For example, at evaluation when the threshold value is XX when there is a VLAN and YY when there is no VLAN, this scenario can be greatly simplified by splitting into two scenarios one with the VLAN, And one without the VLAN. Or in this case, it may be more efficient for the field technician to perform pass/fail evaluation by eye and omit automatic evaluation. In this latter case, create a scenario to display the message “Confirm XXX is YYY. OK/NG”.

In both these examples, although the scenarios are simple, the field technician has more work to do, increasing the risk of human error. When performing evaluations, it is important to consider the balance between the cost of creating and maintaining the scenario and the operation cost.

Like the previously described test parameters, there are cases where the pass/fail threshold values cannot be decided at scenario creation. In these cases, it is best to document the reasons for the variability and the range.

2.3 Handling Variable Parameters and Threshold Values

As explained previously, sometimes setting parameters and threshold values either cannot be decided at scenario creation, or may change in the future. There are two methods for dealing with these types of variable factors.

(1) Allocating Global Variables

Use the function explained in section 3.4.4 *Global Variable* of the MX100003A instruction manual. Since, unlike local variables, the value of a global variable can be changed at a Network Master screen, this function makes it unnecessary to update and redistribute scenarios. The changed value is backed-up, so it is saved after restarting the Network Master. It can be locked with a password, preventing the field technician changing it in error.

Use of global variables is convenient when parameter settings change with test site. For example, when the parameter is different between sites A and B, two Network Master units are used—one at each site. In this case, the site-dependent parameters are set in each Network Master, supporting integrated testing at all sites.

There are some precautions regarding global variables; if the same scenarios are re-registered in a Network Master, when the scenario is updated, the values saved in the main frame are initialized. As a result, the last updated value is in error. It is necessary to manage conditions when changing global variables. Refer to section 2.4 *Updating Scenarios* in this note for how to transfer global variables when updating scenarios.

(2) Questioning Field Technician Running Test Scenarios

One scenario command is use of "Message". Executing this command while executing a scenario, displays a dialog box on the Network Master screen requesting input by the field technician.

This is convenient if values cannot be decided before the test start date, or if there may be small changes in the values depending on circumstances. However, too many of these input messages increases the work of the field technician, which may increase the chance of operation errors. Consequently, it is better not to use too many Message questions for field technicians.

2.4 Updating Scenarios

Manage scenario updates by including the version number in the scenario name. For example, the first version of a scenario named “Example” would be “Example v00”; when this scenario is upgraded, change the name of the scenario to “Example v01”, and so on with each upgrade.

Register upgraded scenarios in the Network Master main frame. The following screen shows an example when both versions have been registered.




Fig. 2.4-1 Registering revised scenario

Before deleting an old version, it may sometimes be necessary to transfer global variables. Use the [Edit] button while the focus is on the old version as shown in the above figure.




Fig. 2.4-2 Transferring global variables

Make a note of the displayed global variables and input them to the new version. At this time, it is possible that the structure of the global variables will be different between the new and old versions. The test manager should consider transfer of global variables at scenario update and subsequently distribute the updated scenario.

When transfer of the required global variables is completed, use the [Delete] button to delete the old version. To keep the old version without it being visible, use the [Hide] button to hide it.

3 Sample Scenarios

This section shows the scenario creation process using sample scenarios. Scenario creation can be completed quickly by revising sequences to be automated using these samples as templates.

Sample scenarios can be downloaded from the Anritsu website at the following URL.

<http://www.anritsu.com/en-au/test-measurement/support/downloads/software/dwl17512>

These sample scenarios assume use of the MT1000A but can be easily changed for use by the MT1100A. Refer to section 3.4.1 *Instrument Configuration* in the MX100003A instruction manual for how to use the MT1100A.

Table 3-1 List of sample scenarios

Title	Outline	Programming Skills
Error-free commissioning test	Confirms network communications. Checks for error-free transmission by looping-back traffic sent from tester at far end	Not required
Error insertion commissioning test	Confirms network communications. Loops-back traffic sent with inserted errors from tester at far end and confirms errors returned	Required (low difficulty level)
Automated long-term testing	Automates multiple long-term measurements as one processing sequence	Not required
Category 5 cable test	Confirms continuity of pulled Category 5 cables	Required (high difficulty level)

3.1 Error-free Communications Test

3.1.1 Test Objective

This test uses a 10-Gbps Ethernet network. The Network Master located at the user side sends traffic to the central exchange. When a specific IP address is specified as the destination, the traffic is looped-back by the central exchange.




Fig. 3.1-1 Network configuration at sample scenario commissioning test

3.1.2 SCPI Commands

No SCPI commands are used.

3.1.3 Test Specifications

Network Master Initial Conditions

This sample uses the Ethernet BERT application; after using [Restore Application Defaults] to set the initial conditions, the Ethernet BERT application is launched and the settings are changed as follows. Save the changed settings to a settings file.

Table 3.1-1 Changing setting contents

Screen	Setting	Setting
[Setting] – [Port]	Port	[Off] → [SFP+ 10 Gbps LAN]
[Setting] – [Stream]	[MAC] – [ARP]	No check → Check
	[MAC] – [Default]	No check → Check
[Test] – [Generator]	[Automatically start traffic generator when test started]	No check → Check
[Test] – [Stream]	[Frame Size]	[Constant] → [Random]
	[End]	[64] → [1500]
[Test] – [Thresholds]	[Pattern Errors]	No check → Check
	[Sequence Errors]	No check → Check
	[Ethernet]	No check → Check
	Type (See Fig. 3.1-2.)	No check → Check




Fig. 3.1-2 Threshold settings screen

Pass/Fail Evaluation Standards

After completing measurement, a pass evaluation is awarded only when the values for all the following statistics are zero.

Pattern Error, Sequence Error, Fragmented Frames, Undersized Frames, Oversized Frames, FCS Errored Frames, Oversized&FCS Errored Frames, IFG Violations, Preamble Violations

Parameters

The following table shows the parameters used by this sample.

Table 3.1-2 Parameters

Parameter	Class/Variable Name	Explanation
Src IPv4 Address	Global Variable MY_IP	Network Master IPv4 Address
Dest IPv4 Address	Global Variable NOC_IP	IP Address for looping-back by central exchange

The following global variables are defined at the MX100003A screen according to this table.




Fig. 3.1-3 Global setting changes

Test flowchart

The following shows the match between the test flowchart and the scenario command sequence.





Fig. 3.1-4 Test flowchart


3.1.4 Explanation of Scenario

This section explains the setting contents of each command in line with the test flowchart.


1. Setting Network Master Initial Conditions



2. Connecting Cable and Confirming Link




3. Measuring Every 10 Seconds and Evaluating Results



4. Creating Report

Using the Save command last saves the measurement results file (*.res) in the same way as saved by using normal screen operation. This measurement file is converted to a report (pdf, xml, csv) when the scenario is completed.



When the test evaluation result is Fail, the *.res file file can provide useful clues; we recommend placing the Save command after evaluation for this reason.

3.2 Communications Test with Error Insertion

3.2.1 Test Objective

This test uses a 10-Gbps Ethernet network. The Network Master located at the user side sends traffic to the central exchange. When a specific IP address is specified as the destination, the traffic is looped-back by the central exchange. This sample scenario instructs the Network Master to insert packets including a user signal with bit errors into the traffic which is looped-back and checked for the same bit errors.




Fig. 3.2-1 Network configuration for sample scenario commissioning test

3.2.2 SCPI Commands

The following table lists the SCPI commands used by this sample scenario.

Table 3.2-1 SCPI Commands

Command	Explanation
ETHernet:PORT1:STIMuli:EBLength	Sets number of bit errors to insert
SYSTem:STIMuli:INSert	Inserts bit errors
ETHernet:PORT1:IFETch? (BPE)	Captures bit error measurement results

3.2.3 Test Specifications

Network Master Initial Conditions

This sample uses the Ethernet BERT application; after initializing the settings using [Restore Application Defaults], the Ethernet BERT is launched and the following settings are changed. Save the changed settings to a settings file.

Table 3.2-2 Changing setting contents

Screen	Setting	Setting Value
[Setting] - [Port]	Port	[Off] → [SFP+ 10 Gbps LAN]
[Setting] - [Stream]	[MAC] - [ARP]	No check → Check
	[MAC] - [Default]	No check → Check
[Test] - [Stream]	[Frame Size]	[Constant] → [Random]
	[End]	[64] → [1500]

Fig. 3.2-2 Changing setting contents (continued)

Screen	Setting	Setting Value
[Test] - [Thresholds]	[Pattern Errors]	No check → Check
Alarms/Errors/Others	[Errors/Violations]	No check → Check
	[Destination]	[Off] → [Manual]
	[Insertion]	[No Error] → [BERT Pattern Error]




Fig. 3.2-2 Settings at Alarms/Errors/Others screen

Pass/Fail Evaluation Standards

After completing measurement, a pass evaluation is awarded only when the bit error count and detected bit error count match.

Parameters

The following table lists the parameters used by this sample scenario.

Table 3.2-3 Parameters

Parameter	Type/Variable Name	Explanation
Src IPv4 Address	Global variable MY_IP	Network Master IPv4 Address
Dest IPv4 Address	Global variable NOC_IP	IP Address for looping-back by central exchange

The following global variables are defined at the MX100003A screen according to this table.




Fig. 3.2-3 Global variable settings

Test Flowchart

The following shows the match between the test flowchart and the scenario command sequence.





Fig. 3.2-4 Test flowchart


3.2.4 Explanation of Scenario

This section explains the setting contents of each command in line with the test flowchart.


1. Setting Network Master Initial Conditions.




2. Connecting Cable and Confirming Link





3. Starting Measurement



4. Queries Inserted Bit Error Count and Inserts Errors for That Count



5. Stopping Measurement and Evaluating Measurement Result



Selects [Custom] at Judge and describes following script

```
001: '=== GET Pattern Error Bit
002: VAR_STORE,, "ETHERnet:PORT1:IFETch? (BPE) ", %RESP

003: '=== Extract Number of Error bit from Response
004: ' Response is "(Bit,Rate)" format.
005: ' Such as "(2,1.31E-12)"
006: ' Only the first number is interested,
007: SPLIT,%BIT,1,%RESP
008: LOG,"Measured error bit is " %BIT
009:
010: '=== Judgement
011: IF,%BIT,==,%NUM_OF_ERROR
012: ELSE, JUDGE_FAIL
```

Line 002

First, saves measurement results to local variable RESP.

Lines 003 ~ 008

Represent measurement results as character string like "(2,1.31E-12)". Extract part indicating bit error count and save to local variable BIT. For confirmation, displays obtained bit error count on screen.

Lines 010 ~ 012

Compare obtained bit error count with the one input by field technician and evaluate as fail if different before finally terminating scenario.

3.3 Automating Long-Term Continuous Measurement

3.3.1 Test Objective

When long-term test taking 8 hours for example has many test runs under different conditions, procedures are required to save measurements, and change the conditions and restart measurement every 8 hours. This sample scenario automates this continuing process to obtain three sets of test results each 24 hours (every 8 hours) without manual intervention. Each test is conducted with different frame size, 64 bytes, 256 bytes and 1518 bytes.

3.3.2 SCPI Commands

No SCPI commands are used.

3.3.3 Test Specifications

Initial Network Master Condition

This sample scenario uses the Ethernet BERT application. After first using [Restore Application Defaults] to set the initial conditions, the Ethernet BERT application is launched and the settings are changed as follows.

Table 3.3-1 Changing setting contents (1/3)

Screen	Setting	Setting Value
[Setting] - [Port]	Port	[Off] → [SFP+ 10 Gbps LAN]
[Setting] - [Stream]	[MAC] - [ARP]	No check → Check
	[MAC] - [Default]	No check → Check
[Test] - [Generator]	[Automatically start traffic generator when test started]	No check → Check

After making the above changes, save the settings file as file name Longrun64.cfg and then make the following setting changes.

Table 3.3-1 Changing setting contents (2/3)

Screen	Setting	Setting Value
[Test] - [Stream]	[Start]	[64] → [256]

After making the above changes, save the settings file as file name Longrun256.cfg and then make the following setting changes.

Table 3.3-1 Changing setting contents (3/3)

Screen	Setting	Setting Value
[Test] - [Stream]	[Start]	[256] → [1518]

After making the above changes, save the settings file as file name Longrun1518.cfg and then make the following setting changes.

Pass/Fail Evaluation Standards

Only the measurement results are required and there is no pass/fail evaluation; the result is always pass.

Parameters

The following table shows the parameters used by this sample scenario.

Table 3.3-2 Parameters

Parameters	Type/Variable Name	Explanation
Src IPv4 Address	Global Variable MY_IP	Network Master IPv4 Address
Dest IPv4 Address	Global Variable DEST_IP	IPv4 address of traffic destination

The following global variables are defined at the MX100003A screen according to this table.




Fig. 3.3-1 Global Variable Settings

Test Flowchart

The following shows the match between the test flowchart and the scenario command sequence.





Fig. 3.3-1 Test flowchart

3.3.4 Explanation of Scenario


This section explains the setting contents of each command in line with the test flowchart.

1. Setting Network Master Initial Conditions




2. Connecting Cable and Confirming Link

This command is placed only in the Ethernet BERT applications started first.



3. Measuring for 8 hours and Saving Measurement Results



3.4 Testing Category 5 Cable

3.4.1 Test Objective

This test confirms the continuity of Category 5 cable pulls in facilities such as data centers. The Network Master is connected to one end of the cable and a RJ-45 loop-back jack is connected to the other end to loop-back the test signal.




Fig. 3.4-1 Network configuration for sample scenario commissioning test

The main test procedure flow is outlined below.

1. Measure the cable length using the Cable Test application with the far end open.
2. Measure the cable length again using the Cable Test application with the loop-back jack connected to the far end to loop-back the test signal.
3. Measure the bit error rate with the loop-back jack connected to the far end to loop-back the test signal.

3.4.2 SCPI Commands

The following table lists the SCPI commands used by this sample scenario.

Table 3.4-1 SCPI Commands

Command	Explanation
ETHernet:CABLe:RESults:PAIR<Pr>?	Queries Cable Test Application measurement results
ETH:STAT:PORT1:LINK?	Queries Ethernet Link status
ETHernet:PORT1:STReam:PAYLoad	Sets Ethernet sent traffic pattern

3.4.3 Test Specifications

Initial Network Master Condition

This sample scenario uses the Cable Test and Ethernet BERT applications. Since the Cable Test Application has no setting items, it is not necessary to define the initial conditions. After setting the initial condition using [Restore Application Defaults], the Ethernet BERT application is started and the settings are changed as follows. Save the settings to a file after completing the settings.

Table 3.4-2 Changing setting contents

Screen	Setting	Setting Value
[Setting] - [Port]	[Port Setup] - [Interface Type]	Off → [Electrical]
	[Port Setup] - [Port Mode]	[Autonegotiate]
	Auto Negotiation Advertisement	1000M FDX only Off; all others On
[Setting] - [Stream]	Layer 2 (See Fig. 3.4-2.)	[Unframed]
	Payload Pattern	[PRBS31]
[TEST] - [Threshold]	[Pattern Errors]	Off → On
	[Pattern Errors] - [Threshold]	[0]




Fig. 3.4-2 Settings at Setup-Stream screen




Fig. 3.4-3 Settings at Setup-Stream screen

Pass/Fail Evaluation Standards

The test is evaluated as pass only when all the following conditions are satisfied.

1. The measurement results for the four cable pairs are sufficiently similar when the cable length is measured while the far end is open.
2. The measurement results for the same cable pairs are sufficiently similar when the cable length is measured while the far end is open and when shorted by the far-end loop-back jack.
3. The bit-error measurement results are error-free when measured for 1 minute.

Parameters

The following table shows the parameters used by this sample scenario.

Table 3.4-3 Parameters

Parameter	Type/Variable Name	Explanation
N/A	Global variable OPEN_LENGTH1 OPEN_LENGTH2 OPEN_LENGTH3 OPEN_LENGTH4	Variables for measurements result saves In this sample scenario, the Cable Test application is launched twice. In these circumstances, it is best to use global variables to transfer data between applications.
Threshold value	Global variable LENGTH_MARGIN	Pass/Fail evaluation margins The results for the lengths of the four cable pairs are evaluated based on the average $\pm$ LENGTH_MARGIN.

The global variables are defined as follows at the MX10003A screen according to this table.




Fig. 3.4-4 Global variable settings

Test Flowchart

The following shows the match between the test flowchart and the scenario.





Fig. 3.4-5 Test flowchart


3.4.4 Explanation of Scenario

This section explains the setting contents of each command in line with the test flowchart.

1. Connecting Cable



2. Starting Measurement (Open) and Recording Measurement Results



Message

Start

Action

Test Mode

Auto

Only Auto can be selected at Cable Test

Action: Custom

Script SCPI

Import from file

```
'=== Query the results of all pairs. ===
VAR_STORE,, "ETHernet:CABLe:RESults:PAIR1?", %RESP1
VAR_STORE,, "ETHernet:CABLe:RESults:PAIR2?", %RESP2
VAR_STORE,, "ETHernet:CABLe:RESults:PAIR3?", %RESP3
VAR_STORE,, "ETHernet:CABLe:RESults:PAIR4?", %RESP4
006:
007:'=== Substitute all results into variables ===
008:SPLIT,%STATUS1,1,%RESP1
009:SPLIT,%OPEN_LENGTH1,2,%RESP1
010:SPLIT,%STATUS2,1,%RESP2
011:SPLIT,%OPEN_LENGTH2,2,%RESP2
012:SPLIT,%STATUS3,1,%RESP3
013:SPLIT,%OPEN_LENGTH3,2,%RESP3
014:SPLIT,%STATUS4,1,%RESP4
015:SPLIT,%OPEN_LENGTH4,2,%RESP4
016:
017:LOG,"Status: Pair1=" %STATUS1 " Pair2=" %STATUS2 "
Pair3=" %STATUS3 " Pair4=" %STATUS4
018:LOG,"Length: Pair1=" %OPEN_LENGTH1" Pair2=" %OPEN_LENGTH2"
Pair3=" %OPEN_LENGTH4 " Pair4=" %OPEN_LENGTH4
```

Selects [Custom] at Action and describes following script.

Lines 001 ~ 005

Use ETHernet:CABLe:RESults:PAIR<Pr>? query and save obtained measurement results (lengths for four cable pairs) to each of four local variables %RESP1, %RESP2, %RESP3, and %RESP4, respectively. Pay attention to the blank second column of the VAR_STORE command.


Lines 007 ~ 015

Analyze response string to ETHernet:CABLe:RESults:PAIR1<Pr>? query to obtain cable lengths and status, and store them in appropriate variables. Response string to ETHernet:CABLe:RESults:PAIR<Pr>? query composed of three comma-separated measurement values for <status>, <distance>, and <amplitude> in form of "SHRT,20.6,-0.6". Specific measurement values obtained using SPLIT command.

Lines 017 ~ 18

Output log for measurement results to screen using LOG command.

3. Evaluating Measurement Results



Selects [Custom] at Judge and describes following script.

```
001:'=== Calculate average length ===
002:COPY,%TOTAL,%OPEN_LENGTH1
003:CALC,%TOTAL,%TOTAL,+,0.0000
004:CALC,%TOTAL,%TOTAL,+,%OPEN_LENGTH2
005:CALC,%TOTAL,%TOTAL,+,%OPEN_LENGTH3
006:CALC,%TOTAL,%TOTAL,+,%OPEN_LENGTH4
007:CALC,%AVERAGE,%TOTAL,/,4.000
008:LOG,"Average Length= " %AVERAGE
009:
010:'=== Decide thredold ===
011:CALC,%THRESHOLD_L,%AVERAGE,-,%LENGTH_MARGIN
012:CALC,%THRESHOLD_H,%AVERAGE,+,%LENGTH_MARGIN
013:
014:'==== Status Check ===
015:COPY,%OK_COUNT_S,0
016:IF,%STATUS1,==,"OPEN"
017:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
018:IF,%STATUS2,==,"OPEN"
019:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
020:IF,%STATUS3,==,"OPEN"
021:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
022:IF,%STATUS4,==,"OPEN"
023:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
024:
025:IF,%OK_COUNT_S,==,4
026:THEN,LOG,"All of Statuses are OPEN -> OK", "GREEN"
027:ELSE,LOG,"All of Statuses are not OPEN -> NG", "RED"
028:
029:'==== Length Check ===
030:COPY,%OK_COUNT_L,0
031:IF_EX," (%OPEN_LENGTH1>=%THRESHOLD_L) && (%OPEN_LENGTH1<=%THRESHOLD_H) "
032:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
033:IF_EX," (%OPEN_LENGTH2>=%THRESHOLD_L) && (%OPEN_LENGTH2<=%THRESHOLD_H) "
034:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
035:IF_EX," (%OPEN_LENGTH3>=%THRESHOLD_L) && (%OPEN_LENGTH3<=%THRESHOLD_H) "
036:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
037:IF_EX," (%OPEN_LENGTH4>=%THRESHOLD_L) && (%OPEN_LENGTH4<=%THRESHOLD_H) "
038:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
039:
040:IF,%OK_COUNT_L,==,4
041:THEN,LOG,"All of length are within margin -> OK", "GREEN"
042:ELSE,LOG,"All of length are out of margin -> NG", "RED"
043:
044:'==== Total Judgement ====
045:IF_EX," (%OK_COUNT_S == 4) && (%OK_COUNT_L == 4) "
```

The average values are used to evaluate whether the lengths of the four cable pairs are sufficiently similar. Evaluation is performed by examining whether the difference between the average and length of each cable pair is within or outside the permissible margin.

Lines 001 ~ 008

Find average lengths of four cable pairs

Lines 010 ~ 012

Use found average lengths and %LENGTH_MARGIN global variable to calculate pass/fail evaluation high and low limits

Lines 014 ~ 027

Evaluate whether status of four cable pairs is all "OPEN". Although can Use JUDGE_FAIL command here to confirm pass/fail evaluation, in this case, subsequent evaluation processing not performed. In order to perform next evaluation irrespective of whether status pass or fail, evaluation result is counted in %OK_COUNT_S variable (pass when value is 4).

Lines 029 ~ 042

Evaluate whether lengths of four cable pairs within pass range


Lines 044 ~ 046

Overall evaluation


The following color-coded screen is output using the LOG command.

	Time	Description
15	2016-04-13 20:39:45	'Length: Pair1=0.8 Pair2=0.8 Pair3=0.8 Pair4=0.8
16	2016-04-13 20:39:45	'All of Statuses are not SHORT-> NG
17	2016-04-13 20:39:45	'All of length are within margin -> OK

4. Looping-back Far End



5. Starting Measurement (Short) and Obtaining Measurement Result



Start

Action

Judge

Test Mode

Auto

Only Auto can be selected at Cable Test

Action: Custom

Script

SCPI

Import from file

'=== Query the results of all pairs. ===
VAR_STORE,, "ETHERnet:CABLE:RESuLts:PAIR1?", %RESP1
VAR_STORE,, "ETHERnet:CABLE:RESuLts:PAIR2?", %RESP2
VAR_STORE,, "ETHERnet:CABLE:RESuLts:PAIR3?", %RESP3
VAR_STORE,, "ETHERnet:CABLE:RESuLts:PAIR4?", %RESP4
006:
007:'=== Substitute all results into variables ===
008:SPLIT,%STATUS1,1,%RESP1
009:SPLIT,%LENGTH1,2,%RESP1
010:SPLIT,%STATUS2,1,%RESP2
011:SPLIT,%LENGTH2,2,%RESP2
012:SPLIT,%STATUS3,1,%RESP3
013:SPLIT,%LENGTH3,2,%RESP3
014:SPLIT,%STATUS4,1,%RESP4
015:SPLIT,%LENGTH4,2,%RESP4
016:
017:LOG,"Status: Pair1=" %STATUS1 " Pair2=" %STATUS2 " Pair3=" %STATUS3 " Pair4=" %STATUS4
018:LOG,"Length: Pair1=" %LENGTH1 " Pair2=" %LENGTH2 " Pair3=" %LENGTH3 " Pair4=" %LENGTH4

Lines 001 ~ 005

Use ETHERnet:CABLE:RESuLts:PAIR<Pr>? query and save obtained measurement results (lengths for four cable pairs) to each of four local variables %RESP1, %RESP2, %RESP3, and %RESP4, respectively. Pay attention to the blank second column of the VAR_STORE command.


Lines 007 ~ 015

Analyze response string to ETHERnet:CABLE:RESuLts:PAIR<Pr>? query to obtain cable lengths and status, and store them in appropriate variables. Response string to ETHERnet:CABLE:RESuLts:PAIR<Pr>? query composed of three comma-separated measurement values for <status>, <distance>, and <amplitude> in form of "SHRT,20.6,-0.6". Specific measurement values obtained using SPLIT command.

Lines 017 ~ 018

Output log for measurement results to screen using LOG command.

6. Evaluating Measurement results



Selects [Custom] at Judge and describes following script.

```
001:'==== Status Check ===
002:COPY,%OK_COUNT_S,0
003:IF,%STATUS1,==,"SHRT"
004:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
005:IF,%STATUS2,==,"SHRT"
006:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
007:IF,%STATUS3,==,"SHRT"
008:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
009:IF,%STATUS4,==,"SHRT"
010:THEN,CALC,%OK_COUNT_S,%OK_COUNT_S,+,1
011:
012:IF,%OK_COUNT_S,==,4
013:THEN,LOG,"All of Statuses are SHORT-> OK", "GREEN"
014:ELSE,LOG,"All of Statuses are not SHORT-> NG", "RED"
015:
016:'==== Length Check ===
017:COPY,%OK_COUNT_L,0
018:
019:'-- pair 1 ---
020:COPY,%OK_COUNT_L,0.0
021:COPY,%OK_COUNT_H,0.0
022:CALC,%THRESHOLD_L,%OPEN_LENGTH1,-,%LENGTH_MARGIN
023:CALC,%THRESHOLD_H,%OPEN_LENGTH1,+,%LENGTH_MARGIN
024:IF_EX,"(%LENGTH1>=%THRESHOLD_L) && (%LENGTH1<=%THRESHOLD_H) "
025:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
026:LOG,"Threshold1 Low=" %THRESHOLD_L" High=" %THRESHOLD_H
027:
028:'-- pair 2 ---
029:CALC,%THRESHOLD_L,%OPEN_LENGTH2,-,%LENGTH_MARGIN
030:CALC,%THRESHOLD_H,%OPEN_LENGTH2,+,%LENGTH_MARGIN
031:IF_EX,"(%LENGTH2>=%THRESHOLD_L) && (%LENGTH2<=%THRESHOLD_H) "
032:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
033:LOG,"Threshold2 Low=" %THRESHOLD_L" High=" %THRESHOLD_H
034:
035:'-- pair 3 ---
036:CALC,%THRESHOLD_L,%OPEN_LENGTH3,-,%LENGTH_MARGIN
037:CALC,%THRESHOLD_H,%OPEN_LENGTH3,+,%LENGTH_MARGIN
038:IF_EX,"(%LENGTH3>=%THRESHOLD_L) && (%LENGTH3<=%THRESHOLD_H) "
039:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
040:LOG,"Threshold3 Low=" %THRESHOLD_L" High=" %THRESHOLD_H
041:
042:'-- pair 4 ---
043:CALC,%THRESHOLD_L,%OPEN_LENGTH4,-,%LENGTH_MARGIN
044:CALC,%THRESHOLD_H,%OPEN_LENGTH4,+,%LENGTH_MARGIN
045:IF_EX,"(%LENGTH4>=%THRESHOLD_L) && (%LENGTH4<=%THRESHOLD_H) "
046:THEN,CALC,%OK_COUNT_L,%OK_COUNT_L,+,1
047:LOG,"Threshold4 Low=" %THRESHOLD_L" High=" %THRESHOLD_H
048:LOG,"OK Count=" %OK_COUNT_L
049:
050:IF,%OK_COUNT_L,==,4
051:THEN,LOG,"All of length are within margin -> OK", "GREEN"
052:ELSE,LOG,"All of length are out of margin -> NG", "RED"
053:
054:'==== Total Judgement ====
055:IF_EX,"( %OK_COUNT_S == 4) && (%OK_COUNT_L == 4) "
056:ELSE, JUDGE_FAIL
```

The length values recorded in the global variables as the previous measurement (open) are used to evaluate whether the lengths of the four cable pairs are sufficiently similar when the far end is shorted by the loop-back jack and when it is open. Evaluation is performed by examining whether the difference between the opened and the shorted lengths is within or outside the permissible margin.

Lines 001 ~ 014

Evaluate whether status of four cable pairs is all "SHRT". Although can Use JUDGE_FAIL command here to confirm pass/fail evaluation, in this case, subsequent evaluation processing not performed. In order to perform next evaluation irrespective of whether status pass or fail, evaluation result is counted in %OK_COUNT_S variable (pass when value is 4).


Lines 016 ~ 052

Evaluate whether lengths of four cable pairs within pass range


Lines 054 ~ 056

Overall evaluation

7. Setting Network Master Initial Condition for BER Measurement



8. Confirming Link Status



Line 002

Waits until Link established after completing preceding Load Setup


Line 002

Saves response to ETH:STAT:PORT1:LINK? query in local variable %RESP


Lines 005 ~ 011

Perform evaluation. If no Link established, evaluate as fail and terminate processing

9. Selecting Pattern



10. Starting Measurement and Evaluating Measurement Results



• United States

Anritsu Company

1155 East Collins Blvd., Suite 100, Richardson,
TX 75081, U.S.A.
Toll Free: 1-800-267-4878
Phone: +1-972-644-1777
Fax: +1-972-671-1877

• Canada

Anritsu Electronics Ltd.

700 Silver Seven Road, Suite 120, Kanata,
Ontario K2V 1C3, Canada
Phone: +1-613-591-2003
Fax: +1-613-591-1006

• Brazil

Anritsu Eletronica Ltda.

Praça Amadeu Amaral, 27 - 1 Andar
01327-010 - Bela Vista - Sao Paulo - SP
Brazil
Phone: +55-11-3283-2511
Fax: +55-11-3288-6940

• Mexico

Anritsu Company, S.A. de C.V.

Av. Ejército Nacional No. 579 Piso 9, Col. Granada
11520 México, D.F., México
Phone: +52-55-1101-2370
Fax: +52-55-5254-3147

• United Kingdom

Anritsu EMEA Ltd.

200 Capability Green, Luton, Bedfordshire, LU1 3LU, U.K.
Phone: +44-1582-433200
Fax: +44-1582-731303

• France

Anritsu S.A.

12 avenue du Québec, Bâtiment Iris 1- Silic 612,
91140 VILLEBON SUR YVETTE, France
Phone: +33-1-60-92-15-50
Fax: +33-1-64-46-10-65

• Germany

Anritsu GmbH

Nemetschek Haus, Konrad-Zuse-Platz 1
81829 München, Germany
Phone: +49-89-442308-0
Fax: +49-89-442308-55

• Italy

Anritsu S.r.l.

Via Elio Vittorini 129, 00144 Roma, Italy
Phone: +39-6-509-9711
Fax: +39-6-502-2425

• Sweden

Anritsu AB

Kistagången 20B, 164 40 KISTA, Sweden
Phone: +46-8-534-707-00
Fax: +46-8-534-707-30

• Finland

Anritsu AB

Teknobulevardi 3-5, FI-01530 VANTAA, Finland
Phone: +358-20-741-8100
Fax: +358-20-741-8111

• Denmark

Anritsu A/S

Kay Fiskers Plads 9, 2300 Copenhagen S, Denmark
Phone: +45-7211-2200
Fax: +45-7211-2210

• Russia

Anritsu EMEA Ltd.

Representation Office in Russia

Tverskaya str. 16/2, bld. 1, 7th floor.
Moscow, 125009, Russia
Phone: +7-495-363-1694
Fax: +7-495-935-8962

• Spain

Anritsu EMEA Ltd.

Representation Office in Spain

Edificio Cuzco IV, Po. de la Castellana, 141, Pta. 8
28046, Madrid, Spain
Phone: +34-915-726-761
Fax: +34-915-726-621

• United Arab Emirates

Anritsu EMEA Ltd.

Dubai Liaison Office

902, Aurora Tower,
P O Box: 500311 - Dubai Internet City
Dubai, United Arab Emirates
Phone: +971-4-3758479
Fax: +971-4-4249036

• India

Anritsu India Private Limited

2nd & 3rd Floor, #837/1, Binnamangla 1st Stage,
Indiranagar, 100ft Road, Bangalore - 560038, India
Phone: +91-80-4058-1300
Fax: +91-80-4058-1301

• Singapore

Anritsu Pte. Ltd.

11 Chang Charn Road, #04-01, Shriro House
Singapore 159640
Phone: +65-6282-2400
Fax: +65-6282-2533

• P.R. China (Shanghai)

Anritsu (China) Co., Ltd.

Room 2701-2705, Tower A,
New Caohejing International Business Center
No. 391 Gui Ping Road Shanghai, 200233, P.R. China
Phone: +86-21-6237-0898
Fax: +86-21-6237-0899

• P.R. China (Hong Kong)

Anritsu Company Ltd.

Unit 1006-7, 10/F., Greenfield Tower, Concordia Plaza,
No. 1 Science Museum Road, Tsim Sha Tsui East,
Kowloon, Hong Kong, P.R. China
Phone: +852-2301-4980
Fax: +852-2301-3545

• Japan

Anritsu Corporation

8-5, Tamura-cho, Atsugi-shi, Kanagawa, 243-0016 Japan
Phone: +81-46-296-6509
Fax: +81-46-225-8359

• Korea

Anritsu Corporation, Ltd.

5FL, 235 Pangyoeyeok-ro, Bundang-gu, Seongnam-si,
Gyeonggi-do, 13494 Korea
Phone: +82-31-696-7750
Fax: +82-31-696-7751

• Australia

Anritsu Pty. Ltd.

Unit 20, 21-35 Ricketts Road,
Mount Waverley, Victoria 3149, Australia
Phone: +61-3-9558-8177
Fax: +61-3-9558-8255

• Taiwan

Anritsu Company Inc.

7F, No. 316, Sec. 1, NeiHu Rd., Taipei 114, Taiwan
Phone: +886-2-8751-1816
Fax: +886-2-8751-1817