

LITHIUM BATTERY TEST SUMMARY

UN/DOT 38.3

to SUBSECTION 38.3 of the UN/DOT MANUAL of TESTS and CRITERIA

Battery Tested: Xantrex Lithium Ion (LiFePO₄) Battery - **105Ah-12Vdc, P/N: 883-0105-12**

Test Report Number: TCTTJ20210310970ZB-BR08;

Date of Test: 2021-05-13

Xantrex's product lithium ion batteries have successfully been tested and comply with UN/DOT Model Regulations, Manual of Test and Criteria, Part III, Subsection 38.3 to the following:

SUMMARY OF PERFORMED TESTS				RESULTS
38.3.4.1	T1	Altitude Simulation	Battery	Pass
38.3.4.2	T2	Thermal Test	Battery	Pass
38.3.4.3	T3	Vibration	Battery	Pass
38.3.4.4	T4	Shock	Battery	Pass
38.3.4.5	T5	External Short Circuit	Battery	Pass
38.3.4.6	T6	Crush / Impact	Cell	Pass
38.3.4.7	T7	Overcharge	Battery	Pass
38.3.4.8	T8	Forced Discharge	Cell	Pass

The UN/DOT 38.3 tests were performed by the following test laboratory and were tested to UN/DOT Manual of Test and Criteria, Revision 6, Amendment 1 revisions and amendments:

Test Laboratory: Shenzhen Tiansu Calibration and Testing Co., Ltd.
B/1,4, No. 2 Jinlong Road, Longgang District,
Shenzhen, China

Battery Test Information:

Model Number	Physical Description	Battery weight (kg) - Mass	Capacity Rating (V,Ah,Wh)	Net Equivalent Lithium Content (g)
883-0105-12	Lithium-ion Iron Phosphate (LiFePO ₄) battery with internal BMS	11.5 kg (25.4 lbs)	12.8 Vdc, 105 Ah, 1344 Wh	126 g (0.28 lbs)

Signed on: 2021-06-11



David Miller

Director, Engineering

Xantrex Business, Mission Critical Electronics