

# Copyright

© 2014-2021 International WELL Building Institute pbc. All rights reserved.

This WELL Building Standard version 1 (WELL v1) constitutes proprietary information of the International WELL Building Institute pbc (IWBI). All information contained herein is provided without warranties of any kind, either express or implied, including but not limited to warranties of the accuracy or completeness of the information or the suitability of the information for any particular purpose. Use of this document in any form implies acceptance of these conditions.

IWBI authorizes individual use of WELL v1. In exchange for this authorization, the user agrees:

- 1. to retain all copyright and other proprietary notices contained in WELL v1,
- 2. not to sell or modify WELL v1,
- 3. not to reproduce, display or distribute WELL v1 in any way for any public or commercial purpose, unless authorized in writing by IWBI, and
- 4. to ensure that any and all authorized uses of WELL v1, including excerpts thereof, should be accompanied by attribution, including the appropriate addendum (indicated, for example, by "Q2 2019") and WELL feature number and name.

Unauthorized use of WELL v1 violates copyright, trademark and other laws and is prohibited. International WELL Building Institute™, IWBI™, WELL™, the WELL Building Standard™, the WELL Community Standard™, WELL Certified™ and others and their related logos are trademarks of the International WELL Building Institute pbc in the US and other countries. All third-party trademarks and Standards referenced herein such as GREEN STAR™, BREEAM™, LEED™ and others are trademarks and/or Standards of their respective owners.

#### **Disclaimer**

None of the parties involved in the funding or creation of WELL v1, including IWBI, or its affiliates, members, employees, or contractors, assume any liability or responsibility to the user or any third parties for the accuracy, completeness, or use of or reliance on any information contained in WELL v1, or for any injuries, losses, or damages (including, without limitation, equitable relief) arising from such use or reliance. Although the information contained in WELL v1 is believed to be reliable and accurate, all materials set forth within are provided without warranties of any kind, either express or implied, including but not limited to warranties of the accuracy or completeness of information or the suitability of the information for any particular purpose. This document and WELL v1 are intended to educate and assist building stakeholders, real estate owners and tenants in their efforts to create healthier spaces and communities, and nothing in this document or in WELL v1 should be considered, or used as a substitute for, quality control, safety analysis, legal compliance (including zoning), comprehensive urban planning, medical advice, diagnosis or treatment.

As a condition of use, the user covenants not to sue and agrees to waive and release IWBI, its affiliates, members, employees, or contractors from any and all claims, demands, and causes of action for any injuries, losses or damages (including, without limitation, equitable relief) that the user may now or hereafter have a right to assert against such parties as a result of the use of, or reliance on WELL v1.

# **TABLE OF CONTENTS**

ORGANIZATIONAL STRUCTURE	3
WELLNESS – A COMPLEX ISSUE	4
ORGANIZATION OF THE WELL BUILDING STANDARD	6
PROJECT TYPES	
PILOT PROGRAM	13
WELL CERTIFICATION	15
WELL BUILDING STANDARD FEATURES MATRIX	19
A * .	22
Air	
Water	
Nourishment	
Light	92
Fitness	107
Comfort	119
Mind	134
Innovation	
APPENDICES	159
A: Glossary	
B: Standards Citations	166
C: Tables	
D: Feature Types And Verification Methods	
E: LEED v4 Similarities	
F: Living Building Challenge 3.0 Overlap	
G: External Reviewers	
H: Concept And Feature References	
I: Core and Shell Scope	004

# THE WELL BUILDING STANDARD® EXECUTIVE SUMMARY

# The WELL Building Standard (WELL) focuses on the people in the building.

Over the last decade, green building standards and standard-setting organizations have made significant strides towards the market transformation of the building industry, resulting in a rapid expansion of green buildings and environmentally conscious building practices throughout the world.

Over the same period, strategies to enhance human health and well-being have played a relatively small role in the evolution of building standards. We believe that the time has come to elevate human health and comfort to the forefront of building practices and reinvent buildings that are not only better for the planet, but also for people.

- 1. This is the first standard of its kind that focuses solely on the health and wellness of building occupants.
- 2. WELL identifies 100 performance metrics, design strategies, and policies that can be implemented by the owners, designers, engineers, contractors, users and operators of a building.
- 3. WELL is based on a thorough review of the existing research on the effects of spaces on individuals and has been advanced through a thorough scientific and technical review.
- 4. In order to achieve the requirements of the WELL Building Standard, the space must undergo a process that includes an on-site assessment and performance testing by a third party.



# A Wellness Standard for Buildings

The WELL Building Standard marries best practices in design and construction with evidence-based health and wellness interventions. It harnesses the built environment as a vehicle to support human health, well-being and comfort. WELL Certified™ spaces and developments can lead to a built environment that helps to improve the nutrition, fitness, mood, sleep, comfort and performance of its occupants. This is achieved in part by implementing strategies, programs and technologies designed to encourage healthy, more active lifestyles and reducing occupant exposure to harmful chemicals and pollutants.

This document presents the overall strategies, performance targets, certification and adherence steps required for projects to meet the WELL Building Standard. WELL Building Standard v1 is applicable for commercial and institutional buildings and WELL Certification can be applied to three project types:

- 1. New and Existing Buildings
- 2. New and Existing Interiors
- 3. Core and Shell

Pilot programs are available for other building sectors, including multifamily residences, retail and restaurants. Projects representing these building sectors are invited to join our ongoing pilot program.

# Updates to the WELL Building Standard

The WELL Building Standard is a dynamic rating system. As the intersection between design and human health evolves, we strongly believe in the importance of advancing alongside. The WELL Building Standard (WELL) v1.0 was launched in October 2014, and as part of the development process, updates to the standard incorporate early user feedback, including simplifications, language enhancements and additional clarifications to certain feature requirements.

# ORGANIZATIONAL STRUCTURE

WELL is the culmination of seven years of rigorous research in collaboration with leading physicians, scientists and industry professionals. The WELL Building Standard® was pioneered by Delos, is administered by the International WELL Building Institute $^{\text{IM}}$  (IWBI $^{\text{IM}}$ ), and is third-party certified through IWBI's collaboration with Green Business Certification Inc. (GBCI) – the certification body for the LEED Green Building Rating System.

# International WELL Building Institute, PBC (IWBI)

IWBI is a public benefit corporation whose mission is to improve human health and well-being through the built environment. Public benefit corporations like IWBI are an emerging U.S. structure for corporations committed to balancing public benefits with profitability – harnessing the power of private capital for greater good. IWBI administers the WELL Building Standard (WELL) – a performance-based system for measuring, certifying, and monitoring features of buildings that impact the health and wellbeing of the people who live, work, and learn in them. Fulfilling the vision of IWBI Founder Paul Scialla, IWBI has a pioneering altruistic capitalism model that will address social responsibility and demonstrate a sustainable model for philanthropy. IWBI has committed to direct 51% of net profits received from WELL Certification project fees toward charitable contributions and impact investment focused on health, wellness, and the built environment. IWBI was established by Delos in 2013 pursuant to a Clinton Global Initiative commitment to improve the way people live by developing spaces that enhance occupant health and quality of life by sharing the WELL Building Standard globally.

# **Delos Living LLC**

Delos<sup>®</sup> is pioneering the integration of health and wellness technologies into the places we live, work and learn. By placing health and wellness at the center of design, construction, technology and programming decisions, Delos is transforming our homes, offices, schools and other indoor environments into spaces that actively contribute to human health and well-being.

# **Alignment with Green Building Standards**

The WELL Building Standard is designed to work harmoniously with the LEED Green Building Rating System, the Living Building Challenge and other leading global green building standards. We encourage projects to pursue both WELL and standards that address environmental sustainability.

# WELLNESS - A COMPLEX ISSUE

Comprehensive and interdisciplinary approaches are necessary to meaningfully address the complex issues of human health and well-being. A narrow focus on select aspects of health is inadequate to the task. Many factors of the physical environment have a significant impact on day-to-day health and productivity, but it is often the interactions between multiple environmental factors that matter most. A growing body of research supports these claims but little has been done to translate research into practice. The WELL Building Standard® therefore draws from multiple disciplines of scientific study, and presents an integrated approach that reinvents the built environment around its occupants, transforming the places we live, work and learn into systems intended to promote and improve human health and well-being.

# Interactions Between Humans and the Built Environment

Traditional healthcare delivery systems primarily focus on addressing health after people have already become sick. With rising costs and the increased burden of chronic diseases such as diabetes, cardiovascular disease and cancer, people are turning to more lifestyle-oriented and preventative approaches to health. The WELL Building Standard is founded on the understanding that facets of our environment interact with personal, genetic and behavioral factors to shape our overall health and well-being. WELL recognizes that many behaviors are subconsciously dictated by external cues, and thus it carefully considers interactions between humans and the built environment that shape not only our physical health but also our behavior.

# The Basis for the WELL Building Standard

The WELL Building Standard v1 is the product of seven years of research and development culminating with an expert review process encompassing a scientific, practitioner and medical review. The WELL Building Standard was developed by integrating scientific and medical research and reviewing existing literature on environmental health, behavioral factors, health outcomes and demographic risk factors. By compiling leading practices in building design and management and referencing existing standards and best practice guidelines set by governmental and professional organizations, WELL works to harmonize and clarify existing thresholds and requirements. Where important issues have not been adequately addressed by the literature, the WELL Building Standard relies on expert consultation as the basis for defining performance requirements.

WELL is in large part performance-based; in most cases, specific, measurable "markers" (thresholds) are provided that must be met. In other cases, particular strategies are required, as strong evidence suggests there are benefits to implementation.

Overall, the WELL Building Standard is designed to comprehensively cover the various individual needs of building occupants while also building a common foundation for measuring wellness in the built environment.

# WELLographies™

A rich body of research supported the development of the underlying concepts and requirements of the WELL Building Standard. A review of this literature is described in a series of WELLography<sup>™</sup> publications. The WELLographies will provide the content and references for all main topics that constitute the WELL Building Standard. WELLographies cite major regulatory guidelines, position statements from trusted organizations, medical and scientific literature and well-established best practice guidelines on the topics covered in WELL.

# **Acknowledgements**

We would like to thank all parties involved in the review of the WELL Building Standard and the supporting WELLographies. The WELL Building Standard has been evaluated by leading scientists, practitioners from the building industry and physicians from leading medical institutions.

Scientists were consulted to help prioritize the factors that contribute to wellness. In order to assess the applicability of WELL in practice, building professionals and other stakeholders were asked for input. We give special thanks to the Clinton Global Initiative, U.S. Green Building Council, International Living Future Institute, GBCI, Mayo Clinic and CBRE, who have given institutional support for our efforts.

IWBI is especially grateful for the support of Cleveland Clinic Wellness over the last few years. The organization has been an inspirational example of the effect that wellness policies can have on the health and well-being of the staff of an institution. Under the leadership of Dr. Michael F. Roizen, Cleveland Clinic Wellness has conducted a review of the WELL Building Standard and WELLographies.

A complete list of reviewers can be found in Appendix G and at <a href="https://www.wellcertified.com">www.wellcertified.com</a>.

# ORGANIZATION OF THE WELL BUILDING STANDARD®

The WELL Building Standard is organized into seven categories of wellness called Concepts: Air, Water, Nourishment, Light, Fitness, Comfort and Mind.

# WELL Building Standard Features, Parts and Requirements

The seven Concepts are comprised of 105 features. Every feature is intended to address specific aspects of occupant health, comfort or knowledge. Each feature is divided into parts, which are often tailored to a specific building type. This means that depending on the building type (e.g., New and Existing Interiors or Core and Shell), only certain parts of a given feature may be applicable. Within each part are one or more requirements, which dictate specific parameters or metrics to be met. In order for a project to receive credit for a particular feature, all of its applicable component parts specifications must be satisfied.

#### Features can be:

- Performance-based standards that allow flexibility in how a project meets acceptable quantified thresholds
- Prescriptive standards that require specific technologies, design strategies or protocols to be implemented

#### **Preconditions**

Some WELL features are categorized as Preconditions—necessary for all levels of WELL Certification. These features represent the core of the WELL Building Standard. Preconditions can be thought of as the foundation for wellness in the built environment. It is important to note that for certification to be awarded, all applicable Preconditions must be met.

# **Optimizations**

Optimizations are not required to achieve Silver level certification, but create a flexible pathway towards Gold and Platinum level certification. These features include optional technologies, strategies, protocols and designs. IWBI recommends that all projects strive to achieve as many Optimizations as possible.

STANDARD VERSION	LEVEL OF ACHIEVEMENT	PRECONDITIONS THAT MUST BE ACHIEVED	OPTIMIZATIONS THAT MUST BE ACHIEVED
	Silver Certification	All applicable	None
WELL Building Standard®	Gold Certification	All applicable	40% of applicable
	Platinum Certification	All applicable	80% of applicable
	Silver Certification	All applicable	20% of applicable
WELL Pilot Standards	Gold Certification	All applicable	40% of applicable
	Platinum Certification	All applicable	80% of applicable

# **Not Applicable Features**

Features that are labeled as 'not applicable' (N/A) to a particular project type are not expected to be relevant to that project type. These features are not included in the project type's total optimization count in scoring. However, if a project finds that a 'not applicable' feature is indeed relevant and meets all of the feature's requirements, the project may receive credit for the achieved optimization without increasing the total applicable optimization count for scoring purposes.

# Feature Intents in the WELL Building Standard

Each WELL Building Standard feature is designed to address issues that impact the health, comfort or knowledge of occupants. Many features intended to improve health are supported by existing government standards or other standard-setting organizations. Some features are intended to change behavior through education and corporate culture, providing, for example, information and support for making positive lifestyle choices.


# **Wellness and Body Systems**

Each feature of the WELL Building Standard is ascribed to the human body systems that are intended to benefit from its implementation. This enables project teams to classify the intended benefits of each WELL feature and develop a comprehensive set of strategies. While there are different ways to group the body's various systems, the WELL Building Standard considers each feature's impact on the following categories of body systems:

# Cardiovascular System

The cardiovascular system consists of the heart, vessels and blood. Its primary function is to supply nutrients and remove waste from the body tissues. However, stress, unhealthy diets and lifestyle choices, and exposure to environmental pollutants can negatively impact cardiovascular health and lead to the development of chronic conditions that reduce quality of life.

The WELL Building Standard addresses factors that play a vital role in cardiovascular health: stress, nutrition, fitness and environmental pollutants. Comfort features mitigate stress and help to maintain hormonal balance in the body. Healthy diets and active lifestyles control body weight and strengthen the muscles of the heart. Elimination of environmental pollutants in air, such as tobacco and VOCs – which directly harm the heart and vessels – also contribute towards good cardiovascular health.



# **Digestive System**

The digestive system consists of the mouth, esophagus, stomach, small and large intestines, and the auxiliary organs – liver and pancreas – that produce digestive hormones and enzymes. This complex system is responsible for nutrient breakdown, absorption and assimilation. In addition, the gut is the largest reservoir of bacteria, which assist in digestion and play a role in immune health. These critical functions can be compromised by poor dietary habits and stress, as well as by microbes and environmental pollutants in the foods we eat and the surfaces that we touch.

The features of WELL support interventions that reduce factors that negatively impact digestive health. Comfort features mitigate stress, which affects the health and function of the microbiome. Proper diets help to limit the consumption of foods and substances that cause digestive discomfort and allergic reactions. Treatment of surfaces ensures that microbes and toxins do not enter our digestive system via our foods. Together, the features of WELL contribute towards maintaining optimal digestive and overall health.



# **Endocrine System**

The endocrine system is made up of hormone-secreting glands. Hormones are chemical compounds that regulate many important processes including growth, immunity, metabolism, reproduction, mood and digestion. Unfortunately, stress, environmental pollutants and many of today's foods and products contain chemicals that disrupt the function of the endocrine system and can cause a variety of health problems.


The features of the WELL Building Standard aim to mitigate or eliminate exposure to potentially harmful endocrine system disruptors. Comfort features help to reduce stress that can lead to chronic health conditions. Nourishment features limit the ingestion of compounds that mimic hormones and disrupt proper endocrine regulation. Elimination of environmental pollutants prevents the exposure to toxins and compounds that interfere with the endocrine regulation of many of the body's functions.



# **Immune System**

The immune system is a complex cohort of highly specialized cells, proteins, tissues and organs that make up the body's defense system against internal and foreign disease-causing agents. It is affected by the cumulative effect of toxins, poor sleep, nutrition and excessive stress. Failure to maintain proper immune function can increase the incidence of infections by bacterial and viral pathogens, and contribute towards the development of chronic conditions such as arthritis, diabetes, cardiovascular or respiratory disease and even cancer.


The features in the WELL Building Standard aim to promote and enhance immune health. The use of non-toxic materials limits the exposure to chemicals that weaken the immune function. Water and air filtration systems limit the exposure to bacterial and viral pathogens and allergens. In addition, WELL includes features that reduce stress and improve nutrition and fitness, which help strengthen the immune system.



# **Integumentary System**

The skin, hair and nails form the outer layer of the body, or the integumentary system. It functions to protect internal organs from impact, prevents water loss, regulates body temperature and protects the body against foreign pathogens and harmful toxins. The skin is also a host to a large community of symbiotic microorganisms that produce a moisturizing layer and aid in immune function.

The WELL Building Standard helps to maintain integumentary system integrity, as this system provides the first line of defense against injury and/or infections. In addition, it requires that building materials are absent of toxins that could be harmful if absorbed through the body's outermost layers.



# **Muscular System**

The human muscular system is comprised of skeletal, smooth and cardiac muscle. It supports posture, movement, blood circulation and digestion. The muscular system is also responsible for generating heat through the contraction of muscles. Balanced diet and physical activity greatly affect muscular health, as they ensure that the muscles receive adequate nutrients for proper development and function.


The WELL Building Standard contains features that are designed to encourage or enhance the opportunities for safe physical activity, promoting an active lifestyle. To complement this, ergonomic designs are intended to reduce the likelihood of ligament strain and muscular injuries. Other features promote the use of active furnishings or design principles that encourage small amounts of physical activity throughout the day and reduce sedentariness.



# **Nervous System**

The nervous system includes the central nervous system, made up of the brain and spinal cord, and the peripheral nervous system, composed of nerves. The nervous system is directly and indirectly responsible for controlling nearly every bodily process, including movement, cognitive processes and maintenance of vital organ functions.

The WELL Building Standard places the utmost importance on supporting neurologic and cognitive function through a variety of interventions. Features work to limit the exposure to environmental toxins in air and water, encourage balanced diets and optimal levels of physical activity, and enhance sleep quality and mitigate stress through the implementation of a variety of comfort measures.



# Reproductive System

The reproductive system consists of hormone-secreting glands in the brain and the reproductive organs. Failure to maintain proper reproductive health can have negative consequences on overall health. Further, the effects of this system are broad-reaching and can have an impact on personal and prenatal health.

The WELL Building Standard introduces features intended to help protect reproductive health. Proper diet and exercise are two important factors that are addressed by WELL; these are complemented by ergonomic and toxin avoidance strategies that help support reproductive health.



# **Respiratory System**

The respiratory system includes the mouth, nose, diaphragm, the trachea and the airways that reach deep into the lungs. The respiratory system works in tandem with the circulatory system in order to provide oxygen and remove carbon dioxide from the body tissues.


The features of the WELL Building Standard help to promote optimal respiratory system function by improving the quality of the air we breathe, limiting exposure to molds and microbes and by improving access to opportunities for greater fitness. Elimination of VOCs and particulate matter from ambient air helps to prevent direct damage to the lungs. Mitigation of molds and microbes reduces the incidence of infections and allergic reactions. Fitness features help to improve lung function and the overall strength of the respiratory system.



# **Skeletal System**

The skeletal system provides support and movement, protects internal organs against impact, stores minerals, produces blood cells and aids in hormone regulation. Similarly to the closely related muscular system, skeletal health is strongly affected by proper nutrition and adequate levels of physical activity.


The WELL Building Standard is grounded in the latest research in universal design and ergonomics to improve posture and alignment and limit physical stress. In addition, features provide guidelines for fitness and nutrition that are designed to support skeletal system health and function.



# **Urinary System**

The urinary system consists of the kidneys, ureters, bladder and the urethra. The urinary system serves a number of critical functions, including the filtration of toxins, balance of blood pH and electrolytes, maintenance of blood pressure and the elimination of waste through urine. The kidneys are sensitive organs that can be damaged by exposure to toxins, chronic high blood pressure, and excessive quantities of alcohol or medications.

The features of the WELL Building Standard help to support urinary health by reducing stress and exposure to toxins and infection-causing pathogens. Comfort features that reduce stress prevent the likelihood of high blood pressure and hormone levels that negatively affect urinary function. Restriction of toxins and pathogens helps to limit the incidence of urinary infections and other potentially serious problems.



# **PROJECT TYPES**

The features of the WELL Building Standard<sup>®</sup> can be applied across many real estate sectors, but the version presented herein is applicable to commercial and institutional buildings. Furthermore, not all WELL features apply to all buildings, depending on the stage of construction. WELL v1 is therefore further organized into project types, which take into account the specific set of considerations that are unique to a particular building type or phase of construction. For WELL v1, there are three project types.

PROJECT TYPES	PRECONDITIONS	OPTIMIZATIONS	TOTAL
New and Existing Buildings	41	59	100
New and Existing Interiors	36	62	98
Core and Shell	26	28	54

#### Core and Shell

WELL Certification is available for Core and Shell building projects seeking to implement fundamental features into the entire base building for the benefit of future tenants. The Core and Shell project type addresses the building structure, window locations and glazing, building proportions, heating, cooling and ventilation systems, and water quality. This project type also encourages consideration of the site in relation to amenities and opportunities for wellness.

Core and Shell is appropriate for projects in which at least 75% of the project area is occupied by one or more tenants and/or serves as common space in the building accessible to all tenants. Note that offices affiliated with the project owner but unrelated to the management of the project property may be considered a tenant so long as there is at least one additional tenant unaffiliated with the project owner. Independent of the portion of the building controlled by the owner, 100% of the building core and shell and all portions of the interior buildout or managed by the project owner are included in the project scope for design and operations. The Performance Verification Guidebook describes methods for on-site measurements and inspections.

## **New and Existing Interiors**

This project type is relevant for office projects only occupying a portion of the space in a building, or those that occupy an entire existing building not undergoing major renovation. In Core and Shell buildings that are WELL Certified<sup>™</sup>, some WELL features may already apply towards New and Existing Interiors certification, making certification easier. WELL Certification for tenants is also possible in buildings that have not first achieved Core and Shell certification.

## **New and Existing Buildings**

Entire buildings present opportunities for implementation of the greatest number of WELL features. This project type applies to new and existing buildings and addresses the full scope of project design and construction as well as aspects of building operations. It is relevant for office buildings where a minimum of 90% of the total floor area is occupied by the building owner and is operated by the same management (i.e., up to 10% of the building may be occupied by a different tenant or operated by different management). For example, a large office building may rent out the ground floor for retail or restaurant purposes; in these cases, the non-office area would not be subject to requirements of the WELL Building Standard or used in area calculations.

# **PILOT PROGRAM**

Given the unique opportunities and challenges presented by different building types, additional time and resources are needed to aggregate the necessary scientific and institutional support to refine the WELL Building Standard® to the specific needs of additional project types. As such, pilot programs are in development to test and refine how WELL can best apply to different space types. The WELL Building Standard is a continuously evolving program that is updated as improved evidence and technologies become available. The following pilot standards have been released:

## **Current Pilots**

# **Multifamily Residential**

Multifamily Residential applies specifically to projects with at least five dwelling units in a single building with common structural elements. Projects that qualify include apartments, condominiums, townhouses and other residential complexes within all market thresholds – affordable housing, market-rate and luxury. Single-family homes and duplexes are not part of the residential pilot.

#### **Educational Facilities**

Places of learning, including elementary schools, middle schools, high schools and higher education facilities must provide for the needs of teachers and students of all ages. Educational Facilities applies to projects where dedicated staff are employed for instructional purposes, and students can be of any age. Courses may cover any range of topics, and facilities may be typified by fully scheduled days, or distinct classes that students enroll in at will.

#### Retail

Retail centers, including boutique shops and big-box stores, are another opportunity to design and construct buildings to the WELL Building Standard. Retail spaces are unique in that they simultaneously house and cater to two distinct groups: the transient consumer and the staff, who spend many more hours in the facility. Retail applies to locations where consumers can view and purchase merchandise on-site, and staff are employed to assist in the sale of products. The Retail pilot standard is applicable to both owner- and tenant-occupied projects, and to both those in stand-alone buildings and those integrated into larger structures.

#### Restaurant

Away-from-home meals constitute a significant source of nourishment for many, making restaurants a crucial place for health and wellness intervention. The design of eating spaces and the way foods are presented can subtly nudge occupants towards specific behaviors and help make healthy eating decisions. Restaurants applies to locations where a customer purchases food and dines on-site, and includes indoor or outdoor seating. The establishment may include wait staff that tend to customers, or be self-serve. The Restaurant pilot standard does not include take-out only establishments, or establishments whose primary source of revenue derives from the sale of alcoholic beverages. Further, the Restaurant pilot standard only applies to dining spaces—it does not cover kitchens in which food is prepared (see Commercial Kitchen).

#### Commercial Kitchens

Commercial Kitchens applies to locations where cooks prepare food for other building users. The kitchen component of a space requires specific considerations relating to ventilation and contamination. It is not applicable to office kitchenettes or home kitchens. In general, spaces subject to local health inspection are likely to use this

pilot standard. Commercial Kitchen is always paired with another standard, such as Restaurant or Education. For example, the Commercial Kitchen pilot standard may be coupled with the Restaurant pilot standard to cover both the food preparation and customer dining spaces, respectively. This pilot standard may also be paired with WELL v1 for commercial and institutional offices if projects feature kitchens with associated food-service staff engaged in food preparation activities on-site.

#### Communities

Communities include multiple buildings and diverse populations and must function to protect the health and wellbeing of both residents and visitors. WELL features address aspects relevant to the design and operations of the communities as well as WELL Certification of the buildings within them.

# WELL CERTIFICATION

Projects become certified if a sufficient number of features are satisfied. To maintain WELL Certification, projects must be recertified a minimum of every three years because building conditions can deteriorate over time to the point of adversely affecting the health and wellness of occupants.

The full process for WELL Certification is outlined in the Certification Guidebook.

## **Project Registration**

Projects seeking to achieve WELL Certification must be registered with IWBI through WELL Online, the official online registration and project management system for WELL. Project teams may register at any point as they progress through the design and development process. However, it is advantageous to register as close to the beginning of the process as possible so that strategies to meet the WELL Building Standard® can be integrated from the very beginning.

At registration, projects define the borders of project scope. The WELL boundary may not unreasonably exclude portions of the building, space, or site to give the project an advantage in complying with credit requirements. The WELL project must accurately communicate the scope of the certifying project in all promotional and descriptive materials and distinguish it from any non-certifying space. The WELL project should be defined by a clear boundary such that the WELL project is physically distinct from other interior spaces within the building. Regardless of boundary, WELL organizational protocol requirements (as defined within Appendix D) must be adopted by the entire entity seeking certification located in the project's building, such that an occupant's location within the building does not determine the availability of these protocol requirements.

The Following Features Contain WELL Organizational Protocol Requirements:

Feature 65 – Activity Incentive Programs

Feature 66 – Structured Fitness Opportunities

Feature 90 – Healthy Sleep Policy

Feature 91 – Business travel

Feature 92 – Building Health Policy

Feature 93 – Workplace Family Support

Feature 94 – Self-monitoring

Feature 95 – Stress and Addiction Treatment

Feature 96 – Altruism

Feature 98 – Organizational Transparency

#### **WELL Accredited Professionals**

IWBI oversees the WELL Accredited Professional (WELL AP) program. WELL APs are trained on the conceptual and applied frameworks of WELL and experienced in its application on registered and certified WELL projects and can help guide projects to successful certification awards. Further information on the WELL AP program can be found in the WELL AP Candidate Handbook, on wellcertified.com/resources/well-ap.

#### **Alternative Adherence Paths**

WELL allows for innovative, alternate solutions for meeting requirements through the alternative adherence path process, as long as proposals still meet the intent of the requirement and are supported by cited scientific, medical and industry research. Project teams may propose an alternative for any requirement of WELL by submitting a completed alternative adherence path for review.

#### **Documentation Submission and Review**

Verification that the requirements of the WELL Building Standard have been met necessitates detailed documentation. Project teams are expected to provide various documents attesting to the satisfaction of certain parts of features (See Appendix D for more information).

#### **Performance Verification**

Since large parts of the WELL Building Standard are based on building conditions, IWBI uses Performance Verification as a process for on-site assessments. These inspections and measurements include tests related to air and water quality and sound and light levels. It is a process distinct from traditional building commissioning, and assures that the building is performing as intended in accordance to the WELL Building Standard.

Performance Verification is completed by an authorized WELL Performance Testing Agent who will usually spend one to three days in the building to validate the project's design documentation and to complete a series of performance tests, spot-checks and measurements spanning all WELL Concepts. Testing is completed according to IWBI's sampling protocols based on the size and type of the project, and samples are sent to third-party labs for analysis.

Any WELL feature is subject to verification on-site by a WELL Performance Testing Agent during Performance Verification—even those accounted for by documentation. The Performance Testing Agent may therefore provide additional documentation generated during spot-checks or spot-measurements for final consideration, in the form of an inspection document.

## Scoring

In evaluating adherence to the WELL Building Standard, a project's assessor will grade each Concept independently on a numerical scale. While this Concept-by-Concept analysis is used initially to ensure that all Preconditions per Concept are met, the final WELL Score is calculated based on the total Preconditions and Optimizations achieved across the board—not as a function of averaging independent Concept scores.

Failure to achieve any Precondition in any Concept will preclude the award of WELL Certification. If all Preconditions are satisfied, higher levels of certification award are possible. In evaluating award levels, all Optimization features are treated equally.

Concept scores and the overall WELL score are calculated as follows for the number of WELL features applicable to a specific project type:

Total Preconditions = TP

Preconditions Achieved = PA

Total Optimizations = TO

Optimizations Achieved = OA

Wellness Score = WS

**FAIL:** If 
$$\left(\frac{PA}{TP}\right) < 1$$
 then WS =  $\left(\frac{PA}{TP}\right) \times 5$  (rounded down to nearest whole number)

**PASS:** If 
$$\left(\frac{PA}{TP}\right) = 1$$
 then WS = 5 +  $\left(\frac{OA}{TO}\right) \times 5$  (rounded down to nearest whole number)

In making these calculations, Innovation and Not Applicable features are not included among the Total Optimizations (TO), though achieving them will increase Optimizations Achieved (OA).

The example below shows an office that successfully meets the requirements of the New and Existing Buildings project type. With all Preconditions met and 29 Optimizations met, it will receive the scores calculated as shown.

CONCERT	PRECONDITIONS		OPTIMIZATIONS		CONCERT COORES
CONCEPT	APPLICABLE	ACHIEVED	APPLICABLE	ACHIEVED	CONCEPT SCORES
Air	12	12	17	3	5
Water	5	5	3	0	5
Nourishment	8	8	7	7	10
Light	4	4	7	2	6
Fitness	2	2	6	3	7
Comfort	5	5	7	2	6
Mind	5	5	12	12	10
Total and WELL Score	41	41	59	29	7

Lower scores (0 – 4) comprise the compulsory Precondition features; a score less than 5 would denote failure to meet the Preconditions in that Concept and thus failure for overall certification or compliance. Silver scores (5 – 6) mean that all compulsory Precondition features have been met in the Concept. Gold scores (7 – 8) and Platinum scores (9 – 10) comprise the non-compulsory Optimizations.

#### **WELL Scorecard**

The WELL Scorecard is the aggregate of all of the WELL Scores for each Concept. The scorecard shows Gold level certification for the previous building example.

### **Recertification Requirements**

WELL Certification is valid for three years. In order to maintain a current certification, WELL Certified™ projects must undergo Performance Verification again and apply for recertification to verify that the building continues to perform in accordance with the requirements of the WELL Building Standard before the end of the three-year Certification period. During the Certification period, annual data must also be submitted for the features that require more frequent reporting.

Project scores may change at the time of recertification if additional improvements have been made or if WELL features have not been properly maintained. It is possible for the building's certification to be revoked if the quality of the interior environment declined considerably since initial certification. Projects may also submit evidence of achievement of additional features to improve their certification level at this time.



# **WELL BUILDING STANDARD FEATURES MATRIX**

This table shows which features are preconditions and optimizations for the different project types of the standard for commercial and institutional offices. Refer to the tables in the beginning of each concept for details about the applicability of specific parts.

		Core and Shell	New and Existing Interiors	New and Existing Buildings
Air				
01	Air quality standards	Р		Р
02	Smoking ban	Р	Р	Р
03	Ventilation effectiveness	Р		Р
04	VOC reduction	Р		Р
05	Air filtration	Р	Р	Р
06	Microbe and mold control	Р	Р	Р
07	Construction pollution management	Р	Р	Р
08	Healthy entrance	Р		Р
09	Cleaning protocol		Р	Р
10	Pesticide management	Р		P
11	Fundamental material safety	Р	Р	Р
12	Moisture management	Р		Р
13	Air flush		0	О
14	Air infiltration management	0		0
15	Increased ventilation			0
16	Humidity control			0
17	Direct source ventilation	0		0
18	Air quality monitoring and feedback			0
19	Operable windows			О
20	Outdoor air systems			О
21	Displacement ventilation			О
22	Pest control			О
23	Advanced air purification	0		О
24	Combustion minimization			О
25	Toxic material reduction			О
26	Enhanced material safety			0
27	Antimicrobial activity for surfaces			0
28	Cleanable environment			О
29	Cleaning equipment			0
Water				
30	Fundamental water quality	Р	Р	Р
31	Inorganic contaminants	Р	Р	Р
32	Organic contaminants	Р		Р
33	Agricultural contaminants	Р	Р	Р
34	Public water additives	Р	Р	Р
35	Periodic water quality testing		0	0
36	Water treatment	О		0
37	Drinking water promotion	0	0	0

		Core and Shell	New and Existing Interiors	New and Existing Buildings
Nouris				
38	Fruits and vegetables		Р	Р
39	Processed foods	Р		Р
40	Food allergies	Р	Р	Р
41	Hand washing		Р	Р
42	Food contamination		Р	Р
43	Artificial ingredients	0	Р	Р
44	Nutritional information	0	Р	Р
45	Food advertising	0	Р	Р
46	Safe food preparation materials		0	O
47	Serving sizes		0	О
48	Special diets		0	О
49	Responsible food production		0	О
50	Food storage		0	О
51	Food production	0		О
52	Mindful eating	0		0
Light				
53	Visual lighting design		Р	Р
54	Circadian lighting design		Р	Р
55	Electric light glare control	Р	Р	Р
56	Solar glare control	0	Р	Р
57	Low-glare workstation design		0	0
58	Color quality		0	0
59	Surface design		0	О
60	Automated shading and dimming controls		0	0
61	Right to light	0	0	0
62	Daylight modeling	0		0
63	Daylighting fenestration	0		0
Fitness	1			
64	Interior fitness circulation	Р	0	Р
65	Activity incentive programs		Р	Р
66	Structured fitness opportunities		0	О
67	Exterior active design	0	0	0
68	Physical activity spaces	0		О
69	Active transportation support	0		О
70	Fitness equipment	0		О
71	Active furnishings		0	0
Comfo	1			
72	Accessible design	Р	Р	Р
73	Ergonomics: visual and physical		Р	P
74	Exterior noise intrusion	Р	0	P
75	Internally generated noise	0	Р	P
76	Thermal comfort	Р	P	P
77	Olfactory comfort		0	0
78	Reverberation time		0	0
79	Sound masking		0	0
80	Sound reducing surfaces		0	0
81	Sound barriers		0	0
82	Individual thermal control		0	0
83	Radiant thermal comfort	0	0	0
- 55	Tagain diomar comore			

		Core and Shell	New and Existing Interiors	New and Existing Buildings
Mind				
84	Health and wellness awareness	Р	Р	Р
85	Integrative design	Р	Р	Р
86	Post-occupancy surveys			Р
87	Beauty and design I	Р	Р	Р
88	Biophilia I - qualitative		Р	Р
89	Adaptable spaces			О
90	Healthy sleep policy			О
91	Business travel			О
92	Building health policy			О
93	Workplace family support			О
94	Self-monitoring			О
95	Stress and addiction treatment			О
96	Altruism			О
97	Material transparency			О
98	Organizational transparency			О
99	Beauty and design II			О
100	Biophilia II - quantitative			О
Innova	tion			
101	Innovation I			О
102	Innovation II			О
103	Innovation III			O
104	Innovation IV			О
105	Innovation V	0	0	О



# **BACKGROUND**

Clean air is a critical component to our health. Air pollution is the number one environmental cause of premature mortality, contributing to 50,000 premature deaths annually in the United States and approximately 7 million, or one in eight premature deaths worldwide.

Globally, outdoor air quality is deteriorating due to pollution from traffic, construction, agricultural activity, combustion sources and particulate matter. Because ambient air diffuses easily, even distant sources of pollution have a huge impact on the more than 15,000 liters of air we breathe every day. Indoor air quality can be degraded by these outdoor sources, as well as by off-gassing from building materials, indoor combustion sources and water leaks. Poor ventilation practices can fail to address these sources, exposing us to volatile organic compounds (VOCs), polycyclic aromatic hydrocarbons (PAHs) and microbial pathogens. Another way in which indoor air quality may be diminished is via surfaces, which can accumulate airborne germs. All of these contaminants contribute to a range of negative health outcomes such as asthma, allergies and other upper respiratory illnesses. In addition, air quality issues can diminish work productivity and lead to sick building syndrome (SBS), where no disease or cause can be identified, yet acute health effects are linked to time spent in a building. SBS symptoms include various nonspecific symptoms such as eye, skin and airway irritation, as well as headache and fatigue.

The reactions people have to air pollutants vary widely and depend on multiple factors including the concentration of the contaminant, the rate of intake and the duration of exposure. Pollution source avoidance, proper ventilation and air filtration are some of the most effective means of achieving high indoor air quality. In the U.S., the Environmental Protection Agency (EPA) sets National Ambient Air Quality Standards (NAAQS) according to ongoing research and monitoring. These Standards have been credited with dramatic improvements in outdoor air quality, and create exposure limits based on both duration of exposure and concentration for the six major air pollutants: carbon monoxide (CO), lead (Pb), nitrogen dioxide (NO $_2$ ), ozone (O $_3$ ), particulate matter (PM $_1$ 0 and PM $_2$ . $_5$ ) and sulfur dioxide (SO $_2$ ). The WELL Building Standard® expands upon these requirements by incorporating standards from additional agencies, such as the World Health Organization (WHO). To help minimize transmission through contact with unsanitary surfaces, the WELL Building Standard provides an approach that combines the installation of appropriate materials with the implementation of effective protocols to regularly disinfect targeted areas.

In addition to limiting pollutant and contaminant concentrations, WELL incorporates best practices from industry organizations, whose guidelines are evidence-based and recommended by professionals. One such group is the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE), which regularly updates its building handbook to include new techniques for enhancing air quality within buildings. Although ASHRAE is a technical society without a legal mandate, many state and local governments have modeled their codes based on ASHRAE's standards. In addition, the U.S. Green Building Council's LEED® program continues to set new standards for both air filtration and building material selection to improve air quality.

# **INTENT**

The WELL Building Standard for Air promotes clean air through reducing or minimizing the sources of indoor air pollution, requiring optimal indoor air quality to support the health well-being of building occupants.

# **AIR FEATURE LEVEL MATRIX**

	Core and Shell	New and Existing Interiors	New and Existing Buildings
01 AIR QUALITY STANDARDS			
1: Standards for Volatile Substances	Р	Р	Р
2: Standards for Particulate Matter and Inorganic Gases	Р		
3: Radon	Р	Р	Р
02 SMOKING BAN			
1: Indoor Smoking Ban	Р	Р	Р
2: Outdoor Smoking Ban	Р	-	Р
03 VENTILATION EFFECTIVENESS			
1: Ventilation Design	Р	Р	Р
2: Demand Controlled Ventilation	Р		
3: System Balancing	-	Р	
04 VOC REDUCTION			
1: Interior Paints and Coatings	Р	Р	Р
2: Interior Adhesives and Sealants	Р		
3: Flooring	Р		
4: Insulation	Р		
5: Furniture and Furnishings	Р	Р	Р
05 AIR FILTRATION			
1: Filter Accommodation	Р	Р	Р
2: Particle Filtration	Р		
3: Air Filtration Maintenance	Р	Р	Р
06 MICROBE AND MOLD CONTROL			
1: Cooling Coil Mold Reduction	Р	Р	Р
2: Mold Inspections	Р		
07 CONSTRUCTION POLLUTION MANAGE	MENT		
1: Duct Protection	Р	Р	Р
2: Filter Replacement	Р		
3: Moisture Absorption Management	Р		
4: Dust Containment and Removal	Р		
08 HEALTHY ENTRANCE			
1: Entryway Walk-Off Systems	Р	О	Р
2: Entryway Air Seal	Р	0	Р
09 CLEANING PROTOCOL			
1: Cleaning Plan for Occupied Spaces	-	Р	Р


	Core and Shell	New and Existing Interiors	New and Existing Buildings
10 PESTICIDE MANAGEMENT			
1: Pesticide Use	Р	-	Р
11 FUNDAMENTAL MATERIAL SAFETY			
1: Asbestos and Lead Restriction	Р	Р	Р
2: Lead Abatement	Р		Р
3: Asbestos Abatement	Р		Р
4: Polychlorinated Biphenyl Abatement	Р		Р
5: Mercury Limitation	Р	Р	Р
12 MOISTURE MANAGEMENT			
1: Exterior Liquid Water Management	Р	-	Р
2: Interior Liquid Water Management	Р	-	Р
3: Condensation Management	P	-	Р
4: Material Selection and Protection	Р	-	Р
13 AIR FLUSH			
1: Air Flush	-	Ο	0
14 AIR INFILTRATION MANAGEMENT			
1: Air Leakage Testing	О	O	0
15 INCREASED VENTILATION			
1: Increased Outdoor Air Supply	Ο	0	0
16 HUMIDITY CONTROL			
1: Relative Humidity	-	Ο	0
17 DIRECT SOURCE VENTILATION			
1: Pollution Isolation and Exhaust	О	0	О
18 AIR QUALITY MONITORING AND FEEDB	ACK		
1: Indoor Air Monitoring	-	О	0
2: Air Data Record Keeping and Response	-	0	
3: Environmental Measures Display	-	0	0
19 OPERABLE WINDOWS			
1: Full Control	Ο	Ο	0
2: Outdoor Air Measurement	0		
3: Window Operation Management	О	О	0
20 OUTDOOR AIR SYSTEMS			
1: Dedicated Outdoor Air Systems	0	0	0
21 DISPLACEMENT VENTILATION			
1: Displacement Ventilation Design and Application	-	О	О
2: System Performance	-	0	
22 PEST CONTROL			
1: Pest Reduction	-	О	0
2: Pest Inspection	-	0	0
23 ADVANCED AIR PURIFICATION			
1: Carbon Filtration	Ο	Ο	0
2: Air Sanitization	0		0
3: Air Quality Maintenance	О	Ο	0

	Core and Shell	New and Existing Interiors	New and Existing Buildings
24 COMBUSTION MINIMIZATION			
1: Appliance and Heater Combustion Ban	О	О	О
2: Low-Emission Combustion Sources	0	-	0
3: Engine Exhaust Reduction	0	-	0
4: Construction Equipment	0	-	0
25 TOXIC MATERIAL REDUCTION			
1: Perfluorinated Compound Limitation	-	0	0
2: Flame Retardant Limitation	-	О	
3: Phthalate (Plasticizers) Limitation	-	0	
4: Isocyanate-Based Polyurethane Limitation	-	0	
5: Urea-Formaldehyde Restriction	-	0	
26 ENHANCED MATERIAL SAFETY			
1: Precautionary Material Selection	-	О	О
27 ANTIMICROBIAL ACTIVITY FOR SURFACE	CES		
1: High-Touch Surfaces	-	О	О
28 CLEANABLE ENVIRONMENT			
1: Material Properties	-	0	О
2: Cleanability	-	0	
29 CLEANING EQUIPMENT			
1: Equipment and Cleaning Agents	-	О	О
2: Chemical Storage	-	0	

# **AIR QUALITY STANDARDS**

Pollutants generated indoors can lead to a variety of symptoms and health conditions. Volatile organic compounds (VOCs), combustion byproducts and airborne particulate matter are known to trigger nausea, headaches, asthma, respiratory irritation and allergies. While ambient outdoor air is often better quality, natural ventilation methods, operable doors and windows, and general building envelope infiltration can diminish indoor air quality if external air quality parameters are poor.

Intent: To ensure a basic level of high indoor air quality.



Cardiovascular Endocrine Immune Integumentary Nervous Respiratory

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
Р	Р	Р

#### PART 1: STANDARDS FOR VOLATILE SUBSTANCES

The following conditions are met:

- a. Formaldehyde levels less than 27 ppb.
- b. Total volatile organic compounds less than 500 μg/m³.

# PART 2: STANDARDS FOR PARTICULATE MATTER AND INORGANIC GASES

The following conditions are met:

- a.<sup>2</sup> Carbon monoxide less than 9 ppm.
- b.  $^2$  PM<sub>2.5</sub> less than 15  $\mu$ g/m<sup>3</sup>.
- c.  $^3$  PM<sub>10</sub> less than 50  $\mu$ g/m<sup>3</sup>.
- d.<sup>3</sup> Ozone less than 51 ppb.

# PART 3: RADON

The following conditions are met in projects with regularly occupied spaces at or below grade:

a. <sup>4</sup> Radon less than 0.148 Bq/L [4 pCi/L] in the lowest occupied level of the project.

## **SMOKING BAN**

Over 42 million adults in the U.S. and over a billion individuals worldwide are cigarette smokers. In the U.S. alone, smoking tobacco is related to over 400,000 premature annual deaths. Furthermore, the average life expectancy of a smoker is 10 years less than that of a non-smoker. In addition to nicotine, cigarettes contain about 600 ingredients that form over 7,000 compounds when burned, of which at least 69 are known to be carcinogenic. Secondhand smoke exposes non-smokers to the same toxins, increasing the number of people subject to health risks from smoking.

Intent: To deter smoking, minimize occupant exposure to second hand smoke, and reduce smoke pollution.



Cardiovascular
Digestive
Endocrine
Immune
Integumentary
Muscular
Nervous
Reproductive
Respiratory
Skeletal
Urinary

Core New and Pew and Existing Existing Existing Existing Buildings

P P P P

#### PART 1: INDOOR SMOKING BAN

Building policy or local code reflects the following:

a. 5 Smoking and the use of e-cigarettes is prohibited inside the project.

#### PART 2: OUTDOOR SMOKING BAN


Signage is present to indicate:

- a. A smoking ban within 7.5 m [25 ft] (or the maximum extent allowable by local codes) of all entrances, operable windows and building air intakes.
- b. A smoking ban on all decks, patios, balconies, rooftops and other regularly occupied exterior building spaces.
- c. The hazards of smoking, in all areas beyond 7.5 m of the building entrances (if smoking is permitted in this areas). These signs are to be placed along all walkways with a distance of not more than 30 m [100 ft] between signs.

## **VENTILATION EFFECTIVENESS**

Routine indoor activities including cooking, cleaning, building operations and maintenance and even the presence of occupants themselves can degrade air quality. Many indoor pollutants resulting from such activities, including particulate matter and VOCs can cause discomfort and trigger asthma and eye, nose and throat irritation. Because it is difficult to test for every potential pollutant, and because carbon dioxide is easy to detect, carbon dioxide levels serve as a proxy for other indoor pollutants.

Intent: To ensure adequate ventilation and high indoor air quality.



Cardiovascular Nervous Respiratory


Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: VENTILATION DESIGN

One of the following requirements is met for all spaces:

- ventilation rates comply with all requirements set in ASHRAE 62.1-2013 (Ventilation Rate Procedure or IAQ Procedure).
- b. 6 Projects comply with all requirements set in any procedure in ASHRAE 62.1-2013 (including the Natural Ventilation Procedure) and demonstrate that ambient air quality within 1.6 km [1 mi] of the building is compliant with either the U.S. EPA's NAAQS or passes the Air Quality Standards feature in the WELL Building Standard for at least 95% of all hours in the previous year.

#### PART 2: DEMAND CONTROLLED VENTILATION



- a. A demand controlled ventilation system regulates the ventilation rate of outdoor air to keep carbon dioxide levels in the space below 800 ppm (measured at 1.2-1.8 m [4-6 ft] above the floor).
- b. Projects that have met the Operable windows feature demonstrate that natural ventilation is sufficient to keep carbon dioxide levels below 800 ppm at maximum intended occupancies (measured at 1.2-1.8 m [4-6 ft] above the floor).

### PART 3: SYSTEM BALANCING

After the HVAC system is installed, the following requirement is met:

a. After substantial completion and prior to occupancy, the HVAC system has (within the last 5 years), or is scheduled to, undergo testing and balancing.

## **VOC REDUCTION**

Indoor air quality can be degraded significantly by volatile organic compounds (VOCs) that off-gas from paints, finishes and other coatings, and also result from the use of cleaning products, air fresheners, personal care products and other materials brought into the building. VOCs include benzene (classified by the EPA as a known human carcinogen), formaldehyde and other chemical compounds, which at high concentrations can lead to irritation of the nose and pharvnx, and have been associated with leukemia, childhood asthma and other respiratory disorders. VOC levels can be 5 times higher indoors than outdoors.

Intent: To minimize the effect of VOCs in building materials on indoor air quality.



Cardiovascular Endocrine Immune Integumentary Nervous Respiratory

Core New and New and Existing Existing and Shell Interiors Buildinas

#### PART 1: INTERIOR PAINTS AND COATINGS

The VOC limits of newly applied interior paints and coatings meet one of the following requirements:

- 100% of installed products meet California Air Resources Board (CARB) 2007, Suggested Control Measure (SCM) for Architectural Coatings, or South Coast Air Quality Management District (SCAQMD) Rule 1113, effective June 3, 2011 for VOC content.
- b. 1 At minimum 90%, by volume, meet the California Department of Public Health (CDPH) Standard Method v1.1-2010 (or later) for VOC emissions.
- Applicable national VOC content regulations or conduct testing of VOC content in accordance with ASTM D2369-10; ISO 11890, part 1; ASTM D6886-03; or ISO 11890-2.

### PART 2: INTERIOR ADHESIVES AND SEALANTS



The VOC limits of newly applied interior adhesives and sealants meet one of the following requirements:

- a. 100% of installed products meet South Coast Air Quality Management District (SCAQMD) Rule 1168 for VOC content. Volatile organic compound (VOC) limits correspond to an effective date of July 1, 2005 and rule amendment date of January 7, 2005.
- b. At minimum 90%, by volume, meet the California Department of Public Health (CDPH) Standard Method v1.1-2010 (or later) for VOC emissions.
- Applicable national VOC content regulations or conduct testing of VOC content in accordance with ASTM D2369-10; ISO 11890, part 1; ASTM D6886-03; or ISO 11890-2.

# **PART 3: FLOORING**

The VOC emissions of all newly installed interior flooring meet all limits set by the following, as applicable:

California Department of Public Health (CDPH) Standard Method v1.1-2010 (or later).

PART 4: INSULATION

P P P

The VOC emissions of all newly installed interior thermal and acoustic insulation (excluding duct insulation) meet all limits set by the following, as applicable:

a. California Department of Public Health (CDPH) Standard Method v1.1-2010 (or later).

#### **PART 5: FURNITURE AND FURNISHINGS**




The VOC emissions of at least 95% (by cost) of all newly purchased interior furniture and furnishings within the project scope meet all limits set by the following, as applicable:

- a. ANSI/BIFMA e3-2011 Furniture Sustainability Standard sections 7.6.1 or 7.6.2, tested in accordance with ANSI/BIFMA Standard Method M7.1-2011.
- b. California Department of Public Health (CDPH) Standard Method v1.1-2010 (or later).

### **AIR FILTRATION**

Air quality is subject to variability due to weather, dust, traffic and localized pollutant sources. Seasonal variations in pollen can trigger asthma and allergies in sensitive individuals. Similarly, exposure to high levels of coarse and fine particulate matter introduced from the outside can lead to respiratory irritation and has been associated with increases in lung cancer as well as cardiovascular disease and mortality. Carbon filters are designed to absorb such volatile pollutants and remove the largest particles, while media filters are meant to address smaller particles.

Intent: To remove indoor and outdoor airborne contaminants through air filtration.



Cardiovascular Endocrine Immune Integumentary Nervous Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: FILTER ACCOMMODATION

If recirculated air is used, the following requirements are met in ventilation assemblies in the main air ducts for recirculated air:


- a. Rack space is available and rack location identified for future implementation of carbon filters or combination particle/carbon filters.
- b. The mechanical system is sized to accommodate the additional filters.

#### **PART 2: PARTICLE FILTRATION**

One of the following requirements is met:

- a. MERV 13 (or higher) media filters are used in the ventilation system to filter outdoor air.
- b. Project demonstrates that for 95% of all hours in a calendar year, ambient outdoor  $PM_{10}$  and  $PM_{2.5}$  levels measured within 1.6 km [1 mi] of the building are below the limits set in the WELL Air Quality Standards feature.

#### PART 3: AIR FILTRATION MAINTENANCE




a. Records of air filtration maintenance, including evidence that filters have been properly maintained as per the manufacturer's recommendations.

## MICROBE AND MOLD CONTROL

Mold often grows on cooling coils in HVAC systems due to moisture condensation and can be introduced into the building's indoor air. It can also occur on or within wall assemblies due to water damage or improper detailing in humid locations, for example kitchens and bathrooms. Mold spores can trigger asthma, headaches, allergies and other respiratory system disorders.

Intent: To reduce mold and bacteria growth within buildings, particularly from water damage or condensation on cooling coils.



Immune Integumentary Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: COOLING COIL MOLD REDUCTION

In buildings that rely on a mechanical system for cooling, one of the following requirements is met:

- a. Ultraviolet lamps (using a wavelength of 254 nm so as not to generate ozone) are employed on the cooling coils and drain pans of the mechanical system supplies. Irradiance reaching the cooling coil and drain pan, including the plenum corners, is modeled.
- b. Building policy states that all cooling coils are inspected on a quarterly basis for mold growth and cleaned if necessary. Dated photos demonstrating adherence are provided to the IWBI on an annual basis.

#### **PART 2: MOLD INSPECTIONS**


The following are not present:

- a. 12 Signs of discoloration and mold on ceilings, walls or floors.
- b. 12 Signs of water damage or pooling.

# CONSTRUCTION POLLUTION MANAGEMENT

Proper design and material selection is essential in creating healthy indoor air quality. However, this strategy can be compromised if equal care is not taken during construction to clear the space of dust, chemical vapors and other debris. Pollutants inadvertently introduced into the space can lead to various respiratory symptoms and will increase the likelihood of failing indoor air quality standards.

Intent: To minimize the introduction of construction-related pollutants into indoor air and protect building products from degradation.



Cardiovascular Immune Integumentary Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: DUCT PROTECTION**

To prevent pollutants from entering the ventilation system, all newly installed ducts are either:

- a. Sealed and protected from possible contamination during construction.
- b. Vacuumed out prior to installing registers, grills and diffusers.

#### **PART 2: FILTER REPLACEMENT**

To prevent pollutants from entering the air supply post-occupancy, if the ventilation system is operating during construction occurring within one year prior to Performance Verification, the following requirement is met:

a. All filters are replaced prior to occupancy.

#### PART 3: MOISTURE ABSORPTION MANAGEMENT

To prevent building materials from absorbing water or moisture during construction occurring within one year prior to Performance Verification, the following requirements are met:

a. A separate area is designated to store and protect absorptive materials, including but not limited to carpets, acoustical ceiling panels, fabric wall coverings, insulation, upholstery and furnishings.

#### PART 4: DUST CONTAINMENT AND REMOVAL


The following procedures are followed during building construction occurring within one year prior to Performance Verification:

- a. All active areas of work are isolated from other spaces by sealed doorways or windows or through the use of temporary barriers.
- b. Walk-off mats are used at entryways to reduce the transfer of dirt and pollutants.
- c. Saws and other tools use dust guards or collectors to capture generated dust.

# **HEALTHY ENTRANCE**

Occupants often track harmful contaminants indoors, including bacteria, heavy metals, lawn and agricultural pesticides, among other toxins. In addition, as occupants walk through entry doors, potentially polluted air can enter the building. Both of these modes of introducing outdoor pollutants to the indoor environment highlight the need for measures that minimize or prevent the introduction of potentially harmful substances to indoor spaces.

Intent: To minimize the introduction of pollutants into indoor air at building entrances.



Cardiovascular Immune Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: ENTRYWAY WALK-OFF SYSTEMS

To capture particulates from occupant shoes at all regularly used entrance(s) to the project, including doors with pedestrian traffic only to/from terraces or patios (no traffic to/from surrounding grounds), one of the following is installed and is maintained on a weekly basis:

- a. Permanent entryway system comprised of grilles, grates or slots, which allow for easy cleaning underneath, at least the width of the entrance and 3 m [10 ft] long in the primary direction of travel (sum of indoor and outdoor length).
- b. Rollout mats, at least the width of the entrance and 3 m [10 ft] long in the primary direction of travel (sum of indoor and outdoor length).
- c. Any other material manufactured as an entryway walk-off system, at least the width of the entrance and 3 m [10 ft] long in the primary direction of travel (sum of indoor and outdoor length).

#### **PART 2: ENTRYWAY AIR SEAL**


One of the following is in place to slow the movement of air from outdoors to indoors within mechanically ventilated main building entrances:

- a. Building entry vestibule with two normally-closed doorways.
- b. Revolving entrance doors.
- c. At least 3 normally-shut doors that separate occupied space from the outdoors. For example, a space on the fifth-floor could be separated by the exterior building doors, the first-floor elevator doors and the fifth-floor elevator doors. This option is applicable only for buildings whose entrance lobby is not a regularly occupied space or to projects where the building entrance is outside the project boundary.

# **CLEANING PROTOCOL**

Regular cleaning is an important practice as it helps to remove potentially harmful debris and maintain a healthy indoor environment. However, numerous chemicals and improper cleaning techniques can undermine indoor air quality. Harmful ingredients in cleaning products can lead to eye, nose, throat and skin irritation, and emit VOCs into the indoor environment, which may lead to other health effects including sick building syndrome (SBS). An adequate cleaning regimen using non-toxic, hypoallergenic cleaners helps to reduce bioloads, pests, environmental allergens and unpleasant odors without introducing chemicals that might adversely impact indoor air quality.

Intent: To reduce occupant exposure to pathogens, allergens, and harmful cleaning chemicals.



Immune Integumentary Reproductive Respiratory Urinary

Core and Shell New and Existing Interiors New and Existing Buildings

#### PART 1: CLEANING PLAN FOR OCCUPIED SPACES


A cleaning plan is created that includes:

- a. The Cleaning Equipment and Training section of Table A4 in Appendix C
- b. A list of approved product seals with which all cleaning, disinfection and hand hygiene products must comply in accordance with the Cleaning, Disinfection and Hand Hygiene Product section in Table A4 in Appendix C.
- c. A list of high-touch surfaces and schedule of sanitization or disinfection as specified in the Disinfection and Sanitization section in Table A4 in Appendix C.
- d. A cleaning schedule that specifies the extent and frequency of cleaning, including the Entryway Maintenance section of Table A4 in Appendix C.
- e. Dated cleaning logs that are maintained and available to all occupants.

# PESTICIDE MANAGEMENT

Approximately one billion pounds of pesticides are used in a typical year in the U.S. alone. Pesticides and herbicides contaminate rivers and streams, and seep into groundwater through runoff. A U.S. Geological Survey conducted in the 1990s detected pesticide compounds in virtually every stream in agricultural, urban and mixed-use areas, as well as in over 50 percent of sampled wells assessing ground water in agricultural and urban areas. Atrazine, one of the most widely used pesticides, is a suspected endocrine disruptor and is associated with cardiovascular problems. Long-term exposure to glyphosate, a widely used herbicide, may lead to kidney problems and reproductive difficulties.

Intent: To reduce the presence of pests in buildings and minimizing occupant exposure to harmful chemicals.



Cardiovascular
Digestive
Endocrine
Immune
Nervous
Reproductive
Respiratory
Urinary

Core and Shell New and Existing Interiors New and Existing Buildings

#### **PART 1: PESTICIDE USE**


Pesticide and herbicide use on outdoor plants is eliminated, or hazards are minimized through one of the following:

- a. <sup>14</sup> The creation of a pest management plan in place of pesticide/herbicide use, based on Chapter 3 of the San Francisco Environment Code Integrated Pest Management (IPM) program.
- b. 14 Use of pesticides with a Hazard Tier ranking of 3 (least hazardous) based on screening lists described in Table A2 in Appendix C.

# **FUNDAMENTAL MATERIAL SAFETY**

Some hazardous materials, such as asbestos, a known human carcinogen, and polychlorinated biphenyls (PCBs), a probable human carcinogen, are currently restricted or banned in many countries, but are often encountered in older buildings. Others, including lead, remain in limited use. Exposure to asbestos fibers through inhalation can occur when building materials degrade over time or are disturbed during renovation or demolition, and is associated with lung cancer and mesothelioma. Exposure to lead can have neurotoxic effects, even at low levels, and in early development is associated with negative effects on memory, IQ, learning and behavior.

Intent: To reduce or eliminate occupant exposure to lead, asbestos, and PCBs from building materials.



Cardiovascular Nervous Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: ASBESTOS AND LEAD RESTRICTION

All newly-installed building materials meet the following materials composition requirements:

- a. No asbestos.
- b. 11 Not more than a weighted average of 0.25% lead in wetted surfaces of pipes, pipe fittings, plumbing fittings, and fixtures, and 0.20% for solder or flux used in plumbing for water intended for human consumption.
- c. Not more than 100 ppm (by weight) added lead in paint, ductwork, conduits, roofing/flashing, door hardware, vinyl blinds and wall coverings. For door hardware, project teams may document attempt to meet the requirement and demonstrate a petition or a formal request has been filed with manufacturers who were unable to meet their needs.

#### **PART 2: LEAD ABATEMENT**



For repair, renovation, demolition or painting of projects constructed prior to any applicable laws banning or restricting lead paint, lead evaluation and abatement is conducted in accordance with the following guidelines:

- a. <sup>31</sup> An on-site investigation of the space conducted by a certified risk assessor or inspector technician to determine the presence of any lead-based hazards in paint, dust and soil using the definitions in U.S. EPA 40 CFR Part 745.65 for residential dwellings or child-occupied facilities.
- b. All commercial and institutional spaces found to have lead-based hazards must adhere to work practice standards for conducting lead-based paint activities, as outlined in U.S. 40 CFR Part 745.227 for multi-family dwellings and in U.S. 29 CFR Part 1926.62 for general construction work. An occupant protection plan must be implemented during the work activities.
- Adherence to final rules, as they are proposed by the U.S. EPA, regarding the lead renovation, repair and painting program for public and commercial buildings (RIN: 2070-AJ56) supersedes adherence to definitions and protocols outlined in U.S. EPA 40 CFR Part 745 for residential dwellings or child-occupied facilities.

#### **PART 3: ASBESTOS ABATEMENT**

To reduce hazards in projects constructed prior to any applicable laws banning or restricting asbestos, the following testing, evaluation and abatement is conducted:

- a. 33 Inspection is conducted every three years through an accredited professional per Asbestos Hazard Emergency Response Act (AHERA)'s Asbestos Model Accreditation Plan (MAP), National Standards for Hazardous Air Pollutants (NESHAP) or accredited asbestos consultant (state or local equivalent).
- b. In accordance with the Asbestos Hazard Emergency Response Act (AHERA), development, maintenance and update of asbestos management plans, including all necessary actions to minimize asbestos hazards: repair, encapsulation, enclosure, maintenance and removal, follow protocol detailed in the Asbestos-Containing Materials in Schools Rule (40 CFR part 763).
- c. <sup>33</sup> Projects conduct post-abatement clearance in accordance with Asbestos Hazard Emergency Response Act (AHERA) Asbestos-Containing Materials in Schools (40 CFR part 763).

#### PART 4: POLYCHLORINATED BIPHENYL ABATEMENT

For any projects undergoing current renovation or demolition that were constructed or renovated between 1950 and the institution of any applicable laws banning or restricting PCBs the below guidelines are applied:

- a.<sup>34</sup> Conduct evaluation and abatement of materials in accordance with the U.S. EPA Steps to Safe PCB Abatement Activities.
- b. Conduct removal and safe disposal of PCB-containing fluorescent light ballasts in accordance with the U.S. EPA guidelines.

#### **PART 5: MERCURY LIMITATION**


Mercury-containing equipment and devices are restricted in accordance with the below guidelines:

- a. Project does not specify or install new mercury containing thermometers, switches and electrical relays.
- b. Project does not install any lamps not compliant with the low-mercury limits specified in Appendix C, Table A5. Project develops a plan to upgrade any existing non-compliant lamps to low-mercury or mercury-free lamps.
- c. Illuminated exit signs only use Light-Emitting Diode (LED) or Light-Emitting Capacitor (LEC) lamps.
- d. No mercury vapor or probe-start metal halide high intensity discharge lamps are in use.

# **MOISTURE MANAGEMENT**

Good design principles and strategies to mitigate water damage help to preserve good indoor air quality. Moisture can enter buildings and building assemblies in four ways: bulk water, capillary water, airtransported moisture and vapor diffusion. In addition to preventing wetting from all four channels, managing moisture is also about promoting drying potential.

Intent: To limit the potential for bacteria and mold growth within buildings from water infiltration and condensation.



Immune Integumentary Respiratory

Core New and New and Existing Existing and Shell Interiors Buildinas

#### PART 1: EXTERIOR LIQUID WATER MANAGEMENT

A point-by-point narrative describes how liquid water from outside the building is addressed, responding to the nature and intensity of wetting based on the project's site and climate, and includes the following leading concerns:

- a. 176 Site drainage, including the impact of any site irrigation.
- 176 The local water table. b.
- Building penetrations (especially windows and plumbing/electrical/mechanical penetrations). C.
- Porous building materials connected to exterior sources of liquid water.

#### PART 2: INTERIOR LIQUID WATER MANAGEMENT



a. 176 Plumbing leaks.

concerns:

- b. 176 "Hard-piped" plumbing appliances (appliances such as clothes washers exposed to building water pressure even when not in use).
- c. <sup>176</sup> Porous building materials connected to interior sources of liquid water.
- d. 176 New building materials with "built-in" high moisture content or building materials wetted during construction but now on the inside of the building.

#### PART 3: CONDENSATION MANAGEMENT



A point-by-point narrative describes how condensation is addressed, including these leading concerns:

- a. <sup>176</sup> High interior relative humidity levels, particularly in susceptible areas like bath and laundry rooms and below-grade spaces.
- b. Air leakage which could wet either exposed interior materials or interstitially "hidden" materials.
- c. <sup>176</sup> Cooler surfaces, such as basement or slab-on-grade floors, or closets/cabinets on exterior walls.
- d. Oversized air conditioning units.

#### PART 4: MATERIAL SELECTION AND PROTECTION




A point-by-point narrative describes how moisture-tolerant materials have been selected and/or moisture-sensitive materials (MSP) are being protected, considering these leading concerns:

- a. 176 Exposed entryways and glazing.
- b. 176 Porous cladding materials.
- c. <sup>176</sup> Finished floors in potentially damp or wet rooms such as basements, bathrooms and kitchens.
- d. Interior sheathing in damp or wet rooms.
- e. Sealing and storing of absorptive materials during construction.

# **AIR FLUSH**

An air flush or building flush is a technique whereby air is forced through a building after construction and prior to occupancy in order to remove or reduce pollutants, such as VOCs and particulate matter, inadvertently introduced indoors during construction. Air flushing improves indoor air quality by limiting the exposure to an intense contamination period.

Intent: To remediate construction-related indoor air contamination.



Cardiovascular Immune Respiratory

Core New and Sexisting Existing Shell Interiors Buildings

#### **PART 1: AIR FLUSH**


A building air flush is performed while maintaining an indoor temperature of at least 15  $^{\circ}$ C [59  $^{\circ}$ F] and relative humidity below 60%, at one of the following volumes:

- a. A total air volume of 4,266 m³ of outdoor air per m² of floor area [14,000 ft³ per ft² of floor area] prior to occupancy.
- b. A total air volume of 1,066 m³ of outdoor air per m² of floor area [3,500 ft³ per ft² of floor area] prior to occupancy, followed by a second flush of 3,200 m³ of outdoor air per m² of floor area [10,500 ft³ per ft² of floor area] post-occupancy. While the post-occupancy flush is taking place, the ventilation system must provide at least 0.1 m³ per minute of outdoor air per m² of floor area [0.3 CFM outdoor air per ft² of floor area] at all times.

# **AIR INFILTRATION MANAGEMENT**

Indoor air quality and thermal comfort can be compromised by leaks and gaps that break the building's air barrier. These weak points are not only wasteful but can also lead to conditions conducive to growth of molds and the infiltration of pests or polluted air.

Intent: To minimize air quality and thermal comfort issues resulting from the infiltration of untreated air through the building envelope.



Immune Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: AIR LEAKAGE TESTING**


The following is performed after substantial completion and prior to occupancy to ensure the structure is airtight:

- a. Envelope commissioning in accordance with ASHRAE Guideline 0-2005 and the National Institute of Building Sciences (NIBS) Guideline 3-2012 (for new construction or structural renovation).
- b. Detailed plan for action and remediation of unacceptable conditions.

# **INCREASED VENTILATION**

The guidelines put forth by ASHRAE provide the basis for acceptable indoor air quality, but not necessarily for best-in-class air quality for buildings. Unusually high building occupancy, a high risk of accidents that might degrade air quality or space capacity to install filtration make exceeding ASHRAE requirements a worthwhile strategy.

Intent: To expel internally-generated pollutants through an increased supply of outdoor air.



Cardiovascular Immune Respiratory

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
0	0	0

#### PART 1: INCREASED OUTDOOR AIR SUPPLY


One of the following is required in all regularly occupied spaces:

- a. Exceed outdoor air supply rates met in Feature 03, Part 1a by 30%.
- b. Follow CIBSE AM10, Section 4, Design Calculations, to predict that room-by-room airflows will provide effective natural ventilation.

# **HUMIDITY CONTROL**

Extremely low humidity can lead to dryness and irritation of the skin, eyes, throat and mucous membranes. Conversely, high humidity may promote the accumulation and growth of microbial pathogens, including bacteria, dust mites and mold, which can lead to odors and cause respiratory irritation and allergies in sensitive individuals. Additionally, higher humidity levels can lead to increased off-gassing: an increase in relative humidity of 35% can increase the emissions of formaldehyde by a factor of 1.8–2.6.

Intent: To limit the growth of pathogens, reduce off-gassing, and maintain thermal comfort by providing the appropriate level of humidity.



#### **PART 1: RELATIVE HUMIDITY**


At least one of the following is required:

- a. A ventilation system with the capability to maintain relative humidity between 30% to 50% at all times by adding or removing moisture from the air.
- b. Modeled humidity levels in the space are within 30% to 50% for at least 95% of all business hours of the year. Buildings in climates with narrow humidity ranges are encouraged to pursue this option.

# **DIRECT SOURCE VENTILATION**

Air pollution can be created from a number of indoor sources, including cleaning products, office equipment and humid environments. Chemical storage closets can be a source of harmful vapors, including VOCs that are linked to cancer, organ and central nervous system damage. Copy rooms can contribute to the production of ozone, which is linked to asthma and other respiratory diseases. Bathrooms can be a source of mold and mildew that release spores and toxins, which can trigger asthma and allergies in susceptible individuals.

Intent: To preserve air quality in occupied spaces through the isolation and proper ventilation of indoor pollution sources and chemical storage areas.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings

#### PART 1: POLLUTION ISOLATION AND EXHAUST


All cleaning and chemical storage units, all bathrooms, and all rooms that contain printers and copiers (except those meeting the low-emission criteria of Ecologo CCD 035, Blue Angel RAL-UZ 171, Blue Angel RAL-UZ 205 or Green Star) meet the following conditions:

- a. Are closed from adjacent spaces, such as by using self-closing doors.
- b. Air is exhausted so that all air is expelled rather than recirculated.

# AIR QUALITY MONITORING AND FEEDBACK

Building performance, such as ventilation and infiltration rates, is highly variable and has a direct effect on indoor air quality. To maintain ideal performance metrics, projects must continuously gather data on building performance. Collecting this data allows individuals to be aware of and promptly fix any deviations in indoor quality metrics.

Intent: To monitor and effectively remediate indoor air quality issues and inform building managers and occupants of the quality of the indoor environment.



Cardiovascular Integumentary Nervous Respiratory

Core New and New and and Existing Existing Buildings

#### PART 1: INDOOR AIR MONITORING

Monitors measure 2 of the following pollutants in a regularly occupied or common space (minimum one per floor) within the building, at intervals no longer than once an hour (measured at 1.2-1.8 m [4-6 ft] above the floor), and results are annually transmitted to the IWBI:

- Particle count (resolution 35,000 counts per  $m^3$  [1,000 counts per  $ft^3$ ] or finer) or particle mass (resolution 10  $\mu$ g/ $m^3$  or finer).
- b. Carbon dioxide (resolution 25 ppm or finer).
- c. Ozone (resolution 10 ppb or finer).

#### PART 2: AIR DATA RECORD KEEPING AND RESPONSE

In an effort to consistently meet the WELL parameters, projects provide a written policy specifying:

- a. Detailed enforcement strategies for monitoring and record-keeping of parameters listed in Part 1: Indoor Air Monitoring.
- b. Records are to be kept for a minimum of 3 years, including full data from field inspectors or laboratory results where appropriate.
- c. Detailed plan for action and remediation of unacceptable conditions.

#### PART 3: ENVIRONMENTAL MEASURES DISPLAY




- a. Temperature.
- b. Humidity.
- c. Carbon dioxide concentration.

# **OPERABLE WINDOWS**

Achieving natural ventilation through open windows, doors and louvers can provide a positive occupant experience, but challenges the ability to maintain strict control over interior air quality. When weather and local ambient parameters indicate high quality outdoor air, WELL encourages the use of natural ventilation strategies. Open windows can then provide a supply of outdoor air and lower the levels of carbon dioxide and VOCs, such as formaldehyde, without compromising indoor air quality.

Intent: To increase the supply of high quality outdoor air and promote a connection to the outdoor environment by encouraging occupants to open windows when outdoor air quality is acceptable.



Cardiovascular Respiratory

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
0	0	0

#### **PART 1: FULL CONTROL**

The following requirement is met:


a. <sup>13</sup> Every regularly occupied space has operable windows that provide access to outdoor air and daylight.

#### PART 2: OUTDOOR AIR MEASUREMENT



a. A data-gathering station located within 1.6 km [1 mi] of the building.

#### PART 3: WINDOW OPERATION MANAGEMENT




- a. Software on occupants' computers or smartphones.
- b. Indicator lights at all operable windows.

# **OUTDOOR AIR SYSTEMS**

Dedicated outdoor air systems (DOAS) remove the constraints associated with linking heating and cooling with ventilation, so that optimal air quality and thermal comfort can be independently achieved. A properly designed DOAS can save energy compared to conventional systems while always supplying the appropriate amount of ventilation.

Intent: To allow buildings to control the outdoor air supply independently from the heating/cooling needs of the building.



#### PART 1: DEDICATED OUTDOOR AIR SYSTEMS


Dedicated outdoor air systems are used for ventilation and verified as being adequate through one of the following:

- a. The system complies with local codes or standards regarding dedicated outdoor air systems.
- b. A detailed design review of the proposed system is conducted by an independent, qualified and registered professional mechanical engineer (not employed or compensated by the mechanical engineer on record). The review addresses thermal comfort (temperature, humidity, air velocity, etc.) and ventilation rates, as well as overall serviceability and system reliability. Report must demonstrate satisfactory compliance with ventilation standards used in Feature 03 Ventilation effectiveness.

# **DISPLACEMENT VENTILATION**

By strategically designing the height of air ventilation, displacement ventilation can enhance air change effectiveness. Displacement ventilation supplies air at very low velocity levels at or near the floor level, which then rises to the ceiling level. Since heat in a room is naturally stratified, displacement ventilation not only ensures that air is not delivered and pushed through the return air path (often the dirtiest portion of the air stream), but also tends to concentrate pollutants near the ceiling. Once there, the pollutants are out of the breathing zone and can be more easily removed.

Intent: To improve air quality in the breathing zone of the room and maintain thermal comfort by supplying low velocity outdoor air near the floor and expelling near the ceiling.



Cardiovascular Immune

Core New and Sexisting Existing Existing Buildings

#### PART 1: DISPLACEMENT VENTILATION DESIGN AND APPLICATION

Projects implement a displacement ventilation system for heating and/or cooling in which one of the following is met:

- Low side wall air distribution with the air supply temperature slightly cooler or warmer than the desired space temperature. The system must use the System Performance Evaluation and ASHRAE Guidelines RP-949 as the basis for design.
- b. 37 Underfloor Air Distribution (UFAD) with the air supply temperature slightly cooler or warmer than the desired space temperature. This system must use ASHRAE's UFAD Guide (Design, Construction and Operations of Underfloor Air Distribution Systems) as the basis of design. Displacement ventilation applied as part of an underfloor air distribution system must be installed at a raised floor height whereby the underfloor area can be cleaned on an annual basis.

#### **PART 2: SYSTEM PERFORMANCE**


The following requirements are met:

- a. A Computational Fluid Dynamics (CFD) analysis is conducted for the displacement ventilation system.
- b. <sup>92</sup> The displacement ventilation system meets ASHRAE 55-2013 (Thermal Environmental Conditions for Human Occupancy) for comfort for at least 75% of all regularly occupied space.

# **PEST CONTROL**

Unhygienic conditions lead to the presence of pests and dust mites, which are common sources of indoor allergens. Their bodies, feces and saliva contain allergens which can trigger asthma and allergic reactions in susceptible individuals. Asthma can also be compounded by sensitivity to other allergens; up to 60% of individuals with asthma who live in urban environments also have a sensitivity to cockroach allergens.

Intent: To reduce the presence of pests in buildings and minimize occupant exposure to pest-related allergens.



#### **PART 1: PEST REDUCTION**

The following are met:

- a. All non-refrigerated perishable food, including pet food, is stored in sealed containers.
- b. All indoor garbage cans (except paper recycling bins) less than 113 liters [30 gallons] have lids and hands-free operation, or are enclosed by cabinetry in an under-counter pull-out drawer, with a handle separate from the trash can.
- c. All indoor garbage cans (except paper recycling bins) greater than 113 liters [30 gallons] have a lid.

#### **PART 2: PEST INSPECTION**




Visual inspections during Performance Verification show that the following are not present:

a. Signs of infestation by cockroaches, termites or other pests.

# **ADVANCED AIR PURIFICATION**

Some circumstances justify greater investment in air purification strategies. For example, proximity to highly traveled roads, manufacturing plants and seasonal variation can affect outdoor air quality, increasing ozone and VOC content, and in turn diminishing indoor air quality. Similarly, climates with high humidity levels and inadequate indoor ventilation can foster the development of mold and spores in indoor environments.

Intent: To improve recirculated indoor air quality through the implementation of advanced air purification strategies.



Cardiovascular Immune Respiratory

Core New and Existing Existing Shell Interiors Buildings

#### **PART 1: CARBON FILTRATION**

To reduce VOCs in the indoor air, buildings which recirculate air use one of the following methods:

- a. Activated carbon filters or combination particulate/carbon filters in the main air ducts to filter recirculated air. Replacement is required as recommended by the manufacturer.
- b. A standalone air purifier with a carbon filter used in all regularly occupied spaces. Purifiers must be sized appropriately to the spaces they are serving. Filter replacement is required as recommended by the manufacturer.

#### **PART 2: AIR SANITIZATION**



- a. 15 Ultraviolet germicidal irradiation.
- b. 15 Photocatalytic oxidation.

#### PART 3: AIR QUALITY MAINTENANCE




a. Records of air filtration/sanitization maintenance, including evidence that the filter and/or sanitizer has been properly maintained as per the manufacturer's recommendations.

# **COMBUSTION MINIMIZATION**

Although wood and gas fireplaces have aesthetic benefits, they can also be detrimental to indoor air quality. If not effectively sealed off from the living space, they can contribute harmful combustion byproducts such as carbon monoxide and particulate matter. Carbon monoxide has 210 times the binding affinity for hemoglobin compared to oxygen, and thus prevents oxygen from being delivered to the body, leading to hypoxia—lack of oxygen delivery to body tissues that can cause nausea, loss of consciousness and death. Carbon monoxide leads to about 170 non-automotive fatal poisonings in the U.S. every year.

Intent: To reduce occupant exposure to combustion-related air pollution from heating and transportation sources.



Cardiovascular Respiratory Urinary

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
0	0	0

#### PART 1: APPLIANCE AND HEATER COMBUSTION BAN

The following are forbidden in regularly occupied spaces:

a. Combustion-based fireplaces, stoves, space-heaters, ranges and ovens.

# PART 2: LOW-EMISSION COMBUSTION SOURCES

All combustion equipment used in the project for heating, cooling, water-heating, process heating or power generation (including back-up if used more than 200 hours per year) meets California's South Coast Air Quality Management District rules for pollution:

- a. Internal combustion engines.
- b. Furnaces.
- c. <sup>39</sup> Boilers, steam generators and process heaters.
- d. 39 Water heaters.

# PART 3: ENGINE EXHAUST REDUCTION

Signage, visible from pick-up, drop-off and parking areas indicates:

a. Idling with vehicle engines on for more than 30 seconds is prohibited.



#### **PART 4: CONSTRUCTION EQUIPMENT**




To reduce particulate matter emissions from both on-road and non-road diesel fueled vehicles and construction equipment, the following requirements are met for construction occurring within one year prior to Performance Verification:

- a. 85 All non-road diesel engine vehicles comply with the U.S. EPA Tier 4 PM emissions standards or local equivalent when applicable. Engines may be retrofitted with verified technology (required to be U.S. EPA or California Air Resources Board approved) at the time the equipment is first placed on the job site.
- b. 85 All on-road diesel engine vehicles meet the requirements set forth in the U.S. EPA model year 2007 on-road standards for PM, or local equivalent when applicable. Engines may be retrofitted with verified technology (required to be U.S. EPA or California Air Resources Board approved) at the time the equipment is first placed on the job site.
- c. 85 All equipment, vehicles and loading/unloading are located away from air intakes and operable openings of adjacent buildings when available.

# **TOXIC MATERIAL REDUCTION**

Various chemicals are still used in the manufacture of building materials, despite known or suspected health hazards. Flame retardant chemicals, which are used to increase fire-resistance of materials, include PBDEs (polybrominated diphenyl ethers)—which, based on animal tests, are associated with potential neurobehavioral, carcinogenic and immune effects. Some of these chemicals can bioaccumulate in fat and result in food chain contamination, including human milk. All parts of this feature only apply to materials installed inside the weather proofing membrane of a project.

Intent: To minimize the impact of hazardous building material chemicals on indoor air quality and protect the health of manufacturing and maintenance workers.



Endocrine Reproductive

Core New and New and and Existing Existing Buildings

#### PART 1: PERFLUORINATED COMPOUND LIMITATION

No perfluorinated compounds (PFCs) are present in the following condition:

a. <sup>36</sup> At levels equal to or greater than 100 ppm in components that constitute at least 5% by weight of a furniture or furnishing (drapes/curtains) assembly.

#### PART 2: FLAME RETARDANT LIMITATION

Halogenated flame retardants are limited in the following components to 0.01% (100 ppm) to the extent allowable by local code:

- a. 36 Window and waterproofing membranes, door and window frames and siding.
- b. 56 Flooring, ceiling tiles and wall coverings.
- c. <sup>36</sup> Piping and electrical cables, conduits and junction boxes.
- d. d. Duct, pipe, acoustic and thermal insulation.
- e. 36 Upholstered furniture and furnishings, textiles and fabrics.

#### PART 3: PHTHALATE (PLASTICIZERS) LIMITATION

DEHP, DBP, BBP, DINP, DIDP or DNOP (often found in polyvinyl chloride [PVC]) are limited in the following components to 0.01% (100 ppm):

- a. Flooring, including resilient and hard surface flooring and carpet.
- b. 36 Wall coverings, window blinds and shades, shower curtains, furniture and upholstery.
- c. 36 Plumbing pipes and moisture barriers.

# PART 4: ISOCYANATE-BASED POLYURETHANE LIMITATION

- O O

Isocyanate-based polyurethane products are not used in:

a. 16 Interior finishes.

# PART 5: UREA-FORMALDEHYDE RESTRICTION

- 0 0

Urea-formaldehyde presence is limited in the following components to 100 ppm:

- a. Furniture or any composite wood products.
- b. 59 Laminating adhesives and resins.
- c. 59 Thermal insulation.

# **ENHANCED MATERIAL SAFETY**

Some of the chemicals used in building materials have not been fully evaluated for safety and may carry potential health risks. Off-gassing from such materials can contribute to SBS (sick building syndrome) and associated respiratory, neurotoxic and dermatologic symptoms. A precautionary approach—taking reasonable steps to minimize risks and avoid hazards—suggests substituting potentially dangerous materials with safe ones when possible. Various voluntary programs in the market allow suppliers that have carefully screened the composition of their products and avoided potentially harmful substances to be recognized for their achievements.

Intent: To minimize the impact of hazardous building material ingredients on indoor air quality and protect the health of manufacturing and maintenance workers.



Cardiovascular
Digestive
Endocrine
Immune
Integumentary
Muscular
Nervous
Respiratory

Core and Shell New and Existing Interiors New and Existing Buildings

#### PART 1: PRECAUTIONARY MATERIAL SELECTION

At least 25% of all furnishings, built-in furniture, interior finishes, and finish materials (calculated by cost) meet one or more of the following requirements:

- a. <sup>13</sup> Have a Declare: Living Building Challenge Red List Free, Declare: Living Building Challenge Compliant, or Living Product Challenge label.
- b. Are Cradle to Cradle Certified™ products with a Bronze, Silver, Gold or Platinum level in the Material Health category or products with a Bronze, Silver, Gold or Platinum level Material Health Certificate from the Cradle to Cradle Products Innovation Institute.
- c. Have no GreenScreen® Benchmark 1, List Translator 1 or List Translator Possible 1 substances over 1,000 ppm, as verified by a qualified Ph.D. toxicologist or Certified Industrial Hygienist.

# **ANTIMICROBIAL ACTIVITY FOR SURFACES**

Antimicrobial activity on surfaces can accelerate the natural rate of microbial cell death. Non-leaching antimicrobial surfaces are capable of killing microorganisms upon contact without leaching significant amounts of antimicrobial materials into the surrounding environment. Alternatively, cleaning processes and equipment that use short wavelength ultraviolet light (UV-C) effectively can reduce the bacterial load on surfaces, so long as they are used with sufficient frequency to prevent the bioload from being re-established.

Intent: To reduce occupant exposure to both harmful pathogens and hazardous cleaning agents.



Digestive
Endocrine
Immune
Integumentary
Reproductive
Respiratory
Urinary

Core New and New and and Existing Existing Buildings

#### **PART 1: HIGH-TOUCH SURFACES**

All countertops and fixtures in bathrooms and kitchens, and all handles, doorknobs, lightswitches and elevator buttons are one of the following:

- a. Coated with or comprised of a material that is abrasion-resistant, non-leaching and antimicrobial.
- b. Cleaned with a UV cleaning device, used as recommended by the manufacturer.

# **CLEANABLE ENVIRONMENT**

Surfaces exposed to frequent human touch can harbor microbes and toxins for extended periods of time. However, these surfaces can be kept sanitary if they are designed with suitable materials that facilitate easy cleaning. This reduces the need for cleaning products that contain potentially toxic chemicals and may also reduce the frequency of cleaning.

Intent: To reduce occupant exposure to pathogens on high-touch surfaces.



Digestive
Endocrine
Immune
Integumentary
Reproductive
Urinary

Core New and New and and Existing Existing Buildings

#### **PART 1: MATERIAL PROPERTIES**

High-touch and non-porous surfaces (refer to Table A1 in Appendix C) meet the following requirements:

- a. Smooth and free of defects visible to the unaided eye.
- b. Finished to maintain smooth welds and joints.
- c. Free of crevices and other hard-to-reach places.

#### **PART 2: CLEANABILITY**

The following requirements are met:

- a. No permanent wall-to-wall carpeting is used; only removable rugs, removable carpet tiles or hard surfaces are allowed.
- b. The building provides adequate flexible storage space for all permanent, movable items to allow high-touch surfaces to be completely cleared during cleaning.
- c. Right angles between walls and windows/floors are sealed.

# **CLEANING EQUIPMENT**

High performance cleaning equipment increases the effectiveness of cleaning practices. Cleaning equipment that effectively removes debris and fomite material not only prevents the spread of contaminants, but also reduces repetitive work and contact with potentially harmful chemicals.

Intent: To reduce occupant exposure to both harmful pathogens and hazardous chemicals through the use of high quality cleaning equipment and the proper storage of cleaning agents.



Digestive Endocrine Immune Reproductive Urinary

Core New and Existing Existing Shell Interiors Buildings

#### PART 1: EQUIPMENT AND CLEANING AGENTS

All cleaning equipment meets the following:

- a.<sup>23</sup> Mops, rags and dusters used to clean all non-porous surfaces consist of microfiber with a denier no higher than 1.0.
- b. 23 Mops do not have to be wrung by hand.
- c. 40 Vacuum cleaners contain filters with a HEPA rating.

#### **PART 2: CHEMICAL STORAGE**

All cleaning equipment meets the following:

- a.<sup>26</sup> In cleaning storage areas, bleach and ammonia-based cleaning products are kept in separate bins from one another.
- b. 23 Any bins and bottles of bleach and ammonia-based cleaning products are affixed with large, color-coded labels indicating they are not to be mixed.

# WATER

# **BACKGROUND**

Clean drinking water is a prerequisite for optimal health. More than two-thirds of the human body is comprised of water, a major component of cells, and the medium for the transport of nutrients and waste throughout the body. In addition, water helps to regulate the internal body temperature and serves as a shock absorber for the brain and spinal cord. The Institute of Medicine (IOM) recommends that women consume approximately 2.7 liters [91 oz] and men 3.7 liters [125 oz] of water per day (from all sources including drinking water, other beverages and food). These amounts are appropriate to offset what leaves the body through respiration, perspiration and excretion, aiding in the removal of toxins, byproducts and other waste.

Drinking water contamination is a major public health issue. Many people receive water that has been exposed to potentially harmful levels of biological, chemical and mineral contaminants. The World Health Organization (WHO) reports that almost one billion people lack access to safe drinking water worldwide, and two million annual deaths are attributable to unsafe water, sanitation and hygiene.

The source of water contamination can sometimes be traced back to industry and its related processes. Contaminants like lead, arsenic, glyphosate, atrazine and microbes that are naturally occurring or inadvertently introduced into the water can pose serious health threats. However, treatment and distribution systems meant to keep our drinking water safe are also potential sources of contamination. For example, chlorine and chloramine which are commonly added to water to kill pathogenic organisms can lead to the formation of disinfectant byproducts such as trihalomethanes (THMs) and haloacetic acids (HAAs), as well as N-nitrosodimethylamine (NDMA), which may lead to cancer and other adverse health effects when exposure occurs at levels above the EPA standards. Finally, pharmaceuticals, personal care products (PPCPs) and other emerging contaminants are increasingly finding their way into our water supplies, with largely unknown health effects.

The quality of the U.S. surface water relies largely on The Clean Water Act of 1974. The U.S. Environmental Protection Agency (EPA) works to implement this Act and others (namely, the Safe Drinking Water Act), and publishes threshold concentration standards for water contaminants. These limits are set based on the likelihood of the development of cancer and other adverse health effects after long-term exposure to the specified contaminants. Nevertheless, drinking water contamination is a persistent problem. In a 2009 report, the EPA warned that "threats to drinking water are increasing," adding that "we can no longer take our drinking water for granted."

While taste and aesthetic preferences lead many people to drink bottled water, consumption of bottled water is not without its drawbacks. Overreliance on bottled water has environmental implications, but even putting aside those concerns, the quality of bottled water is subject to degradation. In one study, levels of antimony in 48 brands of bottled water from 11 European countries increased by 90% after 6 months of storage due to antimony leaching from polyethylene terephthalate bottles (PET(E) bottles, designated as recyclable "1").

The same standards for quality are typically applied across all uses of potable water. This can result in a significant waste of resources, since each use does not require the same level of protection. The WELL Building Standard® seeks to simultaneously preserve this resource while enhancing its quality for human health in the context of different uses. Therefore, WELL requires a broad initial assessment to evaluate a building's water source. From there, filtration can be installed to meet the thresholds required for each use. Buildings can continue to perform periodic testing to maintain quality water over time.

# INTENT

The WELL Building Standard for Water promotes safe and clean water through the implementation of proper filtration techniques and regular testing in order for building occupants to receive optimal quality of water for various uses.

# **WATER FEATURE LEVEL MATRIX**

		Core and Shell	New and Existing Interiors	New and Existing Buildings
30 FUNDAMENT	AL WATER QUALITY			
1: Sediment		Р	Р	Р
2: Microorganisms		Р		
31 INORGANIC	CONTAMINANTS			
1: Dissolved Metals		Р	Р	Р
32 ORGANIC CO	NTAMINANTS			
1: Organic Pollutants		Р	Р	Р
33 AGRICULTURA	AL CONTAMINANTS			
1: Herbicides and Pesticio	les	Р	Р	Р
2: Fertilizers		Р		
34 PUBLIC WATE	R ADDITIVES			
1: Disinfectants		Р	Р	Р
2: Disinfectant Byproduct	s	Р		
3: Fluoride		Р	Р	Р
35 PERIODIC WA	TER QUALITY TESTING			
1: Quarterly Testing		-	0	
2: Water Data Record Kee	eping and Response	-	О	0
36 WATER TREAT	ΓMENT			
1: Organic Chemical Rem	oval	О	0	0
2: Sediment Filter		О		
3: Microbial Elimination		О		
4: Water Quality Mainten	ance	О		
5: Legionella Control		0	0	0
37 DRINKING WA	ATER PROMOTION			
1: Drinking Water Taste P	roperties	О	0	
2: Drinking Water Access		-	О	
3: Water Dispenser Maint	enance	-	0	0

# **FUNDAMENTAL WATER QUALITY**

Two properties of water—turbidity and total coliforms—serve as indicators for the possible presence of many harmful contaminants. High turbidity can provide food and shelter for germs, and may also indicate that a building's filtration system is not working properly. Removing turbidity may also remove harmful pathogens such as protozoa. Another test is the measurement of total coliforms. Coliform bacteria are naturally present in the environment and are generally considered harmless. However, their presence in water suggests that water may contain more dangerous pathogens, including bacteria, viruses and protozoa. Exposure to these pathogens through water containing coliforms can lead to adverse gastrointestinal effects such as diarrhea, vomiting, nausea and cramps.

Intent: To limit the presence of sediment and water-borne pathogens in water designated for human contact.



Digestive Immune Nervous Urinary


Core and Shell New and Existing Interiors New and Existing Buildings

**PART 1: SEDIMENT** 

All water being delivered to the project area except water not designated for human contact meets the following requirements:

a. Turbidity of the water sample is less than 1.0 NTU.

#### **PART 2: MICROORGANISMS**



a.<sup>54</sup> Total coliforms (including E. coli) are not detected in the sample.

# **INORGANIC CONTAMINANTS**

While there are numerous metals that are necessary for healthy body functions, high levels of these essential metals can be harmful to health. Many dissolved metals that contaminate water supplies can be acutely or chronically toxic. Contamination levels vary widely by geographic location and water source, spurring the need for localized testing. Exposure to even minute amounts of certain metals such as lead and mercury through drinking water has been linked to developmental delays and deficits in learning abilities in children, as well as high blood pressure and kidney problems in adults. If necessary, reverse osmosis (RO) systems or Kinetic Degradation Fluxion (KDF) filters can remove dissolved metals at the point of delivery.

Intent: To limit the presence of inorganic contaminants in drinking water.



Cardiovascular Digestive Nervous Reproductive Urinary

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: DISSOLVED METALS**

All water being delivered to the project area for human consumption (at least one water dispenser per project) meets the following limits:

- a. 53 Lead less than 0.01 mg/L.
- b. 54 Arsenic less than 0.01 mg/L.
- c. <sup>54</sup> Antimony less than 0.006 mg/L.
- d. Mercury less than 0.002 mg/L.
- e. Nickel less than 0.012 mg/L.
- f. 54 Copper less than 1.0 mg/L.

# **ORGANIC CONTAMINANTS**

Organic contaminants are generally found in trace amounts in ground and surface waters and may pose serious threats to human health. Common sources of organic pollutants include industrial activities that inadvertently leach chemical runoff into surface waters. Exposure to organic contaminants such as polychlorinated biphenyls (PCBs) and vinyl chloride in drinking water has been associated with a range of adverse health effects, including cancer, immune deficiencies and nervous system difficulties. Activated carbon filters are effective in removing these and other harmful chemical substances.

Intent: To limit the presence of organic contaminants in drinking water.



Digestive Endocrine Immune Nervous Reproductive Urinary

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: ORGANIC POLLUTANTS**


All water being delivered to the project area for human consumption (at least one water dispenser per project) meets the following limits:

- a. 45 Styrene less than 0.0005 mg/L.
- b. Benzene less than 0.001 mg/L.
- c. 44 Ethylbenzene less than 0.3 mg/L.
- d.  $^{54}$  Polychlorinated biphenyls less than 0.0005 mg/L.
- e.  $^{54}$  Vinyl chloride less than 0.002 mg/L.
- f. 44 Toluene less than 0.15 mg/L.
- g. Sylenes (total: m, p and o) less than 0.5 mg/L.
- h.  $^{54}$  Tetrachloroethylene less than 0.005 mg/L.

# AGRICULTURAL CONTAMINANTS

A U.S. Geological Survey conducted in the 1990s detected pesticide compounds in virtually every stream in agricultural, urban and mixeduse areas, as well as in 30-60% of the groundwater. These chemicals may enter the water supply from agricultural and storm water runoff, and their exposure has been linked to kidney, thyroid, gastrointestinal and reproductive effects. Atrazine, one of the most widely used pesticides, is a suspected endocrine disruptor and is associated with cardiovascular difficulties. Long-term exposure to glyphosate, a widely used herbicide, may lead to kidney problems and reproductive difficulties. If detected, these contaminants can be removed with carbon filters.

Intent: To limit the presence of agricultural contaminants in drinking water.



Cardiovascular Digestive Endocrine Nervous Reproductive Urinary

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: HERBICIDES AND PESTICIDES**

All water being delivered to the project area for human consumption (at least one water dispenser per project) meets the following limits:

- a. 44 Atrazine less than 0.001 mg/L.
- b. 53 Simazine less than 0.002 mg/L.
- c. <sup>54</sup> Glyphosate less than 0.70 mg/L.
- d. 54 2,4-Dichlorophenoxyacetic acid less than 0.07 mg/L.

#### **PART 2: FERTILIZERS**




a.  $^{53}$  Nitrate less than 50 mg/L (11 mg/L as nitrogen).

# **PUBLIC WATER ADDITIVES**

Sometimes, chemicals are intentionally added to water supplies. For example, chlorine or chloramine may be added to water to act as disinfectants, and fluoride may be added to prevent tooth decay. Although the addition of small amounts of these chemicals is beneficial for public health and safety, excessive exposure can lead to adverse effects, including fluorosis (aesthetic mottling of the teeth), stomach discomfort and eye and skin irritation. In addition, the use of chlorine can lead to the formation of disinfectant byproducts (DBPs), such as trihalomethanes (THMs) and haloacetic acids (HAAs), which have been linked to cancer and kidney damage.

Intent: To limit the presence of certain disinfectants, disinfection byproducts and fluoride in drinking water.



Digestive Integumentary Reproductive Respiratory

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
Р	Р	Р

#### **PART 1: DISINFECTANTS**

All water being delivered to the project area for human consumption (at least one water dispenser per project) meets the following limits:


- a. 54 Total chlorine less than 4 mg/L.
- b. 54 Chloramine less than 4 mg/L.

### **PART 2: DISINFECTANT BYPRODUCTS**

All water being delivered to the project area for human consumption (at least one water dispenser per project) meets the following limits:

- a. Total trihalomethanes less than 0.08 mg/L.
- b. $^{54}$  Total haloacetic acids less than 0.06 mg/L.

# PART 3: FLUORIDE




a. Fluoride less than 4.0 mg/L.

# PERIODIC WATER QUALITY TESTING

Changing industrial practices and temporal variations in temperature, pH and weather may affect the leaching rate of inorganic metals into drinking water sources. Where possible, routine testing can help to detect any large variations in the chemicals present in water and help alert building occupants if a building is inconsistently receiving high quality water.

Intent: To maintain high quality water through regular water quality monitoring and remediation.



Core and Shell New and Existing Interiors New and Existing Buildings

#### **PART 1: QUARTERLY TESTING**

All water being delivered to the project area for human consumption is tested quarterly (with reports submitted annually to the IWBI) for the presence of the following dissolved metals or metalloids:

- a. 53 Lead.
- b. 53 Arsenic.
- c. 53 Mercury.
- d.<sup>53</sup> Copper.

#### PART 2: WATER DATA RECORD KEEPING AND RESPONSE


Projects provide a written policy specifying:

- a. Detailed enforcement strategies for monitoring and keeping record of, at minimum, water quality parameters listed in Feature 35 Part 1 of the WELL Building Standard.
- b. Records are kept for a minimum of 3 years, including full data from field inspections or laboratory results where appropriate.
- c. A detailed plan for action and remediation of unacceptable conditions.

#### **WATER TREATMENT**

There are many types of contaminants that may compromise water quality, from pathogens and heavy metals to pesticide and herbicide residues. While routine testing helps to keep track of potential pollutants, sampling alone cannot guarantee the elimination of all risk. Disruptions to water supply, droughts, flooding and construction and infrastructure changes can temporarily affect water quality. Therefore, implementing and maintaining appropriate water treatment systems - including carbon filters, sediment filters and UV sanitization - is key in order to continuously deliver high quality water.

Intent: To improve water quality by requiring the use of water treatment systems.



Digestive Immune

Core New and New and Existing Existing Buildings

O O O

#### PART 1: ORGANIC CHEMICAL REMOVAL

All water being delivered to the project area for human consumption is treated with the following:

a. 25 Activated carbon filter.

#### **PART 2: SEDIMENT FILTER**

All water being delivered to the project area for human consumption is treated with the following:

a. Filter to remove suspended solids tested with standard NSF 42 or EN 13443-2.


#### PART 3: MICROBIAL ELIMINATION



a. 24 UVGI water sanitation.

b. Filter rated by the NSF to remove or reduce microbial cysts.

#### PART 4: WATER QUALITY MAINTENANCE



a. Record-keeping for a minimum of 3 years, including evidence that the filter and/or sanitizer has been properly maintained as per the manufacturer's recommendation.

#### **PART 5: LEGIONELLA CONTROL**




A point-by-point narrative describes how the building addresses Legionella, and includes the following:

- a. Tormation of a team for Legionella management in the building.
- b. Water system inventory and production of process flow diagrams.
- c. <sup>177</sup> Hazard analysis of water assets.
- d. 1777 Identification of critical control points.
- e.<sup>177</sup> Maintenance and control measures, monitoring, establishment of performance limits and corrective actions.
- f. Documentation, verification and validation procedures.

#### DRINKING WATER PROMOTION

Access to clear, good-tasting water helps to promote proper hydration throughout the day. Many otherwise healthy people unknowingly suffer from mild dehydration, a condition where there is less water and fluids in the body than there should be, which results in avoidable symptoms such as muscle cramps, dry skin and headaches. Drinking plenty of water, especially when exercising and at higher temperatures is essential to ensure good hydration. Improving the taste and appearance of tap water encourages increased water consumption and reduces reliance on bottled water.

Intent: To promote the consumption of water by making high quality drinking water easily accessible to occupants.



Digestive Endocrine Urinary

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
0	0	О

#### PART 1: DRINKING WATER TASTE PROPERTIES

All water being delivered to the project area for human consumption:

- a. 54 Aluminum less than 0.2 mg/L.
- b. 54 Chloride less than 250 mg/L.
- c. 54 Manganese less than 0.05 mg/L.
- d. 47 Sodium less than 270 mg/L.
- e. Sulfate less than 250 mg/L.
- f. 54 Iron less than 0.3 mg/L.
- g. 54 Zinc less than 5 mg/L.
- h. Total Dissolved Solids less than 500 mg/L.

#### **PART 2: DRINKING WATER ACCESS**

To encourage water consumption, the following is met:

a. At least one dispenser is located within 30 m [100 ft] of all parts of regularly occupied floor space (minimum one per floor).

#### PART 3: WATER DISPENSER MAINTENANCE



- a.  $^{48}$  Daily, for mouthpieces, protective guards and collective basins, to prevent lime and calcium build-up.
- b. 48 Quarterly, for outlet screens and aerators, to remove debris and sediment.

## NOURISHMENT

## **BACKGROUND**

Nutrition plays a key role in health maintenance, weight management and chronic disease prevention. However, adherence to the dietary recommendations in the U.S. is poor. Similarly, global dietary patterns are also less than optimal; in many countries, people consume more than 500 calories from added sugars per day. In the U.S., half of the population consumes sugar-sweetened beverages (SSBs) on any given day, with a quarter of the population consuming over 200 calories from SSBs daily. In addition, the average dietary intake of calories in the U.S. in 2010 was nearly 2,600 calories per person per day, which is a 25% increase in energy intake since 1970. Consumption of flour and cereal products, added fats and oils, and added sugars and sweeteners are some of the chief contributors to the increase in caloric intake.

Together with physical inactivity, poor diet is a major contributor to the U.S. overweight (Body Mass Index (BMI) of 25-29.9) and obesity (BMI over 30) epidemic, increasing the risk of cardiovascular disease, diabetes and cancer. Over two thirds (69%) of all American adults (20 years and older) today are overweight, and more than a third (35%) are obese. The situation is similar worldwide, with more than 1.9 billion (39%) adults overweight in 2014, of which over 600 million (13%) were obese, making obesity not just an epidemic but a global pandemic.

Suboptimal dietary patterns can also lead to other detrimental health outcomes. For example, high consumption of SSBs has been linked to diabetes, metabolic syndrome, obesity, hypertension, dental caries and even depression. High intake of red and processed meat is associated with heart failure, hypertension, coronary heart disease, and colorectal and breast cancers. Moreover, low fruit and vegetable consumption is associated with a higher rate of type 2 diabetes, cardiovascular mortality, as well as breast and gastrointestinal cancers. The World Health Organization (WHO) reports that 2.7 million deaths worldwide are attributed to insufficient fruit and vegetable intake, making it one of the top 10 risk factors contributing to global mortality.

While the components and ingredients that often make up our foods represent a significant and reasonable concern, another issue is the changes in cultural food practices. Busy lives and longer workdays are encouraging unhealthy behaviors, including eating meals on the go and in front of the TV, snacking between meals and eating large portion meals. Further, high-fat, high-sugar snack foods of low nutritional quality are engineered to be tastier, with potentially addictive qualities. These foods are often supported by colorful and enticing advertisements that inundate our environments, from vending machines to restaurants and supermarket shelves. In the U.S. alone, more than \$1.6 billion is spent annually by the food industry specifically marketing cereal, fast-food and soft drinks to children and adolescents, which, according to the Institute of Medicine (IOM), is "out of balance with recommended healthful diets", contributing to unhealthy dietary patterns and putting the health of the American youth at risk.

Fortunately, food purchase and consumption decisions, dietary patterns and preparation practices all represent not only points of concern, but also venues for health improvement. A variety of social, economic, physiological and environmental factors can affect individual dietary behaviors; the built environment is one of them. Distance and access to grocery stores and other places that have fresh fruits and vegetables, access to farmers' markets, the use of behavioral economics in cafeterias, increased availability of healthy foods and reduced marketing and availability of unhealthy foods, provision of caloric information and many other strategies can have an effect on our food choices and overall dietary patterns. The WELL Building Standard® recognizes this and seeks to implement design strategies and policies within the built environment that increase access to healthy food options, enable people to make more informed dietary choices and lead to better health and well-being.

## INTENT

The WELL Building Standard for Nourishment requires the availability of fresh, wholesome foods, limits unhealthy ingredients and encourages better eating habits and food culture.

#### **NOURISHMENT FEATURE LEVEL MATRIX**

	ı			I
		Core and Shell	New and Existing Interiors	New and Existing Buildings
38	FRUITS AND VEGETABLES			
1: F	ruit and Vegetable Variety	-	Р	Р
	ruit and Vegetable Promotion	-	Р	
39	PROCESSED FOODS			'
1: R	efined Ingredient Restrictions	Р	Р	Р
2: T	rans Fat Ban	Р		
40	FOOD ALLERGIES			
1: F	ood Allergy Labeling	Р	Р	Р
41	HAND WASHING			
1: H	land Washing Supplies	-	Р	Р
2: C	Contamination Reduction	-	Р	
3: S	ink Dimensions	-	Р	Р
42	FOOD CONTAMINATION			
1: C	Cold Storage	-	Р	Р
43	ARTIFICIAL INGREDIENTS			
1: △	rtificial Substance Labeling	0	Р	Р
44	NUTRITIONAL INFORMATION			
1: D	etailed Nutritional Information	О	Р	Р
45	FOOD ADVERTISING			
1: △	dvertising and Environmental Cues	0	Р	Р
2: N	lutritional Messaging	0	Р	Р
46	SAFE FOOD PREPARATION MATERIALS			
1: C	Cooking Material	-	0	
2: C	Cutting Surfaces	-	0	0
47	SERVING SIZES			
1: N	Meal Sizes	-	0	
2: 0	ishware	-	0	0
48	SPECIAL DIETS			
1: F	ood Alternatives	-	0	0
49	RESPONSIBLE FOOD PRODUCTION			
	ustainable Agriculture	-	0	0
2: ⊦	lumane Agriculture	-	О	0
50	FOOD STORAGE			
1: S	torage Capacity	-	0	

	Core and Shell	New and Existing Interiors	New and Existing Buildings
51 FOOD PRODUCTION			
1: Gardening Space	0	О	0
2: Planting Support	0		
52 MINDFUL EATING			
1: Eating Spaces	0	O	0
2: Break Area Furnishings	0		

#### FRUITS AND VEGETABLES

Regular consumption of fresh fruits and vegetables is the cornerstone of a healthy diet and can lower the risk of cancer, diabetes, heart disease and obesity. Insufficient fruit and vegetable intake, on the other hand, is one of the top 10 risk factors contributing to global mortality, leading to approximately 2.7 million deaths worldwide. The Dietary Guidelines for Americans recommend an average consumption of at least 4 servings of fruits and 5 servings of vegetables per day. However, only 8% of the U.S. population consume the recommended amount of fruit, and only 6% achieve the recommended intake of vegetables.

Intent: To promote the consumption of fruits and vegetables by making fruits and vegetables easily accessible to occupants.



Cardiovascular Digestive Endocrine Immune

Core New and New and Existing Existing and Shell Interiors Buildinas

#### PART 1: FRUIT AND VEGETABLE VARIETY

If foods are sold or provided on a daily basis on the premises by (or under contract with) the project owner, then the selection includes at least one of the following:

- At least 2 varieties of fruits (containing no added sugar) and at least 2 varieties of non-fried а vegetables.
- At least 50% of available options are fruits (containing no added sugar) and/or non-fried b. vegetables.

#### PART 2: FRUIT AND VEGETABLE PROMOTION




Cafeterias operated or contracted by the project owner, if present, include the following design interventions:

- 180 a. Salad bar or similar salad-providing section, positioned in a visible and accessible location.
- b.<sup>73</sup> Fruits and vegetables are visually apparent, either through display or through color photographs on the menu.
- Vegetable dishes are placed at the beginning of the food service line.
- $d.^{73}$ Fruits or fruit dishes are placed in a bowl or in a stand at the checkout location.

#### **PROCESSED FOODS**

Foods that contain highly processed ingredients tend to be high in sugar, calories and added fats, and have low nutritional value. More than half of the U.S. population consumes sugar-sweetened beverages on a given day, and the average consumption of added sugars is more than 22 teaspoons per day, even though the recommended limit is 6-9 teaspoons. High consumption of added sugars is associated with weight gain, obesity, type 2 diabetes, kidney disease, hypertension and other negative health effects.

Intent: To help occupants avoid highly-processed ingredients and foods.



Cardiovascular Digestive Endocrine Reproductive Urinary


Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: REFINED INGREDIENT RESTRICTIONS

All foods and beverages sold or provided on a daily basis on the premises by (or under contract with) the project owner, including in vending machines, meet the following conditions:

- a.  $^{'8}$  Beverages do not contain more than 30 g of sugar per container. Bulk containers of 1.9 L (2 quart) or larger are exempt from this requirement.
- $b^{.78}$  At least 50% of beverages have 1 g of sugar or less per 16 mL [1.87 g of sugar or less per 1 oz].
- c. <sup>78</sup> No non-beverage food item contains more than 30 g of sugar per serving.
- d. 55 In at least 50% of grain-based foods, a whole grain is the first ingredient.

#### **PART 2: TRANS FAT BAN**



a. 56 Partially-hydrogenated oil.

#### **FOOD ALLERGIES**

Without clear labeling of ingredients, individuals with food allergies face an increased risk of exposure to allergens. Currently, about 8% of children and 4% of adults in the U.S. have food allergies. Every year, about 30,000 people require emergency room treatment, 2,000 are hospitalized and 150 die because of allergic reactions to food. Because there is no cure for food allergies, sensitive individuals must strictly avoid all foods containing the allergen in order to prevent serious allergic reactions. The FDA requires that all packaged foods explicitly declare the presence of common allergens, and several municipalities and state governments have additional guidelines regarding allergen labeling for prepared foods served in food service establishments.

Intent: To help occupants avoid consumption of or contact with potential food allergens.



Digestive Endocrine Immune Integumentary Respiratory

Core and Shell New and Existing Interiors New and Existing Buildings

#### PART 1: FOOD ALLERGY LABELING

All foods and beverages sold or provided on a daily basis on the premises by (or under contract with) the project owner are clearly labeled on packaging, menus, signage, or electronic media to indicate if they contain the following allergens:

- a. Peanuts.
- b. 57 Fish.
- c. 57 Shellfish.
- d. 57 Soy.
- e. 57 Milk and dairy products.
- f. <sup>57</sup> Egg.
- g. 57 Wheat.
- h. 57 Tree nuts.
- i. 57 Gluten.

#### **HAND WASHING**

Hand washing is one of the most important and effective means of reducing the transmission of pathogens through food. Responsible for approximately 48 million illnesses, 128,000 hospitalizations and 3,000 deaths occurring in the U.S. each year, foodborne illness is a major cause of preventable illness and death, personal distress and avoidable economic burden. Regular rinsing with soap and water helps to reduce the spread of unwanted and potentially dangerous germs. In addition, using paper towels to dry hands is more effective in removing bacteria than using air dryers. Since liquid soap in bulk refillable dispensers is prone to bacterial contamination, utilizing sealed liquid soap cartridges reduces the possibility for bacterial contamination and significantly reduces bacteria on hands whereas contaminated refillable dispensers increase bacteria on hands after handwashing. Handwashing sinks should also provide sufficient room for washing one's hands without touching the sink sides, to prevent possible recontamination.

Intent: To reduce pathogen transmission by providing accessible and sanitary hand washing facilities.

### - P P

#### **PART 1: HAND WASHING SUPPLIES**

The following are provided, at a minimum, at all sink locations:

- a. Fragrance-free hand soap in accordance with the Cleaning, Disinfection and Hand Hygiene Product section in Table A4 in Appendix C.
- b. 68 Disposable paper towels (air dryers are not forbidden, but are supplemented).

#### **PART 2: CONTAMINATION REDUCTION**

One of the following is provided, at a minimum, at all sink locations:

- a. 68 Liquid soap in dispensers with disposable and sealed soap cartridges.
- b. Bar soap with a soap rack that allows for drainage.

#### **PART 3: SINK DIMENSIONS**

Bathroom and kitchen sinks meet the following requirements:

- a. The sink column of water is at least 25 cm [10 inches] in length.
- b. The handwashing basin is at least 23 cm [9 inches] in width and length.


Digestive Endocrine Immune Integumentary Reproductive

Core and Shell New and Existing Interiors New and Existing Buildings

#### **FOOD CONTAMINATION**

Foods such as raw meat, fish and poultry pose an increased risk of becoming contaminated with bacteria. Microorganisms from such foods can be transmitted to other products via cutting boards and other equipment and surfaces, leading to gastrointestinal problems associated with food poisoning. To mitigate foodborne illnesses, foods must be properly stored and clearly labeled, and prepared at sufficiently high temperatures. Effective sanitation techniques also need to be put in place to prevent or minimize the growth of pathogenic microorganisms and thus reduce the risk of contamination and transmission.

Intent: To minimize occupant exposure to food-borne pathogens by providing safe food storage.



#### **PART 1: COLD STORAGE**

If raw meat, fish, or poultry is prepared or stored on site, cold storage spaces contain the following:

- a. At least one removable, cleanable drawer or container located at the bottom of the unit, designated and labeled for storing raw meat, fish and poultry.
- b. A visual display of holding temperatures to ensure accurate representation of storage temperatures.

#### **ARTIFICIAL INGREDIENTS**

Numerous artificial ingredients are typically added to highly processed foods to improve taste and extend shelf life. However, some people may be sensitive to these ingredients, such as sulfites, which can lead to breathing problems in individuals with asthma. Since these additives do not add nutritional value to a food, and tend to appear in foods with low nutritional qualities, they should be avoided as often as possible.

Intent: To help occupants avoid artificial colors, sweeteners and preservatives in food.



Digestive Nervous Urinary

Core Ne and Ex Shell In

New and Existing Interiors New and Existing Buildings

#### PART 1: ARTIFICIAL SUBSTANCE LABELING

All foods and beverages sold or provided on a daily basis on the premises by (or under contract with) the project owner are clearly labeled on packaging, nearby menus or signage to indicate if they contain the following:

- a. 10 Artificial colors.
- b. 10 Artificial flavors.
- c. 10 Artificial sweeteners.
- d. Brominated vegetable oils.
- e. 10 Potassium bromate.
- f. <sup>10</sup> BHA (Butylated hydroxyanisole).
- g. <sup>10</sup> BHT (Butylated hydroxytoluene).
- h. Monosodium glutamate (MSG).
- i. <sup>10</sup> Hydrolyzed vegetable protein (HVP).
- j. Sodium nitrate and sodium nitrite.
- k. 10 Sulfites.

#### **NUTRITIONAL INFORMATION**

Access to nutritional information allows consumers to make informed dietary choices. For example, being able to compare the sodium content of two different snacks can enable individuals who need to limit their salt intake choose the better option. The FDA sets specific requirements for nutrition labeling in packaged foods, and several municipal administrations have extended a labeling regulation to apply to prepared foods as well.

Intent: To help occupants make informed food consumption choices.



Cardiovascular Digestive Muscular Skeletal

Core New and New and and Existing Existing Buildings

#### PART 1: DETAILED NUTRITIONAL INFORMATION

For foods and beverages sold or provided on a daily basis on the premises by (or under contract with) the project owner, the following are displayed (per meal or item) on packaging, menus or signage:

- a. 74 Total calories.
- b. 61 Macronutrient content (total protein, total fat and total carbohydrate) in weight and/or as a percent of the estimated daily requirements (daily values).
- c. 61 Total sugar content.

#### **FOOD ADVERTISING**

Every year, food companies spend billions of dollars marketing and advertising unhealthy foods to children and adults, contributing to the creation of an obesogenic (obesity-promoting) environment. Over a billion dollars are spent annually on marketing breakfast cereals, carbonated beverages and restaurant food to youth alone. However, access to nutrition information can help individuals learn about and develop better eating habits. Further, limiting advertising cues for unhealthy foods can help individuals make better food selections and mitigate suboptimal nutritional choices.

Intent: To promote healthy food consumption choices.



Cardiovascular Digestive Endocrine Immune Integumentary Skeletal


Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: ADVERTISING AND ENVIRONMENTAL CUES

The following requirement is met:

a. Advertisements for any food or beverage items that do not conform to the requirements set forth in the Processed Foods feature are not displayed on the premises.

#### PART 2: NUTRITIONAL MESSAGING



- a. The consumption of whole, natural foods and cuisines.
- b. Discourage the consumption of sugary or processed foods and beverages.

#### SAFE FOOD PREPARATION MATERIALS

Food preparation equipment can be a source of potentially hazardous contaminants. Porous surfaces can harbor harmful toxins, while chemicals used to impart special attributes to food preparation equipment, such as non-stick properties for cookware, can leach or volatize during use. One such contaminant is bisphenol-A (BPA), a phenolic-based chemical that is used in products ranging from baby bottles and plastic foodware to water bottles and food can linings. While generally stable, BPA can be released when products containing BPA are exposed to heat or UV light, and may have negative effects on human health.

Intent: To reduce occupant exposure to harmful contaminants that may originate from food preparation materials and eliminate surfaces that harbor pathogens.



Digestive
Endocrine
Immune
Integumentary
Reproductive
Urinary


Core New and Existing Existing Shell Interiors Buildings

#### PART 1: COOKING MATERIAL

Pots, pans, dishware and other cooking tools used to prepare food (except cutting boards) are made entirely of one or more of the following inert materials:

- a. 67 Ceramics, except those containing lead.
- b. 67 Cast iron.
- c. 67 Stainless steel.
- d.<sup>67</sup> Glass.
- e. 67 Coated aluminum.
- f. Solid (non-laminated) wood that is untreated or treated with food-grade mineral or linseed oil.

#### **PART 2: CUTTING SURFACES**




- a. <sup>75</sup> Marble.
- b. 75 Plastic.
- c. 75 Glass.
- d.<sup>75</sup> Pyroceramic.
- e. 'S Solid (non-laminated) wood that is untreated or treated with food-grade mineral or linseed oil.
- f. 75 Bamboo.

#### **SERVING SIZES**

Excess caloric intake, especially through easy access to oversized meal options, can lead to excess weight gain and obesity. Some studies show that individuals will serve and eat more food when provided with larger plates and bowls compared to smaller ones. In addition, larger portions of energy-dense foods also promote overconsumption. Therefore, reducing the size and caloric content of meals can reduce the likelihood of unintended overeating, thereby encouraging healthier eating habits.

Intent: To reduce unintended overconsumption and encourage portion control.



Cardiovascular Digestive Endocrine Immune

Core New and New and and Existing Existing Buildings

#### **PART 1: MEAL SIZES**

If food is sold or provided on a daily basis by (or under contract with) the project owner and is prepared to order, the following is available and listed on the menu for at least half of all available main course options:

a. A version or portion of the main course that is 650 kcal [650 Cal] or less and at a lower cost compared to the larger, regular version.

#### **PART 2: DISHWARE**

If food is sold or provided on a daily basis on the premises by (or under contract with) the project owner, is self-serve, and requires the use of serving plate, bowl, or cup, each of the following is met (as applicable):

- a. Circular plates: the diameter of a plate is no larger than 25 cm [10 in].
- b. Non-circular plates: the total surface area of a plate does not exceed 507 cm<sup>2</sup> [79 in<sup>2</sup>].
- c. Bowls are no larger than 473 mL [16 oz].
- d. Cups are no larger than 473 mL [16 oz].

#### **SPECIAL DIETS**

Individuals with food allergies or dietary restrictions often encounter difficulty in finding suitable meal options. Clear labeling can prevent unintended exposure to allergens or food items that require some degree of restriction, but if a sufficient variety of alternatives is unavailable, these individuals may be at risk for consuming potentially harmful foods.

Intent: To provide alternative food choices to individuals with food restrictions or allergies.



Digestive Immune Integumentary

Core New and New and and Existing Existing Buildings

#### **PART 1: FOOD ALTERNATIVES**


Meals sold or provided by the project owner (on a daily basis) or catering (provided at least once a month) include at least one main course option for each of the following criteria (as necessary, by request):

- a. <sup>32</sup> Peanut-free.
- b. 60 Gluten-free.
- c. 60 Lactose-free.
- d. Egg-free.
- e. Contains no animal, seafood or dairy products.
- f. 60 Contains no animal or seafood products, except for eggs and dairy.

#### RESPONSIBLE FOOD PRODUCTION

Organic and sustainable farming practices are designed to reduce environmental pollution and increase the quality of life of livestock that we rely upon for food. Organic farming makes up a rapidly growing share of food cultivation processes in the U.S. due to increasing demand from conscientious consumers. While research on health effects of consuming organic versus conventionally-grown foods is still inconclusive, studies have found higher levels of antioxidants and lower levels of pesticide residues and antibiotic-resistant bacteria in organic as compared to conventionally-grown foods.

Intent: To reduce occupant exposure to pesticides or hormones, limit environmental degradation and promote humane livestock practices.



Cardiovascular Immune


Core New and New and and Existing Existing Buildings

#### PART 1: SUSTAINABLE AGRICULTURE

Produce is sold or provided on the premises on a daily basis by (or under contract with) the project owner that meets the following criteria:

a. 63 Federally Certified Organic labeling.

#### **PART 2: HUMANE AGRICULTURE**




- a. 64 Certified Humane™ labeling.
- b. Federally Certified Organic labeling.

**50** 

#### **FOOD STORAGE**

Most refrigerators are not designed with the intent to preserve the taste and nutrient content of fresh fruits and vegetables, which are typically best stored at relatively higher temperatures. Additionally, crisper drawers are often too small to store a sufficient quantity of produce for a moderately-sized group of people, potentially discouraging individuals from bringing healthier food options to work.

Intent: To encourage the consumption of fresh foods by providing sufficient cold food storage to occupants.



#### **PART 1: STORAGE CAPACITY**

The space provides cold storage that meets one of the following requirements:

- a. Total volume of at least 20 L [0.7 ft³] per occupant (no more than 7,000 L [247 ft³] of combined space is required).
- b. Evidence that the volume provided exceeds occupant demand by at least 20%.

#### **FOOD PRODUCTION**

Gardening or the cultivation of produce and herbs increases access to healthy, fresh and nutrient-rich foods and allows individuals to be more engaged with food production processes. Studies show that gardening can lead to better eating habits and more positive perceptions of overall health, and has been associated with lower BMI as well as lower odds of overweight and obesity.

Intent: To improve access to fresh produce by providing space, infrastructure and tools for on-site food production.



Cardiovascular Digestive Immune Muscular Skeletal

Core New and New and and Existing Existing Buildings

#### **PART 1: GARDENING SPACE**

A space of at least  $0.1 \text{ m}^2$  [1 ft²] per occupant (no more than  $70 \text{ m}^2$  [754 ft²] maximum is required) is accessible and located within 0.8 km [0.5 mi] of the project boundary for one or a combination of the following:

- a. 22 A garden with food-bearing plants.
- b. 22 A greenhouse with food-bearing plants.
- c. Edible landscaping (e.g., fruit trees, herbs).

#### **PART 2: PLANTING SUPPORT**


Adequate quantities of the following supplies are provided to grow and maintain vegetables, herbs or other edible plants in the Gardening Space provided:

- a. 22 Planting medium.
- b. 22 Watering system.
- c. 22 Lighting (interior spaces only).
- d. 22 Plants.
- e. Gardening tools.

#### MINDFUL EATING

Demanding work schedules and a lack of communal eating spaces can lead people to eat in isolation during meal breaks. Distracted eating at workstations while doing work, reading, watching television or listening to the radio may result in eating more, both immediately and during later food intake. Eating attentively and placing focus on the process of eating, on the other hand, may lead to better control of food intake. Time spent in break areas can lead to better eating habits, encourage social interactions, and help reduce stress.

Intent: To encourage mindful eating behaviors and socialization by providing communal eating spaces.



Digestive Nervous

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
0	0	

#### **PART 1: EATING SPACES**

Eating spaces for occupants adhere to the following requirements:

a. Contain tables and chairs to accommodate at least 25% of total occupants at a given time.

#### **PART 2: BREAK AREA FURNISHINGS**

Eating spaces for occupants contain all of the following:

- a. Refrigerator, device for reheating food (such as microwave or toaster oven), and sink.
- b. Amenities for dish washing.
- c. At least one cabinet or storage unit available for occupant use.
- d. Eating utensils, including spoons, forks, knives and microwave-safe plates and cups.

## LIGHT

## BACKGROUND

Light is a visible form of electromagnetic radiation, bordered in the spectrum by ultraviolet radiation at smaller wavelengths and infrared at larger wavelengths. Current lighting codes and guidelines provide illuminance recommendations for different room types, derived from usual lighting requirements for typical activities per room. These standards, created by technical groups such as Illuminating Engineering Society (IES), ensure good visual acuity in a variety of tasks to avoid eyestrain and to minimize productivity losses and headaches.

Light enters the eye and hits photoreceptors on the retina: rods, cones and intrinsically photosensitive retinal ganglion cells (ipRGCs). All of these cells absorb light and send it as information in the form of electrochemical signals to different parts of the brain. Rods facilitate peripheral vision and vision in dim lighting conditions, with peak sensitivity to green-blue light (498 nm). Cones facilitate daytime vision and color perception, and the peak sensitivity for the sensation of brightness with this system occurs at green-yellow light (555 nm).

In addition to facilitating vision, light influences the human body in non-visual ways. Humans and animals have internal clocks that synchronize physiological functions on roughly a 24-hour cycle called the circadian rhythm. The body responds to a number of zeitgebers—the external cues that align physiological functions to the solar day in this cycle. Light is the most important of these zeitgebers, keeping the body's internal clocks synchronized in a process known as circadian photoentrainment.

The ipRGCs are critical to the circadian system, sending information to various parts of the brain to trigger reactions downstream in the body. These cells demonstrate peak sensitivity to teal-blue light ( $\approx$ 480 nm). Notably, the ipRGCs project information to a specific part of the brain called the suprachiasmatic nucleus to let it know the time of day based on the light received, and this main clock then acts as an oscillator to likewise synchronize clocks in peripheral tissues and organs.

Multiple physiological processes—including those relating to alertness, digestion and sleep—are regulated in part by the variance and interplay of hormones involved in this cycle. A consideration of light exposure is particularly significant considering the role this plays in sleep, and given that the Institute of Medicine reports that about 50 to 70 million U.S. adults have a chronic sleep or wakefulness disorder. Further, such disorders and chronic sleep deprivation are associated with increased risk of certain morbidities, including diabetes, obesity, depression, heart attack, hypertension and stroke.

All light—not just sunlight—can contribute to circadian photoentrainment. Given that people spend much of their waking day indoors, insufficient illumination or improper lighting design can lead to a drift of the circadian phase, especially if paired with inappropriate light exposure at night. Humans are continuously sensitive to light, and under normal circumstances, light exposure in the late night/early morning will shift our rhythms forward (phase advance), whereas exposure in the late afternoon/early night will shift our rhythms back (phase delay). To maintain optimal, properly synchronized circadian rhythms, the body requires periods of both brightness and darkness.

## INTENT

The WELL Building Standard® for Light provides illumination guidelines that are aimed to minimize disruption to the body's circadian system, enhance productivity, support good sleep quality and provide appropriate visual acuity where needed.

#### **LIGHT FEATURE LEVEL MATRIX**

Core and Shell   New and Existing   New and Existing   Shell   Interiors   Shell   Interiors   Shell   Shell   Interiors   Shell   Shell   Interiors   Shell   Shell					
1: Visual Acuity for Focus - P P P 2: Brightness Management Strategies - P P 54 CIRCADIAN LIGHTING DESIGN 1: Melanopic Light Intensity for Work Areas - P P 55 ELECTRIC LIGHT GLARE CONTROL 1: Luminaire Shielding - P P P 2: Glare Minimization P P P P 56 SOLAR GLARE CONTROL 1: View Window Shading O P P P 2: Daylight Management O P P P 57 LOW-GLARE WORKSTATION DESIGN 1: Glare Avoidance - O P P 58 COLOR QUALITY 1: Color Rendering Index - O O 59 SURFACE DESIGN 1: Working and Learning Area Surface Reflectivity - O O 60 AUTOMATED SHADING AND DIMMING CONTROLS 1: Automated Sunlight Control - O O 2: Responsive Light Control - O O 2: Window Access - O O 61 RIGHT TO LIGHT 1: Lease Depth O O O 2: Window Access - O O 63 DAYLIGHT MODELING 1: Window Sizes for Working and Learning Spaces O O 2: Window Strass for Working and Learning Areas O O				_	New and Existing Buildings
2: Brightness Management Strategies - P P  54 CIRCADIAN LIGHTING DESIGN  1: Melanopic Light Intensity for Work Areas - P P  55 ELECTRIC LIGHT GLARE CONTROL  1: Luminaire Shielding - P P P  2: Glare Minimization P P P P  56 SOLAR GLARE CONTROL  1: View Window Shading O P P  57 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance - O P  58 COLOR QUALITY  1: Color Rendering Index - O O  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity - O O  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control - O O  2: Responsive Light Control - O O  61 RIGHT TO LIGHT  1: Lease Depth O O O  62: Window Access - O O  63 DAYLIGHT MODELING  1: Window Sizes for Working and Learning Spaces O O  2: Window Sizes for Working and Learning Areas O O O  2: Window Sizes for Working and Learning Areas O O	53 VISUAL LIGH	TING DESIGN			
54 CIRCADIAN LIGHTING DESIGN  1: Melanopic Light Intensity for Work Areas - P P P  55 ELECTRIC LIGHT GLARE CONTROL  1: Luminaire Shielding - P P P  2: Glare Minimization P P P P  56 SOLAR GLARE CONTROL  1: View Window Shading P P P  2: Daylight Management P P P  57 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance - O S  58 COLOR QUALITY  1: Color Rendering Index - O S  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity - O S  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control - O S  51: Lease Depth O O O S  52: Window Access - O O O O O O O O O O O O O O O O O O	1: Visual Acuity for Focu	s	-	Р	Р
1: Melanopic Light Intensity for Work Areas - P P P  55 ELECTRIC LIGHT GLARE CONTROL  1: Luminaire Shielding - P P P  2: Glare Minimization P P P P  56 SOLAR GLARE CONTROL  1: View Window Shading O P P P  2: Daylight Management O P P P  57 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance - O O  58 COLOR QUALITY  1: Color Rendering Index - O O  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity - O O  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control - O O  2: Responsive Light Control - O O  61 RIGHT TO LIGHT  1: Lease Depth O O O O  2: Window Access - O O  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces O O O  2: Window Sizes for Working and Learning Spaces O O O  2: Window Transmittance in Working and Learning Areas	2: Brightness Managem	ent Strategies	-	Р	Р
55 ELECTRIC LIGHT GLARE CONTROL  1: Luminaire Shielding - P P P 2: Glare Minimization P P P P 56 SOLAR GLARE CONTROL  1: View Window Shading O P P P 2: Daylight Management O P P P 57 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance - O O 58 COLOR QUALITY  1: Color Rendering Index - O O 59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity - O O 60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control - O O 2: Responsive Light Control - O O 2: Responsive Light Control - O O 2: Window Access - O O  61 RIGHT TO LIGHT  1: Lease Depth O O O 2: Window Access - O O  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces O O O 2: Window Sizes for Working and Learning Spaces O O O 2: Window Transmittance in Working and Learning Areas	54 CIRCADIAN	LIGHTING DESIGN			
1: Luminaire Shielding	1: Melanopic Light Inter	nsity for Work Areas	-	Р	Р
2: Glare Minimization P P P P  56 SOLAR GLARE CONTROL  1: View Window Shading P P P  2: Daylight Management P P P  57 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance O O O O O O O O O O O O O O O O O O O	55 ELECTRIC LIC	GHT GLARE CONTROL			
56 SOLAR GLARE CONTROL  1: View Window Shading 2: Daylight Management 0 PPP  7 PP  7 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance	1: Luminaire Shielding		-	Р	Р
1: View Window Shading 2: Daylight Management 0 P P P  57 LOW-GLARE WORKSTATION DESIGN 1: Glare Avoidance -	2: Glare Minimization		Р	Р	Р
2: Daylight Management  O P P  57 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance  - O O  58 COLOR QUALITY  1: Color Rendering Index  - O O  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity  - O O  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control  2: Responsive Light Control  - O O  61 RIGHT TO LIGHT  1: Lease Depth  0 O O  2: Window Access  - O O  63 DAYLIGHT MODELING  1: Window Sizes for Working and Learning Spaces  2: Window Transmittance in Working and Learning Areas	56 SOLAR GLAF	RE CONTROL			
57 LOW-GLARE WORKSTATION DESIGN  1: Glare Avoidance - O O  58 COLOR QUALITY  1: Color Rendering Index - O O  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity - O O  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control - O O  2: Responsive Light Control - O O  61 RIGHT TO LIGHT  1: Lease Depth O O O  2: Window Access - O O  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure O O O  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces O O O  2: Window Transmittance in Working and Learning Areas	1: View Window Shadin	g	0	Р	Р
1: Glare Avoidance - O O  58 COLOR QUALITY  1: Color Rendering Index - O O  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity - O O  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control - O O  2: Responsive Light Control - O O  61 RIGHT TO LIGHT  1: Lease Depth O O O  2: Window Access - O O  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure O O O  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces O O O  2: Window Transmittance in Working and Learning Areas O O O	2: Daylight Managemer	t	О	Р	Р
58 COLOR QUALITY  1: Color Rendering Index  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control  2: Responsive Light Control  61 RIGHT TO LIGHT  1: Lease Depth  2: Window Access  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces  2: Window Transmittance in Working and Learning Areas	57 LOW-GLARE	WORKSTATION DESIGN			
1: Color Rendering Index  59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity  - O O  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control  - O O  2: Responsive Light Control  61 RIGHT TO LIGHT  1: Lease Depth 2: Window Access  - O O  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces 2: Window Transmittance in Working and Learning Areas	1: Glare Avoidance		-	0	О
59 SURFACE DESIGN  1: Working and Learning Area Surface Reflectivity  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control  2: Responsive Light Control  61 RIGHT TO LIGHT  1: Lease Depth  2: Window Access  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces  2: Window Transmittance in Working and Learning Areas	58 COLOR QUA	LITY			
1: Working and Learning Area Surface Reflectivity  60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control  2: Responsive Light Control  61 RIGHT TO LIGHT  1: Lease Depth  2: Window Access  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces  2: Window Transmittance in Working and Learning Areas	1: Color Rendering Inde	×	-	0	0
60 AUTOMATED SHADING AND DIMMING CONTROLS  1: Automated Sunlight Control 2: Responsive Light Control 61 RIGHT TO LIGHT  1: Lease Depth 2: Window Access	59 SURFACE DE	SIGN			
1: Automated Sunlight Control 2: Responsive Light Control  61 RIGHT TO LIGHT  1: Lease Depth 2: Window Access - 0 0  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces 2: Window Transmittance in Working and Learning Areas	1: Working and Learning	g Area Surface Reflectivity	-	0	О
2: Responsive Light Control  61 RIGHT TO LIGHT  1: Lease Depth 2: Window Access - 0  62 DAYLIGHT MODELING 1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces 2: Window Transmittance in Working and Learning Areas	60 AUTOMATE	SHADING AND DIMMING	CONTROLS		
61 RIGHT TO LIGHT  1: Lease Depth 2: Window Access -  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces 2: Window Transmittance in Working and Learning Areas  O  O  O  O  O  O  O  O  O  O  O  O  O			-	0	О
1: Lease Depth 2: Window Access - 0 0 0 0 2: Window Access - 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	2: Responsive Light Cor	ntrol	-	О	О
2: Window Access  62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces  2: Window Transmittance in Working and Learning Areas	61 RIGHT TO LI	GHT			
62 DAYLIGHT MODELING  1: Healthy Sunlight Exposure  63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces  2: Window Transmittance in Working and Learning Areas	1: Lease Depth		0		
1: Healthy Sunlight Exposure  O O O O O O O O O O O O O O O O O O	2: Window Access		-	0	О
63 DAYLIGHTING FENESTRATION  1: Window Sizes for Working and Learning Spaces  2: Window Transmittance in Working and Learning Areas	62 DAYLIGHT M	IODELING			
1: Window Sizes for Working and Learning Spaces 2: Window Transmittance in Working and Learning Areas 0 0	1: Healthy Sunlight Exp	osure	О	0	О
2: Window Transmittance in Working and Learning Areas	63 DAYLIGHTING FENESTRATION				
	1: Window Sizes for Wo	rking and Learning Spaces	0	0	0
3: Uniform Color Transmittance	2: Window Transmittance in Working and Learning Areas		0		
	3: Uniform Color Transn	nittance	0	0	0

#### **VISUAL LIGHTING DESIGN**

Adequate light levels are needed for a broad variety of activities, including reading various qualities and types of print, and working on detail-oriented tasks. Brightness levels also contribute to the perception of spaciousness, as well as to the overall visual appeal of illuminated spaces. Targeted task lighting can provide the necessary amount of light at workspaces without over-illuminating ancillary spaces; ambient light levels of 300 lux are sufficient for most tasks. Pairing adjustable direct task lighting with indirect or diffuse ambient lighting allows user customization and good visual acuity while providing more suitable background light. Light intensity for visual acuity is measured in lux (or foot candles), which is a measure of the way the eye responds to light weighted to the response of the cone cells—the main photoreceptors for daytime vision, located on the retina of the human eye.

Intent: To support visual acuity by setting a threshold for adequate light levels and requiring luminance to be balanced within and across indoor spaces.

# Core New and New and and Existing Existing Shell Interiors Buildings

Endocrine

Muscular

Nervous

#### PART 1: VISUAL ACUITY FOR FOCUS

The following requirements are met at workstations or desks:

- a. The ambient lighting system is able to maintain an average light intensity of 215 lux [20 fc] or more, measured on the horizontal work plane. The lights may be dimmed in the presence of daylight, but they are able to independently achieve these levels.
- b. The ambient lighting system is zoned in independently controlled banks no larger than 46.5 m<sup>2</sup> [500 ft<sup>2</sup>] or 20% of open floor area of the room (whichever is larger).
- c. 81 If average ambient light is below 300 lux [28 fc] and meets Part 1a, task lights providing 300 to 500 lux [28 to 46 fc] at the work surface are available upon request.

#### PART 2: BRIGHTNESS MANAGEMENT STRATEGIES

- P P

Provide a narrative that describes strategies for maintaining luminance balance in spaces, which takes into consideration at least two of the following:

- a. 52 Maximum brightness contrasts between main rooms and ancillary spaces, such as corridors and stairwells, if present. For example, projects may establish that, while still maintaining lighting variety, a main room cannot exhibit 10 times greater or lesser luminance than an ancillary space.
- b. 52 Maximum brightness contrasts between task surfaces and immediately adjacent surfaces, including adjacent visual display terminal screens. For example, projects may establish that, while still maintaining lighting variety, a surface cannot exhibit 3 times greater or lesser luminance than an adjacent surface.
- c. <sup>52</sup> Brightness contrasts between task surfaces and remote, non-adjacent surfaces in the same room. For example, projects may establish that, while still maintaining lighting variety, a surface cannot exhibit 10 times greater or lesser luminance than another remote surface in the same room.
- d. The way brightness is distributed across ceilings in a given room that maintains lighting variety but avoids both dark spots, or excessively bright, potentially glaring spots. For example, projects may establish that, while still maintaining lighting variety, one part of the ceiling cannot be 10 times greater or lesser luminance than another part of the ceiling in the same room.

#### **CIRCADIAN LIGHTING DESIGN**

Light is one of the main drivers of the circadian system, which starts in the brain and regulates physiological rhythms throughout the body's tissues and organs, affecting hormone levels and the sleep-wake cycle. Circadian rhythms are kept in sync by various cues, including light which the body responds to in a way facilitated by intrinsically photosensitive retinal ganglion cells (ipRGCs): the eyes' non-image-forming photoreceptors. Through ipRGCs, lights of high frequency and intensity promote alertness, while the lack of this stimulus signals the body to reduce energy expenditure and prepare for rest. The biological effects of light on humans can be measured in Equivalent Melanopic Lux (EML), a proposed alternate metric that is weighted to the ipRGCs instead of to the cones, which is the case with traditional lux. During Performance Verification, EML is measured on the vertical plane at eye level of the occupant. Tables L1 and L2 in Appendix C show how to calculate the EML of individual lamps and larger spaces.

Intent: To support circadian health by setting a minimum threshold for daytime light intensity.

Cardiovascular Digestive Endocrine Immune Muscular Nervous

Core and Shell New and Existing Interiors New and Existing Buildings

#### PART 1: MELANOPIC LIGHT INTENSITY FOR WORK AREAS

Light models or light calculations demonstrate that at least one of the following requirements is met:

- a. At 75% or more of workstations, at least 200 equivalent melanopic lux is present, measured on the vertical plane facing forward, 1.2 m [4 ft] above finished floor (to simulate the view of the occupant). This light level may incorporate daylight, and is present for at least the hours between 9:00 AM and 1:00 PM for every day of the year.
- b. For all workstations, electric lights provide maintained illuminance on the vertical plane facing forward (to simulate the view of the occupant) of 150 equivalent melanopic lux or greater.

#### **ELECTRIC LIGHT GLARE CONTROL**

Non-diffuse, bright indoor lights create uneven levels of brightness in the visual field. The resulting glare, defined as "excessive brightness of the light-source, excessive brightness-contrasts and excessive quantity of light", can cause visual discomfort (discomfort glare), fatigue, visual impairment and even injury (disability glare), and can be attributed to either direct or reflected glare. In the case of glare caused by electric light sources, lamps should be shielded based on their luminance. This quantity, often given in cd/m², can be measured directly or calculated from lighting specification sheets with sufficient detail. Light fixtures of greater luminous intensity require a greater shielding angle to reduce the likelihood of creating direct glare for occupants.

Intent: To minimize direct and overhead glare by setting limits on the luminous intensity of luminaires.



Core and Shell New and Existing Interiors New and Existing Buildings

#### **PART 1: LUMINAIRE SHIELDING**

The following shielding angles ( $\alpha = 90$  - cutoff angle) must be observed for lamps in regularly occupied spaces with luminance values in the ranges specified:

- a. No shielding required for less than 20,000 cd/m² (including reflected sources).
- b.  $\alpha$ : 15° for 20,000 to 50,000 cd/m<sup>2</sup>.
- c.  $\alpha$ : 20° for 50,000 to 500,000 cd/m<sup>2</sup>.
- d.  $\alpha$ : 30° for 500,000 cd/m<sup>2</sup> and above.

#### **PART 2: GLARE MINIMIZATION**



- a. Luminaires more than 53° above the center of view (degrees above horizontal) have luminances less than 8.000 cd/m².
- b. Workstations achieve a UGR of 19 (or less).

#### **SOLAR GLARE CONTROL**

Though bright light during the day is conducive to good health, uneven levels of brightness in the visual field can cause visual fatigue and discomfort. Glare, or excessive brightness, is caused by light scattering within the eye (intraocular scattering), thereby creating a "veil" of luminance that reduces the luminance contrast as received by the retina. In buildings, sources of glare are often unshielded or poorly shielded light, or sunlight directly hitting the eye or reflective surfaces.

Intent: To avoid glare from the sun by blocking or reflecting direct sunlight away from occupants.



Muscular Nervous Skeletal

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: VIEW WINDOW SHADING

At least one of the following is present for all glazing less than 2.1 m [7 ft] above the floor in regularly occupied spaces (excluding lobbies):

- a.  $^{80}$  Interior window shading or blinds that are controllable by the occupants or set to automatically prevent glare.
- b. External shading systems that are set to prevent glare.
- c. Variable opacity glazing, such as electrochromic glass, which can reduce transmissivity by 90% or more.

#### **PART 2: DAYLIGHT MANAGEMENT**



At least one of the following is required for all glazing greater than 2.1 m [7 ft] above the floor in regularly occupied spaces (excluding lobbies):

- a.  $^{80}$  Interior window shading or blinds that are controllable by the occupants or set to automatically prevent glare.
- b. External shading systems that are set to prevent glare.
- c. Interior light shelves to reflect sunlight toward the ceiling.
- d. A film of micro-mirrors on the window that reflects sunlight toward the ceiling.
- e. Variable opacity glazing, such as electrochromic glass, which can reduce transmissivity by 90% or more.

#### **LOW-GLARE WORKSTATION DESIGN**

Glare is commonly generated when high-intensity electric or natural light reflects off glossy surfaces that may be positioned at suboptimal angles in and around occupant spaces, in relation to windows. The resulting discomfort can be a hindrance to an otherwise comfortable and effective work environment. Adjusting the angle at which the light hits a surface can help guide the light away from reflecting directly into the eye, thereby avoiding glare.

Intent: To minimize visual discomfort by situating computer monitors in a way that avoids glare and luminance contrast.



Core New and and Existing Shell Interiors

New and Existing Buildings

#### **PART 1: GLARE AVOIDANCE**


The following requirements are met:

- a. To minimize glare caused by incoming sunlight, all computer screens at desks located within 4.5 m [15 ft] of view windows can be oriented within a 20° angle perpendicular to the plane of the nearest window.
- b. Overhead luminaires are not aimed directly at computer screens.

#### **COLOR QUALITY**

Color quality is a function of the spectral output of a light source, the spectral absorbance/reflectance of an object, and the sensitivity of the eye's cone photoreceptors to different wavelengths of light, which we perceive as color. Color quality impacts visual appeal and can either contribute to or detract from occupant comfort. Poor color quality can reduce visual acuity and the accurate rendering of illuminated objects. For instance, foods, human skin tones and plants may appear dull or unsaturated under lights that have low color quality metrics. Color rendering index (CRI) is a common way to measure color quality, capturing R1-R8 metrics. R9, while not always reported, is also included as part of this feature, as R9 values further take into consideration how we perceive the saturation of warmer hues.

Intent: To enhance spatial aesthetics and color differentiation through the use of lamps with quality color rendering abilities.



#### **PART 1: COLOR RENDERING INDEX**

To accurately portray colors in the space and enhance occupant comfort, all electric lights in occupiable spaces (except decorative fixtures, emergency lights and other special-purpose lighting) meet the following conditions:

- a. 80 Color Rendering Index Ra (CRI, average of R1 through R8) of 80 or higher.
- b. 80 Color Rendering Index R9 of 50 or higher.

#### **SURFACE DESIGN**

Exposure to light not only facilitates image-formation and color perception, but can also trigger a series of non-visual effects involving the regulation of the circadian cycle. Light exposure mainly occurs via two ways: (1) directly from luminous sources, and (2) indirectly from reflected surfaces. Since most light encountered within buildings is reflective, quality of surfaces greatly affects the amount of light ultimately reaching the eye. Surfaces with lower light reflectance values (LRVs) absorb light from the source and result in lower overall light intensity. Higher LRVs mean that the surface reflects more light from the source, resulting in maximum light intensity and promoting alertness and activity. Choosing surfaces with higher LRV values thus represents a good strategy for ensuring that a sufficient amount of light reaches the eye without increasing energy consumption or glare.

Intent: To increase overall room brightness through reflected light from room surfaces and avoiding glare.



Endocrine Muscular Nervous

Core and Shell New and Existing Interiors New and Existing Buildings

#### PART 1: WORKING AND LEARNING AREA SURFACE REFLECTIVITY

The following Light Reflectance Values (LRV) are met:

- a. Ceilings have an average LRV of 0.8 (80%) or more for at least 80% of surface area in regularly occupied spaces.
- b. 80 Vertical surfaces have an average LRV of 0.7 (70%) or more for at least 50% of surface area directly visible from regularly occupied spaces.
- c. Furniture systems have an average LRV of 0.5 (50%) or more for 50% of surface area directly visible from regularly occupied spaces.

#### **AUTOMATED SHADING AND DIMMING CONTROLS**

Design features such as adjustable window shades and lights with dimmers must be actively managed to be effective. Automated controls can help to ensure that these systems continually operate as intended and meet intended benefits such as glare avoidance and energy reduction. Furthermore, setting these features to automatically adjust can greatly contribute to comfort without disrupting occupants from other tasks.

Intent: To prevent glare and encourage reliance on natural light through automated shading and dimming.



Endocrine Immune Muscular Nervous Reproductive Skeletal

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: AUTOMATED SUNLIGHT CONTROL

All windows larger than 0.55 m<sup>2</sup> [6 ft<sup>2</sup>] have the following:

a. Shading devices that automatically engage when light sensors indicate that sunlight could contribute to glare at workstations and other seating areas.

#### PART 2: RESPONSIVE LIGHT CONTROL



- a. 80 All lighting except decorative fixtures is programmed using occupancy sensors to automatically dim to 20% or less (or switch off) when the zone is unoccupied.
- b. 80 All lighting except decorative fixtures has the capacity and is programmed to dim continuously in response to daylight.

#### **RIGHT TO LIGHT**

Exposure to adequate levels of sunlight is critical for health and well-being, for effects ranging from visual comfort to potential psychological and neurological gains: there are measurable physiological benefits to receiving the quality of light provided by the sun, as well as positive subjective reports from occupants able to enjoy access to sunlight. Proximity to windows, outdoor views and daylight in indoor spaces are some of the most sought-after elements of design. As such, buildings should utilize daylight as a primary source of lighting to the greatest extent possible.

Intent: To promote exposure to daylight and views of varying distances by limiting the distance workstations can be from a window or atrium.



Cardiovascular
Digestive
Endocrine
Immune
Muscular
Nervous
Reproductive

Core New and New and Existing Shell Interiors Buildings

#### **PART 1: LEASE DEPTH**

The following requirement is met:

a. 75% of the area of all regularly occupied spaces is within 7.5 m [25 ft] of view windows.

#### **PART 2: WINDOW ACCESS**

The following conditions are met:

- a. 75% of all workstations are within 7.5 m [25 ft] of an atrium or a window with views to the exterior.
- b. 95% of all workstations are within 12.5 m [41 ft] of an atrium or a window with views to the exterior.

#### **DAYLIGHT MODELING**

Exposure to appropriate amounts of natural light reinforces the alignment of our circadian rhythms and reduces dependence on electricity for artificial lighting; however, excessive sunlight, during can cause glare and unwanted visual contrast. This is not only important to consider throughout the course of the day, but also throughout the course of the year, such that occupants are able to enjoy the benefits of daylight exposure in all seasons. Therefore, it is necessary to find a balance between Spatial Daylight Autonomy (sDA), which measures the percentage of floor area that receives adequate sunlight, and Annual Sun Exposure (ASE), which measures the percentage of floor area receives too much direct sunlight.

Intent: To support circadian and psychological health by setting thresholds for indoor sunlight exposure.



Cardiovascular
Digestive
Endocrine
Immune
Muscular
Nervous
Reproductive

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: HEALTHY SUNLIGHT EXPOSURE

Lighting simulations demonstrate that the following conditions are expected:

- a. Spatial daylight autonomy (sDA300,50%) is achieved for at least 55% of regularly occupied space. In other words, at least 55% of the space receives at least 300 lux [28 fc] of daylight for at least 50% of operating hours each year.
- b. Annual sunlight exposure (ASE1000,250) is achieved for no more than 10% of regularly occupied space. In other words, no more than 10% of the area can receive more than 1,000 lux [93 fc] for 250 hours each year.

#### DAYLIGHTING FENESTRATION

Exposure to natural light can improve occupant mood, alertness and overall health. Ideal lighting involves proper exposure to diffuse daylight, as well as careful design of windows and glazing to avoid excessive glare and heat gain. Windows are therefore a key variable for both ensuring that occupants receive enough light for positive physiological and subjective effects, but also not too much light that causes discomfort or becomes a source of distraction. Balancing energy performance, thermal comfort and access to quality daylight are essential to proper building design.

Intent: To optimize occupant exposure to daylight and limit glare through enhanced fenestration parameters.



Cardiovascular
Digestive
Endocrine
Immune
Muscular
Nervous
Reproductive

Core New and New and and Existing Existing Buildings

#### PART 1: WINDOW SIZES FOR WORKING AND LEARNING SPACES

The following conditions are met on façades along regularly occupied spaces:

- a. Window-wall ratio as measured on external elevations is between 20% and 60%. Percentages greater than 40% require external shading or adjustable opacity glazing to control unwanted heat gain and glare.
- b. Between 40% and 60% of window area is at least 2.1 m [7 ft] above the floor.

## PART 2: WINDOW TRANSMITTANCE IN WORKING AND LEARNING AREAS



The following visible transmittance (VT) conditions are met for all non-decorative glazing:

- a. All glazing (excluding skylights) located higher than 2.1 m [7 ft] from the floor has VT of 60% or more.
- b. All glazing located 2.1 m [7 ft] or lower from the floor has VT of 50% or more.

#### PART 3: UNIFORM COLOR TRANSMITTANCE



All windows used for daylighting meet the following requirement:

a. The visible light transmittance of wavelengths between 400 and 650 nm does not vary by more than a factor of 2.

# FITNESS

## BACKGROUND

The Centers for Disease Control (CDC) define fitness as "the ability to carry out daily tasks with vigor and alertness, without undue fatigue, and with ample energy to enjoy leisure-time pursuits and respond to emergencies". Regular physical activity is essential to achieve optimal health, including weight management, chronic disease prevention and fitness maintenance. The American College of Sports Medicine, among others, recommends that all healthy adults engage in at least 30 minutes of moderate-intensity aerobic activity five days per week, and muscle-strengthening activities at least two days per week. Numerous types of physical activities, including walking, running, cycling, swimming and resistance training have demonstrated health benefits, with greater gains when performed at higher intensities or for longer periods of time.

However, the majority of people today are physically inactive. Modern transportation, labor saving conveniences and sedentary jobs have created an environment in which millions of people fail to achieve the minimum level of activity necessary to help prevent type 2 diabetes, metabolic syndrome, obesity, heart disease and other chronic conditions. In the U.S. alone, fewer than 50% of elementary school students, 10% of adolescents and 5% of adults obtain 30 minutes of daily physical activity. An average adult obtains only 6-10 minutes of moderate to vigorous intensity physical activity a day. The situation is similar worldwide—over 60% of all people do not get the recommended daily 30-minute minimum of moderate-intensity physical activity, and are thus considered inactive.

Physical inactivity poses one of the biggest modern threats to public health. It is an independent risk factor for numerous chronic diseases and is estimated to be responsible for 30% of ischemic heart disease, 27% of type 2 diabetes and 21-25% of breast and colon cancer cases. Lack of physical activity can also increase the odds of having a stroke by 20-30% and shave off 3-5 years of life. Together, these and other conditions make physical inactivity the fourth leading risk factor for mortality, accounting for 6-9% of deaths worldwide, or three to five million mortalities every year.

While the issue of insufficient activity is multi-faceted, one of the factors known to impact physical activity levels is the built environment. Neighborhood walkability, access to and use of mass transit, active transportation, availability of physical activity facilities near workplaces and homes, stair accessibility in buildings, active furnishings and many other factors can affect the physical activity level of an individual. Considering that 90% of our time is spent within the built environment, urban planning and building design strategies that are consciously articulated either to encourage more physical activity or discourage sedentariness can constitute powerful intervention strategies to promote a more active lifestyle.

The WELL Building Standard® recognizes the physical activity-promoting policies and strategies that can be implemented in the built environment to encourage physical activity and reduce sedentariness, thus helping to combat obesity and other chronic diseases.

# INTENT

The WELL Building Standard for Fitness promotes the integration of physical activity into everyday life by providing the opportunities and support for an active lifestyle and discouraging sedentary behaviors.

### FITNESS FEATURE LEVEL MATRIX

	Core and Shell	New and Existing Interiors	New and Existing Buildings
64 INTERIOR FITNESS CIRCULATION			
1: Stair Accessibility and Promotion	Р	О	Р
2: Staircase Design	Р		
3: Facilitative Aesthetics	Р	0	Р
65 ACTIVITY INCENTIVE PROGRAMS			
1: Activity Incentive Programs	-	Р	Р
66 STRUCTURED FITNESS OPPORTUNITIE	S	_	
1: Fitness Programs	-	0	0
2: Fitness Education	-	0	
67 EXTERIOR ACTIVE DESIGN		_	
1: Pedestrian Amenities	0	0	0
2: Pedestrian Promotion	О		
3: Neighborhood Connectivity	0		
68 PHYSICAL ACTIVITY SPACES			
1: Site Space Designation for Offices	0	0	0
2: External Exercise Spaces	О		
69 ACTIVE TRANSPORTATION SUPPORT			
1: Bicycle Storage and Support	0	0	0
2: Post Commute and Workout Facilities	0		
70 FITNESS EQUIPMENT			
1: Cardiorespiratory Exercise Equipment	О	О	О
2: Muscle-strengthening Exercise Equipment	0		
71 ACTIVE FURNISHINGS			
1: Active Workstations	-	0	0
2: Prevalent Standing Desks	-	0	

#### INTERIOR FITNESS CIRCULATION

The integration of interior pathways and stairs within the built environment can provide a convenient way to incorporate short periods of physical activity into the workday, thus reducing sedentary tendencies. Stair climbing is a low-impact, moderate-to-vigorous intensity physical activity that burns calories and has been associated with improved cardiorespiratory fitness and a lower risk of stroke. To encourage greater use, pathways and stairs should be aesthetically pleasing and easily accessible from high-traffic routes.

Intent: To encourage intermittent bouts of physical activity and reduce sedentary behavior through accessible, safe, and visually appealing stairs, entryways, and corridors.



Cardiovascular Muscular Skeletal

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: STAIR ACCESSIBILITY AND PROMOTION

In projects of 2 to 4 floors, at least one common staircase meets the following requirements:

- a. Stairs are accessible to regular building occupants during all regular business hours.
- b. Throughout the space, wayfinding signage and point-of-decision prompts are present to encourage stair use (at least one sign per elevator bank).

#### **PART 2: STAIRCASE DESIGN**



- a. 27 Located within 7.5 m [25 ft] of the main project entrance, main entry check-point (e.g., welcome/reception desk), the edge of its main lobby, or edge of its main welcome area.
- b. Clearly visible from the main project entrance, main entry check-point (e.g., welcome/reception desk), the edge of its main lobby, or edge of its main welcome area, or are located visually before any elevators present upon entering from the main entrance.
- c. Stair width set at a minimum of 1.4 m [56 in] between handrails, or the maximum width allowable by local code.

#### **PART 3: FACILITATIVE AESTHETICS**




In projects of 2 to 4 floors, both common stairs and paths of frequent travel display elements of aesthetic appeal by incorporating at least 2 of the following throughout:

- a. 87 Artwork.
- b. 87 Music.
- c.  $^{27}$  Daylighting using windows or skylights of at least 1 m $^2$  [10.8 ft $^2$ ] in size.
- d. View windows to the outdoors or building interior.
- e. Light levels of at least 215 lux [20 fc] when in use.
- f. Biophilic elements.

#### **ACTIVITY INCENTIVE PROGRAMS**

The health benefits of physical activity are numerous, from reduced risk of chronic diseases such as cancer, cardiovascular disease and diabetes, to better mental health and increased quality of life. In addition, relatively small amounts of activity can lead to significant benefits: just 2.5 hours of moderate-intensity physical activity per week can reduce overall mortality risk by nearly 20%. Research shows that even small incentives can significantly influence individual decisions and behaviors towards physical activity. However, the effectiveness of varying types of incentives (e.g., monetary, non-monetary), their distribution schedule, their magnitude, and their relationship to specific types of activity engagement remain largely unknown. In addition, implementation of physical activity incentives for different populations and geographic regions adds an additional layer of complexity in prescribing and implementing effective incentive programs. Therefore, projects play a fundamental role in defining and creating incentive programs that are meaningful to their project population and aim to help develop and maintain regular exercise and physical activity behaviors.



Core and Shell New and Existing Interiors New and Existing Buildings

Intent: To promote active lifestyles through the provision of physical activity incentive programs.

#### **PART 1: ACTIVITY INCENTIVE PROGRAMS**


At least two of the following are implemented for all full-time employees:

- a. Tax-exempt payroll deductions relating to active transportation (e.g., a subsidy to purchase a personal bicycle) or mass transit (includes public transportation) use. Direct subsidies of an equivalent amount are also acceptable.
- b. Meaningful reimbursements or incentive payments (including non-monetary) offered for every 6-month period that an employee meets a 50-visit minimum to a gym or physical activity program.
- c. A meaningful subsidy offered at least yearly towards participation or membership costs for fitness activities such as races, group fitness classes, sports teams, fitness centers, training centers, gyms, or studios. Direct subsidies of an equivalent amount are also acceptable.
- d. A meaningful subsidy offered at least yearly towards the cost of an annual bicycle share membership
- e. No cost or discounted physical activity opportunities or memberships, in which it can be demonstrated that 30% of occupants have utilized on a regular basis (at least weekly) over the last six months.

### STRUCTURED FITNESS OPPORTUNITIES

Access to advice and training programs developed by experts can help individuals learn new fitness techniques and achieve physical health goals. Individuals with special considerations that require further guidance to ensure they engage in physical activity routines that are safe and appropriate for their level or particular disability can especially benefit from expert guidance. Training programs, depending on frequency and duration, can help increase aerobic fitness and muscle endurance, assist in weight loss, lower blood pressure and decrease worker absenteeism. Providing individuals with access to fitness services is an important step towards making exercise a part of a healthy work culture.

Intent: To promote safe and convenient exercise through access to onsite professional fitness training and education.



Cardiovascular Digestive

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
-		

#### **PART 1: FITNESS PROGRAMS**

The following is offered from a qualified professional at least once a month:

a. 84 Onsite fitness or training programs.

#### **PART 2: FITNESS EDUCATION**



- a. Different modes of exercise.
- b. Safe fitness techniques.
- c. Comprehensive exercise regimens.

#### **EXTERIOR ACTIVE DESIGN**

Greater land-use mix has been linked to higher physical activity levels and lower rates of obesity. In addition, the presence of retail shops, bus stops and offices within walking distance from residences is linked to a higher likelihood of walking and using transit. Similarly, integrating elements of active design into the building and site, and creating cyclist and pedestrian-friendly environments around the building can help incentivize physical activity. Providing facilities such as benches, drinking fountains and water bottle refilling stations along a building's walking routes can help support occupant activity throughout the day. Incorporating active design principles is particularly important for projects that are isolated from urban centers where automobile transportation predominates.

Intent: To promote active lifestyles through the integration of active design elements into the building exterior.



Cardiovascular Muscular Nervous Respiratory Skeletal

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: PEDESTRIAN AMENITIES**

Sites in which the building takes up less than 75% of the total lot size provide at least one of the following within highly-trafficked areas, such as building entrances, public transportation stops, walking paths and plazas:

- a. 87 A bench.
- b. 87 A cluster of movable chairs and tables.
- c. 87 A drinking fountain or water refilling station.

#### **PART 2: PEDESTRIAN PROMOTION**

To encourage more pedestrian activity, sites in which the building takes up less than 75% of the total lot size include at least two of the following in the outdoors:

- a. A water fountain or other water feature.
- b. A plaza or open air courtyard.
- c. A garden or other landscaped elements.
- d.<sup>87</sup> Public art.

#### PART 3: NEIGHBORHOOD CONNECTIVITY

To encourage neighborhood connectivity and daily activity, at least one of the following requirements is met:

- a. The building address has a Walk Score® of 70 or greater.
- b. At least four existing and publicly available diverse uses (listed in LEED BD+C: Surrounding Density and Diverse Uses, Appendix 1) are present within 800 m [0.5 mi] of the main building entrance.

#### PHYSICAL ACTIVITY SPACES

In the U.S., the presence of both indoor and outdoor physical activity facilities within a census-block group is associated with an increased likelihood of performing five or more bouts of moderate- to vigorous-intensity physical activity per week, and is linked to a lower risk of being overweight. In addition, buildings that contain an interior fitness space incentivize occupants to engage in regular exercise routines and allow a variety of exercise activities, including low-impact exercises like yoga or Pilates, or more intense activities such as aerobic and muscle-strengthening exercise.

Intent: To promote physical activity through complimentary access to on-site indoor and local outdoor physical activity spaces.



Cardiovascular Muscular Skeletal

Core New and New and and Existing Existing Buildings

#### PART 1: SITE SPACE DESIGNATION FOR OFFICES

Spaces with more than 10 regular occupants provide complimentary access to the following:

a. Bedicated exercise space that is at least 18.6 m<sup>2</sup> [200 ft<sup>2</sup>] plus 0.1 m<sup>2</sup> [1 ft<sup>2</sup>] per regular building occupant, up to a maximum of 370 m<sup>2</sup> [4,000 ft<sup>2</sup>].

#### **PART 2: EXTERNAL EXERCISE SPACES**

At least one of the following spaces is within 0.8 km [0.5 mi] walking distance of the main project entrance with complimentary access:

- a.  $^{87}$  A green space or park with playground features.
- b. A workout station or fitness zone.
- c. A trail network.
- d. An accessible body of water or public swimming pool.
- e. A gym, fitness or training center.
- f. A recreational field.

#### **ACTIVE TRANSPORTATION SUPPORT**

Active transportation is a cost-effective way to integrate physical activity into daily routines while reducing carbon footprint. Biking or walking to work has been associated with lower rates of diabetes, hypertension, overweight and obesity. Showers and changing rooms at work are preferred by the majority of employees as a support strategy for more physical activity. Therefore, providing amenities and facilities on-site can support the ability of occupants to engage in active commuting.

Intent: To promote daily physical activity through the provision of complimentary on-site support for active commuting.



Cardiovascular Nervous

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
О	О	О

#### PART 1: BICYCLE STORAGE AND SUPPORT

The following are provided onsite or within 200 m [650 ft] of the main project entrance:

- a. Basic bicycle maintenance tools, including tire pumps, patch kits and hex keys available for use.
- b. Separate and secure bicycle storage for at least 5% of regular building occupants, as well as short-term bicycle storage for at least 2.5% of all peak visitors.

#### PART 2: POST COMMUTE AND WORKOUT FACILITIES



The following are provided onsite or within 200 m [650 ft] of the main project entrance:

- a. One shower with changing facility for the first 100 regular building occupants and one additional shower for every 150 regular building occupants thereafter.
- b. One locker for every 5 regular building occupants, or evidence that the lockers provided exceed demand by at least 20%.

#### **FITNESS EQUIPMENT**

Convenient access to varied types of fitness equipment can make regular exercise habits easier to achieve. Aerobic and musclestrengthening activities each provide unique health benefits, including weight control, lower risk of cardiovascular disease, diabetes and cancer, better bone health, cardiorespiratory and muscular fitness, and improved cognitive function. Providing equipment that allows for a variety of exercise options can give occupants a wider range of health benefits.

Intent: To promote both cardiovascular and muscle-strengthening exercise by providing complimentary access to on-site fitness equipment.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
0	0	0

#### PART 1: CARDIORESPIRATORY EXERCISE EQUIPMENT

The following requirement is met:

a. <sup>27</sup> Projects provide some combination of cardiorespiratory exercise equipment in an interior fitness space free of charge, in a quantity that would allow use by at least 1% of regular building occupants and accompanied by instructions for safe use.

#### PART 2: MUSCLE-STRENGTHENING EXERCISE EQUIPMENT



The following requirement is met:

a. Projects provide some combination of muscle-strengthening exercise equipment in an interior fitness space free of charge, in a quantity that would allow use by at least 1% of regular building occupants and accompanied by instructions for safe use.

#### **ACTIVE FURNISHINGS**

Most individuals spend the majority of their time indoors in a seated position. Prolonged sitting is associated with a number of adverse health conditions, including an increased risk of cancer, weight gain, and greater fatigue and back discomfort. In addition, sitting burns 50 fewer calories per hour than standing, and sitting for more than 3 hours per day is associated with a 2-year lower life expectancy. Unfortunately, regular exercise does not appear to negate the health consequences of long periods of sitting. Therefore, creating opportunities that mitigate prolonged sitting, while sustaining work productivity is essential to reduce sitting time during the workday.

Intent: To reduce sedentary behavior by making active workstations readily available to occupants.



Cardiovascular Muscular Skeletal

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: ACTIVE WORKSTATIONS**

Some combination of the following is required for 3% or more of employees (minimum one), and are available for any employee to reserve or use:

- a. Treadmill desks.
- b. Bicycle desks.
- c. Portable desk pedal or stepper machine.

#### PART 2: PREVALENT STANDING DESKS

At least 60% of workstations feature one of the following:

- a. Adjustable height standing desk.
- b. Standard desk with desk-top height adjustment stand.
- c. Pairs of fixed-height desks of standing and seated heights (which need not be located adjacent to each other).

# COMFORT

## **BACKGROUND**

The indoor environment should be a place of comfort. In pursuit of that vision, the WELL Building Standard® focuses on significantly reducing the most common sources of physiological disruption, distraction and irritation and on enhancing acoustic, ergonomic, olfactory and thermal comfort to prevent stress and injury and facilitate comfort, productivity and well-being.

Built environments can harbor sounds that are distracting and disruptive to work or relaxation. Employee surveys show that acoustic problems are a leading source of dissatisfaction within the environmental conditions of an office. As acoustic comfort is determined in part by the physical properties and contents of environments, the WELL Building Standard aims to shape spaces to mitigate unwanted indoor noise levels and reduce exterior noise intrusion in order to enhance social interaction, learning, satisfaction and productivity. While noise is ubiquitous, we are able to adopt policies, technologies and practices that ensure quieter acoustical environments and minimize our exposure to harmful and unnecessary sound.

In addition to acoustic comfort, ergonomics and universal design play a significant role in mitigating physical and mental stress. Most of the adverse health effects related to ergonomics are seen in the musculoskeletal and nervous systems of the human body. Musculoskeletal disorders (MSDs), including low back pain, neck pain, osteoarthritis and others are extremely common in nearly all populations. Low back pain affects about 31 million Americans, and 380,600 days of work were missed in 2013 because of musculoskeletal disorders, accounting for one third of the total number of days away from work. The statistics are similar worldwide and in 2010, nearly 7% (more than 169 million) of all disability-adjusted life years (DALYs) resulted from musculoskeletal disorders. The WELL Building Standard promotes comprehensive ergonomics solutions that help prevent stress and injury and facilitate comfort and well-being. These design strategies not only provide access for people with limited mobility, but also prevent injury by encouraging navigable spaces for everyone.

Thermal comfort is another factor that plays a large role in the way we experience places where we live and work. In 2006, only 11% of the office buildings surveyed in the U.S. provided thermal environments that met generally accepted goals of occupant satisfaction. Six primary personal and environmental variables contribute to an occupant's thermal comfort: air speed, dry bulb temperature, radiant temperature, humidity, metabolic rate and clothing or other insulation, all of which interact to create a subjective, individualized response. Finally, in addition to the measurable metrics, there are also psychological parameters such as individual expectations that may also affect thermal comfort. This makes thermal comfort subjective, meaning that not everyone will be equally comfortable under the same conditions. The WELL Building Standard takes a holistic approach to thermal comfort and provides a combination of strategies to address occupant issues.

# INTENT

The WELL Building Standard for Comfort establishes requirements designed to create distraction-free, productive and comfortable indoor environments.


## **COMFORT FEATURE LEVEL MATRIX**

	Core and Shell	New and Existing Interiors	New and Existing Buildings
72 ACCESSIBLE DESIGN			
1: Accessibility and Usability	Р	Р	Р
73 ERGONOMICS: VISUAL AND PHYSICA	L		
1: Visual Ergonomics	-	Р	Р
2: Desk Height Flexibility	-	Р	
3: Seat Flexibility	-	Р	Р
74 EXTERIOR NOISE INTRUSION			
1: Sound Pressure Level	Р	О	Р
75 INTERNALLY GENERATED NOISE			_
1: Acoustic Planning	-	Р	Р
2: Mechanical Equipment Sound Levels	О	Р	
76 THERMAL COMFORT			
1: Ventilated Thermal Environment	Р	Р	Р
2: Natural Thermal Adaptation	Р	Р	Р
77 OLFACTORY COMFORT			
1: Source Separation	-	О	О
78 REVERBERATION TIME			
1: Reverberation Time	-	О	О
79 SOUND MASKING			
1: Sound Masking Use	-	О	0
2: Sound Masking Limits	-	О	
30 SOUND REDUCING SURFACES			
1: Ceilings	-	О	О
2: Vertical Surfaces	-	О	0
31 SOUND BARRIERS			
1: Wall Construction Specifications	-	О	О
2: Doorway Specifications	-	0	
3: Wall Construction Methodology	-	О	О
32 INDIVIDUAL THERMAL CONTROL			
1: Free Address	-	О	0
2: Personal Thermal Comfort Devices	-	О	0
33 RADIANT THERMAL COMFORT			
1: Lobbies and Other Common Spaces	0	-	0
2: Offices and Other Regularly Occupied Spaces	-	O	

### **ACCESSIBLE DESIGN**

Ensuring that individuals with physical disabilities have access and mobility is an important aspect of an equitable building environment.

Intent: To promote equity by providing buildings that are accessible and usable by people of all physical abilities.



#### PART 1: ACCESSIBILITY AND USABILITY


The project demonstrates compliance with one of the following:

- a. 89 Current ADA Standards for Accessible Design or comparable local code or standards.
- b. 42 ISO 21542:2011 Building Construction Accessibility and Usability of the Built Environment.

#### **ERGONOMICS: VISUAL AND PHYSICAL**

Overuse of the same muscles and ligaments while trying to adjust to static furniture or equipment over time can cause discomfort and strain the body, especially in occupational environments that require repetitive tasks. Under such conditions, the effects of even slight visual or physical discomfort are compounded, leading to decreased occupant comfort and focus.

Intent: To reduce physical strain and maximize ergonomic comfort and safety.



Shell

Interiors

Buildinas

#### **PART 1: VISUAL ERGONOMICS**

The following requirement is met:

All computer screens, including laptops, are adjustable in terms of height and distance from the user.

#### PART 2: DESK HEIGHT FLEXIBILITY



- a. Adjustable height sit-stand desks.
- b. Desk-top height adjustment stands.
- Pairs of fixed-height desks of standing and seated heights (which need not be located adjacent to C. each other).

#### **PART 3: SEAT FLEXIBILITY**


Occupant furnishings are adjustable in the following ways:

- a.  $^{178}$  Workstation chair height adjustability is compliant with the HFES 100 standard or BIFMA G1 quidelines.
- Workstation seat depth adjustability is compliant with the HFES 100 standard or BIFMA G1 guidelines.

#### **EXTERIOR NOISE INTRUSION**

Particularly in urban areas, loud or repetitive exterior noises can be a source of stress and a risk factor for certain health outcomes. Studies show that individuals exposed to traffic noise have a higher risk for diabetes, stroke and heart attack, and those exposed to road traffic and aircraft noises have a higher risk for hypertension. In addition, exposure to noise can lead to reduced reaction time and increased levels of annoyance. Preventing excessive exterior noise from reaching building interiors can help improve occupant comfort and well-being.

Intent: To reduce acoustic disruptions by limiting external noise intrusion.



#### **PART 1: SOUND PRESSURE LEVEL**


Each regularly occupied space meets the following sound pressure level as measured when the space and adjacent spaces are unoccupied, but within 1 hour of normal business hours:

a. Average sound pressure level from outside noise intrusion does not exceed 50 dBA.

#### **INTERNALLY GENERATED NOISE**

Electronics, HVAC systems, mechanical equipment and other noiseemitting office devices, as well as occupants themselves, can be sources of indoor noise. As offices and workspaces are increasingly designed to promote employee interaction, occupants can experience decreased levels of privacy and acoustic comfort, especially when users with different job types share a space. Office noise can lead to decreased productivity, especially in open-plan offices where aural distractions and interruptions from other employees are frequent. Additionally, studies show that exposure to noise generated within the building can lead to reduced concentration and mental arithmetic performance, and increased distraction due to reduced speech privacy.

Intent: To reduce acoustic disruptions from internal noise sources and increase speech privacy:



Cardiovascular Endocrine Nervous

Core and Shell New and Existing Interiors

New and Existing Buildinas

#### PART 1: ACOUSTIC PLANNING

An acoustic plan is developed that identifies the following spaces and potential sources of disruption:

- Loud and quiet zones.
- b. Noisy equipment in the space.

#### PART 2: MECHANICAL EQUIPMENT SOUND LEVELS



The mechanical equipment system meets the following requirements once interior build-out is complete in the following spaces:

- a. 90 Open office spaces and lobbies that are regularly occupied and/or contain workstations: maximum noise criteria (NC) of 40.
- Enclosed offices: maximum noise criteria (NC) of 35. b. 1
- Conference rooms and breakout rooms: maximum noise criteria (NC) of 30 (25 recommended). C.

#### THERMAL COMFORT

Thermal comfort in the body is provided through homeothermy, the balancing of heat gains and losses to maintain the body's core temperature within its narrow range, 36-38 °C [97-100 °F], and regulated by the hypothalamus. Thermal comfort can affect mood, performance and productivity. However, temperature preferences are highly personal and differ from one individual to another. Balancing the energy requirements of large buildings with the varied occupant preferences can thus be challenging.

Intent: To promote occupant productivity and ensure a sufficient level of thermal comfort.



Immune Integumentary Nervous Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: VENTILATED THERMAL ENVIRONMENT

All occupiable spaces in mechanically-conditioned projects (including circulation areas) meet the design, operating and performance criteria:

a.<sup>92</sup> ASHRAE Standard 55-2013 Section 5.3, Standard Comfort Zone Compliance.

#### PART 2: NATURAL THERMAL ADAPTATION



a. 92 ASHRAE Standard 55-2013 Section 5.4, Adaptive Comfort Model.

#### **OLFACTORY COMFORT**

Excessively strong or distinct odors can disrupt physical and psychological comfort, and even trigger eye, nose and throat irritation, nausea and headaches. Limiting these odors is a simple strategy that can greatly contribute to occupant comfort and well-being.

Intent: To maximize olfactory comfort by reducing the transmission of strong smells and odors within the building.



Digestive
Endocrine
Immune
Integumentary
Nervous
Respiratory

Core New and and Existing Shell Interiors

New and Existing Buildings

#### **PART 1: SOURCE SEPARATION**


All restrooms, janitorial closets, kitchens, cafeterias and pantries prevent strong odors from migrating to workspaces through one or more of the following separation methods:

- a. Negative pressurization.
- b. Self-closing doors.
- c. Hallways, vestibules or other intermediate areas.

#### **REVERBERATION TIME**

Reverberation time, or RT60, is a metric which describes the length of time taken for a sound to decay by 60 dB from its original level. Optimal reverberation times vary depending on room volume, intended use of the space and the frequency of transmitted sound. In spaces with high reverberation times, the sounds of voices and footsteps take longer to dissipate, contributing to higher levels of ambient noise. The noise produced by reverberation can decrease speech intelligibility and in some situations cause additional stress. This performance specification can be met through the use of soundabsorbing materials on various surface and design elements.

Intent: To help maintain comfortable sound levels by limiting reverberation times.



Cardiovascular Endocrine Nervous

Core New and New and and Existing Existing Buildings

#### **PART 1: REVERBERATION TIME**


The following spaces have maximum reverberation time (RT60) as described:

- a. Conference rooms: 0.6 seconds.
- b. Open workspaces: 0.5 seconds.

#### **SOUND MASKING**

Ambient silence can be just as distracting as a loud environment as it highlights acoustical disturbances and decreases speech privacy. Overhearing private conversations is reported as a specific cause of employee acoustic dissatisfaction in open offices. Sound masking systems supply a low level of background noise to provide workers with a degree of confidentiality in their communications and can decrease distraction associated with aural interruptions.

Intent: To reduce acoustic disruptions and increase speech privacy by implementing sound masking into the building design.



Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: SOUND MASKING USE**

All open workspaces use the following:

a. 90 Sound masking systems.

#### **PART 2: SOUND MASKING LIMITS**


If sound masking systems are used, sound levels fall within the following range, when measured from the nearest workspace:

- a. Open workspaces: 45 48 dBA.
- b. Enclosed offices: 40 42 dBA.

#### **SOUND REDUCING SURFACES**

Proper design and construction are not always enough to achieve acoustic comfort in buildings. Sources that contribute to acoustic dissatisfaction such as sound transmission from internal and external sources, footfall noise and voices from adjacent spaces are difficult to control. However, sound reduction treatments that incorporate absorptive surfaces, such as wall panels, ceiling baffles and surface enhancements can help with reverberation management and improve acoustic comfort. The noise reduction coefficient (NRC) of a material is an average value that determines its absorptive properties. The larger the NRC value, the better the material is at absorbing sound under standardized conditions.

Intent: To reduce sound reverberation and maintain comfortable sound levels though absorptive ceiling and vertical surfaces.



Cardiovascular Endocrine Nervous

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: CEILINGS**

The following spaces, if present, have ceilings that meet the specifications described:

- Open workspaces: minimum NRC of 0.9 for the entire surface area of the ceiling (excluding lights, skylights, diffusers, beams, joists and grilles).
- b. Conference and teleconference rooms: minimum NRC of 0.8 on at least 50% of the surface area of the ceiling (excluding lights, skylights, diffusers, beams, joists and grilles).

#### **PART 2: VERTICAL SURFACES**




- a. <sup>90</sup> Enclosed offices, conference and teleconference rooms: minimum NRC of 0.8 on at least 25% of the surface area of interior surrounding walls.
- b. Open workspaces: minimum NRC of 0.8 on at least 25% of the surface area of the surrounding walls
- e. Partitioned office spaces: partitions reach at least 1.2 m [48 inches] and have a minimum NRC of 0.8.

#### **SOUND BARRIERS**

Noise from adjacent spaces can be disturbing to building occupants. Careful detailing and high quality construction materials can greatly improve the sound reducing abilities of interior partitions or doors that act as sound barriers and reduce sound transmission between adjacent spaces.

Intent: To reduce sound transmission and acoustic disruptions through sound barriers.




Core and Shell New and Existing Interiors New and Existing Buildings

#### PART 1: WALL CONSTRUCTION SPECIFICATIONS

The following spaces, if present, have interior partition walls that meet the Sound Transmission Class (STC) described:

- a.  $^{90}$  Enclosed offices: minimum STC of 40 when a sound masking system is present, or minimum STC of 45 when no sound masking system is used.
- b. Onference rooms and teleconference rooms: minimum STC of 53 on walls adjoining private offices, conference rooms or other teleconference rooms.

#### **PART 2: DOORWAY SPECIFICATIONS**



- a. 90 Gaskets.
- b. 90 Sweeps.
- c. Non-hollow core.

#### PART 3: WALL CONSTRUCTION METHODOLOGY



- a.  $^{90}$  Properly sealing all acoustically rated partitions at the top and bottom tracks.
- b. Staggering all gypsum board seams.
- c. To Packing and sealing all penetrations through the wall.

#### INDIVIDUAL THERMAL CONTROL

Thermal comfort preferences are highly individual, and can be affected by metabolism, body type and clothing. These factors make it nearly impossible to find a temperature that will satisfy all occupants in the same space at the same time. Providing areas with different thermal gradients, as well as individual thermal comfort devices can ensure that building occupants can choose areas with temperatures that best fit their thermal preferences (termed "free address").

Intent: To maximize and personalize thermal comfort among all occupants.



Immune Integumentary Nervous Respiratory

Core New and New and and Existing Existing Shell Interiors Buildings

#### **PART 1: FREE ADDRESS**

Projects over 200 m<sup>2</sup> [2,150 ft<sup>2</sup>] meet the following free address requirement:

- a. The building provides a thermal gradient of at least 3 °C [5 °F] across open workspaces and between floors or rooms with more than 10 people.
- b. All open office spaces with occupants performing tasks that require similar workstations allow for at least 50% free address to allow occupants to select a work space with a desired temperature.

#### PART 2: PERSONAL THERMAL COMFORT DEVICES



a. Occupants have access to personal thermal comfort devices such as fans (excluding space heaters).

#### RADIANT THERMAL COMFORT

New technology surrounding radiant temperature systems has led to recent advances making the systems more energy efficient. Additional benefits include saved floor space, lower dust transportation and increased thermal comfort through the separation of temperature controls and outdoor air supply systems. In addition, with the use of radiant heating, the mean radiant temperature in a space can be kept lower compared to convective heating, providing the benefit of a slightly higher relative humidity in winter time.

Intent: To maximize floor space, reduce dust transmission and increase thermal comfort by incorporating radiant heat and cooling systems into the building design.



Immune Integumentary Nervous Respiratory

Core New and Existing Existing Shell Interiors Buildings

#### PART 1: LOBBIES AND OTHER COMMON SPACES

All lobbies and other common spaces meet the requirements set forth in ASHRAE Standard 55-2013 for thermal comfort through the use of one of the following systems:

- a. 93 Hydronic radiant heating and/or cooling systems.
- b. 93 Electric radiant systems.

#### PART 2: OFFICES AND OTHER REGULARLY OCCUPIED SPACES



- a. Hydronic radiant heating and/or cooling systems.
- b. Electric radiant systems.

# MIND

## BACKGROUND

While mental and physical health are often conceptualized as separate domains, our minds and bodies are inextricably connected. For instance, exercise increases the release of serotonin, which can elevate mood and regulate the sleep cycle. The simple act of worrying, on the other hand, can trigger physiological responses similar to the way physical stress and injury can. While the body has a remarkable capacity for recovering from a single acute stressor, chronic, repeated activation of the stress response can be especially damaging both physiologically and psychologically. Because humans have the capacity to worry about abstract and often non-immediately resolvable problems such as loss, career, finance issues and self-esteem, modern life can be wrought with stressors that lead to low mood, depression and a negative sense of self.

The global burden of mental health illnesses is significant. In 2010, mental illnesses and substance use disorders accounted for nearly 184 million disability-adjusted life years (DALYs), 8.6 million years of life lost to premature mortality (YLL) and over 175 million years lived with disability (YLD) worldwide. Furthermore, it is estimated that the life expectancy among those with mental illness is more than 10 years shorter compared to those without mental illnesses, and that more than 14%, or 8 million deaths each year are attributable to mental disorders.

The lifetime prevalence of mood disorders in the U.S. (classified as the presence of a major depressive disorder, dysthymic disorder or bipolar disorder) is estimated at nearly 21%. Major depression is one of the most common of all mood disorders, affecting about 16 million adults in the U.S. Mood disorders are inevitably linked to physical illness and are associated with a range of detrimental health outcomes. Chronic low level disturbances or mental distress play increasingly important roles in some of the most common chronic diseases. For example, depression is associated with a higher risk of heart disease and immunosuppression. Chronic stress and anxiety are also directly responsible for stress hormones associated with a variety of negative physiological outcomes, including increased risk of metabolic syndrome, cardiovascular disease, gastrointestinal disorders and skin conditions such as acne and psoriasis.

Because the mind plays a vital role in an individual's overall health and well-being, an atmosphere that supports a healthy mental state can have significant psychological and physical benefits. Interventions to mediate stress can either be direct or indirect. This includes providing access to therapies that help promote relaxation and address mental or emotional trauma, instituting policies that improve sleep hygiene or encourage altruism and community engagement, and promoting the use of sensor technologies that increase awareness of physiological and environmental factors to inform positive behavioral changes.

The WELL Building Standard® recognizes the features of the built environment and identifies workplace policies that can be implemented to positively impact mood, sleep, stress levels and psychosocial status in order to promote and enable overall occupant health and well-being.

# **INTENT**

The WELL Building Standard for Mind requires design, technology and treatment strategies designed to provide a physical environment that optimizes cognitive and emotional health.

## MIND FEATURE LEVEL MATRIX

	Core and Shell	New and Existing Interiors	New and Existing Buildings
84 HEALTH AND WELLNESS AWARENESS			
1: WELL Building Standard® Guide	Р	Р	Р
2: Health and Wellness Library	Р		
85 INTEGRATIVE DESIGN			
1: Stakeholder Charrette	Р	Р	Р
2: Development Plan	Р		
3: Stakeholder Orientation	Р		
86 POST-OCCUPANCY SURVEYS			
1: Occupant Survey Content	-	Р	Р
2: Information Reporting	-	Р	
87 BEAUTY AND DESIGN I			
1: Beauty and Mindful Design	Р	Р	Р
88 BIOPHILIA I - QUALITATIVE			
1: Nature Incorporation	О	Р	Р
2: Pattern Incorporation	О		
3: Nature Interaction	0	-	Р
89 ADAPTABLE SPACES			
1: Stimuli Management	-	О	О
2: Privacy	-	0	
3: Space Management	-	0	
4: Workplace Sleep Support	-	О	0
90 HEALTHY SLEEP POLICY			
1: Non-Workplace Sleep Support	-	0	
91 BUSINESS TRAVEL			
1: Travel Policy	-	О	О
92 BUILDING HEALTH POLICY			
1: Health Benefits	-	0	0
93 WORKPLACE FAMILY SUPPORT			
1: Parental Leave	-	0	0
2: Employer Supported Child Care	-	0	
3: Family Support	-	0	
94 SELF-MONITORING			
1: Sensors and Wearables	-	0	0

Core and Shell New and Existing Interiors Building  95 STRESS AND ADDICTION TREATMENT  1: Mind and Behavior Support 2: Stress Management - 0 0 0  96 ALTRUISM  1: Charitable Activities - 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
1: Mind and Behavior Support       -       O         2: Stress Management       -       O         96 ALTRUISM         1: Charitable Activities       -       O	
2: Stress Management - O O  96 ALTRUISM  1: Charitable Activities - O O	
96 ALTRUISM  1: Charitable Activities - O	
1: Charitable Activities - O	
2: Charitable Contributions - O	
97 MATERIAL TRANSPARENCY	
1: Material Information O O	
2: Accessible Information	
98 ORGANIZATIONAL TRANSPARENCY	
1: Transparency Program Participation - O	
99 BEAUTY AND DESIGN II	
1: Ceiling Height O O	
2: Artwork O O	
3: Spatial Familiarity O O	
100 BIOPHILIA II - QUANTITATIVE	
1: Outdoor Biophilia O O	
2: Indoor Biophilia - O	
3: Water Feature O O O	

#### **HEALTH AND WELLNESS AWARENESS**

Health literacy, defined by the National Academy of Medicine as "the degree to which individuals can obtain, process, and understand the basic health information and services they need to make appropriate health decisions", is essential for optimal health and well-being. Literacy requires awareness and an ability to decipher health literature and options for health services. Both accessibility and customizability of health-oriented literature are necessary to promote increased health awareness and well-being.

Intent: To promote a deeper understanding of factors that impact health and wellness.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings

#### PART 1: WELL BUILDING STANDARD® GUIDE

Explanatory guides allow occupants to familiarize themselves with and benefit from features that are incorporated into the project, as well as gain a broader understanding of health and wellness factors beyond the built environment. The following is provided:

a. A guide (available to all occupants) describing the WELL Building Standard features pursued by the project.

#### PART 2: HEALTH AND WELLNESS LIBRARY

A digital and/or physical library of resources is provided that focuses on mental and physical health and meets the following criteria:

- a. Contains at least one book title or one magazine subscription for every 20 occupants (no more than 20 titles are required).
- b. Is prominently displayed and readily available to all occupants.

#### **INTEGRATIVE DESIGN**

A truly collaborative design process ensures that construction and upkeep of a space follows the original expectations and goals for the building. A focus on health and wellness principles throughout the design process guarantees that health-promoting criteria are well understood and integrated into a project.

Intent: To facilitate a collaborative development process and ensure adherence to collective wellness goals.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings

#### **PART 1: STAKEHOLDER CHARRETTE**

Project stakeholders, including at a minimum the owner, architects, engineers and facilities management team, meet to:

- a. Perform a values assessment and alignment exercise within the team to inform any project goals as well as strategies to meet occupant expectations.
- b. Discuss the needs of the occupants, focusing on wellness.
- c. Set future meetings to stay focused on the project goals and to engage future stakeholders who join the process after the initial meeting, such as contractors and sub-contractors.

#### **PART 2: DEVELOPMENT PLAN**

A written document detailing the building's health-oriented mission is produced with the consent of all stakeholders, incorporating all of the following:

- a. Building site selection, taking into account public transportation.
- b. WELL concepts of air, water, nourishment, light, fitness, comfort and mind.
- c. Plans for implementation of the above analyses and decisions.
- d. Operations and maintenance plans for facility managers and building policy requirements related to wellness.

#### PART 3: STAKEHOLDER ORIENTATION



Upon construction completion, the designers, owners, managers and facilities staff must:

- a. Tour the building as a group.
- b. Discuss how building operations will support adherence to the WELL Building Standard.

#### **POST-OCCUPANCY SURVEYS**

Given the diversity of built environments, it is difficult to prescribe a comprehensive set of features that are effective across all settings. Occupancy surveys can be useful in measuring the extent to which a building is effectively promoting and protecting the health and comfort needs of its occupants. In addition, the ability to offer feedback and have a recognized stake in one's comfort and well-being can have a positive impact on occupant mood.

Intent: To allow occupants to provide feedback to building owners and management, and help further develop the WELL Building Standard.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings

#### PART 1: OCCUPANT SURVEY CONTENT

In buildings with 10 or more occupants, the Occupant Indoor Environmental Quality (IEQ) Survey™ from the Center for the Built Environment at UC Berkeley (or approved alternative) is completed by a representative sample of at least 30% of occupants at least once per year. The survey covers the following topics of occupant satisfaction:

- a. 35 Acoustics.
- b. Thermal comfort, including humidity and air flow, at least twice a year (once during the cooling season and once during the heating season).
- c. 35 Furnishings.
- d. 35 Workspace light levels and quality.
- e. 35 Odors, stuffiness and other air quality concerns.
- f. 35 Cleanliness and maintenance.
- g. 35 Layout.

#### PART 2: INFORMATION REPORTING


Aggregate results from surveys are reported within 30 days to the following groups:

- a. Building owners and managers.
- b. Building occupants (upon request).
- c. The International WELL Building Institute.

#### **BEAUTY AND DESIGN I**

A physical space in which design principles align with an organization's core cultural values can positively impact employees' mood and morale. Integrating aesthetically pleasing elements into a space can help building occupants derive a measure of comfort or joy from their surroundings. The incorporation of design elements and artwork to a space can create a calming environment able to improve occupant mood.

Intent: To thoughtfully create unique and culturally-rich spaces.



Nervous

#### PART 1: BEAUTY AND MINDFUL DESIGN


The project contains features intended for all of the following:

- a. <sup>13</sup> Human delight.
- b. 13 Celebration of culture.
- c. 13 Celebration of spirit.
- d. 13 Celebration of place.
- e. Meaningful integration of public art.

# **BIOPHILIA I - QUALITATIVE**

Until relatively recently in human history, people had constant interaction with living things and their natural surroundings. Biophilia, or the idea that humans have an affinity towards the natural world, is an emerging field that aims to address our psychological need to be around life and life-like processes. Exposure to views and images of nature can help to speed up healing and recovery time, boost positive feelings and reduce negative ones. Interior environments that are cold, sterile and devoid of life, on the other hand, can diminish our experience, mood and happiness. Modeled after the Living Building Challenge, the biophilia requirements involve conducting historical, cultural, ecological and climatic studies to inform biophilic elements and creating a biophilic framework that tracks biophilia at each design phase of the project.

Intent: To nurture the innate human-nature connection within the project.



Core New and And Existing Existing Shell Interiors Buildings

#### **PART 1: NATURE INCORPORATION**

A biophilia plan is developed that includes a description of how the project incorporates nature through the following:

- a. 13 Environmental elements.
- b. 13 Lighting.
- c. Space layout.

#### **PART 2: PATTERN INCORPORATION**

A biophilia plan is developed that includes a description of how the project incorporates the following:

a. 13 Nature's patterns throughout the design.

# **PART 3: NATURE INTERACTION**


A biophilia plan is developed that provides sufficient opportunities for human-nature interactions:

- a. 13 Within the building.
- b. 13 Within the project boundary, external to the building.

# **ADAPTABLE SPACES**

Healthy work environments should be designed to mitigate stress and optimize productivity, and should therefore be sufficiently adaptable to working, focusing, collaborating and resting as needed. Research demonstrates that the presence of a variety of workspaces that enable individuals to adjust their environments and choose the degrees of engagement is associated with job satisfaction and group cohesiveness.

Intent: To reduce distractions, mitigate stress and enable focused work by integrating a stimuli management program within the building.



Cardiovascular Immune

Core New and New and and Existing Existing Buildings

#### PART 1: STIMULI MANAGEMENT

Seating and spatial layouts are organized into separate workplace zones and provide differing degrees of sensory engagement. Regularly occupied spaces of 186 m² [2,000 ft²] or larger provide documentation of methods used to establish appropriate zones based on the below guidelines:

- a. A programing plan is developed, using data from interviews, surveys, focus groups and observational research, to establish the organization's culture, work patterns, work processes and space utilization.
- b. Annotated floor plans incorporate research data to establish work zones that support a variety of work functions.
- c. Designated quiet zones are provided as enclosable or semi-enclosable rooms with no more than 3 seats per room.
- d. Designated collaboration zones are provided as enclosable or semi-enclosable rooms with no less than 3 seats and at minimum one visual vertical surface area for communicating ideas or work.

# **PART 2: PRIVACY**



- a. Space is at minimum 7 m<sup>2</sup> [75 ft<sup>2</sup>] plus 0.1 m<sup>2</sup> [1 ft<sup>2</sup>] per regular building occupant, up to a maximum of 74 m<sup>2</sup> [800 ft<sup>2</sup>].
- b. Ambient lighting provides continuously dimmable light levels at 2,700 K or less.
- c. Noise Criteria (NC) from mechanical systems is 30 or lower.
- d. A plan is developed that includes a description of how the project incorporates two of the following elements into the space: (i) plant wall and/or floor plantings, (ii) audio device with nature sounds, (iii) variety of seating arrangements.

## **PART 3: SPACE MANAGEMENT**

- 0 0

To minimize clutter and maintain a comfortable, well-organized environment, minimal storage requirements are addressed through the provision of some combination of the following:

- a. A workstation cabinet at a minimum volume of 0.1 m³ [4 ft³] for each regular occupant.
- b. A personal locker at a minimum volume of 0.1 m³ [4 ft³] for each regular occupant.

# **PART 4: WORKPLACE SLEEP SUPPORT**



Short naps are an effective and healthy means for improving mental and physical acuity, even more so than caffeine, which can disrupt sleep. At least one of the following furniture options must be provided for the first 30 regular building occupants and an additional one for every 100 regular building occupants thereafter:

- a. Couch.
- b. Cushioned roll-out mat.
- c. Sleep pod.
- d. Fully reclining chair.
- e. Hammock.

# **HEALTHY SLEEP POLICY**

High quality sleep is essential to good health. Adequate sleep improves mental health, is necessary for maintaining sustained mental and physical performance throughout the day and can help prevent unhealthy weight gain. Insufficient sleep, on the other hand, has been associated with a higher risk of depression, diabetes, heart attack, hypertension and stroke. Adopting this feature demonstrates that the organization values sleep quality and understands its impact on overall worker productivity and well-being.

Intent: To support healthy sleep habits by discouraging occupants from working late at night and providing them with sleep support software.



Cardiovascular Endocrine Immune Muscular

Core New and New and and Existing Existing Shell Interiors Buildings

#### PART 1: NON-WORKPLACE SLEEP SUPPORT


The following requirements are met:

- a. For non-shift work, introduce organizational cap at midnight for late night work and communications.
- b. Provide employees with a 50% subsidy on software and/or applications that monitor daytime sleep-related behavior patterns such as activity levels, caffeine and alcohol intake, and eating habits.

# **BUSINESS TRAVEL**

Business travel is often associated with a number of negative health outcomes. Research from the World Bank indicates that business travel is associated with higher total medical claim costs, with the highest increase attributed to psychological disorders related to stress. Additionally, findings indicate that the main stressors of business travel are impacts on family and personal life, jetlag, increased workload upon return and isolation from family and friends.

Intent: To minimize disruptions to occupants' sleep and fitness regimens, and personal relationships by adopting supportive travel policies.



Cardiovascular Nervous

Core New and New and and Existing Existing Buildings

### **PART 1: TRAVEL POLICY**


In order to reduce stress related to business travel, employers promote the following policies:

- a. Employees are provided the option to select non red-eye flights or are given the option to work remotely on the day of arrival from a red-eye flight.
- b. Employees are not required to take business trips for which the total travel time (including layovers, wait times and travel to and from terminals) exceeds both 5 hours and 25% of the total trip duration.
- c.<sup>119</sup> During long business trips (domestic travel lasting more than 2 weeks and international travel lasting more than 4 weeks), employees are given the time off and a budget to fly home for at least 48 hours or to fly a friend or family member to meet them.
- d. 119 Employees are booked at hotels with free fitness centers or reimbursed for any gym usage fees incurred during their travel.

# **BUILDING HEALTH POLICY**

Protecting employee health is of the utmost importance since it impacts various aspects of work including productivity, concentration and even the health of coworkers. Employees often feel overwhelmed and unable to take appropriate rest or time away from work to recover. Workplace health policies can help support employees' physical and mental well-being, make adopting and maintaining healthy behaviors easier and create and foster a company culture promoting good health.

Intent: To protect the overall health and well-being of occupants and their families by adopting comprehensive health policies.



### **PART 1: HEALTH BENEFITS**

Employers provide at least three of the following to employees:

- a. Employer-based health insurance for part- and full-time workers, as well as their spouses and dependents, or subsidies to purchase individual insurance through an exchange.
- b. 184 Flexible spending accounts or any other employer-established benefit plan designed to reimburse employees for qualified medical expenses.
- c. 184 Health savings accounts.
- d. On-site immunizations or time off during the workday to receive immunizations.
- e. Workplace policies that encourage ill employees to stay home or work remotely.

# **WORKPLACE FAMILY SUPPORT**

Work-life balance can often be overlooked and personal lives neglected to work responsibilities. Family care policies ensure that employees are able to take the necessary time off for self-care and balance their work and personal lives in a healthy manner. Research shows that employees with extensive time-flexible policies report lower stress levels.

Intent: To ensure occupants are able to properly care for themselves and their families by adopting supportive family care policies.



Digestive Endocrine Immune Respiratory

Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
-	0	

### **PART 1: PARENTAL LEAVE**

Employers provide the following:

- a.<sup>98</sup> Paid paternity and maternity leave for 6 workweeks during any 12-month period.
- b. 46 Additional 12 workweeks of paternity or maternity leave during any 12-month period.

# PART 2: EMPLOYER SUPPORTED CHILD CARE

Employers provide at least one of the following:

- a. 66 On-site child care centers compliant with local child care licensure.
- b. Subsidies or vouchers for child care.

# **PART 3: FAMILY SUPPORT**


Employers provide the following:

- a. 40 At least 12 workweeks of leave during any 12-month period for the care of a seriously ill child, spouse, domestic partner, parent, parent-in-law, grandparent, grandchild or sibling.
- b. The option to use paid sick time for the care of a child, spouse, domestic partner, parent, parent-in-law, grandparent, grandchild or sibling.
- c. 51 All nursing mothers with break times of at least 15 minutes, every 3 hours.

# **SELF-MONITORING**

Self-monitoring devices that accurately observe and quantify changes to the body over time show promise in promoting awareness of one's health status. These technologies can provide a powerful tool for gaining personal insight into the physiological states of the body, thereby encouraging positive behavioral and lifestyle changes. Monitoring food intake, weight and physical activity is a proven behavior therapy technique that can aid in weight loss and weight maintenance programs, promoting improved health and well-being.

Intent: To promote awareness of individual biomarkers associated with health and wellness.



Cardiovascular

Core New and New and and Existing Existing Shell Interiors Buildings

### **PART 1: SENSORS AND WEARABLES**


A sensor capable of measuring at least 2 of the following parameters is made available to each employee for his/her personal use and is subsidized by at least 50%:

- a. 94 Body weight/mass.
- b. 62 Activity and steps.
- c. Heart rate variability.
- d. Sleep duration, quality and regularity.

# STRESS AND ADDICTION TREATMENT

Chronic stress adversely impacts the body, from the nervous to the cardiovascular system. Substance addiction is one of the most damaging manifestations of stress, combining the toxicity of the substance itself with the mental distress associated with the social stigma of the disease. In recent years, refinements in addiction treatment and stress reduction therapies, as well as pharmacological interventions have been successful in helping to mitigate these debilitating conditions.

Intent: To avoid or mitigate substance use and addiction issues by providing access to stress management programs.



Cardiovascular Digestive Endocrine Immune Reproductive

Core New and New and and Existing Existing Buildings

### PART 1: MIND AND BEHAVIOR SUPPORT

A program that addresses psychological and behavioral distress is made available to workplace occupants through:

en. <sup>97</sup> Employee Assistance Programs (EAPs) offering short-term treatment and referrals to qualified professionals for depression, anxiety, substance use, addiction and co-occurring mental health issues.

# **PART 2: STRESS MANAGEMENT**

A stress management program is made available to occupants through:


a. A qualified counselor offering group or private workshops and referrals.

# 96

# **ALTRUISM**

Research demonstrates beneficial health and wellness outcomes associated with acts of generosity and charity. Volunteering fulfills many functions, providing a way for individuals to express their values, strengthen social relationships and gain career-related experience. The Mental Health Foundation states that helping others increases social support by increasing feelings of belonging, while decreasing feelings of isolation and loneliness. For these reasons, altruistic sentiments and behaviors are increasingly incentivized within the workplace.

Intent: To enhance community identity and promote social cohesion.



Core New and New and and Existing Existing Shell Interiors Buildings

### **PART 1: CHARITABLE ACTIVITIES**

Individuals are given the option to take paid time off work to participate in volunteer activities as follows:

a. 8 hours of paid time organized by the employer for a registered charity twice a year.

# **PART 2: CHARITABLE CONTRIBUTIONS**

Employers commit to the following:

a. Contributing annually to a registered charity to match employee donations.

# **MATERIAL TRANSPARENCY**

Just as consumers have a right to know the contents of the food they consume (whether to avoid allergic reactions or to make healthier nutrition choices), they should also have a right to know what is in the products and materials that make up the buildings they occupy. Due to the complex and multi-tiered nature of the global material production supply chain, little is known about the tens of thousands of chemicals in circulation today. This lack of data obscures necessary information required to identify potential hazards to the environment and human health. Demand for material ingredient disclosure at the consumer level pushes supply chain transparency and—even more importantly—supports innovation and green chemistry.

Intent: To promote material transparency along the supply chain.



Cardiovascular
Digestive
Endocrine
Immune
Integumentary
Nervous
Reproductive
Respiratory

Core New and Existing Existing Shell Interiors Buildings

#### PART 1: MATERIAL INFORMATION

At least 50% (as measured by cost) of interior finishes and finish materials, furnishings (including workstations) and built-in furniture have some combination of the following material descriptions (in order to contribute, the product must indicate that all ingredients have been evaluated and disclosed down to 1,000 ppm):

- a. 19 Declare Label.
- b. Health Product Declaration.
- c. Any method accepted in USGBC's LEED v4 MR credit: Building Product Disclosure and Optimization Material Ingredients, Option 1: material ingredient reporting.

# **PART 2: ACCESSIBLE INFORMATION**



The following condition is met:

a. All declaration information is compiled and made readily available to occupants either digitally or as part of a printed manual.

# **ORGANIZATIONAL TRANSPARENCY**

Organizations that espouse fair, equitable and just treatment toward their workforce help create a culture of reduced stress and greater employee satisfaction, as well as a heightened sense of loyalty. Research shows that high levels of perceived justice in the decision making process at work are correlated with a lower risk of poor health, whereas declining levels of perceived justice can in turn increase such risk. By transparently sharing their policies and investment decisions, organizations not only allow employees, clients and patrons to determine if their personal values are shared by the organization, but also provide them the opportunity to voice their opinion about the organization's social equity practices.

Intent: To promote economic and social equity by requiring the adherence to and disclosure of fair and equitable business practices.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
-	0	О

#### PART 1: TRANSPARENCY PROGRAM PARTICIPATION


The entity seeking WELL certification must participate in one of the following programs, and results must be publicly available within the project premises and on the entity's website:

- a. The JUST program operated by the International Living Future Institute (for more information, see www.justorganizations.com).
- b. Reporting in compliance with the GRI Standards operated by the Global Reporting Initiative, including Universal Standards and at least one additional topic-specific Standard (for more information, see www.globalreporting.org).

# **BEAUTY AND DESIGN II**

A beautiful and meaningful space in which design aesthetics are expressly considered can have a positive impact on occupant morale and mood. Elements that provide visual complexity, balance and proportion can impart a sense of comfort, ease and potentially mitigate stress.

Intent: To promote occupant comfort and spatial familiarity by designing spacious, familiar and aesthetically appealing spaces.



Core New and New and and Existing Existing Buildings

#### PART 1: CEILING HEIGHT

Ceiling height that is proportional to room dimensions provides an expansive, comfortable and open feel to the interior space. Floor to ceiling heights for regularly occupied spaces meet the following requirements:

- a. Rooms of 9 m [30 ft] width or less have ceiling height of at least 2.7 m [8.8 ft].
- b. Rooms of greater than 9 m [30 ft] width have ceiling height of at least 2.75 m [9 ft] plus at least 1 m per 20 m [1 ft per 20 ft].
- c. Rooms that provide a full wall view to the outdoors or an atrium space (with at least twice the ceiling height of the room) have a minimum ceiling height of 2.75 m [9 ft] for a room width of 12 m [40 ft] plus at least 1 m per 30 m [1 ft per 30 ft].

## **PART 2: ARTWORK**



- a. Entrances and lobbies.
- b. All regularly occupied space greater than 28 m<sup>2</sup> [300 ft<sup>2</sup>].

### **PART 3: SPATIAL FAMILIARITY**



Design elements can be used to establish way-finding, aid in orientation and provide spatial familiarity. A plan is developed that includes a description of how the project incorporates way-finding elements in projects with floor plates 929 m² [10,000 ft²] or larger through use of the following elements:


- a. Artwork that is distinct in shape and color.
- b. Visually grouped zones or areas that use the following unifying design components: (i) lighting, (ii) furniture color and (iii) flooring pattern/color.
- c. Corridors over 9 m [30 ft] in length end in artwork or a view window to the exterior with a sill height no taller than 0.9 m [3 ft] from the floor and with at least a 30 m [100 ft] vista.

# 100

# **BIOPHILIA II - QUANTITATIVE**

Biophilia supports the idea that humans have an affinity towards the natural world. Evidence on the emotional and psychological benefits of nature is mounting. Research indicates that the experience of nature or nature-derived patterns can improve experience, mood and happiness.

Intent: To support occupant emotional and psychological well-being by including the natural environment in interior and exterior design.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
О	0	0

### **PART 1: OUTDOOR BIOPHILIA**

At least 25% of the project site area meets the following requirements:

- a. Features either landscaped grounds or rooftop gardens accessible to building occupants.
- b. 95 Consists of, at minimum, 70% plantings including tree canopies (within the 25%).

# **PART 2: INDOOR BIOPHILIA**

Wall and potted plants are incorporated into the design of interior space according to the following:

- a. 55 Potted plants or planted beds cover at least 1% of floor area per floor.
- b. 95 A plant wall per floor, covering a wall area equal or greater than 2% of the floor area, or covering the largest of the available walls, whichever is greater.

# **PART 3: WATER FEATURE**

At least one water feature for every 9,290  $m^2$  [100,000 ft<sup>2</sup>] in projects larger than 9,290  $m^2$  [100,000 ft<sup>2</sup>] which meets the following requirements:

- a. At least 1.8 m [5.8 to 6 ft] in height or 4 m $^2$  [43 ft $^2$ ] in area.
- b. Ultraviolet sanitation or other technology to address water safety.

# INNOVATION

# 101-105

# **INNOVATION FEATURES**

As the scientific understanding of health continues to evolve, so too does the ability to address complex issues of promoting wellness through the built environment. Recent discoveries in neuroscience, for example, have led to new insights in light's impact on the human brain, opening the door for addressing sleep disruption through improvements in lighting design. It is likely that similar discoveries will continue to be made. The WELL Building Standard embraces the creative thinking that is needed to address the complex ways in which interior spaces contribute to health and wellness.

Intent: To promote the continuous evolution of the Standard by enabling projects to propose a new feature that addresses health and wellness in a novel way.



Core	New and	New and
and	Existing	Existing
Shell	Interiors	Buildings
0		

#### **PART 1: INNOVATION PROPOSAL**

The feature meets one of the following requirements:

- a. Goes above and beyond the current requirements of the existing WELL feature.
- b. Relates to the wellness concept in a novel way that is not already covered in the WELL Building Standard to impact the occupants of the project or the general public in a positive manner.

## **PART 2: INNOVATION SUPPORT**

The feature is supported by the following:

a. The feature is fully substantiated by existing scientific, medical and industry research, and is consistent with applicable laws and regulations and leading practices in building design and management.

# **Appendix A: Glossary**

#### **General Terms**

Acute Exposure Single exposure to an environmental condition (not lasting more than a day). Acute exposures contrast with

chronic exposures, which are prolonged and repeated. Single exposures still have effects on health.

Allergic Reaction An exaggerated or pathological reaction (sneezing, respiratory irritation, itching or skin rashes) to

substances that are without comparable effect on the average individual.

Alveoli Small thin-walled air-containing compartments of the lung that are typically arranged in saclike clusters that

give the tissue a honeycomb appearance and expand its surface area for the purpose of air exchange.

Alzheimer's Disease A type of dementia marked by the loss of cognitive ability, affecting memory, thinking and behavior

generally over a period of 10 to 15 years.

Ambient Lighting Electric lighting fixtures on walls and ceilings that contribute to the ambient amount of light in a space. This

excludes light from daylight, task lamps, and sources such as computer screens.

Asthma Chronic inflammatory disease of the airways. Asthma attacks are often triggered by exposure to allergens,

and during an attack the airways spasm, alternatively swelling and narrowing, causing the individual to

wheeze or gasp for air.

Building Envelope The separation between the interior and the exterior environments of a building, restricting transfer of air,

water, heat, light, noise and creatures.

Chronic Diseases Any disease that is persistent or has long-lasting health effects.

Chronic Exposure Repeated, continuous exposure to a substance or condition over an extended period from several years to

a lifetime.

Circadian Rhythms Internal clock that keeps the body's hormones and bodily processes on a roughly 24-hour cycle, even in

continuous darkness.

Collaboration Zone A physical area within a building that encourages group interplay and discussion though its strategic layout

and design.

Cone Cells Photosensitive cells in the eye used to differentiate colors and brightness in moderate and high levels of

illumination

Diabetes A group of diseases that impact the metabolism due to insufficient insulin production (Type 1) and/or high

insulin resistance (Type 2), and a leading cause of death. Results in poor blood sugar control, frequent

urination, increased thirst, increased hunger and other symptoms.

**Environmental Product** 

Declaration (EPD)

Quantified environmental data for a product with pre-set categories of parameters based on the International Organization of Standards (ISO) 14040 series of standards, but not excluding additional

environmental information.

Fenestration An opening in a surface (as a wall or membrane).

Focus Zone A physical area within a building that encourages concentration and attentiveness to a task among

occupants though its strategic layout and design.

Free Address Ability for occupants to be able to choose their own workspace within the office or workplace.

Fungi Any of a group of unicellular, multicellular or syncytial spore-producing organisms feeding on organic

materials.

Glasswork, which must be carefully designed in order to avoid excessive glare and heat gain.

Health Product Declaration

(HPD)

A standard format for reporting product content and associated health information for building products

and materials.

Heart Disease A class of disease that affects the heart, arteries, capillaries or veins.

Heating, Ventilating, and Air Conditioning System (HVAC) Equipment, distribution systems and terminals that provide the processes of heating, ventilating or air

conditioning.

High Efficiency Particulate Air

(HEPA) Filter

Filter which removes 99.97% of all particles greater than 0.3 micrometers and satisfies standards of efficiency

set by the Institute of Environmental Sciences and Technology.

High-touch Surfaces Surfaces that are frequently touched by building users and occupants such as door knobs, hand rails and

tables. See Table A1.

Homeostasis A state of having regulated responses to environmental conditions to retain stability.

Immune System The integrated body system of organs, tissues, cells and cell products such as antibodies that differentiates

self from non-self and neutralizes potentially harmful organisms or substances.

Immuno-compromised An inability to develop a normal immune response, usually as a result of disease, malnutrition or medical

therapy that affects the immune system.

Inflammation Localized protective reaction of tissue to irritation, injury or infection, characterized by pain, redness,

swelling and sometimes loss of function.

Interior Pertaining to products within (but not including) the waterproofing membrane.

Intrinsically Photoreceptive Retinal Ganglion Cells

(ipRGCs)

Relay environmental light levels to the suprachiasmatic nucleus through the retinohypothalamic tract. Most

sensitive to blue light.

Liver An organ that plays a vital role in a range of important metabolic processes including detoxification, protein

synthesis and glycogen storage.

Main Air Duct The duct or ducts connected directly to the air handling unit

Malnutrition A condition that results from insufficient nutrient intake, excess nutrient intake or nutrient intake in the

wrong proportions.

Metabolic Any biochemical process that occurs within an organism that is necessary to sustain life.

Metabolic Syndrome A cluster of medical conditions or risk factors that increase the chances of developing cardiovascular

disease, diabetes fatty liver disease and several cancers.

Metamers Different spectral distributions of light which produce the same response on the cones and are therefore

visually identical.

Nanoparticles Particles between 1 and 100 nanometers in size.

Nap Pod A personal dedicated resting space optimized to offer a short but regenerative sleep.

ANSI/ASHRAE Standards 62.1 is the recognized standard for ventilation system design and acceptable National Ventilation Procedure

procedure with regards to establishing an effective ventilation system.

Neurocognitive Diseases Diseases of the brain and nervous system.

Newly Installed Products or materials applied or installed within one year prior to the WELL Performance Verification are

considered to be newly installed.

Obesity A medical condition in which the accumulation of excess adipose tissue poses an adverse effect on health.

Occupational Safety and Health Administration (OSHA) Outlines current indoor air quality guidelines for the workplace.

Occupiable Space An enclosed space intended primarily for human activities. Excludes storage rooms, equipment rooms and

others that are occupied only occasionally and for short periods of time.

Party Wall A wall separating spaces under different ownership or tenancy.

Pathogen An infectious biological agent such as bacteria, virus and fungus that is capable of causing disease in its

host.

Permanent movable items Items that are permanently located on site, but not fixed or stationary, for example desk or desktop

Photocatalytic oxidation (PCO) Achieved when you combine UV light rays with a TiO2-coated filter.

Public Health Goals (PHGs) Unenforced regulations developed by California Office of Environmental Health Hazard Assessment. Similar

in concept to the EPA's Maximum Contaminant Level Goal (MCLG).

The energy and particles which are released during the decomposition process of atomic nuclei is called Radioactivity

Regularly Occupied Space An area or areas where workers or other building occupants perform focused activities inside a building for

an average of one hour a day or more.

Inadequate gas exchange by the respiratory system, with the result that oxygen and/or carbon dioxide Respiratory Failure

levels leaving the heart cannot be maintained within their normal ranges.

Light-sensitive membrane found at the back end of the eyeball that receives the image produced by the Retina

Rod Cells Photosensitive cells in the eye used to discern peripheral vision in low levels of illumination.

Sick Building Syndrome (SBS) A set of symptoms, such as headache, fatigue, eye irritation and breathing difficulties, that typically affect

workers in modern airtight office buildings, and that are believed to be caused by indoor pollutants and

poor environmental control.

Sleep Hygiene Personal habits and practices that help maximize sleep quality. Tissues A group of cells that perform a common and specified function. At an organizational level, tissues are

between cells and organs.

Toxicity Extent to which a substance is harmful to a living thing.

Trail Any outdoor pathways designated for pedestrian or biker use.

Ultraviolet Germicidal Irradiation (UVGI)

A sterilization method that uses ultraviolet (UV) light to break down microorganisms by destroying their

DNA. Often used in a variety of applications, such as food, air and water purification.

Universal Design (UD) Designing objects and spaces with aesthetically pleasing while maximizing accessibility, usability and

operability regardless of the user's age, ability and other factors.

Ventilation Rate Rate of exchange of outside air, as well as the circulation of air within the building.

Wayfinding Act of spatial problem solving.

Weather Resistant Barrier

(WRB)

A sheet, spray- or trowel-applied membrane or material layer that prevents the passage of liquid water even

after long or continuous exposure to moisture.

Workstation An area where an individual performs daily work-related tasks. This could comprise of a traditional seated-

 $height\ desk, standing-height\ desk,\ adjustable-height\ desk\ or\ other\ work\ surface\ that\ is\ appropriate\ for\ the$ 

type of work being performed.

Zeitgebers Physical stimuli which have an impact on the body's circadian rhythm. Examples include light, temperature

and eating or drinking behaviors.

#### **Substances**

 $2,\!4\text{-}Dichlorophenoxyacetic}$ 

Acid (2,4-D) Acrylamides A major herbicide that is very susceptible to running off or leaching into ground and surface water sources.

A potentially toxic and potentially cancer-causing substance that can be naturally present in uncooked, raw

foods in very small amounts.

Aerosols Substances consisting of very fine particles of a liquid or solid suspended in a gas. For example, mist which

consists of very fine droplets of water in air.

Allergen Environmental substance that can produce an allergic reaction in the body but may not be intrinsically

harmful. Common allergens include pollen, animal dander, house dust, feathers and various foods.

Antibody Proteins generally found in the blood that detect and rid the body of potentially damaging organisms, such

as bacteria and viruses.

Antimony A naturally occurring metal found in ore deposits; the most common form of antimony is antimony trioxide,

which is used as a flame retardant.

Arsenic An element found in the earth's crust that has applications in various industrial processes, however runoff

from factories, agricultural practices and natural deposits can lead to high concentrations in water.

Asbestos A naturally occurring mineral that was commonly used in insulation because of its chemical and flame

resistance, tensile strength and sound absorption properties. It is now known to be a leading cause of

mesothelioma and lung cancer.

Atrazine Among the most widely used pesticides in the United States and among the most commonly detected

pesticide in drinking water.

Benzene Widely used as a precursor to various materials such as detergents, dyes, pesticides, Styrofoam, nylon and

other synthetic fibers.

Carbohydrate Any of a group of organic compounds that includes sugars, starches, celluloses and gums and serves as a

major energy source to support bodily functions and physical activity. Easily digestible carbohydrates found in white bread, pastries and soda may contribute to weight gain and promote diabetes and heart disease.

Carbon Monoxide Colorless, odorless and highly poisonous gas formed by incomplete combustion. Replaces oxygen in

hemoglobin, limiting blood's ability to deliver oxygen and can lead to death.

Carcinogens A compound that increases the risk of developing cancer.

Chloramine A disinfectant formed when ammonia is added to chlorine and is commonly used as a secondary

disinfectant in public water systems.

Chlorine A highly irritating, greenish-yellow gaseous halogen, capable of combining with nearly all other elements,

produced principally by electrolysis of sodium chloride and used widely to purify water, as a disinfectant and

bleaching agent.

Coarse Particles Particulate matter larger than 2.5 micrometers and smaller than 10 micrometers in diameter. Often found

near roadways and dusty industries.

Copper Metallic element that enters water sources through natural deposits, but contamination most commonly

occurs through corrosion of copper or brass.

Cortisol A hormone that plays a primary role in stress, during which it increases blood sugar, suppresses the immune

system and aids in protein, fat and carbohydrate metabolism. Also undergoes diurnal variation, playing an

important role in the sleep-wake cycle.

Decorative Glazing Coating on window surfaces purely for aesthetic purposes with no other functionality.

Ethylbenzene A naturally occurring component of crude oil and a combustion byproduct.

Fine Particules Particulate matter 2.5 micrometers in diameter or smaller. Can be directly emitted from combustion sources

such as forest fires or can form when gases emitted from power plants, industries and automobiles react in

the air. Also called PM<sub>2.5</sub>

Flame Retardants Chemicals used in thermoplastics, thermosets, textiles and coatings that inhibit or resist the spread of fire.

Some of these chemicals have been linked to cancer, delayed development, low IQ and thyroid disruption.

Food Additives Substances typically added to processed foods to enhance or preserve flavor or appearance.

Formaldehyde A colorless gas compound, HCHO. Used for manufacturing melamine and phenolic resins, fertilizers, dyes

and embalming fluids as preservatives and disinfectants.

Fructose A simple sugar that is found naturally in small amounts in fruits and vegetables, but which occurs in

extremely large quantities in many modern foods. High fructose intake has been implicated in liver disease,

inflammation, metabolic syndrome, diabetes, heart disease and cancer.

Fungicides Chemicals applied to crops or structures to reduce the harmful effects of mold, mushrooms and other fungi.

Glucose A simple sugar that occurs widely in most plant and animal tissue. It is the principal circulating sugar in the

blood and the major energy source of the body. Once eaten, carbohydrates break down immediately into

glucose. Elevated blood glucose levels are one of the distinguishing elements of diabetes.

Glyphosate A non-selective herbicide used in many pesticide formulations; exposure may result from its normal use due

to spray drift, residues in food crops and from runoff into drinking water sources.

Haloacetic Acid When chlorine and chloramine are added to water and react with other organic matter to produce

haloacetic acids known as a disinfectant byproduct (DBP), these can damage internal organs and the

nervous system in elevated concentrations and can lead to cancer.

Herbicides A group of pesticides commonly used on farms and lawns to eliminate weeds from the fields.

Hormones A chemical released by a cell, gland or organ that transmits a signal to another part of the body.

Hydrogenation Made by forcing hydrogen gas into oil at high pressure in order to increase the shelf life and prevent

rancidity of an oil.

Inorganic Chemicals Refers to a chemical compound that is not "organic". Broadly, compounds not containing carbon.

Iron Necessary for healthy blood circulation, but excessive iron particles in water can provide a shelter for

disease-causing bacteria.

Lead A naturally occurring metal found deep within the ground. Used in creation of old pipes, ceramics and paint.

Also the stable final element of uranium's radioactive decay series.

Manganese Small amounts are required for a healthy diet, but higher amounts may cause neurological damage.

Melatonin "Darkness hormone" whose levels in the body is regulated by the circadian rhythm and the presence of

light and in humans acts a driver for sleep.

Mercury A naturally-occurring poisonous metal element which occurs naturally in the earth's surface.

Microflora Bacteria and microscopic algae and fungi, especially those living in a particular site or habitat.

Nickel Enters groundwater and surface water by dissolution of rocks and soils, from atmospheric fallout and

biological decays and waste disposal.

Nitrogen Dioxide ( $NO_2$ ) A product of combustion mainly found near burning sources (for instance, wood smoke and traffic

combustion).

Nutrient A chemical that is required for metabolic processes, which must be taken from food or another external

source. Macronutrients taken from food sources include carbohydrates, proteins, fats and vitamins.

Organic Chemicals Broadly refers to chemical compounds that possess carbon-based atoms, generally found in biological

systems.

Oxidized Lipids A lipid, any of a diverse group of organic compounds including fats, oils, hormones and certain components

of membranes that are grouped together because they do not interact appreciably with water, combined

chemically with oxygen.

Ozone Triatomic form of oxygen. Hazardous to the respiratory system at ground level, but a layer in the upper

atmosphere blocks much of the ultraviolet radiation from the sun.

Partially Hydrogenated Oil Vegetable oils that have been hydrogenated or partially hydrogenated for the purpose of being solid at

room-temperature, which contain trans-fats.

Particulate Matter A complex mixture of elemental and organic carbon, salts, mineral and metal dust, ammonia and water that

coagulate together into tiny solids and globules.

Perfluorinated Compound

(PFC)

A family of fluorine-containing chemicals with unique properties to make materials stain- and stick-resistant.

Petrochemical A chemical that is made from petroleum or natural gas.

Polychlorinated Biphenyls

(PCBs)

A former commercially produced synthetic organic chemical compound that may be present in products and materials produced before the 1979 PCB ban.

Polyunsaturated Fat Polyunsaturated fats are among the "good" fats that can help reduce cholesterol levels and risk of heart

disease and stroke. Polyunsaturated fats are found in sunflower, corn, soybean and flaxseed oils, walnuts

and many fish.

Polyurethane A synthetic resin used chiefly in paints and varnishes. Diisocyanates in polyurethane products can be toxic if

inhaled or touched during installation.

Polyvinyl Chloride (PVC) An inexpensive plastic that is widely used for many objects. Exposure to its chemical precursors, additives

and products of combustion can be harmful.

Radioactive, carcinogenic noble gas generated from the decay of natural deposits of uranium.

Saturated Fat Typically solid at room temperature, saturated fats are found in high concentrations in salmon, butter,

bacon, beef and cheese.

Serotonin Neurotransmitter hormone produced in the gut and brain stem which regulates mood, sleep and digestion.

Simazine Widely used in agriculture as an herbicide to control weeds; high levels of simazine exposure over a short

period can cause weight loss and blood damage.

Sodium Sodium is consumed as sodium chloride in common salt. It is a vital nutrient, but unhealthy in high amounts.

Sulfates Sulfates occur naturally and can erode into water supplies; the health effects of sulfates are uncertain, but

ingesting large amounts has been linked to negative health effects.

Tetrachloroethylene A chlorinated hydrocarbon used as a dry cleaning solvent, an additive in textile processing and metal

degreasing that has been linked to cancer.

Toxicant Any toxic substance, generally created by human activity.

Toxin A poisonous substance produced by a living organism.

Trihalomethane Chlorine in water can combine with organic matter to form compounds called disinfectant byproducts

(DBPs), such as trihalomethanes.

Ultrafine Particles Also called nanoparticles, ultrafine particles are a subcategory of P<sub>2-5</sub> which are exclusively less than 0.1 µm.

Due to the small size they are often airborne and can easily reach the alveoli of the lungs.

Urea-formaldehyde (UF) A low-cost thermosetting resin that is used in the wood product industry.

Volatile Organic Compounds

(VOCs)

Organic, and therefore carbon and hydrogen containing, materials which evaporate and diffuse easily at ambient temperature. VOCs are emitted by a wide array of building materials, paints and common

consumer products.

Xylene Typical applications include solvents for the printing, rubber and leather industries as well as ingredients in

paper and fabric coatings.

#### **Units and Measures**

Air Changes Per Hour (ACH) A measure of how many times the volume of air within a defined space is replaced, used in the context of

building ventilation and air tightness.

Annual Sunlight Exposure

aSE)

Percentage of space in which the light level from direct sun alone exceeds a pre-defined threshold (such as 1000 lux) for some quantity of hours (such as 250) in a year.

A-Weighted Decibel (dBA) Acoustic decibel modified using "A-weighting" to adjust the frequency-dependent response of human

hearing.

Candela (cd) Measurement of luminous intensity and the SI base unit of light.

Clothing Insulation (CLO) Clothing insulation is the resistance to heat transfer provided by clothing measured in clo (1 clo = 0.155

 $m^2K/W = 0.88$ °F ft<sup>2</sup>h/BTU).

Color Rendering Index (CRI) Comparison of the appearance of 8 to 14 colors under a light source in question, to a blackbody source of

the same color temperature. CRI or Ra refers to the average of the first 8 comparisons and R9 describes the

lighting accuracy on red surfaces.

Correlated Color Temperature (CCT) Spectral distribution of electromagnetic radiation of a blackbody at a given temperature. For example, the color temperature during the daytime is approximately 15,000 K, while during sunset is approximately 1,850

Cubic feet per minute (CFM)

Measures the mass of gas that passes through a certain point.

Decibel (dB)

A unit of measurement for sound. The decibel is a logarithmic unit so an increase in 10 decibels equals an increase by a factor of 10.

Dry Bulb Temperature (DBT)

Temperature of air measured by a thermometer freely exposed to the air but shielded from radiation and moisture. This temperature is usually thought of as air temperature and it is the true thermodynamic temperature. Dry bulb temperature does not take humidity into account.

Equivalent Continuous Level (LAeq)

The time averaged sound pressure level on the A-weighted scale, converted to decibels.

Equivalent Melanopic Lux (EML)

A measure of light used to quantify how much a light source will stimulate melanopsin's light response.

Footcandle (fc)

Unit of illuminance, equivalent to one lumen per square foot.

Frequency (f)

The number of times an event repeats itself per a specified unit of time. Hertz (Hz) is a common unit for frequency and equals cycles per second i.e. 1 Hz = 1 cycle/second. Most commonly used with waves (sound

and light) and is the number of times the wave repeats itself at its particular wavelength.

Illuminance (Lux) Amount of light passing through a given area in space. Measured in lux or foot-candles.

Impact Insulation Class (IIC) Extent to which a physical structure blocks out sound, typically used in describing flooring, a higher IIC

reduces footfall noise, and other impact sounds.

Light Reflectance Value (LRV) Rating from 0 (black) to 100 (white) describing the amount of visible and usable light that reflects from (or

absorbs into) a painted surface.

Lumens Measure of luminous flux, derived from the SI base unit candela, and therefore weighted to the eye's

sensitivity to light; 1 W of light at 555 nm equates to 683 lumens.

Luminance (cd/m²) Measurement of how bright a surface or light source will appear to the eye. Measured in candela/m² or foot-

lamberts

Luminous Flux Total luminous output of a light source, measured in lumens. Weighted to the eye's visual sensitivity.

Luminous Intensity Radiant power weighted to human vision, describing light emitted by a source in a particular direction.

Measured by the candela.

Lux Unit of illuminance, one lux being equivalent to one lumen per square meter.

Maximum Contaminant Level Goal (MCLG)

Concentration of a substance in drinking water believed to result in no adverse effects. Derived from on Population Adjusted Dose and estimated daily water consumption, fraction of exposure from water and

body weight.

Maximum Contaminant Levels

(MCL)

Enforceable water quality limits for a substance, based on the Maximum Contaminant Level Goal, but taking into account technology and cost limitations of treatment.

Mean Radiant Temperature

(MRT)

The uniform surface temperature of an imaginary black enclosure in which an occupant would gain or lose the same amount of radiant heat as in the actual non-uniform space; MRT is a primary driver of human thermal comfort, roughly equal in influence to air temperature.

Metabolic Rate (MET)

Rate that chemical energy in the body is converted to heat and mechanical energy.

Micro-Ra Roughness rating of a physical surface, averaged in micro-meters & micro-inches.

Milliwatt (mW) Unit of measurement for electromagnetic radiation, equal to 1/1000 watt. Not weighted to biological

responses such as vision.

Minimum Efficiency Reporting

Value (MERV)

Value assigned to an air filter to describe the amount of different types of particles removed when operating at the least effective point in its life.

Nephelometric Turbidity Units

(NTU)

Measure the turbidity of water.

Noise Criteria (NC) Define the sound pressure limits of the octave band spectra ranging from 63-8000 Hz. The noise criteria

equals the lowest curve which is not exceeded in the spectrum.

Noise Isolation Class (NIC) Field test for determining the sound transmitting abilities of a wall. Higher NIC values indicate better sound

insulation i.e. more effective sound cancellation between spaces. NIC specifications are defined in ASTM

Standard E366.

Noise Reduction Coefficient

(NRC)

Average value that determines the absorptive properties of materials.

Parts per Billion (PPB) Measurement of the mass of a chemical or contaminate per unit volume of water.

Parts Per Million (PPM) A unit of measurement to express very dilute concentrations of substances.

PicoCurie per Liter (pCi/L) A non-SI unit of radioactivity.

Relative Humidity (rH)

Ratio of partial pressure of water vapor in the air to the saturation pressure of water vapor at the same

temperature and pressure.

Reverberation Time (RT)

Time it takes for sound to decay. The most commonly used reverberation time is RT60, the time it takes for the sound level to decrease 60 decibels. Additional reverberation time measurements are RT20 and RT30,

for decreases of 20 and 30 decibels, respectively.

Sound Pressure Level (SPL)

Sound pressure level (SPL), also known as acoustic pressure, is the pressure variation associated with sound waves. Usually measured in decibels, the acoustic pressure is a ratio between the measured value and a reference value; a common reference is threshold of hearing or the minimum sound level that the average person can hear.

Sound Transmission Class

(STC)

A laboratory method for determining the sound transmission through a wall. Higher STC values indicate more effective noise isolation than lower ones. STC specifications are found in ASTM Standards E90-09 and

Spatial Daylight Autonomy

(sDA)

Percentage of floor space where a minimum light level (for example 300 lux) can be met completely for

some proportion (for example 50%) of regular operating hours by natural light.

Visible Transmittance (VT)

Amount of light in the visible portion of the spectrum that passes through a glazing material.

Walk Score®

A walkability index based on the distance to amenities such as grocery stores, schools, parks, libraries, restaurants, and coffee shops. Scores are normalized from 0 to 100 points and are based on an algorithm that awards maximum points to amenities within a 5 minute walk distance or 400 m [0.25 mi], and a decay

function assigns points for amenities up to 30 minutes away.

Wavelength (λ)

The distance between two points on a wave in which the wave repeats itself. Often used to describe light

 $\mu g/m^3$ 

The concentration of an air pollutant (e.g. ozone) is given in micrograms (one-millionth of a gram) per cubic

meter air or µg/m3.

# **Appendix B: Standards Citations**

Citations are organized by the endnote number found next to each Requirement letter in the WELL Building Standard. The reference codes below the citation refer to a specific Feature number, Part number and Requirement letter.

- U.S. Green Building Council. LEED v4: Reference Guide for Building Design and Construction. Washington D.C.: U.S. Green Building Council; 2013: 37, 43-44, 541-552, 567, 605, 623, 645-53, 658-61, 682-3, 685-6, 723-4.
  - 1.1.a USGBC's LEED v4: Reference Guide for Building Design and Construction EQ Credit: Indoor Air Quality Assessment requires demonstration of formaldehyde levels less than 27 ppb.
  - 1.1.b USGBC's LEED v4: Reference Guide for Building Design and Construction EQ Credit: Indoor Air Quality Assessment requires demonstration of total VOC levels less than 500 µg/m³.
  - 2.2.a USGBC's LEED v4 EQ prerequisite: Environmental Tobacco Smoke requires prohibition of smoking outside the building except in designated smoking areas located at least 25 feet from all entries, outdoor air intakes and operable windows.
  - 4.1.a Adherence to CARB SCM for Architectural Coatings or SCAQMD Rule 1113 satisfies the requirements for VOC content but not the emissions requirement of USGBC's LEED v4 EQ Credit: Low-Emitting Materials for wet-applied products.
  - 4.1.b USGBC's LEED v4 EQ Credit: Low-Emitting Materials requires that 90%, by volume, for emissions of paints and coatings applied to walls, floors and ceilings are tested and determined compliant with CDPH Standard Method v1.1-2010.
  - 4.1.c USGBC's LEED v4 EQ Credit: Low Emitting Materials suggests projects outside the U.S. meet applicable national VOC control regulations or conduct testing of VOC content in accordance with ASTM D2369-10; ISO 11890, part 1; ASTM D6886-03; or ISO 11890-2.
  - 4.2.a USGBC's LEED v4 EQ Credit: Low-Emitting Materials requires that adhesives and sealants wet-applied on site meet the applicable VOC limits of the SCAQMD Rule 1168, in addition to emissions requirements.
  - 4.2.b USGBC's LEED v4 EQ Credit: Low-Emitting Materials requires that 90% of interior adhesives and sealants, for emissions, applied on site are tested and determined compliant with CDPH Standard Method v1.1-2010.
  - 4.2.c USGBC's LEED v4 EQ Credit: Low Emitting Materials suggests projects outside the U.S. meet applicable national VOC control regulations or conduct testing of VOC content in accordance with ASTM D2369-10; ISO 11890, part 1; ASTM D6886-03; or ISO 11890-2.
  - 4.3.a USGBC's LEED v4 EQ Credit: Low-Emitting Materials requires flooring ofollow the test method and meet the emissions criteria of CDPH Standard Method v1.1-2010.
  - 4.4.a USGBC's LEED v4 EQ Credit: Low-Emitting Materials requires insulation follow the test method and meet the emissions criteria of CDPH Standard Method v1.1-2010.
  - 4.5.a USGBC's LEED v4 EQ Credit: Low-Emitting Materials requires furniture and furnishings to comply with ANSI/BIFMA e3-2011 Furniture Sustainability Standard sections 7.6.1 and 7.6.2, and be tested in accordance with ANSI/BIFMA Standard Method M7.1-2011.
  - 5.2.a USGBC's LEED v4 EQ Credit: Enhanced Indoor Air Quality Strategies requires ventilation systems for outdoor air with particle filters to have a MERV of 13 or higher or Class F7 or higher (CEN Standard EN 779-2002) particle air filters.
  - 7.1.a USGBC's LEED v4 EQ Credit: Construction Indoor Air Quality Management Plan requires adherence to certain SMACNA guidelines, including sealing all ductwork, registers, diffusers, and returns when stored on site or not in service.
  - 7.2.a USGBC's LEED v4 BD+C EQ Credit: Construction Indoor Air Quality Management Plan requires the the replacement of all filtration media with new filters before occupancy.
  - 7.3.a USGBC's LEED v4 BD+C EQ Credit: Construction Indoor Air Quality Management Plan requires that absorptive materials stored on-site and installed are protected from moisture damage.
  - 7.4.a USGBC's LEED v4 EQ Credit: Construction Indoor Air Quality Management Plan requires adherence to certain SMACNA guidelines, including sealing doorways and windows, or tenting off areas as needed using temporary barriers, such as plastic separations.
  - 7.4.b USGBC's LEED v4 EQ Credit: Construction Indoor Air Quality Management Plan requires adherence to certain SMACNA guidelines, including the provision of walk-off mats at entryways to reduce introduced dirt and pollutants.

- 7.4.c USGBC's LEED v4 EQ Credit: Construction Indoor Air Quality Management Plan requires adherence to certain SMACNA guidelines, including the use of dust guards and collectors on saws and other tools.
- 8.1.a USGBC's LEED v4: Reference Guide for Building Design and Construction EQ Credit: Enhanced Indoor Air Quality Strategies requires permanent entry walk-off systems.
- 8.1.b USGBC's LEED v4: Reference Guide for Building Design and Construction EQ Credit: Enhanced Indoor Air Quality Strategies requires permanent entry walk-off systems.
- 8.1.c USGBC's LEED v4: Reference Guide for Building Design and Construction EQ Credit: Enhanced Indoor Air Quality Strategies requires permanent entry walk-off systems.
- 11.5.a USGBC's LEED v4 For Healthcare: MR prerequisite, PBT Source Reduction Mercury bans the use of mercury containing equipment, including thermostats, switching devices and other building systems in new construction (of healthcare facilities).
- 11.5.b USGBC's LEED v4 For Healthcare: MR prerequisite, PBT Source Reduction Mercury recommends phasing out mercury products and upgrading current mercury-containing lamps to low mercury or mercury-free lamp technology in renovating healthcare facilities.
- 11.5.c USGBC's LEED v4 For Healthcare: MR prerequisite, PBT Source Reduction Mercury recommends that projects only specify and install illuminated exit signs that use Light Emitting Diode (LED) or Light-Emitting Capacitor (LEC) lamps.
- 11.5.d USGBC's LEED v4 For Healthcare: MR prerequisite: PBT Source Reduction Mercury recommends that projects do not install or specify mercury vapor type high intensity discharge (HID) lamps and probe start metal halide HID lamps in interior spaces.
- 12.4.e USGBC's LEED v4 BD+C EQ Credit: Construction Indoor Air Quality Management Plan requires that absorptive materials stored on-site and installed are protected from moisture damage.
- 13.1.a USGBC's LEED v4 EQ Credit: Indoor Air Quality Assessment requires performance of a building flush-out by supplying a total air volume of 14,000 cubic feet of outdoor air per square foot of gross floor area.
- 13.1.b USGBC's LEED v4 EQ Credit: Indoor Air Quality Assessment requires that the space may be occupied only after delivery of a minimum of 3,500 cubic feet of outdoor air per square foot of gross floor area.
- 14.1.a LEED v4 BD+C: Enhanced commissioning provides two options for the credit, one of which involves following commissioning processes for the building's thermal envelope in accordance with ASHRAE Guideline 0-2005 and NIBS Guideline 3-2012.
- 15.1.a USGBC's LEED v4 EQ prerequisite: Minimum Indoor Air Quality Performance requires using the minimum outdoor air intake flow for mechanical ventilation systems using the ventilation rate procedure from ASHRAE 62.1–2010.
- 17.1.b USGBC's LEED v4 EQ Credit: Enhanced Indoor Air Quality Strategies requires no recirculation of air in spaces where hazardous gases or chemicals may be present or used (e.g., garages, housekeeping and laundry areas, and copying and printing rooms).
- 18.1.b USGBC's LEED v4 EQ prerequisite: Minimum Indoor Quality Performance requires carbon dioxide monitoring within each thermal zone for mechanically ventilated spaces.
- 26.1.b USGBC's LEED v4 MR Credit: Building Product Disclosure and Optimization Material Ingredients allows Cradle to Cradle v2 Gold or Platinum or v3 Silver, Gold or Platinum as one way to achieve Option 2.
- 26.1.c USGBC's LEED v4 MR Credit: Building Product Disclosure and Optimization Material Ingredients allows GreenScreen v1.2 Benchmark as one way to achieve Option 2.
- 62.1.a USGBC's LEED v4 EQ Credit: Daylight, Option 1 requires that at least 55% of space receives at least 300 lux of sunlight for an award of 2 points.
- 62.1.b LUSGBC's LEED v4 EQ Credit: Daylight, Option 1 requires that annual sunlight exposure ASE(1000,250) is achieved for no more than 10% of regularly occupied space.
- 67.3.b USGBC's LEED v4 LT credit: Surrounding Density and Diverse Uses is intended to "promote walkability, and transportation efficiency and reduce vehicle distance traveled" and "improve public health by encouraging daily physical activity".
- 68.2.b USGBC's LEED v4 SS credit: Joint Use of Facilities, for Schools, Option 3 requires collaboration between school authorities and organizations/agencies to provide access to various types of spaces, including gyms, playing fields and swimming pools.
- 85.1.b USGBC's LEED BD+C: Healthcare requires the generation of an Owner's Project Requirements (OPR) document that outlines ways to optimize occupant health.

- 97.1.c USGBC's LEED v4 MR credit: Building Product Disclosure and Optimization Material Ingredients Option 1 has projects use at least 20 permanently installed products from at least 5 different manufacturers that use any of 4 programs described in the credit.
- 2 U.S. Environmental Protection Agency. *National Ambient Air Quality Standards*. 40 CFR Part 50. <a href="https://www.epa.gov/criteria-air-pollutants/naaqs-table">https://www.epa.gov/criteria-air-pollutants/naaqs-table</a>. Revised October 2011. Updated December 14, 2012. Accessed September 16, 2014.
  - 1.2.a The EPA's 2012 NAAQS require ambient air in cities to keep 8-hr average levels of carbon monoxide below 9 ppm and 1-hr averages below 35 ppm, not to be exceeded more than once per year.
  - 1.2.b The EPA's 2012 NAAQS requre PM<sub>2-5</sub> to be less than 12  $\mu$ g/m³ for a primary annual mean, secondary annual mean of 15  $\mu$ g/m³ and a 24-hour concentration of 35  $\mu$ g/m³, averaged over three years .
- World Health Organization. WHO Air Quality Guidelines for Particulate Matter, Ozone, Nitrogen Dioxide and Sulfur Dioxide. Geneva: World Health Organization; 2005: 9, 14.
  - 1.2.c The WHO's Air Quality Guidelines for Particulate Matter, Ozone, Nitrogen Dioxide, and Sulfur set  $50 \,\mu\text{g/m}^3$  as a 24-hour mean concentration limit for  $PM_{10}$ .
  - 1.2.d The WHO's Air Quality Guidelines for Particulate Matter, Ozone, Nitrogen Dioxide, and Sulfur Dioxide recommend ozone limits at 100 μg/m³ 8-hour mean.
- 4 U.S. Environmental Protection Agency. A Citizen's Guide To Radon: The Guide to Protecting Yourself And Your Family From Radon. <a href="http://www.epa.gov/radon/pdfs/citizensguide.pdf">http://www.epa.gov/radon/pdfs/citizensguide.pdf</a>. Published May 2012. Accessed September 16, 2014.
  - 1.3.a The EPA's A Citizen's Guide to Radon recommends radon levels to be less than 4 pCi/L.
- 5 State of New York. Regulation of Smoking in Public and Work Places § 1399.

  https://www.health.ny.gov/regulations/public health law/section/1399/. Revised 2009. Accessed September 15, 2014.
  - 2.1.a The State of New York's Regulation of Smoking in Public and Work Places does not permit smoking indoors at places of employment.
- 6 ASHRAE Standing Standard Project Committee 62.1. ANSI/ASHRAE STANDARD 62.1-2013: Ventilation for Acceptable Indoor Air Quality. Atlanta: ASHRAE; 2013.
  - 3.1.a ASHRAE's Standard 62.1: Ventilation for Acceptable Indoor Air Quality provides guidelines for ventilation rates.
  - 3.1.b ASHRAE's Standard 62.1: Ventilation for Acceptable Indoor Air Quality provides ventilation rates.
- Illinois Department of Public Health. Illinois Department of Public Health Guidelines for Indoor Air Quality. <a href="http://www.idph.state.il.us/envhealth/factsheets/indoorairqualityguide\_fs.htm">http://www.idph.state.il.us/envhealth/factsheets/indoorairqualityguide\_fs.htm</a>. Updated May 2011. Accessed September 15, 2014.
  - 3.2.a The IDPH's Guidelines for Indoor Air Quality recommend properly ventilated buildings should have carbon dioxide levels with a floor or building average of 800 ppm or less.
  - 3.2.b The IDPH's Guidelines for Indoor Air Quality recommend properly ventilated buildings should have carbon dioxide levels with a floor or building average of 800 ppm or less.
- 8 U.S. Environmental Protection Agency. A Brief Guide to Mold, Moisture, and Your Home. <a href="https://www.epa.gov/mold/brief-guide-mold-moisture-and-your-home">https://www.epa.gov/mold/brief-guide-mold-moisture-and-your-home</a>. Published 2010. Accessed September 15, 2014.
  - 16.1.a The EPA's A Brief Guide to Mold, Moisture, and Your Home recommends maintaining relative humidity between 30% and 50%.
- 9 National Air Duct Cleaners Association (NADCA). NADCA White Paper on Ultraviolet Lighting Applications in HVAC Systems.

  http://nadca.com/sites/default/files/userfiles/documents/2014/bod final approved draft uv paper 9-20

   pdf.pdf. Accessed October 8, 2014.
  - 6.1.b NADCA's White Paper on Ultraviolet Lighting Applications in HVAC Systems states that to avoid ozone production, use UVC lamps with a wavelength of 254 nm.
- 10 Jacobson, Michael. Chemical Cuisine: Your guide to food additives. Nutrition Action; 2014.

- 43.1.a The CSPI's Chemical Cuisine reports that artificial colorings often suggest absence of fruit and other natural ingredients, and that artificial colorings can contribute to hyperactivity in some children, cause tumors in animals and allergic reactions.
- 43.1.b The CSPI's Chemical Cuisine reports evidence that most flavoring chemicals also occur in nature and are probably safe, but are used almost exclusively in junk foods.
- 43.1.c The CSPI's Chemical Cuisine states that evidence continues to mount that artificial sweeteners negatively impact the digestive microbiome, leading to glucose intolerance and metabolic dysregulation.
- 43.1.d The CSPI's Chemical Cuisine reports that brominated vegetable oil leaves residue in the human body, and in animal studies has been shown to cause heart lesions, changes in the liver, and impaired growth and behavioral development.
- 43.1.e The CSPI's Chemical Cuisine reports that potassium bromate is banned in most countries, but not in the U.S., where it is frequently used in baked goods.
- 43.1.f The CSPI's Chemical Cuisine reports that BHA is classified as "reasonably anticipated to be a human carcinogen" by the Department of Health and Human Services.
- 43.1.g The CSPI's Chemical Cuisine reports that BHT increases the risk of various cancers in animals and has been shown to accumulate in human fat.
- 43.1.h The CSPI's Chemical Cuisine reports that studies have found that some people are sensitive to large amounts of MSG and may experience adverse reactions.
- 43.1.i The CSPI's Chemical Cuisine reports that HVP contains MSG and may cause reactions in sensitive people.
- 43.1.j The CSPI's Chemical Cuisine reports that sodium nitrate and sodium nitrite "introduce only a small risk", but are still worth avoiding.
- 43.1.k The CSPI's Chemical Cuisine Reports that sulfiting agents destroy vitamin B1 and can cause reactions in people, particularly those who have asthma.
- 11 Environmental Protection Agency. Use of Lead Free Pipes, Fittings, Fixtures, Solder and Flux for Drinking Water. Safe Drinking Water Act (SDWA) Section 1417.
  - 11.1.b Section 1417 of the EPA's Safe Drinking Water Act defines "lead free" as a weighted average of 0.25% lead calculated across the wetted surfaces of a pipe, pipe fitting, plumbing fitting, and fixture and 0.2% lead for solder and flux.
- National Center for Healthy Housing and American Public Health Association. National Healthy Housing Standard. <a href="http://www.nchh.org/Portals/0/Contents/NHHS Full Doc.pdf">http://www.nchh.org/Portals/0/Contents/NHHS Full Doc.pdf</a>. Published 2014. Accessed September 15, 2014.
  - 6.2.a The National Healthy Housing Standard states that building materials affected by mold or mildew should be cleaned, dried, and repaired. It also states that interior and exterior surfaces shall have no signs of visible mold growth.
  - 6.2.b The National Healthy Housing Standard states that the foundation, roof, roofing components, exterior walls, doors, skylights and windows shall be free of persistent dampness or moisture.
- 13 International Living Future Institute. Living Building Challenge 3.0. Seattle; 2014: 38, 43-49, 60.
  - 19.1.a The International Living Future Institute's Living Building Challenge 3.0 Imperative 07 requires full control of windows.
  - 26.1.a The International Living Future Institute's Living Building Challenge 3.0 Imperatives 10 and 12 require independently verified declarations of products.
  - 87.1.a The International Living Future Institute's Living Building Challenge 3.0 Imperative 19 requires design features to support human delight.
  - 87.1.b The International Living Future Institute's Living Building Challenge 3.0 Imperative 19 requires design features to support celebration of culture.
  - 87.1.c The International Living Future Institute's Living Building Challenge 3.0 Imperative 19 requires design features to support celebration of spirit.
  - 87.1.d The International Living Future Institute's Living Building Challenge 3.0 Imperative 19 requires design features to support celebration of place.
  - 87.1.e The International Living Future Institute's Living Building Challenge 3.0 Imperative 19 requires design features to support meaningful integration of public art.

- 88.1.a The International Living Future Institute's Living Building Challenge 3.0 Imperative 9 requires a framework and plan that outlines the way the project will be transformed through the incorporation of nature through environmental elements in the project.
- 88.1.b The International Living Future Institute's Living Building Challenge 3.0 Imperative 9 requires a framework and plan that outlines the way the project will be transformed through the incorporation of nature through lighting elements in the project.
- 88.1.c The International Living Future Institute's Living Building Challenge 3.0 Imperative 9 requires a framework and plan that outlines the way the project will be transformed through the incorporation of nature through space in the project.
- 88.2.a The International Living Future Institute's Living Building Challenge 3.0 Imperative 9 requires a framework and plan that outlines the way the project will be transformed through the incorporation of nature's patterns into the project.
- 88.3.a The International Living Future Institute's Living Building Challenge 3.0 Imperative 9 requires a framework and plan that outlines ways to provide human-nature interactions in the interior of the building.
- 88.3.b The International Living Future Institute's Living Building Challenge 3.0 Imperative 9 requires a framework and plan that outlines ways to provide human-nature interactions in the exterior of the project.
- San Francisco Department of the Environment. Integrated Pest Management Ordinance. <a href="http://www.sfenvironment.org/article/city-staff/pest-management">http://www.sfenvironment.org/article/city-staff/pest-management</a>. Published 2011. Accessed September 14, 2014
  - 10.1.a The San Francisco Department of the Environment's Integrated Pest Management recommends that pesticide products be used as a last result, only after other non-chemical management options have been exhausted.
  - 10.1.b The San Francisco Department of the Environment's Integrated Pest Management Ordinance assigns hazard tiers to pesticide products from lowest to highest concern.
- U.S. Environmental Protection Agency. *Residential Air Cleaners: A Summary of Available Information*. Washington, DC: U.S. Environmental Protection Agency; August 2009.
  - 23.2.a The EPA's "Residential Air Cleaners" notes that properly designed UVGI cleaners in typical airstream disinfection applications could reduce the viability of vegetative bacteria and molds, and could provide low to moderate reduction in viruses.
  - 23.2.b The EPA's Residential Air Cleaners document notes that photocatalytic oxidation cleaners are intended to change gaseous pollutants and associated odors into harmless products.
- U.S. Environmental Protection Agency. Methylene Diphenyl Diisocycanate and Related Compounds Action Plan.http://www.wftaylor.com/wp-content/uploads/2012/03/EPA\_MDI\_Action\_Plan.pdf. Published April 2011. Accessed October 17, 2014.
  - 25.4.a The EPA's Methylene Diphenyl Diisocyanate and Related Compounds Action Plan outlines the risk of exposure to isocyanate-based compounds.
- 18 U.S. Green Building Council. Sustainable Site 4: Alternative Transportation Bicycle Storage and Changing Rooms. <a href="http://www.usgbc.org/node/1731996?return=/credits">http://www.usgbc.org/node/1731996?return=/credits</a>. Published 2009. Accessed October 17, 2014.
  - 69.1.b USGBC's LEED v4 LT Credit: Bicycle Facilities requires separate and secure bicycle storage for at least 5% of regular building occupants (minimum 4) and short-term bicycle storage for at least 2.5% of all peak visitors.
  - 69.2.a USGBC's LEED v4 LT Credit: Bicycle Facilities requires at least one on-site shower with a changing facility for the first 100 regular building occupants and one additional shower for every 150 regular building occupants thereafter.
- 19 Declare. The Ingredients Label for Building Projects. <a href="https://ilbi.org/about/About-Docs/handouts-docs/declare-postcard">https://ilbi.org/about/About-Docs/handouts-docs/declare-postcard</a>. Seattle: International Living Future Institute; Accessed September 15, 2014.
  - 97.1.a Declare promotes materials transparency by providing a platform for manufacturers to disclose product ingredients and other relevant information.
- 20 National Partnership for Women and Families. *Paid Sick Days: Good for for Business, Good for Families.* http://www.nationalpartnership.org/research-library/work-family/psd/paid-sick-days-good-for-business-and-workers.pdf. Published August 2012. Accessed October 16, 2014.
  - 92.1.e National Partnership for Women and Families' Paid Sick Days: Good for Business, Good for Workers notes that "when sick workers are able to stay home, the spread of disease slows and workplaces are both healthier and more productive."

- U.S. Environmental Protection Agency. Protocol for Residual Self-Sanitizing Activity of Dried Chemical Residues on Hard, Non-Porous Surfaces, #01-1A. <a href="https://www.epa.gov/sites/production/files/2015-09/documents/cloroxpcol final.pdf">https://www.epa.gov/sites/production/files/2015-09/documents/cloroxpcol final.pdf</a>. Published September 2015. Accessed Jun 2016.
- U.S. Green Building Council. Pilot Credit 82: Local Food Production. <a href="http://www.usgbc.org/node/2743606?return=/pilotcredits">http://www.usgbc.org/node/2743606?return=/pilotcredits</a>. Published 2009. Accessed October 17, 2014.
  - 51.1.a LEED v4: Reference Guide for Building Design and Construction sets a Pilot Credit (local food production) for onsite food production, which requires provisions for onsite food production.
  - 51.1.b LEED v4: Reference Guide for Building Design and Construction sets a Pilot Credit (local food production) for onsite food production, which requires the provision of a greenhouse.
  - 51.2.a LEED v4: Reference Guide for Building Design and Construction sets a Pilot Credit (local food production) for onsite food production, which requires the provision for onsite food production.
  - 51.2.b LEED v4: Reference Guide for Building Design and Construction sets a Pilot Credit (local food production) for onsite food production, which requires the provision of a watering system.
  - 51.2.c LEED v4: Reference Guide for Building Design and Construction sets a Pilot Credit (local food production) for onsite food production, which requires the provision of access to sunlight.
  - 51.2.d LEED v4: Reference Guide for Building Design and Construction sets a Pilot Credit (local food production) for onsite food production, which requires the provision of vegetable gardens and/or edible nut and fruit-bearing plants.
- Occupational Safety and Health Administration. Protecting Workers Who Use Cleaning Chemicals. <a href="https://www.osha.gov/Publications/OSHA3512.pdf">https://www.osha.gov/Publications/OSHA3512.pdf</a>. Published 2012. Accessed October 17, 2014.
  - 29.1.a OSHA/NIOSH's Protecting Workers Who Use Cleaning Chemicals info sheet recommends the use of microfiber mops, rags and dusters.
  - 29.1.b OSHA's Protecting Workers Who Use Cleaning Chemicals info sheet recommends the use of hands-free mops.
  - 29.2.b Protecting Workers Who Use Cleaning Chemicals info sheet recommends avoiding the mixing of cleaning products that contain bleach and ammonia.
- 24 United States Environmental Protection Agency Office of Water. *Alternative Disinfectants and Oxidants Guidance Manual*. <a href="http://www.epa.gov/ogwdw/mdbp/alternative disinfectants guidance.pdf">http://www.epa.gov/ogwdw/mdbp/alternative disinfectants guidance.pdf</a>. Published April 1999. Accessed June 12, 2015.
  - 36.3.a The US EPA's Alternative Disinfectants and Oxidants Guidance Manual notes that the optimum UV range is between 245 and 285 nm, which corresponds to UV-C radiation (200-280 nm).
- 25 Minnesota Department of Health. Water Treatment Using Carbon Filters (GAC). http://www.health.state.mn.us/divs/eh/hazardous/topics/gac1.pdf. Published 2013. Accessed June 10, 2015.
  - 36.1.a The Minnesota Department of Health notes that "A filter with granular activated carbon (GAC) is a proven option to remove certain chemicals, particularly organic chemicals, from water".
- 26 U.S. Environmental Protection Agency. Chemical Management Resource Guide for School Administrators, EPA 747-R-06-002. Washington, DC: U.S. Environmental Protection Agency; December 2006.
  - 29.2.a The EPA's Chemical Management Resource Guide for School Administrators recommends separate storage for bleach and ammonia products.
- 27 U.S. Green Building Council. Pilot Credit 78: Design for Active Occupants. <a href="http://www.usgbc.org/node/4810558?return=/credits/new-construction/v4">http://www.usgbc.org/node/4810558?return=/credits/new-construction/v4</a>. Published 2013. Accessed October 17, 2014.
  - 64.1.a LEED v4 Pilot Credit 78: Design for Active Occupants for primary staircase(s) includes classifying regularly occupied floors for re-entry, allowing all building users to access them, and providing access via stairs to at least 50% of the tenant floors.
  - 64.2.a LEED v4 Pilot Credit 78: Design for Active Occupants includes a requirement for a main staircase to be located within 25 ft of any edge of the lobby.

27.1.a

- 64.2.b LEED v4 Pilot Credit 78: Design for Active Occupants includes a requirement to locate a main staircase that is visible before occupants encounter elevators and/or escalators.
- 64.3.c LEED v4 Pilot Credit 78: Design for Active Occupants requires some features, one of which is the provision of daylighting with windows and/or skylights that are at least 8 square feet.
- 70.1.a USGBC's LEED Pilot Credit 78: Design for Active Occupants requires equipment to be provided in the interior fitness space and for use by 5% of regular building occupants.
- 70.2.a USGBC's LEED Pilot Credit 78: Design for Active Occupants requires equipment to be provided in the interior fitness space and for use by 5% of regular building occupants.
- Health Product Declaration Collaborative (HPD). Health Product Declaration Standard Version 1.0. <a href="http://hpdcollaborative.org/standard-documents/hpdstandard-v1-0-121215.pdf">http://hpdcollaborative.org/standard-documents/hpdstandard-v1-0-121215.pdf</a> . Updated December 15, 2012. Accessed June 9, 2015.
  - 97.1.b The Health Product Declaration's Standard Version 1.0 provides guidance for declaring "product content and direct health hazards associated with exposure to its individual contents."
- 29 U.S. Environmental Protection Agency. Sources of combusion products: An introduction to indoor air quality. <a href="https://www.epa.gov/indoor-air-quality-iaq/sources-combustion-products-introduction-indoor-air-quality">https://www.epa.gov/indoor-air-quality-iaq/sources-combustion-products-introduction-indoor-air-quality</a>. Accessed Match 30, 2018.
  - 24.1.a The EPA notes that under certain conditions, combustion appliances such as heaters, ranges, ovens, stoves, furnaces, fireplaces, water heaters and clothes dryers can release contaminants into the home that can seriously damage health.
- 30 U.S. Consumer Product Safety Commission. Biological Pollutants in Your Home. <a href="https://www.cpsc.gov/safety-education/safety-guides/home/biological-pollutants-your-home">https://www.cpsc.gov/safety-education/safety-guides/home/biological-pollutants-your-home</a>. Accessed December 15, 2017.
  - 28.2.a The U.S. Consumer Product Safety Commission recommends avoiding wall-to-wall carpets in damp areas and in rooms of individuals with allergies or asthma.
- 31 U.S. Environmental Protection Agency. Work Practice Standards for Conducting Lead-Based Paint Activities: Target Housing and Child-occupied Facilities. <a href="http://www.law.cornell.edu/cfr/text/40/745.227">http://www.law.cornell.edu/cfr/text/40/745.227</a>. Published 1996. Accessed September 15, 2014.
  - 11.2.a The EPA's Work Practice Standards for Conducting Lead-Based Paint Activities document establishes requirements for conducting lead-based paint activities.
  - 11.2.b The EPA's Work Practice Standards for Conducting Lead-Based Paint Activities document establishes requirements for conducting lead-based paint activities.
  - 11.2.c The EPA's Work Practice Standards for Conducting Lead-Based Paint Activities document establishes requirements for conducting lead-based paint activities.
- Centers for Disease Control and Prevention. Voluntary Guidelines for Managing Food Allergies In Schools and Early Care and Education Programs. <a href="http://www.cdc.gov/healthyyouth/foodallergies/pdf/13">http://www.cdc.gov/healthyyouth/foodallergies/pdf/13</a> <a href="http://www.cdc.gov/healthyyouth/foodallergies/pdf/13">http://www.cdc.gov/healthyyouth/foodalle
  - 48.1.a The CDC's Voluntary Guidelines for Managing Food Allergies In Schools and Early Care and Education Programs reports that 50%-62% of fatal or near fatal allergic reactions are caused by peanuts.
- U.S. Environmental Protection Agency. Guidelines for Conducting the AHERA TEM Clearance Test to Determine Completion of an Asbestos Abatement Project. Published 1989: 5
  - 11.3.a AHERA's Asbestos Model Accreditation Plan establishes asbestos limits.
  - 11.3.b The EPA's Guidelines for Conducting the AHERA TEM Clearance Test to Determine Completion of an Asbestos Abatement Project guidelines establish requirements for conducting post-abatement checks.
  - 11.3.c The EPA's Guidelines for Conducting the AHERA TEM Clearance Test to Determine Completion of an Asbestos Abatement Project guidelines establish requirements for conducting post-abatement checks.
- 34 U.S. Environmental Protection Agency. Steps to Safe PCB Abatement Activities. <a href="http://www.epa.gov/epawaste/hazard/tsd/pcbs/pubs/caulk/guide/guide-sect4a.htm">http://www.epa.gov/epawaste/hazard/tsd/pcbs/pubs/caulk/guide/guide-sect4a.htm</a> . Published 2012. Accessed 2011 .
  - 11.4.a The EPA's Steps to Safe PCB Abatement Activities establishes PCB abatement procedures.
  - 11.4.b The EPA's Steps to Safe PCB Abatement Activities provides guidance on the handling, storage, and disposal of PCB waste.

- 35 Center for the Built Environment. Occupant Indoor Environmental Quality (IEQ) Survey. http://www.cbe.berkelev.edu/research/survey.htm. Accessed June 8, 2015.
  - 86.1.a CBE's Occupant Indoor Environmental Quality (IEQ) Survey™ covers several core question areas that address key aspects of the indoor environment, including acoustic quality.
  - 86.1.b CBE's Occupant Indoor Environmental Quality (IEQ) Survey™ covers several core question areas that address key aspects of the indoor environment, including thermal comfort.
  - 86.1.c CBE's Occupant Indoor Environmental Quality (IEQ) Survey™ covers several core question areas that address key aspects of the indoor environment, including office furnishings.
  - 86.1.d CBE's Occupant Indoor Environmental Quality (IEQ) Survey™ covers several core question areas that address key aspects of the indoor environment, including lighting.
  - 86.1.e CBE's Occupant Indoor Environmental Quality (IEQ) Survey™ covers several core question areas that address key aspects of the indoor environment, including air quality.
  - 86.1.f CBE's Occupant Indoor Environmental Quality (IEQ) Survey<sup>TM</sup> covers several core question areas that address key aspects of the indoor environment, including cleanliness and maintenance.
  - 86.1.g CBE's Occupant Indoor Environmental Quality (IEQ) Survey™ covers several core question areas that address key aspects of the indoor environment, including office layout.
- 36 U.S. Green Building Council. Pilot Credit 54: Avoidance of Chemicals of Concern. <a href="http://www.usgbc.org/node/2606894?return=/pilotcredits/Commercial-Interiors/v2009">http://www.usgbc.org/node/2606894?return=/pilotcredits/Commercial-Interiors/v2009</a>. Accessed September 15, 2014.
  - 11.1.c USGBC's LEED v4 Pilot Credit 54, v3 2009 requires that a minimum of 20%, by cost, of at least 3 building product and material types must not contain lead and lead compounds greater than 0.01% (100 ppm) as calculated by mass.
  - 25.1.a USGBC's LEED v3 Pilot Credit 54 requires that third party certified building materials may not include perfluorinated compounds at levels equal to or greater than 100 ppm.
  - 25.2.a USGBC's LEED v3 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) brominated or halogenated flame retardants containing bromine, chlorine, or fluorine.
  - 25.2.b USGBC's LEED v3 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) brominated or halogenated flame retardants containing bromine, chlorine, or fluorine.
  - 25.2.c USGBC's LEED v3 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) brominated or halogenated flame retardants containing bromine, chlorine, or fluorine.
  - 25.2.d USGBC's LEED v3 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) brominated or halogenated flame retardants containing bromine, chlorine, or fluorine.
  - 25.2.e USGBC's LEED v3 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) brominated or halogenated flame retardants containing bromine, chlorine, or fluorine.
  - 25.3.a USGBC's LEED v4 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) of phthalates.
  - 25.3.b USGBC's LEED v4 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) of phthalates.
  - 25.3.c USGBC's LEED v4 Pilot Credit 54 requires that third party certified building products not contain more than 0.01% by mass (100ppm) of phthalates.
- American Society of Heating, Refrigerating and Air-Conditioning Engineers. *UFAD Guide: Design, Construction and Operation of Underfloor Air Distribution Systems*. Atlanta: American Society of Heating, Refrigerating and Air-Conditioning Engineers; 2013.
  - 21.1.b ASHRAE's Underfloor Air Distribution Guide provides recommendations for underfloor air distribution systems.
- 39 South Coast Air Quality Management District. Rules and Regulations, Regulation XI Source Specific Standards. <a href="http://www.aqmd.gov/home/regulations/rules/scaqmd-rule-book/regulation-xi">http://www.aqmd.gov/home/regulations/rules/scaqmd-rule-book/regulation-xi</a>. Accessed October 17, 2014.
  - 24.2.a The South Coast Air Quality Management District Rule 1110.2 (amended 9/7/2012) establishes requirements for gaseousand liquid-fueled engines for the purpose of reducing emission of oxides from nitrogen, VOCs and carbon monoxide.

- 24.2.b The South Coast Air Quality Management District Rule 1111 (amended 9/5/14) establishes requirements for natural gas fired, fan-type central furnaces for the purpose of reducing emission of nitrogen oxides.
- 24.2.c The South Coast Air Quality Management District Rules 1146.1 (amended 11/1/13) and 1146.2 (amended 5/5/06) establish requirements for the reduction of emissions of oxides of nitrogen from boilers, process heaters and steam generators.
- 24.2.d The South Coast Air Quality Management District Rules 1121 (amended 9/3/04) and 1146.2 (amended 5/5/06) establish requirements for emissions of nitrogen oxides from residential natural gas-fired water heaters and large water heaters.
- Centers for Disease Control and Prevention. Guideline for Isolation Precautions: Preventing Transmission of Infectious Agents in Healthcare Settings. <a href="http://www.cdc.gov/hicpac/pdf/isolation/isolation2007.pdf">http://www.cdc.gov/hicpac/pdf/isolation/isolation2007.pdf</a>. Published 2012. Accessed September 15, 2014.
  - 29.1.c The CDC's Guideline for Isolation Precautions: Preventing Transmission of Infectious Agents in Healthcare Settings recommends vacuum cleaners be equipped with HEPA filters.
- 41 ASHRAE. Performance Evaluation and Development of Design Guidelines for Displacement Ventilation, RP-949. Atlanta, GA: American Society of Heating, Refrigerating, and Air-Conditioning Engineers; 1999.
  - 21.1.a The Performance Evaluation and Development of Design Guidelines for Displacement Ventilation document recommends air supply temperatures.
- International Organization for Standardization. *ISO 21542:2011 Accessibility and Usability of the Built Environment*, Technical Committee ISO/TC 59, Buildings and Civil Engineering Works, Subcommittee SC 16.
  - 72.1.b The ISO's 21542:2011 provides standards on accessibility for newly constructed or renovated buildings.
- Office of Environmental Health Hazard Assessment. Public Health Goal for Nickel in Drinking Water. Sacramento: California Environmental Protection Agency; 2010: 1.
  - 31.1.e The California Office of Environmental Health Hazard Assessment and the California EPA set a public health goal for Nickel in drinking water at 0.012 mg/L.
- 44 California Water Boards. Maximum Contaminant Levels and Regulatory Dates for Drinking Water US EPA vs California.
  - http://www.waterboards.ca.gov/drinking\_water/certlic/drinkingwater/documents/dwdocuments/MCLsEP\_AvsDWP-2014-07-01.pdf. Sacramento: California Environmental Protection Agency; 2014.
  - 32.1.b The California Environmental Protection Agency regulates Benzene in drinking water to a Maximum Contaminant Level set at 0.001 mg/L.
  - 32.1.c The California Environmental Protection Agency regulates Ethylbenzene in drinking water to a Maximum Contaminant Level of 0.3 mg/L.
  - 32.1.f The California Environmental Protection Agency regulates Toluene in drinking water to a Maximum Contaminant Level set at 0.15 mg/L.
  - 33.1.a The California Environmental Protection Agency regulates Atrazine in drinking water to a Maximum Contaminant Level of 0.001 mg/L.
- Office of Environmental Health Hazard Assessment. Public Health Goal for Styrene in Drinking Water. Sacramento: California Environmental Protection Agency; 2010: 1.
  - 32.1.a The California Office of Environmental Health Hazard Assessment and the California EPA set a public health goal of Styrene in water at 0.5 µg/L.
- 46 United States Code (2006). 29 U.S.C. § 2612.
  - 93.1.b US federal law entitles eligible employees to up to 12 workweeks of leave during any 12-month period for reasons listed in § 2612(a)(1), including the birth of a child, or placement of a child with the employee for adoption or foster care.
  - 93.3.a United States federal law permits eligible employees to receive up to 12 workweeks of leave during any 12-month period for an employee to care for a spouse, child or parent with a serious health condition.
- 47 New York State Department of Health. *Individual Water Supply Wells Fact Sheet #3 Recommended Residential Water Quality Testing*. Troy: New York State Department of Health Bureau of Water Supply Protection; 2006.
  - 37.1.d The New York State Department of Health notes that water containing more than 270 mg/L of sodium should not be used by people on moderately restricted sodium diets.

- 48 U.S. Environmental Protection Agency (EPA). *Drinking Water Best Management Practices*, EPA 816-B-13-002. Washington, D.C.: U.S. Environmental Protection Agency; April 2013.
  - 37.3.a The EPA's Drinking Water Best Management Practices notes that it is "important to clean drinking water fountains to remove lime and calcium build-up."
  - 37.3.b The EPA's Drinking Water Best Management Practices note to clean debris out of all outlet screens and aerators on a regular basis.
- The Society of Light and Lighting. Lighting for the Built Environment Lighting Guide 13: Lighting for Places of Worship. England: The Lavenham Press; 2014.
  - 89.2.b CIBSE's Lighting Guide 13: Lighting for Places of Worship notes that lamps with a correlated color temperature of 2700-3000 K for congregation spaces can help these spaces feel psychologically "warmer".
- 50 U.S. Environmental Protection Agency. *National Primary Drinking Water Regulations*. EPA 816-F-09-004. Published May 2009. Washington, D.C.
  - 30.1.a The US EPA National Primary Drinking Water Regulations notes that for systems that use conventional or direct filtration, "samples for turbidity must be less than or equal to 0.3 NTU in at least 95 percent of the samples in any month".
- National Partnership for Women and Families. Expecting Better: A State-by-State Analysis of Laws That Help New Parents.
  - http://www.nationalpartnership.org/research-library/work-family/expecting-better-2014.pdf. Published June, 2014:23. Accessed September 15, 2014.
  - 93.3.b The National Partnership for Women and Families' Expecting Better recognizes US states that allow workers to use their earned paid sick days to care for either a new child or an ill family member.
  - 93.3.c The National Partnership for Women and Families' "Expecting Better" recognizes US states that improve upon federal law by "providing all nursing mothers with reasonable break times and/or a place other than a bathroom to express breast milk at work."
- 52 American National Standards Institute and Illuminating Engineering Society of North America. *American National Standard Practice for Office Lighting*. New York, NY: Illuminating Engineering Society of North America; 2012. RP-1-12.
  - 53.2.a ANSI/IES RP-1-12 provides recommended luminance ratios for offices.
  - 53.2.b ANSI/IES RP-1-12 provides recommended luminance ratios for offices. It notes that studies suggest that ratios do not exceed 3:1 or 1:3 between a paper task and an adjacent visual display terminal.
  - 53.2.c ANSI/IES RP-1-12 provides recommended luminance ratios for offices. It notes that for ceiling luminance ratios, 10:1 is the maximum acceptable ratio.
  - 53.2.d ANSI/IES RP-1-12 provides recommended luminance ratios for offices. It notes that studies suggest that ratios do not exceed 10:1 or 1:10 between a task and a remote surface.
  - 55.2.a ANSI/IES American National Standard Practice for Office Lighting (RP-1-12) notes that luminaires at angles higher than 53° above horizontal may cause discomfort, and that such luminaires should be less than 8,000 cd/m².
- World Health Organization. *Guidelines for Drinking-water Quality Fourth Edition*. Geneva: World Health Organization; 2011: 26, 371, 383, 416, 433.
  - 31.1.a The WHO Guidelines for Drinking Water Quality note a provisional guideline value of 0.01 mg/L for Lead concentrations.
  - 32.1.g The WHO Guidelines for Drinking Water Quality set a guideline value for Xylene concentrations at 0.5 mg/L.
  - 33.1.b The WHO Guidelines for Drinking Water Quality set a guideline value for Simazine concentrations at 0.002 mg/L.
  - 33.2.a The WHO Guidelines for Drinking Water Quality set a guideline value for nitrate concentrations at 50 mg/L.
  - 35.1.a The WHO Guidelines for Drinking-water Quality, Fourth Edition notes that some hazards "may arise intermittently, often associated with seasonal activity or seasonal conditions."
  - 35.1.b The WHO Guidelines for Drinking-water Quality, Fourth Edition notes that some hazards "may arise intermittently, often associated with seasonal activity or seasonal conditions."
  - 35.1.c The WHO Guidelines for Drinking-water Quality, Fourth Edition notes that some hazards "may arise intermittently, often associated with seasonal activity or seasonal conditions."

- 35.1.d The WHO Guidelines for Drinking-water Quality, Fourth Edition notes that some hazards "may arise intermittently, often associated with seasonal activity or seasonal conditions."
- Office of Water. 2012 Edition of the Drinking Water Standards and Health Advisories. Washington D.C.: U.S. Environmental Protection Agency; 2012: 2, 3, 5-11.
  - 30.2.a The EPA 2012 Edition of the Drinking Water Standards and Health Advisories set a Maximum Contaminant Level Goal for Total Coliforms at 0.
  - 31.1.b The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Arsenic concentrations at 0.01 mg/L.
  - 31.1.c The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Antimony concentrations at 0.006 mg/L.
  - 31.1.d The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Mercury (inorganic) concentrations at 0.002 mg/L.
  - 31.1.f The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Copper concentrations at 1.0 mg/L.
  - 32.1.d The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Polychlorinated biphenyl concentrations at 0.0005 mg/L.
  - 32.1.e The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Vinyl Chloride at 0.002 mg/L.
  - 32.1.h The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Tetrachloroethylene concentrations at 0.005 mg/L.
  - 33.1.c The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Glyphosate concentrations at 0.7 mg/L.
  - 33.1.d The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for 2,4-Dichlorophenoxyacetic Acid concentrations at 0.07 mg/L.
  - 34.1.a The EPA 2012 Edition of the Drinking Water Standards and Health Advisories includes a Maximum Residual Disinfection Level for chlorine of 4 mg/L.
  - 34.1.b The EPA 2012 Edition of the Drinking Water Standards and Health Advisories includes a Maximum Residual Disinfection Level for chloramine of 4 mg/L.
  - 34.2.a The EPA's 2012 Edition of the Drinking Water Standards and Health Advisories notes that the 1998 Final Rule for Disinfection By-products set the total concentration for trihalomethanes at 0.08 mg/L.
  - 34.2.b The EPA's 2012 Edition of the Drinking Water Standards and Health Advisories notes that the 1998 Final Rule for Disinfection By-products set the total concentration for five Haloacetic acids at 0.06 mg/L.
  - 34.3.a The EPA's Drinking Water Standards and Health Advisories set a Maximum Contaminant Level for Fluoride at 4 mg/L.
  - 37.1.a The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Aluminum concentrations at 0.2 mg/L.
  - 37.1.b The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Chloride concentrations at 250 mg/L.
  - 37.1.c The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Manganese concentrations at 0.05 mg/L.
  - 37.1.e The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Sulfate concentrations at 250 mg/L.
  - 37.1.f The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Iron concentrations at 0.3
  - 37.1.g The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Zinc concentrations at 5 mg/L.
  - 37.1.h The EPA Secondary Drinking Water Regulations set a secondary Maximum Contaminant Level for Total Dissolved Solids concentrations at 500 mg/L.

- 55 American Heart Association. Whole Grains and Fiber.

  http://www.heart.org/HEARTORG/GettingHealthy/NutritionCenter/HealthyEating/Whole-Grains-and-Fiber UCM 303249 Article.jsp. Published 2014. Accessed September 15, 2014.
  - 39.1.d The AHA's Whole Grains and Fiber fact sheet identifies whole grains as good source of fiber and nutrients.
- Centers for Disease Control and Prevention. Trans Fat: The Facts. <a href="http://www.cdc.gov/nutrition/downloads/trans">http://www.cdc.gov/nutrition/downloads/trans</a> fat final.pdf. Published 2010. Accessed September 15, 2014.
  - 39.2.a The CDC Trans Fat: The Facts identifies partially hydrogenated oils as a source of trans fats that should be avoided.
- National Institute of Allergy and Infectious Diseases. Food Allergy: An Overview. <a href="http://www.niaid.nih.gov/topics/foodallergy/documents/foodallergy.pdf">http://www.niaid.nih.gov/topics/foodallergy/documents/foodallergy.pdf</a>. Published 2010. Accessed September 15, 2014.
  - 40.1.a The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children and adults is peanuts.
  - 40.1.b The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children and adults is fish.
  - 40.1.c The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children and adults is shellfish.
  - 40.1.d The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children, especially infants, is soy.
  - 40.1.e The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children is milk.
  - 40.1.f The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children is eggs.
  - 40.1.g The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children is wheat.
  - 40.1.h The NIAID publication, Food Allergy: An Overview states that one of the most common food allergens to children and adults is tree nuts.
  - 40.1.i The NIAID publication, Food Allergy: An Overview states that people with celiac disease cannot tolerate gluten.
- New York City Department of Health and Mental Hygiene. Food Standards.

  <a href="http://www.health.ny.gov/diseases/cardiovascular/heart\_disease/toolkits/docs/cafeterias\_cafes\_impleme\_ntation\_guide.pdf">http://www.health.ny.gov/diseases/cardiovascular/heart\_disease/toolkits/docs/cafeterias\_cafes\_impleme\_ntation\_guide.pdf</a>. Published 2012. Accessed September 15, 2014.
  - 47.1.a The New York State Department of Health's Cafes/Cafeterias Implementation Guide recommends eateries serve at least one healthy value meal that contains no more than 650 calories.
- 59 U.S. Green Building Council (USGBC). *LEED 2009 for Healthcare*. Washington D.C.: U.S. Green Building Council; 2009.
  - 25.5.a USGBC's LEED 2009 for Healthcare MR Credit sets limits for furniture and medical furnishings including textiles, finishes and dyes, to less than 100 ppm of at least four out of five chemical groups, including urea-formaldehyde.
  - 25.5.b USGBC's LEED 2009 for Healthcare MR Credit sets limits for furniture and medical furnishings including textiles, finishes and dyes, to less than 100 ppm of at least four out of five chemical groups, including urea-formaldehyde.
  - 25.5.c USGBC's LEED 2009 for Healthcare MR Credit sets limits for furniture and medical furnishings including textiles, finishes and dyes, to less than 100 ppm of at least four out of five chemical groups, including urea-formaldehyde.
- 60 California Department of Developmental Services. Diet Manual. <a href="http://www.dds.ca.gov/Publications/docs/DDSDietManual.pdf">http://www.dds.ca.gov/Publications/docs/DDSDietManual.pdf</a>. Published 2010. Accessed September 15, 2014.
  - 48.1.b The Diet Manual recommends providing a gluten-free diet to treat gluten induced enteropathy.
  - 48.1.c The Diet Manual recommends providing a milk-free or lactose-controlled diet to prevent or reduce symptoms associated with ingesting cow's milk or dairy containing products.
  - 48.1.d The Diet Manual recommends providing an egg-free diet for individuals with an egg allergy.
  - 48.1.e The Diet Manual recommends providing a vegetarian diet for those who wish to omit all or some animal products from their diet for religious, health, environmental, or ethical reasons.

- 48.1.f The Diet Manual recommends providing a vegetarian diet for those who wish to omit all or some animal products from their diet for religious, health, environmental, or ethical reasons.
- Food and Drug Administration. How to Understand and Use the Nutrition Facts Label. <a href="http://www.fda.gov/Food/IngredientsPackagingLabeling/LabelingNutrition/ucm274593.htm">http://www.fda.gov/Food/IngredientsPackagingLabeling/LabelingNutrition/ucm274593.htm</a>. Published 2004. Accessed September 15, 2014.
  - 44.1.b The FDA's How to Understand and Use the Nutrition Facts Label requires that packaged food items list the macronutrient content as both a weight and a percentage of the recommended daily value.
  - 44.1.c The FDA's How to Understand and Use the Nutrition Facts Label requires that packaged food items list the sugar content as a weight.
- 62 Community Preventive Services Task Force. Technology-supported Multicomponent Coaching or Counseling Interventions to Reduce Weight and Maintain Weight Loss.

  http://www.thecommunityguide.org/obesity/TechnologicalCoaching.html. Updated December 9, 2013. Accessed April 24, 2015.
  - 94.1.b Community Preventive Services Task Force's Technology-supported Multicomponent Coaching or Counseling Interventions to Reduce Weight and Maintain Weight Loss recommends technology-supported interventions, including the use of pedometers.
- U.S. Department of Agriculture. Organic Regulations. <a href="http://www.usda.gov/wps/portal/usda/usdahome?">http://www.usda.gov/wps/portal/usda/usdahome?</a> navid=organic-agriculture. Published 2014. Accessed September 10, 2014.
  - 49.1.a The USDA's Organic Requlations require that organic products do not contain genetically modified ingredients and avoid synthetic materials such as antibiotics and pesticides.
  - 49.2.b The USDA's Organic Requlations require that organic products do not contain genetically modified ingredients and avoid synthetic materials such as antibiotics and pesticides.
- 64 Certified Humane. Humane Farm Animal Care Comprehensive Animal Welfare Standards Comparison By Program. <a href="http://certifiedhumane.org/wp-content/uploads/2014/01/Comp.Standards.Comparison.Chart\_.wappendix.11.26.13.pdf">http://certifiedhumane.org/wp-content/uploads/2014/01/Comp.Standards.Comparison.Chart\_.wappendix.11.26.13.pdf</a>. Published 2013. Accessed September 15, 2014.
  - 49.2.a Humane Farm Animal Care's Humane Farm and Animal Care Comprehensive Animal Welfare Standards Comparison by Program requires that animals are uncaged throughout their lives and not exposed to antibiotics and hormones.
- Sloan Work and Family Research Network. Why is Employer-Supported Child Care an Important Business Issue?
  <a href="https://workfamily.sas.upenn.edu/sites/workfamily.sas.upenn.edu/files/imported/pdfs/EWS\_ESCC.pdf">https://workfamily.sas.upenn.edu/sites/workfamily.sas.upenn.edu/files/imported/pdfs/EWS\_ESCC.pdf</a>.
  Published 2009. Accessed September 15, 2014.
  - 93.2.a Sloan Work and Family Research Network's "Why is Employer-Supported Child Care an Important Business Issue" states that on-site childcare centers increase loyalty to an organization and reduce commuting time for employees.
  - 93.2.b Sloan Work and Family Research Network's "Why is Employer-Supported Child Care an Important Business Issue" notes that subsidies and vouchers provide tax credits for employers and lower employees' personal financial expenses.
- National Institutes of Health. Cooking Utensils and Nutrition. <a href="http://www.nlm.nih.gov/medlineplus/ency/article/002461.htm">http://www.nlm.nih.gov/medlineplus/ency/article/002461.htm</a>. Published 2014. Accessed September 15, 2014.
  - 46.1.a The National Institutes of Health's Cooking Utensils and Nutrition recommends that children be protected from ceramic cookware potentially containing lead.
  - 46.1.b The National Institutes of Health's Cooking Utensils and Nutrition identifies that dietary iron may increase due to the use of cast iron cookware.
  - 46.1.c The National Institutes of Health's Cooking Utensils and Nutrition identifies the low cost, durable, heat resistant and non-hazardous properties of stainless steel.
  - 46.1.d The National Institutes of Health's Cooking Utensils and Nutrition identifies the scratch resistant and cleanable properties of glass cutting boards.
  - 46.1.e The National Institutes of Health's Cooking Utensils and Nutrition identifies easily cleanable, scratch resistant and non-hazardous properties of anodized aluminum cookware.

- Centers for Disease Control and Prevention. Guideline for Hand Hygiene in Health-Care Settings. http://www.cdc.gov/mmwr/PDF/rr/rr5116.pdf. Published 2002. Accessed September 15, 2014.
  - 41.1.b The CDC's Guideline for Hand Hygiene in Health-Care Settings recommend the use of disposable towels for the maintenance of hand-hygiene.
  - 41.2.a The CDC's Guideline for Hand Hygiene in Health-Care Settings identifies that the practice of "topping off" hand soap dispensers can lead to bacterial contamination of soap.
- Facility Guidelines Institute. Guidelines for Design and Construction of Healthcare Facilities. <a href="http://www.apic.org/Resource\_/TinyMceFileManager/Practice\_Guidance/APIC-ASHE-Statement-electronic-faucets.pdf">http://www.apic.org/Resource\_/TinyMceFileManager/Practice\_Guidance/APIC-ASHE-Statement-electronic-faucets.pdf</a>. Published 2011. Accessed September 15, 2014.
  - 41.3.a The Guidelines for Design and Construction of Healthcare Facilities set the discharge point of hand-washing sinks at minimum 10 inches (25.40 centimeters) above the bottom of the basin.
  - 41.3.b The Guidelines for Design and Construction of Healthcare Facilities set the area of a hand washing basin at minimum 144 square inches (929 square cm), with a minimum 9-inch (22.86-cm) width or length.
- U.S. Department of Agriculture Food Safety and Inspection Service. Refrigeration and Food Safety: Specialized Compartments. <a href="https://www.fsis.usda.gov/wps/portal/fsis/topics/food-safety-education/get-answers/food-safety-fact-sheets/safe-food-handling/refrigeration-and-food-safety/ct\_index/">https://www.fsis.usda.gov/wps/portal/fsis/topics/food-safety-education/get-answers/food-safety-fact-sheets/safe-food-handling/refrigeration-and-food-safety/ct\_index/</a>. Published 2015. Accessed March 30, 2017.
  - 42.1.a The USDA Food Safety and Inspection Service recommends keeping raw meat in a separate storage space at the bottom of a refrigerator.
- 72 International Living Future Institute. JUST User Manual.

  <a href="http://justorganizations.com/sites/default/files/140808JUSTmanualRevisedwithoutBibliography.pdf">http://justorganizations.com/sites/default/files/140808JUSTmanualRevisedwithoutBibliography.pdf</a>.

  Published 2013. Accessed September 15, 2014.
  - 98.1.a The JUST program "provides an innovative social justice transparency platform for organizations to disclose their operations, including how they treat their employees and where they make financial and community investments."
- Hanks AS, Just DR, Wansink B. Smarter Lunchrooms Can Address New School Lunchroom Guidelines and Childhood Obesity. 2013. The Journal of Pediatrics, Volume 162, Issue 4, pp. 867-869.
  - 38.2.b Smarter Lunchrooms Can Address New School Lunchroom Guidelines and Childhood Obesity recommends color photo of fruit and vegetables on menu selection.
  - 38.2.c Smarter Lunchrooms Can Address New School Lunchroom Guidelines and Childhood Obesity recommends vegetable dishes be made available at the start of the food distribution line.
  - 38.2.d Smarter Lunchrooms Can Address New School Lunchroom Guidelines and Childhood Obesity recommends that fruits are made available at the checkout location.
- New York City Department of Health and Mental Hygiene. The Requirement to Post Calorie Counts on Menus, Section 81.50. <a href="https://www1.nyc.gov/assets/doh/downloads/pdf/notice/2015/noa-article81.pdf">https://www1.nyc.gov/assets/doh/downloads/pdf/notice/2015/noa-article81.pdf</a>. Published 2015. Accessed December 14, 2017.
  - 44.1.a The New York City Department of Health requires all eating establishments with 15 or more locations to post total calorie counts on menus.
- 75 U.S. Department of Agriculture. Cutting Boards and Food Safety. http://www.fsis.usda.gov/wps/portal/fsis/topics/food-safety-education/get-answers/food-safety-fact-sheets/safe-food-handling/cutting-boards-and-food-safety. Published 2013. Accessed September 15, 2014.
  - 46.2.a The USDA recommends consumers choose cutting boards with a nonporous surface such as marble.
  - 46.2.b The USDA recommends consumers choose cutting boards with a nonporous surface such as plastic.
  - 46.2.c The USDA recommends consumers choose cutting boards with a nonporous surface such as glass.
  - 46.2.d The USDA recommends consumers choose cutting boards with a nonporous surface such as pyroceramic.
  - 46.2.e The USDA recommends consumers choose cutting boards with a nonporous surface such as wood. Laminated boards may crack and split.
  - 46.2.f The USDA recommends consumers choose cutting boards with a surface such as bamboo.

- 76 World Health Organization. WHO Guidelines on Hand Hygiene in Health Care. <a href="http://www.who.int/gpsc/5may/tools/who\_guidelines-handhygiene\_summary.pdf">http://www.who.int/gpsc/5may/tools/who\_guidelines-handhygiene\_summary.pdf</a>. Published 2009. Accessed September 15, 2014.
  - 41.1.a The WHO Guidelines on Hand Hygiene in Health Care state that antibacterials offer no additional benefit to using non-antibacterial soap. Fragrance is not recommended because of the risk of allergies.
- 77 U.S. Department of Agriculture and U.S. Department of Health and Human Services. Dietary Guidelines for Americans, 2010. 7th Edition, December 2010. U.S. Government Printing Office, Washington, D.C.
  - 45.1.a The U.S. Department of Agriculture's Dietary Guidelines for Americans identifies that nutrition and physical activity decisions are influenced by marketing and media.
  - 45.2.a The U.S. Department of Agriculture's Dietary Guidelines for Americans identifies that nutrition and physical activity decisions are influenced by marketing and media.
  - 45.2.b The U.S. Department of Agriculture's Dietary Guidelines for Americans identifies that nutrition and physical activity decisions are influenced by marketing and media.
- Centers for Disease Control and Prevention. Guide to Strategies for Reducing the Consumption of Sugar-Sweetened Beverages.

  <a href="http://dhhs.ne.gov/publichealth/Documents/Guidance Doc Sugar Sweetened Bev.pdf">http://dhhs.ne.gov/publichealth/Documents/Guidance Doc Sugar Sweetened Bev.pdf</a> Published 2010.

  Accessed September 15, 2014.
  - 39.1.a The CDC's Guide to Strategies for Reducing the Consumption of Sugar-Sweetened Beverages identifies that limited access to sugar sweetened beverages can decrease their consumption and increase consumption of healthier beverages.
  - 39.1.b The CDC's Guide to Strategies for Reducing the Consumption of Sugar-Sweetened Beverages identifies that limited access to sugar sweetened beverages can decrease their consumption and increase consumption of healthier beverages.
  - 39.1.c The CDC's Guide to Strategies for Reducing the Consumption of Sugar-Sweetened Beverages identifies that limited access to sugar sweetened beverages can decrease their consumption and increase consumption of healthier beverages.
- 79 licht.de. licht.wissen 04: Office Lighting: Motivating and Efficient. Frankfurt; 2014: 35.
  - 55.1.b Office Lighting: Motivating and Efficient notes that to avoid glare caused by bright light sources, lamps should be shielded. The minimum shielding angle for lamp luminance of 20,000 50,000 cd/m² is 15°.
  - 55.1.c Office Lighting: Motivating and Efficient notes that to avoid glare caused by bright light sources, lamps should be shielded. The minimum shielding angle for lamp luminance of 50,000 500,000 cd/m² is 20°.
  - 55.1.d Office Lighting: Motivating and Efficient notes that to avoid glare caused by bright light sources, lamps should be shielded. The minimum shielding angle for lamp luminance of 500,000 cd/m² and above is 30°.
- 80 U.S. General Services Administration (GSA). *Facilities Standards for the Public Buildings Service*. March 2014, Washington, D.C., pp. 135-136.
  - 56.1.a The U.S. GSA's Facilities Standard for the Public Buildings Service Tier 1 High Performance rating requires view-preserving blinds.
  - 56.2.a The U.S. GSA's Facilities Standard for the Public Buildings Service Tier 1 High Performance rating requires view-preserving blinds.
  - 58.1.a The U.S. GSA's Facilities Standard for the Public Buildings Service Tier 1 High Performance rating requires CRI of 80 or higher.
  - 58.1.b The GSA's Facilities Standard for the Public Buildings Service Tier 2 High Performance requires a Color Rendering Index R9 of at least 50.
  - 59.1.a The GSA's Facilities Standard for the Public Buildings Service Baseline requires an average LRV for ceilings of 80% or greater.
  - 59.1.b The GSA's Facilities Standard for the Public Buildings Service Tier 2 High Performance recommends an average LRV on walls of 70%.
  - 60.1.a The GSA's Facilities Standard for the Public Buildings Service notes that automatic shade controls help occupants manage luminance levels.
  - 60.2.a The GSA's Facilities Standard for the Public Buildings Service notes that automatic controls for occupancy save energy.
  - 60.2.b The GSA's Facilities Standard for the Public Buildings Service notes that automatic controls for daylight dimming save energy.

- Ontario Ministry of Labour. Computer Ergonomics: Workstation Layout and Lighting. Toronto: Ontario Ministry of Labour; September 2004: 16.
  - 53.1.c The Ontario Ministry of Labour's "Computer Ergonomics: Workstation Layout and Lighting" provides a checklist for computer workstations, which includes checking that light levels fall within 300-500 lux, and also that task lights are provided if required.
  - 57.1.a The Ontario Ministry of Labour's "Computer Ergonomics: Workstations and Lighting" recommends that worker's line of sight is parallel to the plane of windows.
- Oxford Health Plans. Gym Reimbursement. <a href="https://www.oxhp.com/secure/materials/Gym\_Reimbursement.pdf">https://www.oxhp.com/secure/materials/Gym\_Reimbursement.pdf</a> . Published 2011. Accessed October 17, 2014.
  - 65.1.b Certain Oxford health plans allow for reimbursement of a portion of the gym membership fee for each 6-month period wherein the employee meets a 50-visit minimum.
- Business + Institution Furniture Manufacturers Association. *BIFMA Ergonomics Guideline Ultimate Test for Fit.* Grand Rapids: Business + Institution Furniture Manufacturers Association; 2013: 3.
  - 73.1.a BIFMA's Ergonomics Guideline for Furniture Used in Office Work Spaces Designed for Computer Use recommends monitors be positioned at heights that permit seated or standing users to view the entire monitor display quickly and with little effort
- Community Preventive Services Task Force. Obesity Prevention and Control: Worksite Programs. <a href="http://www.thecommunityguide.org/obesity/workprograms.html">http://www.thecommunityguide.org/obesity/workprograms.html</a>. Published 2013. Accessed September 15, 2014.
  - 66.1.a The Community Preventive Services Task Force recommends worksite physical activity programs, including the provision of on-site facilities for exercise.
- 85 U.S. Green Building Council. Pilot Credit 75: Clean Construction. <a href="http://www.usgbc.org/node/4810551?">http://www.usgbc.org/node/4810551?</a> return=/credits/new-construction/v4/pilot-credits. Published 2013. Accessed October 18, 2014.
  - 24.4.a USGBC's LEED v4 Pilot Credit 75: Clean Construction requires non-road diesel engine vehicles on site that are 25 horsepower and greater to comply with the US EPA Tier 4 PM emissions standards, or a local equivalent.
  - 24.4.b USGBC's LEED v4 Pilot Credit 75: Clean Construction requires 95% of all diesel engine contractor/subcontractor vehicles meet the requirements set forth in the US EPA model year 2007 on-road standards, or a local equivalent.
  - 24.4.c USGBC's LEED v4 Pilot Credit 75: Clean Construction requires all equipment, vehicles and loading/unloading to be located away from air intakes and operable openings of adjacent buildings.
- Walk Score. Walk Score Methodology. <a href="http://www.walkscore.com/methodology.shtml">http://www.walkscore.com/methodology.shtml</a> . Published 2014. Accessed October 17, 2014.
  - 67.3.a Walk Score's City and Neighborhood Ranking identifies that a Walk Score® of 70 or greater is one that allows most errands to be accomplished on foot.
- New York City Departments of Design and Construction, Health and Mental Hygiene, Transportation, City Planning. Active Design Guidelines: Promoting Physical Activity and Health in Design. Published 2010: 4-7; 34; 43; 72-76; 85-87.
  - 64.1.b NYC Active Design Guidelines: Promoting Physical Activity and Health in Design recommends including permanent signage encouraging stair use, to be integrated with the building's wayfinding program.
  - 64.2.c NYC Active Design Guidelines recommends a strategy for making stairs wide enough for traveling in groups, or in two directions, a width of at least 56 inches can comfortably accommodate this.
  - 64.3.a NYC Active Design Guidelines recommends strategies for encouraging stair use through a number of methods, including the incorporation of artwork into the stair environment.
  - 64.3.b NYC Active Design Guidelines recommends strategies for encouraging stair use through a number of methods, including adding music to stairwells.
  - 64.3.d NYC Active Design Guidelines recommends strategies for encouraging stair use through a number of methods, including highlighting interesting views onto nature or interior areas.
  - 67.1.a NYC Active Design Guidelines identifies the design of pedestrian-friendly streets with a number of features, including benches, as a key recommended measure to encourage active environments.

- 67.1.b NYC Active Design Guidelines recommends strategies for creating pedestrian and bicycle-friendly public spaces, including the provision of both movable and fixed seating.
- 67.1.c NYC Active Design Guidelines recommends strategies for increasing walking, including the provision of supportive infrastructure along walking routes, such as drinking fountains and water refilling stations.
- 67.2.a NYC Active Design Guidelines recommends strategies for creating pedestrian and bicycle-friendly public spaces, including the provision of water fountains.
- 67.2.b NYC Active Design Guidelines: Promoting Physical Activity and Health in Design recommends strategies for creating attractive plaza spaces.
- 67.2.d NYC Active Design Guidelines: Promoting Physical Activity and Health in Design recommends incorporating temporary and permanent public art installations into the streetscape to provide a more attractive and engaging environment.
- 68.1.a The NYC Active Design Guidelines recommend providing physical activity spaces such as exercise rooms, active play spaces, and multi-purpose recreational spaces in public, workplace and residential buildings.
- 68.2.a NYC Active Design Guidelines recommend locating places of residence and work near existing recreational facilities, walking paths, parks, and waterfront areas.
- 88 U.S. Internal Revenue Service. Internal Revenue Code of 1986 §132(f). Washington, D.C.: Internal Revenue Service; 1986.
  - 65.1.a IRC Section 132(f) on qualified transportation fringe allows employers to offer employees the opportunity to set aside a portion of their salary to pay for certain transportation expenses.
- 89 U.S. Department of Justice Civil Rights Division. 2010 ADA Standards for Accessible Design. Washington, D.C.: U.S. Dept of Justice Civil Rights Division; 2010.
  - 72.1.a The Department of Justice Civil Rights Division's 2010 ADA Standards for Accessible Design set accessibility standards for new construction and alterations.
- 90 U.S. General Services Administration Center for Workplace Strategy Public Buildings Service. Sound Matters: How to Achieve Acoustic Comfort in the Contemporary Office. Washington, D.C.: 2012: 11, 29, 32, 33, 36.
  - 75.1.a The General Services Administration's Sound Matters recommends to carefully consider the effect on neighboring workstations when locating supporting activities, i.e. copier rooms, coffee bars, entries to conference rooms.
  - 75.2.a The General Services Administration's Sound Matters recommends a background noise maximum of NC 40 for open plan workspaces.
  - 75.2.b The General Services Administration's Sound Matters recommends a background noise maximum of NC 35 for private offices.
  - 78.1.a The General Services Administration's Sound Matters recommends RT60 of 0.6 seconds for meeting rooms.
  - 79.1.a The General Services Administration's Sound Matters recommends that sound masking should be considered a technique to achieve acoustic comfort in contemporary offices.
  - 79.2.a The General Services Administration's Sound Matters recommends sound masking at 45-48 dBA for open plan workspaces.
  - 79.2.b The General Services Administration's Sound Matters recommends sound masking at 40-42 dBA for private offices.
  - 80.1.a The General Services Administration's Sound Matters recommends this NRC value for open plan workspaces.
  - 80.1.b The General Services Administration's Sound Matters recommends this NRC value for meeting rooms and teleconference rooms.
  - 80.2.a The General Services Administration's Sound Matters recommends a minimum NRC of 0.8 on at least 25% of two adjacent walls for enclosed workspaces.
  - 80.2.b The General Services Administration's Sound Matters recommends this NRC value for open plan workspaces.
  - 80.2.c The General Services Administration's Sound Matters recommends this NRC value for quiet open offices which have head-height walls.
  - 81.1.a The General Services Administration's Sound Matters recommends this NIC value for private offices.
  - 81.1.b The General Services Administration's Sound Matters recommends this NIC value for teleconference rooms.

- 81.2.a The General Services Administration's Sound Matters recommends door gaskets to help prevent noise intrusion into offices.
- 81.2.b The General Services Administration's Sound Matters recommends that the undercut should be shielded in some fashion such as a sweep or drop seal gasket.
- 81.2.c The General Services Administration's Sound Matters advises that as it relates to acoustics, hollow core doors are only good to poor.
- 81.3.a The General Services Administration's Sound Matters recommends caulking gypsum partition slabs as an effective sound blocking technique.
- 81.3.b The General Services Administration's Sound Matters recommends staggering gypsum partition slabs as an effective sound blocking technique.
- 81.3.c The General Services Administration's Sound Matters recommends plugging holes as an effective sound blocking technique.
- Greenbaum E., Meinert E. Vaccinating Against the Flu: A Business Case.

  http://www.businessgrouphealth.org/pub/f3137df6-2354-d714-5143-de37eb0ecd7c. Published 2010.

  Accessed October 16, 2014.
  - 92.1.d The National Business Group on Health's Vaccinating Against the Flu: A Business Case notes to consider offering opportunities for employees to get vaccinated against the flu on-site.
- 92 ASHRAE. Standard 55: Thermal Environmental Conditions for Human Occupancy, Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers; 2013: 4; 8-13.
  - 21.2.b ASHRAE Standard 55 provides guidelines for displacement ventilation systems for thermal environmental comfort.
  - 76.1.a ASHRAE Standard 55: Thermal Environmental Conditions for Human Occupancy sets best practices for thermal comfort in buildings.
  - 76.2.a ASHRAE Standard 55: Thermal Environmental Conditions for Human Occupancy sets best practices for thermal comfort in buildings.
- 93 U.S. Department of Energy. *Radiant Heating*. <a href="http://energy.gov/energysaver/articles/radiant-heating">http://energy.gov/energysaver/articles/radiant-heating</a>. Published 2012. Accessed September 15, 2014.
  - 83.1.a The Department of Energy identifies radiant heating systems as more efficient and less likely to distribute allergens than forced-air systems.
  - 83.1.b The Department of Energy identifies radiant heating systems as more efficient and less likely to distribute allergens than forced-air systems.
  - 83.2.a The Department of Energy recommends radiant heating systems over forced-air systems as they are usually more efficient and do not distribute allergens.
  - 83.2.b The Department of Energy identifies radiant heating systems as more efficient and less likely to distribute allergens than forced-air systems.
- National Heart, Lung, and Blood Institute. *The Practical Guide: Identification, Evaluation, and Treatment of Overweight and Obesity in Adults*. <a href="http://www.nhlbi.nih.gov/files/docs/guidelines/prctgd-c.pdf">http://www.nhlbi.nih.gov/files/docs/guidelines/prctgd-c.pdf</a>. Published 2000. Accessed April 24, 2015.
  - 94.1.a The NHLBI Obesity Education Initiative's "Practical Guide: Identification, Evaluation, and Treatment of Overweight and Obesity in Adults" states that self-monitoring a behavior usually changes that behavior in the desired direction.
- 95 Marcus, C. C. & Sachs, N. A. Therapeutic Landscapes: An Evidence-based Approach to Designing Healing. Hoboken: John Wiley & Sons; 2013.
  - 100.1.b Marcus and Sachs' Therapeutic Landscapes: An Evidence-based Approach to Designing Healing provide guidelines for planting, including the provision of gardens that have an approximate ratio of 70% softscape (plants) to 30% hardscape.
  - 100.2.a Marcus and Sachs' Therapeutic Landscapes: An Evidence-based Approach to Designing Healing recommends providing opportunities for indoor nature connection, such as through the use of potted plants.
  - 100.2.b Marcus and Sachs' Therapeutic Landscapes: An Evidence-based Approach to Designing Healing recommends incorporating vegetation growing at multiple heights, such as through planted walls.
  - 100.3.a Marcus and Sachs' Therapeutic Landscapes: An Evidence-based Approach to Designing Healing recommends providing at least one water feature.

- 76 The New South Wales Planning Department. The Residential Flat Design Code. <a href="http://www.planning.nsw.gov.au/programservices/pdf/designcode/03\_part03\_a.pdf">http://www.planning.nsw.gov.au/programservices/pdf/designcode/03\_part03\_a.pdf</a>. Published 2002. Accessed September 15, 2014.
  - 99.1.a New South Wales Department of Planning's Residential Flat Design Code recommends a minimum ceiling height of 2.7 m for all habitable rooms, and a preferred minimum of 2.4 m for all non-habitable rooms.
- 97 Employee Assistance Professionals Association. Standards and Professional Guidelines for Employee Assistance Programs.
  - http://www.valueoptions.com/providers/Handbook/treatment/EAP\_Guidelines.pdf. Published 2010. Accessed October 17, 2014.
  - 95.1.a The EAPA Standards and Professional Guidelines recommend Employee Assistance Programs with short-term counseling, referrals, and follow-up services for employees who have personal and work-related concerns or issues.
- The White House. Presidential Memorandum -- Modernizing Federal Leave Policies for Childbirth, Adoption and Foster Care to Recruit and Retain Talent and Improve Productivity. <a href="https://www.whitehouse.gov/the-press-office/2015/01/15/presidential-memorandum-modernizing-federal-leave-policies-childbirth-ad">https://www.whitehouse.gov/the-press-office/2015/01/15/presidential-memorandum-modernizing-federal-leave-policies-childbirth-ad</a>. Published January 15, 2015. Accessed June 11, 2015.
  - 93.1.a A 2015 Presidential Memorandum from the White House directs federal agencies to ensure employee policies offering 240 hours (equivalent to 6 workweeks) of advanced (i.e., paid) sick leave for appropriate uses, including the birth or adoption of a child.
- 119 CWT Solutions Group. Stress Triggers for Business Travelers: Traveler Survey Analysis. <a href="http://www.cwt-solutions-group.com/export/sites/cwtpreprod/.content/files/cwt-stress-triggers-for-business-travelers.pdf">http://www.cwt-solutions-group.com/export/sites/cwtpreprod/.content/files/cwt-stress-triggers-for-business-travelers.pdf</a>. Published 2012. Accessed September 24, 2014.
  - 91.1.c CWT Solutions Group's Stress Triggers for Business Travelers notes that, compared to respondents living alone, respondents living with a partner reported that traveling during the weekends was more stressful.
  - 91.1.d In CWT Solutions Group's Stress Triggers for Business Travelers, "not able to maintain workout routine" was listed as a medium stress factor.
- 176 U.S. Environmental Protection Agency. *Moisture Control Guidance for Building Design, Construction and Maintenance*. Washington, DC: U.S. Environmental Protection Agency; Dec 2013. EPA 402-F-13053.
  - 12.1.a EPA 402-F-13053 notes that effectively controlling water intrusion requires directing drain rain and irrigation water away frm the building.
  - 12.1.b EPA 402-F-13053 notes to design buildings such that the interior floor grade is above the local water table.
  - 12.1.c EPA 402-F-13053 notes to design exterior walls to manage rainwater.
  - 12.1.d EPA 402-F-13053 advises to consider key elements of moisture behavior, including transport mechanisms such as moisture wicking through porous materials.
  - 12.2.a EPA 402-F-13053 notes that leaks in pipes or tanks in the plumbing system can release water.
  - 12.2.b EPA 402-F-13053 notes that moisture problems include leaks in pressurized pipes and vessels in appliances that use water.
  - 12.2.c EPA 402-F-13053 advises to consider key elements of moisture behavior, including transport mechanisms such as moisture wicking through porous materials.
  - 12.2.d EPA 402-F-13053 notes to "avoid enclosing wet materials in new construction by protecting moisture-sensitive and porous materials" as part of a comprehensive strategy to control liquid water movement.
  - 12.3.a EPA 402-F-13053 notes that in low-rise buildings, damp basements and crawlspaces may add water vapor to the air.
  - 12.3.b EPA 402-F-13053 notes that air that infiltrates the building through air leaks represents one of the largest sources of humidity.
  - 12.3.c EPA 402-F-13053 notes that condensation may be caused by "excessively high dew point, unusually cold surfaces, or a combination of the two."
  - 12.3.d EPA 402-F-13053 notes that "oversized cooling systems do not solve humidity control problems—instead, they cause them."
  - 12.4.a EPA 402-F-13053 advises to use materials able to tolerate repeated wetting and drying in wet areas. The document also notes that particularly in buildings in cold climates, it is important to consider the condensation potential of glazing designs.

- 12.4.b EPA 402-F-13053 notes that exterior cladding and other measures can intercept most of the rain water and direct it away from the building.
- 12.4.c EPA 402-F-13053 advises to use materials able to tolerate repeated wetting and drying in wet areas.
- 12.4.d EPA 402-F-13053 advises to use low-permeability insulating sheathing and interior finishes.
- ASHRAE Standing Standard Project Committee 188. ANSI/ASHRAE Standard 188-2015: Legionellosis: Risk Management for Building Water Systems. Atlanta; 2015.
  - 36.5.a ASHRAE's Hazard Analysis and Critical Control Point Plan requires the development of a team comprised of members who understand the building's water systems and the principles of the plan.
  - 36.5.b ASHRAE's Hazard Analysis and Critical Control Point Plan requires teams to develop at least two process flow diagrams mapping the receipt, processing and delivery of water to occupants.
  - 36.5.c ASHRAE's Hazard Analysis and Critical Control Point plan for preventing building associated legionellosis includes conducting a hazard analysis.
  - 36.5.d ASHRAE's Hazard Analysis ad Critical Control Point plan includes identifying critical control points.
  - 36.5.e ASHRAE's Hazard Analysis and Critical Control Point plan for preventing building associated legionellosis includes monitoring identified control points and establishing procedures for corrective measures.
  - 36.5.f ASHRAE's Hazard Analysis and Critical Control Point plan for preventing building-associated legionellosis includes establishing documentation and verification procedures.
- Business + Institutional Furniture Manufacturers Association. BIFMA G1 2013 Ergonomics Guideline: Ergonomics Guideline for Furniture Used in Office Work Spaces Designed for Computer Use. 2013.; and Human Factors and Ergonomics Society. ANSI/HFES 100-2007 Human Factors Engineering of Computer Workstations. 2007.
  - 73.3.a HFES standards accommodate at least 90% of the North American workforce. The BIFMA G1 provides recommendations for sizing furniture to accommodate the 5th percentile female to the 95th percentile male of the North American population.
  - 73.3.b HFES standards accommodate at least 90% of the North American workforce. The BIFMA G1 provides recommendations for sizing furniture to accommodate the 5th percentile female to the 95th percentile male of the North American population.
- 180 Wansink B. *Smarter Lunchrooms*. In: Slim By Design: Mindless Eating Solutions for Everyday Life. New York, NY: HarperCollins Publishers; 2014: 185-224.
  - 38.2.a In Slim by Design, Wansink notes that in one intervention in a school, positioning the salad bar away from the wall led to an increase in salad bar sales by 200 to 300 percent within a few weeks.
- 181 Global Reporting Initiative. GRI Standards. <a href="https://www.globalreporting.org/standards/">https://www.globalreporting.org/standards/</a>. Published 2017. Accessed December 5, 2018.
  - 98.1.b The GRI Standards are the first global standards for sustainability reporting and represent the global best practice for reporting on a range of economic, environmental and social impacts.
- 184 Cohen RA. Impact of type of insurance plan on access and utilization of health care services for adults aged 18-64 years with private health insurance: United States, 2007-2008. NCHS Data Brief. 2010(28): 1-8.
  - 92.1.b A 2010 NCHS Data Brief reports that according to the National Health Interview Survey, for privately insured adults, having a flexible spending account or health savings account was associated with increase health care utilization for some services.
  - 92.1.c A 2010 NCHS Data Brief reports that according to the National Health Interview Survey, adults with private health insurance without a health savings account were more likely to have unmet medical needs compared to those with health savings accounts.
- 185 Cohen RA, Martinez ME. Health Insurance Coverage: Early Release of Estimates From the National Health Interview Survey, January–March 2012. Atlanta, GA: Centers for Disease Control and Prevention. 2013.
  - 92.1.a A report from the National Center for Health Statistics found that, based on responses from the National Health Interview Survey, an estimated 45.5 million people in the US were uninsured, including 18.5% of respondents who had employment.

# Appendix C: Tables

The following tables are referred to in various requirements of the Standard. The first letter of the table name denotes the Concept chapter it refers to, e.g. "A" for Air.

**Table A1: High Touch Surfaces** 

**Table A2: Reduced Risk Pesticides** 

Table A3: (Removed in Q2 2017 Addenda)

**Table A4: Cleaning Protocol** 

**Table A5: Mercury Limits** 

**Table L1: Melanopic Ratio** 

**Table L2: Melanopic and Visual Response** 

### **Table A1: High-Touch Surfaces**

These are surfaces that require more frequent and thorough sanitization. Cleaning protocols should list these surfaces within the project and incorporate the correct cleaning instructions accordingly. Based on CDC Environmental Checklist for Monitoring Terminal Cleaning.

#### Non-porous

**Tabletops** 

Doorknobs

Elevator buttons

Telephones

Public digital devices and keyboards

Light switches

Chairs

Bathroom handles and fixtures

Countertops in bathrooms

Toilet handles and lids

Bathtubs and shower walls and floor

Interior shower and bath surfaces

Kitchen handles and fixtures

Countertops in kitchens

Non-disposable medical devices

Bed railing

Serving trays and bed tables

#### **Porous**

Rugs

Upholstered furniture covers

Fabric curtains

Towels

Bedding: linens, pillow cases and comforter

### **Table A2: Reduced Risk Pesticides**

For up-to-date and immediate San Francisco Hazard Review Process evaluation results, the Pesticide Research Institute's PestSmart tool [1] or Pesticide Product Evaluator tool [2] may be used.

If a pesticide has not yet been evaluated by the Pesticide Research Institute's tools above, use the Guide to the San Francisco's Reduced Risk Pesticide List Hazard Tier Review Process, which outlines the procedure for evaluating pesticides [3].

<sup>[1]</sup> http://pesticideresearch.com/site/pestsmart/

<sup>[2]</sup> https://pesticideresearch.com/site/evaluator/

<sup>[3]</sup> http://sfenvironment.org/sites/default/files/fliers/files/sfe\_th\_guide\_to\_reduced\_risk\_pesticide\_listposted.pdf

## **Table A3: (Removed in Q2 2017 Addenda)**

Table A3 was removed from the WELL Building Standard as part of the Q2 2017 Addenda process. However, please note that the remaining tables (Table A4 and Table A5) were not renumbered so that project teams that registered prior to the release of the Q2 addenda can continue to access these tables as they had previously.

### **Table A4: Cleaning Protocol**

#### **Cleaning Equipment and Training**

An effective cleaning protocol must consider equipment use and staff training. A project's cleaning practice must include or be evaluated to incorporate the following changes and/or additions.

#### Cleaning Equipment

Projects must implement a program for the use of sustainably powered cleaning equipment that abide by Green Seal 42, Standard for Commercial and Institutional Cleaning Services for Powered Equipment Use/ Maintenance Plan or local equivalent for projects outside the United States. Additionally, the following requirements must be met:

- 1. For projects in humid climates, as designated by ANSI/ASHRAE/IESNA 90.1-2007, powder carpet cleaning systems must be used in place of traditional carpet extraction systems.
- 2. Battery-powered equipment must be equipped with recyclable, spill-proof rechargeable batteries.
- 3. Equipment must be designed with safeguards, such as rollers or rubber bumpers, to reduce potential damage to building surfaces.

#### **Program Training**

A successful cleaning program requires, beyond the selection of safer products, proper training and use of green cleaning materials and products. Projects must have in place a cleaning program that addresses each of the following:

- 1. Chemical Measuring and Dilution: A control system; for example a wall mounted dispensing system for concentrates, that limits direct handling and worker exposure to chemicals, ensures proper dilution of mixtures and prevents overuse or waste.
- 2. Training on Procedures: Sequencing of cleaning steps and use of personal protective equipment.
- 3. Training on Safety: Training on how to reduce and prevent ergonomic injuries and exposure to hazardous materials.
- 4. Annual In-Service Training: Training on use of certified green cleaning products, materials and equipment.
- 5. Training on Purchasing: Training of purchasing personnel in the selection of green cleaning materials.

#### Cleaning, Disinfection and Hand Hygiene Product Selection

By establishing criteria that consider human health endpoints, certified cleaning products eliminate harmful ingredient contents and reduce potential associated hazards. Cleaning, disinfection, sanitization, hand soap, and sanitizers selected for use must meet the below criteria. Alternatively, projects may use products labeled as "safer" or "healthier" by a Type 1 eco-labeling program, as defined by ISO 14024:1999 (or more recent version) and developed by a member of the Global Ecolabelling Network (GEN) or labeled as such by a third-party certification recognized by the government where the project is located. These include products certified as EPA's Safer Choice, GreenSeal, Environmental Choice New Zealand, EU Ecolabel, Nordic Ecolabel, etc.

#### 1. Cleaning Products

Cleaning products, per appropriate functional class or use case, are not formulated or manufactured with intentionally added ingredients that are:

- 1. Classified under the Globally Harmonized System (GHS) with one or more of following hazard statements: H340 (May cause genetic defects), H350 (May cause cancer), or H360 (May damage fertility of the unborn child).
- 2. Classified under GHS with the following hazard statement: H372 (Causes damage to organs through prolonged or repeated exposure).
- 3. Classified under the Globally Harmonized System (GHS) with one or more of following hazard statements: H317 (May cause an allergic skin reaction), H334 (May cause allergy or asthma symptoms or breathing difficulties if inhaled).

#### 2. Hand Soaps and Hand Sanitizers

Soaps, shampoos and hand sanitizers provided by the project:

1. Use no antimicrobial agents (other than as a preservative) except where prescribed by health codes, public health advisories or other regulations, such as food service and health care requirements.

#### **Disinfection and Sanitization**

High-touch surfaces present increased risk for contamination, particularly in high transit areas. A cleaning protocol must take into account the degree to which disinfection and sanitization are necessary. Disinfection and sanitization reduce exposure to microorganisms and parasites that can result in decreased disease and illness, however these practices are also increasingly linked to a rising prevalence of hypersensitivity disorders and autoimmune diseases, especially in industrialized nations.

#### **Disinfection Limitation**

To effectively apply these cleaning principles, projects must:

- 1. Maintain a list of high touch surfaces.
- 2. Limit disinfection to high-touch surfaces.

#### **Entryway Maintenance**

Entryway maintenance and care is critical to minimizing dirt and pollutants tracked in from the outdoor environment. Clean and well-maintained entryways can contribute greatly to improved indoor air quality.

#### **Entryways and Lobbies**

In order to minimize the migration of contaminants into the building, projects shall adhere to the below cleaning and maintenance guidelines for entryways and lobbies:

- 1. Rollout mats are wet cleaned, including the underside, at least once every two days and allowed to dry before use.
- 2. Rollout mats must be vacuumed using a vacuum with a beater bar in both directions, at least once a day and twice a day during inclement weather.
- 3. Non-toxic and environmentally safe ice melting compounds (e.g., non-corrosive, non- phosphate) must be selected through the winter months.

# Table A5: Mercury Limits

This table indicates allowable mercury limits in lamps, as referred to in the Fundamental Material Safety feature. Values from LEED PBT source reduction - mercury prerequisite

#### **Fluorescent**

Lamp	Maximum Hg Conten		
Compact, integral ballast	3.5	mg	
Compact, nonintegral ballast	3.5	mg	
T-5, circular	9	mg	
T-5, linear	2.5	mg	
T-8, eight-foot	10	mg	
T-8, four-foot	3.5	mg	
T-8, two- and three-foot	3.5	mg	
T-8, U-bent	6	mg	

#### **High-pressure sodium**

Lamp	<b>Maximum Hg Content</b>		
400 W or less	10	mg	
Over 400 W	32	mg	

### **Table L1: Melanopic Ratio**

This unit Equivalent Melanopic Lux (EML) was proposed by Lucas and others (Lucas et al., "Measuring and using light in the melanopsin age." Trends in Neuroscience, Jan 2014). The authors provided a toolbox which for a desired spectrum derives equivalent " $\alpha$ -opic" lux for each of the five photoreceptors in the eye (three cones, rods, and the ipRGCs). The authors selected scaling constants such that each of the values would be identical to each other and the standard definition of lux for a light spectrum of perfectly uniform energy (CIE Standard Illuminant E).

Given a spectrum of light, each equivalent  $\alpha$ -opic lux is related to each other by a constant. To calculate the equivalent melanopic lux (EML), multiply the visual lux (L) designed for or measured in a building by this ratio (R): EML = L × R. For example, if incandescent lights provide 200 lux in a space, they will also produce 108 equivalent melanopic lux. If daylight is modeled to provide the same visual brightness (200 lux), it will also provide 220 equivalent melanopic lux.

Similar melanopic ratios can be determined by incorporating the spectrum of the desired source into the calculations in Table L2. Both the authors of the journal article and the IWBI have spreadsheets to aid in this calculation.

### **Table L2: Melanopic and Visual Response**

To calculate the melanopic ratio of light, start by obtaining the light output of the lamp at each 5 nm increment, either from manufacturer or by using a spectrometer. Then, multiply the output by the melanopic and visual curves given below to get the melanopic and visual responses. Finally, divide the total melanopic response by the total visual response and multiply the quotient by 1.218.

Although the ipRGCs have a peak sensitivity at about 480 nm, the melanopic response in this table peaks at 490 nm because it takes into account the adult eye's lens, which preferentially transmits longer wavelength light.

Wavelength	Light Output	Melanopic Curve	Melanopic Response	Visual Curve	Visual Response
380		0.00092		0.00004	-
385		0.00167		0.00006	
390		0.00309		0.00012	
395		0.00588		0.00022	
400		0.01143		0.00040	
405		0.02281		0.00064	
410		0.04615		0.00121	
415		0.07948		0.00218	
420		0.13724		0.00400	
425		0.18710		0.00730	
430		0.25387		0.01160	
435		0.32068		0.01684	
440		0.40159		0.02300	
445		0.47400		0.02980	
450		0.55372		0.03800	
455		0.62965		0.04800	
460		0.70805		0.06000	
465		0.78522		0.07390	
470		0.86029		0.09098	
475		0.91773		0.11260	
480		0.96560		0.13902	
485		0.99062		0.16930	
490		1.00000		0.20802	
495		0.99202		0.25860	
500		0.96595		0.32300	
505		0.92230		0.40730	
510		0.86289		0.50300	
515		0.78523		0.60820	
520		0.69963		0.71000	
525		0.60942		0.79320	
530		0.51931		0.86200	
535		0.43253		0.91485	
540		0.35171		0.95400	
545		0.27914		0.98030	
550		0.21572		0.99495	
555		0.16206		1.00000	
560		0.11853		0.99500	
565		0.08435		0.97860	

570	0.05870	0.95200
575	0.04001	0.91540
580	0.02687	0.87000
585	0.01786	0.81630
590	0.01179	0.75700
595	0.00773	0.69490
600	0.00507	0.63100
605	0.00332	0.56680
610	0.00218	0.50300
615	0.00143	0.44120
620	0.00095	0.38100
625	0.00063	0.32100
630	0.00042	0.26500
635	0.00042	0.21700
640	0.00019	0.17500
645	0.00017	0.13820
650	0.00019	0.10700
655	0.00007	0.08160
660	0.00004	0.06100
665	0.00004	0.04458
670	0.00003	0.03200
675	0.00002	0.02320
680	0.00001	0.01700
685	0.00001	0.01700
690	0.00000	0.00821
695	0.00000	0.00572
700	0.00000	0.00410
705	0.00000	0.00293
710	0.00000	0.00299
715	0.00000	0.00148
		0.00146
720	0.00000	0.00704
725	0.00000	0.00074
730 735	0.00000	0.00032
740		
745	0.00000	0.00025
	0.00000	0.00017
750	0.00000	0.00012
755	0.00000 0.00000	0.00008
760		0.00006
765	0.00000	0.00004
770	0.00000	0.00003
775	0.00000	0.00002
780	0.00000	0.00001
To	tals:	

### **Appendix D: Feature Types and Verification Methods**

Parts of the WELL Building Standard fall into one of three categories with respect to the interventions necessary for their completion – design elements, protocols or performance standards. Design standards require that a specific technology or design strategy be used. Protocols are also prescriptive, but for building or company policies or schedules. Performance-based standards mandate environmental conditions and therefore are affected by both building design and operation. They are also technology- and practice-neutral, allowing flexibility in how a project meets acceptable quantified thresholds.

The following table also displays the type of documentation relevant (if any) for each Part of a Feature. Project teams should consult this table to understand what document needs to be submitted to demonstrate that the Part has been satisfied, or if no action is necessary because a WELL Performance Testing Agent will check the Part on-site during the Performance Verification through a performance test or spot check.

- -Policy document: a formally adopted set of rules of operation or behavior followed by or implemented in the project to comply with WELL feature requirements.
- -Operations schedule is a document outlining routine or cyclical maintenance implemented in the project to comply with WELL feature requirements.

These documents cover the following:

- (1) The procedures or strategies in place that make up the policy.
- (2) The scope of the building or space to which the policy applies.
- (3) Details on all parties involved in the policy.
- (4) Details on accessibility of the policy by the parties involved.
- (5) The time period for which this policy document is valid.

AIR	Letters of Assurance	Annotated Documents	On-Site Assessment	
FEATURE 01: AIR QUALITY STANDARDS				
PART 1 (Performance) STANDARDS FOR VOLATILE SUBSTANCES			PERFORMANCE TEST	
PART 2 (Performance) STANDARDS FOR PARTICULATE MATTER AND INORGANIC GASES			PERFORMANCE TEST	
PART 3 (Performance) RADON			PERFORMANCE TEST	
FEATURE 02: SMOKING BAN				
PART 1 (Protocol) INDOOR SMOKING BAN		POLICY DOCUMENT		
PART 2 (Protocol) OUTDOOR SMOKING BAN			VISUAL INSPECTION	
FEATURE 03: VENTILATION EFFECTIVENESS				
PART 1 (Design) VENTILATION DESIGN	MEP			
PART 2 (Design) DEMAND CONTROLLED VENTILATION	MEP			
PART 3 (Design) SYSTEM BALANCING	MEP OR CONTRACTOR			

AIR	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 04: VOC REDUCTION	, locarance	Documents	——————————————————————————————————————
PART 1 (Design) INTERIOR PAINTS AND COATINGS	ARCHITECT & CONTRACTOR		
PART 2 (Design) INTERIOR ADHESIVES AND SEALANTS	ARCHITECT & CONTRACTOR		
PART 3 (Design) FLOORING	ARCHITECT & CONTRACTOR		
PART 4 (Design) INSULATION	ARCHITECT & CONTRACTOR		
PART 5 (Design) FURNITURE AND FURNISHINGS	ARCHITECT & OWNER		
FEATURE 05: AIR FILTRATION			
PART 1 (Design) FILTER ACCOMMODATION	MEP		SPOT CHECK
PART 2 (Design) PARTICLE FILTRATION	MEP		SPOT CHECK
PART 3 (Design) AIR FILTRATION MAINTENANCE		OPERATIONS SCHEDULE	
FEATURE 06: MICROBE AND MOLD CONTROL			
PART 1 (Design) COOLING COIL MOLD REDUCTION		MEP DRAWING OR OPERATIONS SCHEDULE	
PART 2 (Performance) MOLD INSPECTIONS			VISUAL INSPECTION
FEATURE 07: CONSTRUCTION POLLUTION MANAGE	SEMENT		
PART 1 (Protocol) DUCT PROTECTION	CONTRACTOR		
PART 2 (Protocol) FILTER REPLACEMENT	CONTRACTOR		
PART 3 (Protocol) MOISTURE ABSORPTION MANAGEMENT	CONTRACTOR		
PART 4 (Protocol) DUST CONTAINMENT AND REMOVAL	CONTRACTOR		
FEATURE 08: HEALTHY ENTRANCE			
PART 1 (Design) ENTRYWAY WALK-OFF SYSTEMS			VISUAL INSPECTION
PART 2 (Design) ENTRYWAY AIR SEAL			VISUAL INSPECTION
FEATURE 09: CLEANING PROTOCOL			
PART 1 (Protocol) CLEANING PLAN FOR OCCUPIED SPACES		OPERATIONS SCHEDULE	

AIR	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 10: PESTICIDE MANAGEMENT PART 1 (Protocol) PESTICIDE USE		OPERATIONS SCHEDULE	
FEATURE 11: FUNDAMENTAL MATERIAL SAFETY PART 1 (Design) ASBESTOS AND LEAD RESTRICTION	ARCHITECT & MEP		
PART 2 (Protocol) LEAD ABATEMENT		REMEDIATION REPORT	
PART 3 (Protocol) ASBESTOS ABATEMENT		REMEDIATION REPORT	
PART 4 (Protocol) POLYCHLORINATED BIPHENYL ABATEMENT		REMEDIATION REPORT	
PART 5 (Design) MERCURY LIMITATION	MEP		
FEATURE 12: MOISTURE MANAGEMENT			
PART 1 (Design) EXTERIOR LIQUID WATER MANAGEMENT		PROFESSIONAL NARRATIVE	
PART 2 (Design) INTERIOR LIQUID WATER MANAGEMENT		PROFESSIONAL NARRATIVE	
PART 3 (Design) CONDENSATION MANAGEMENT		PROFESSIONAL NARRATIVE	
PART 4 (Design) MATERIAL SELECTION AND PROTECTION		PROFESSIONAL NARRATIVE	
FEATURE 13: AIR FLUSH			
PART 1 (Protocol) AIR FLUSH	CONTRACTOR		
FEATURE 14: AIR INFILTRATION MANAGEMENT			
PART 1 (Design) AIR LEAKAGE TESTING		COMMISSIONING REPORT	
FEATURE 15: INCREASED VENTILATION			
PART 1 (Design) INCREASED OUTDOOR AIR SUPPLY	MEP		
FEATURE 16: HUMIDITY CONTROL			
PART 1 (Design) RELATIVE HUMIDITY	MEP		SPOT MEASUREMENT
FEATURE 17: DIRECT SOURCE VENTILATION			
PART 1 (Design) POLLUTION ISOLATION AND EXHAUST		MECHANICAL AND ARCHITECTURAL DRAWINGS	

AIR	Letters of Assurance	Annotated Documents	On-Site Assessment	
FEATURE 18: AIR QUALITY MONITORING AND FEE	DBACK			
PART 1 (Design) INDOOR AIR MONITORING	MEP		SPOT CHECK	
PART 2 (Protocol) AIR DATA RECORD KEEPING AND RESPONSE		POLICY DOCUMENT		
PART 3 (Design) ENVIRONMENTAL MEASURES DISPLAY			VISUAL INSPECTION	
FEATURE 19: OPERABLE WINDOWS				
PART 1 (Design) FULL CONTROL	ARCHITECT		SPOT CHECK	
PART 2 (Design) OUTDOOR AIR MEASUREMENT		POLICY DOCUMENT		
PART 3 (Design) WINDOW OPERATION MANAGEMENT	OWNER		SPOT CHECK	
FEATURE 20: OUTDOOR AIR SYSTEMS				
PART 1 (Design) DEDICATED OUTDOOR AIR SYSTEMS	MEP			
FEATURE 21: DISPLACEMENT VENTILATION				
PART 1 (Design) DISPLACEMENT VENTILATION DESIGN AND APPLICATION	MEP			
PART 2 (Design) SYSTEM PERFORMANCE	MEP			
FEATURE 22: PEST CONTROL				
PART 1 (Design) PEST REDUCTION		POLICY DOCUMENT	SPOT CHECK	
PART 2 (Performance) PEST INSPECTION			VISUAL INSPECTION	
FEATURE 23: ADVANCED AIR PURIFICATION				
PART 1 (Design) CARBON FILTRATION	MEP		SPOT CHECK	
PART 2 (Design) AIR SANITIZATION	MEP		SPOT CHECK	
PART 3 (Protocol) AIR QUALITY MAINTENANCE		OPERATIONS SCHEDULE		

AIR	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 24: COMBUSTION MINIMIZATION			
PART 1 (Design) APPLIANCE AND HEATER COMBUSTION BAN	OWNER		SPOT CHECK
PART 2 (Design) LOW-EMISSION COMBUSTION SOURCES	MEP		
PART 3 (Protocol) ENGINE EXHAUST REDUCTION			VISUAL INSPECTION
PART 4 (Protocol) CONSTRUCTION EQUIPMENT	CONTRACTOR		
FEATURE 25: TOXIC MATERIAL REDUCTION			
PART 1 (Design) PERFLUORINATED COMPOUND LIMITATION	ARCHITECT & OWNER		
PART 2 (Design) FLAME RETARDANT LIMITATION	ARCHITECT & CONTRACTOR		
PART 3 (Design) PHTHALATE (PLASTICIZERS) LIMITATION	ARCHITECT & CONTRACTOR		
PART 4 (Design) ISOCYANATE-BASED POLYURETHANE LIMITATION	ARCHITECT & CONTRACTOR		
PART 5 (Design) UREA-FORMALDEHYDE RESTRICTION	ARCHITECT & CONTRACTOR		
FEATURE 26: ENHANCED MATERIAL SAFETY			
PART 1 (Design) PRECAUTIONARY MATERIAL SELECTION	ARCHITECT, CONTRACTOR, & OWNER		
FEATURE 27: ANTIMICROBIAL ACTIVITY FOR SURFA	ACES		
PART 1 (Design) HIGH-TOUCH SURFACES		ARCHITECTURAL DRAWING OR OPERATIONS SCHEDULE	
FEATURE 28: CLEANABLE ENVIRONMENT			
PART 1 (Design) MATERIAL PROPERTIES	ARCHITECT & CONTRACTOR		SPOT CHECK
PART 2 (Design) CLEANABILITY	ARCHITECT & CONTRACTOR		SPOT CHECK
FEATURE 29: CLEANING EQUIPMENT			
PART 1 (Protocol) EQUIPMENT AND CLEANING AGENTS		OPERATIONS SCHEDULE	
PART 2 (Design) CHEMICAL STORAGE			VISUAL INSPECTION

WATER	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 30: FUNDAMENTAL WATER QUALITY PART 1 (Performance) SEDIMENT			PERFORMANCE TEST
PART 2 (Performance) MICROORGANISMS			PERFORMANCE TEST
FEATURE 31: INORGANIC CONTAMINANTS PART 1 (Performance)			
DISSOLVED METALS			PERFORMANCE TEST
FEATURE 32: ORGANIC CONTAMINANTS PART 1 (Performance)			
ORGANIC POLLUTANTS			PERFORMANCE TEST
FEATURE 33: AGRICULTURAL CONTAMINANTS			
PART 1 (Performance) HERBICIDES AND PESTICIDES			PERFORMANCE TEST
PART 2 (Performance) FERTILIZERS			PERFORMANCE TEST
FEATURE 34: PUBLIC WATER ADDITIVES			
PART 1 (Performance) DISINFECTANTS			PERFORMANCE TEST
PART 2 (Performance) DISINFECTANT BYPRODUCTS			PERFORMANCE TEST
PART 3 (Performance) FLUORIDE			PERFORMANCE TEST
FEATURE 35: PERIODIC WATER QUALITY TESTING			
PART 1 (Protocol)  QUARTERLY TESTING		OPERATIONS SCHEDULE	
PART 2 (Protocol) WATER DATA RECORD KEEPING AND RESPONSE		POLICY DOCUMENT	
FEATURE 36: WATER TREATMENT			
PART 1 (Design) ORGANIC CHEMICAL REMOVAL	MEP		SPOT CHECK
PART 2 (Design) SEDIMENT FILTER	MEP		SPOT CHECK
PART 3 (Design) MICROBIAL ELIMINATION	MEP		SPOT CHECK
PART 4 (Protocol) WATER QUALITY MAINTENANCE		OPERATIONS SCHEDULE	
PART 5 (Design) LEGIONELLA CONTROL		PROFESSIONAL NARRATIVE	

WATER	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 37: DRINKING WATER PROMOTION			
PART 1 (Performance) DRINKING WATER TASTE PROPERTIES			PERFORMANCE TEST
PART 2 (Design) DRINKING WATER ACCESS	ARCHITECT		SPOT CHECK
PART 3 (Protocol) WATER DISPENSER MAINTENANCE		OPERATIONS SCHEDULE	
NOURISHMENT	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 38: FRUITS AND VEGETABLES			
PART 1 (Protocol) FRUIT AND VEGETABLE VARIETY		POLICY DOCUMENT	SPOT CHECK
PART 2 (Protocol) FRUIT AND VEGETABLE PROMOTION		POLICY DOCUMENT	SPOT CHECK
FEATURE 39: PROCESSED FOODS			
PART 1 (Protocol) REFINED INGREDIENT RESTRICTIONS		POLICY DOCUMENT	SPOT CHECK
PART 2 (Protocol) TRANS FAT BAN		POLICY DOCUMENT	SPOT CHECK
FEATURE 40: FOOD ALLERGIES			
PART 1 (Protocol) FOOD ALLERGY LABELING		POLICY DOCUMENT	SPOT CHECK
FEATURE 41: HAND WASHING			
PART 1 (Protocol) HAND WASHING SUPPLIES		POLICY DOCUMENT	SPOT CHECK
PART 2 (Protocol) CONTAMINATION REDUCTION			VISUAL INSPECTION
PART 3 (Design) SINK DIMENSIONS	ARCHITECT		SPOT CHECK
FEATURE 42: FOOD CONTAMINATION			
PART 1 (Design) COLD STORAGE	OWNER		SPOT CHECK
FEATURE 43: ARTIFICIAL INGREDIENTS			
PART 1 (Protocol) ARTIFICIAL SUBSTANCE LABELING		POLICY DOCUMENT	SPOT CHECK
FEATURE 44: NUTRITIONAL INFORMATION			
PART 1 (Protocol) DETAILED NUTRITIONAL INFORMATION			VISUAL INSPECTION

NOURISHMENT	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 45: FOOD ADVERTISING			
PART 1 (Protocol) ADVERTISING AND ENVIRONMENTAL CUES			VISUAL INSPECTION
PART 2 (Protocol) NUTRITIONAL MESSAGING			VISUAL INSPECTION
FEATURE 46: SAFE FOOD PREPARATION MATERIAL	_S		
PART 1 (Protocol) COOKING MATERIAL		POLICY DOCUMENT	SPOT CHECK
PART 2 (Protocol) CUTTING SURFACES		POLICY DOCUMENT	SPOT CHECK
FEATURE 47: SERVING SIZES			
PART 1 (Protocol) MEAL SIZES		POLICY DOCUMENT	SPOT CHECK
PART 2 (Protocol) DISHWARE		POLICY DOCUMENT	SPOT CHECK
FEATURE 48: SPECIAL DIETS			
PART 1 (Protocol) FOOD ALTERNATIVES		POLICY DOCUMENT	
FEATURE 49: RESPONSIBLE FOOD PRODUCTION			
PART 1 (Protocol) SUSTAINABLE AGRICULTURE		POLICY DOCUMENT	
PART 2 (Protocol) HUMANE AGRICULTURE		POLICY DOCUMENT	
FEATURE 50: FOOD STORAGE			
PART 1 (Design) STORAGE CAPACITY	OWNER		SPOT CHECK
FEATURE 51: FOOD PRODUCTION			
PART 1 (Design) GARDENING SPACE	OWNER		SPOT CHECK
PART 2 (Design) PLANTING SUPPORT	OWNER		SPOT CHECK
FEATURE 52: MINDFUL EATING			
PART 1 (Design) EATING SPACES		ARCHITECTURAL DRAWING	
PART 2 (Design) BREAK AREA FURNISHINGS	OWNER		SPOT CHECK

LIGHT	Letters of Assurance	Annotated Documents	On-Site Assessment	
FEATURE 53: VISUAL LIGHTING DESIGN				
PART 1 (Design) VISUAL ACUITY FOR FOCUS	ARCHITECT	POLICY DOCUMENT	SPOT MEASUREMENT	
PART 2 (Design) BRIGHTNESS MANAGEMENT STRATEGIES		PROFESSIONAL NARRATIVE		
FEATURE 54: CIRCADIAN LIGHTING DESIGN				
PART 1 (Design) MELANOPIC LIGHT INTENSITY FOR WORK AREAS	ARCHITECT		SPOT MEASUREMENT	
FEATURE 55: ELECTRIC LIGHT GLARE CONTROL				
PART 1 (Design) LUMINAIRE SHIELDING	ARCHITECT			
PART 2 (Design) GLARE MINIMIZATION	ARCHITECT			
FEATURE 56: SOLAR GLARE CONTROL				
PART 1 (Design) VIEW WINDOW SHADING	ARCHITECT		SPOT CHECK	
PART 2 (Design) DAYLIGHT MANAGEMENT	ARCHITECT		SPOT CHECK	
FEATURE 57: LOW-GLARE WORKSTATION DESIGN				
PART 1 (Design) GLARE AVOIDANCE			VISUAL INSPECTION	
FEATURE 58: COLOR QUALITY				
PART 1 (Design) COLOR RENDERING INDEX	ARCHITECT			
FEATURE 59: SURFACE DESIGN				
PART 1 (Design) WORKING AND LEARNING AREA SURFACE REFLECTIVITY	ARCHITECT			
FEATURE 60: AUTOMATED SHADING AND DIMMIN	IG CONTROLS			
PART 1 (Design) AUTOMATED SUNLIGHT CONTROL	MEP			
PART 2 (Design) RESPONSIVE LIGHT CONTROL	MEP			
FEATURE 61: RIGHT TO LIGHT				
PART 1 (Design) LEASE DEPTH		ARCHITECTURAL DRAWING	SPOT CHECK	
PART 2 (Design) WINDOW ACCESS		ARCHITECTURAL DRAWING	SPOT CHECK	
FEATURE 62: DAYLIGHT MODELING				
PART 1 (Design) HEALTHY SUNLIGHT EXPOSURE		MODELING REPORT		

LIGHT	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 63: DAYLIGHTING FENESTRATION			
PART 1 (Design) WINDOW SIZES FOR WORKING AND LEARNING SPACES		ARCHITECTURAL DRAWING	SPOT CHECK
PART 2 (Design) WINDOW TRANSMITTANCE IN WORKING AND LEARNING AREAS	ARCHITECT		
PART 3 (Design) UNIFORM COLOR TRANSMITTANCE	ARCHITECT		
FITNESS	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 64: INTERIOR FITNESS CIRCULATION			
PART 1 (Design) STAIR ACCESSIBILITY AND PROMOTION			VISUAL INSPECTION
PART 2 (Design) STAIRCASE DESIGN			VISUAL INSPECTION
PART 3 (Design) FACILITATIVE AESTHETICS			VISUAL INSPECTION
FEATURE 65: ACTIVITY INCENTIVE PROGRAMS			
PART 1 (Organizational Protocol) ACTIVITY INCENTIVE PROGRAMS		POLICY DOCUMENT	
FEATURE 66: STRUCTURED FITNESS OPPORTUNITIE	ES		
PART 1 (Organizational Protocol) FITNESS PROGRAMS		POLICY DOCUMENT	
PART 2 (Organizational Protocol) FITNESS EDUCATION		POLICY DOCUMENT	
FEATURE 67: EXTERIOR ACTIVE DESIGN			
PART 1 (Design) PEDESTRIAN AMENITIES	OWNER		SPOT CHECK
PART 2 (Design) PEDESTRIAN PROMOTION	OWNER		SPOT CHECK
PART 3 (Design) NEIGHBORHOOD CONNECTIVITY		ANNOTATED MAP	
FEATURE 68: PHYSICAL ACTIVITY SPACES			
PART 1 (Design) SITE SPACE DESIGNATION FOR OFFICES		ARCHITECTURAL DRAWING	
PART 2 (Design) EXTERNAL EXERCISE SPACES		ANNOTATED MAP	

FITNESS	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 69: ACTIVE TRANSPORTATION SUPPORT			
PART 1 (Design) BICYCLE STORAGE AND SUPPORT	OWNER		SPOT CHECK
PART 2 (Design) POST COMMUTE AND WORKOUT FACILITIES	ARCHITECT		SPOT CHECK
FEATURE 70: FITNESS EQUIPMENT			
PART 1 (Design) CARDIORESPIRATORY EXERCISE EQUIPMENT	OWNER		SPOT CHECK
PART 2 (Design) MUSCLE-STRENGTHENING EXERCISE EQUIPMENT	OWNER		SPOT CHECK
FEATURE 71: ACTIVE FURNISHINGS			
PART 1 (Design) ACTIVE WORKSTATIONS	OWNER		SPOT CHECK
PART 2 (Design) PREVALENT STANDING DESKS	OWNER		SPOT CHECK
COMFORT	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 72: ACCESSIBLE DESIGN	7.554141166	Bocaments	7 (35C33) HCH
PART 1 (Design) ACCESSIBILITY AND USABILITY	ARCHITECT		
FEATURE 73: ERGONOMICS: VISUAL AND PHYSICA	.L		
PART 1 (Design) VISUAL ERGONOMICS	OWNER		SPOT CHECK
PART 2 (Design) DESK HEIGHT FLEXIBILITY	OWNER		SPOT CHECK
PART 3 (Design) SEAT FLEXIBILITY	OWNER		SPOT CHECK
FEATURE 74: EXTERIOR NOISE INTRUSION			
PART 1 (Performance) SOUND PRESSURE LEVEL			PERFORMANCE TEST
FEATURE 75: INTERNALLY GENERATED NOISE			
PART 1 (Protocol) ACOUSTIC PLANNING		PROFESSIONAL NARRATIVE	
PART 2 (Performance) MECHANICAL EQUIPMENT SOUND LEVELS			PERFORMANCE TEST
FEATURE 76: THERMAL COMFORT			
PART 1 (Design) VENTILATED THERMAL ENVIRONMENT	MEP		SPOT MEASUREMENT
PART 2 (Design) NATURAL THERMAL ADAPTATION	MEP		SPOT MEASUREMENT

COMFORT	Letters of Assurance	Annotated Documents	On-Site Assessment	
FEATURE 77: OLFACTORY COMFORT  PART 1 (Design)  SOURCE SEPARATION		ARCHITECTURAL DRAWING		
FEATURE 78: REVERBERATION TIME PART 1 (Performance) REVERBERATION TIME			PERFORMANCE TEST	
FEATURE 79: SOUND MASKING  PART 1 (Design)  SOUND MASKING USE	MEP			
PART 2 (Performance) SOUND MASKING LIMITS			PERFORMANCE TEST	
FEATURE 80: SOUND REDUCING SURFACES  PART 1 (Design)  CEILINGS	ARCHITECT			
PART 2 (Design) VERTICAL SURFACES	ARCHITECT			
FEATURE 81: SOUND BARRIERS  PART 1 (Design)  WALL CONSTRUCTION SPECIFICATIONS	ARCHITECT			
PART 2 (Design) DOORWAY SPECIFICATIONS	ARCHITECT & CONTRACTOR			
PART 3 (Design) WALL CONSTRUCTION METHODOLOGY	CONTRACTOR			
FEATURE 82: INDIVIDUAL THERMAL CONTROL				
PART 1 (Protocol) FREE ADDRESS		POLICY DOCUMENT		
PART 2 (Protocol) PERSONAL THERMAL COMFORT DEVICES	OWNER		SPOT CHECK	
FEATURE 83: RADIANT THERMAL COMFORT				
PART 1 (Design)  LOBBIES AND OTHER COMMON SPACES	MEP			
PART 2 (Design) OFFICES AND OTHER REGULARLY OCCUPIED SPACES	MEP			
MIND	Letters of Assurance	Annotated Documents	On-Site Assessment	
FEATURE 84: HEALTH AND WELLNESS AWARENESS PART 1 (Protocol) WELL BUILDING STANDARD® GUIDE			VISUAL INSPECTION	
PART 2 (Protocol) HEALTH AND WELLNESS LIBRARY		PROFESSIONAL NARRATIVE	VISUAL INSPECTION	

MIND	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 85: INTEGRATIVE DESIGN			
PART 1 (Protocol) STAKEHOLDER CHARRETTE		PROFESSIONAL NARRATIVE	
PART 2 (Protocol) DEVELOPMENT PLAN		PROFESSIONAL NARRATIVE	
PART 3 (Protocol) STAKEHOLDER ORIENTATION		PROFESSIONAL NARRATIVE	
FEATURE 86: POST-OCCUPANCY SURVEYS			
PART 1 (Protocol) OCCUPANT SURVEY CONTENT		POLICY DOCUMENT	
PART 2 (Protocol) INFORMATION REPORTING		POLICY DOCUMENT	
FEATURE 87: BEAUTY AND DESIGN I			
PART 1 (Design) BEAUTY AND MINDFUL DESIGN		PROFESSIONAL NARRATIVE	
FEATURE 88: BIOPHILIA I - QUALITATIVE			
PART 1 (Design) NATURE INCORPORATION		PROFESSIONAL NARRATIVE	
PART 2 (Design) PATTERN INCORPORATION		PROFESSIONAL NARRATIVE	
PART 3 (Design) NATURE INTERACTION		PROFESSIONAL NARRATIVE	
FEATURE 89: ADAPTABLE SPACES			
PART 1 (Design) STIMULI MANAGEMENT	ARCHITECT		SPOT CHECK
PART 2 (Design) PRIVACY	ARCHITECT		SPOT CHECK
PART 3 (Design) SPACE MANAGEMENT	OWNER		SPOT CHECK
PART 4 (Protocol) WORKPLACE SLEEP SUPPORT	OWNER		SPOT CHECK
FEATURE 90: HEALTHY SLEEP POLICY			
PART 1 (Organizational Protocol) NON-WORKPLACE SLEEP SUPPORT		POLICY DOCUMENT	
FEATURE 91: BUSINESS TRAVEL			
PART 1 (Organizational Protocol) TRAVEL POLICY		POLICY DOCUMENT	
FEATURE 92: BUILDING HEALTH POLICY			
PART 1 (Organizational Protocol) HEALTH BENEFITS		POLICY DOCUMENT	

MIND	Letters of Assurance	Annotated Documents	On-Site Assessment	
FEATURE 93: WORKPLACE FAMILY SUPPORT				
PART 1 (Organizational Protocol) PARENTAL LEAVE		POLICY DOCUMENT		
PART 2 (Organizational Protocol) EMPLOYER SUPPORTED CHILD CARE		POLICY DOCUMENT		
PART 3 (Organizational Protocol) FAMILY SUPPORT		POLICY DOCUMENT		
FEATURE 94: SELF-MONITORING				
PART 1 (Organizational Protocol) SENSORS AND WEARABLES		POLICY DOCUMENT		
FEATURE 95: STRESS AND ADDICTION TREATMENT	-			
PART 1 (Organizational Protocol) MIND AND BEHAVIOR SUPPORT		POLICY DOCUMENT		
PART 2 (Organizational Protocol) STRESS MANAGEMENT		POLICY DOCUMENT		
FEATURE 96: ALTRUISM				
PART 1 (Organizational Protocol) CHARITABLE ACTIVITIES		POLICY DOCUMENT		
PART 2 (Organizational Protocol) CHARITABLE CONTRIBUTIONS		POLICY DOCUMENT		
FEATURE 97: MATERIAL TRANSPARENCY				
PART 1 (Design) MATERIAL INFORMATION	ARCHITECT, CONTRACTOR, & OWNER			
PART 2 (Design) ACCESSIBLE INFORMATION			VISUAL INSPECTION	
FEATURE 98: ORGANIZATIONAL TRANSPARENCY				
PART 1 (Organizational Protocol) TRANSPARENCY PROGRAM PARTICIPATION		POLICY DOCUMENT	SPOT CHECK	
FEATURE 99: BEAUTY AND DESIGN II				
PART 1 (Design) CEILING HEIGHT		ARCHITECTURAL DRAWING	SPOT CHECK	
PART 2 (Design) ARTWORK		PROFESSIONAL NARRATIVE		
PART 3 (Design) SPATIAL FAMILIARITY		PROFESSIONAL NARRATIVE		

MIND	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 100: BIOPHILIA II - QUANTITATIVE			
PART 1 (Design) OUTDOOR BIOPHILIA	OWNER		SPOT CHECK
PART 2 (Design) INDOOR BIOPHILIA	ARCHITECT		SPOT CHECK
PART 3 (Design) WATER FEATURE	ARCHITECT		SPOT CHECK
INNOVATION	Letters of Assurance	Annotated Documents	On-Site Assessment
FEATURE 101: INNOVATION I			
PART 1 (Innovation) INNOVATION PROPOSAL		INNOVATION PROPOSAL	
PART 2 (Innovation) INNOVATION SUPPORT		INNOVATION PROPOSAL	
FEATURE 102: INNOVATION II			
PART 1 (Innovation) INNOVATION PROPOSAL 2		INNOVATION PROPOSAL	
PART 2 (Innovation) INNOVATION SUPPORT 2		INNOVATION PROPOSAL	
FEATURE 103: INNOVATION III			
PART 1 (Innovation) INNOVATION PROPOSAL 3		INNOVATION PROPOSAL	
PART 2 (Innovation) INNOVATION SUPPORT 3		INNOVATION PROPOSAL	
FEATURE 104: INNOVATION IV			
PART 1 (Innovation) INNOVATION PROPOSAL 4		INNOVATION PROPOSAL	
PART 2 (Innovation) INNOVATION SUPPORT 4		INNOVATION PROPOSAL	
FEATURE 105: INNOVATION V			
PART 1 (Innovation) INNOVATION PROPOSAL 5		INNOVATION PROPOSAL	
PART 2 (Innovation) INNOVATION SUPPORT 5		INNOVATION PROPOSAL	

# Appendix E: (Removed in Q1 2018 Addenda)

Appendix E was removed from the WELL Building Standard as part of the Q1 2018 Addenda process. Projects pursuing both LEED and WELL should refer to the crosswalk document, Applying LEED and The WELL Building Standard™, available at wellcertified.com/resources. Note that the remaining appendices were not renamed so that project teams that registered prior to the release of these addenda can continue to access the appendices as they had previously.

# Appendix F: (Removed in Q1 2018 Addenda)

Appendix F was removed from the WELL Building Standard as part of the Q1 2018 Addenda process. Projects pursuing both the Living Building Challenge and WELL should refer to the crosswalk document, Living Building Challenge® & the WELL Building Standard™, available at wellcertified.com/resources. Note that the remaining appendices were not renamed so that project teams that registered prior to the release of these addenda can continue to access the appendices as they had previously.

### **Appendix G: External Reviewers**

The IWBI would like to extend its sincere gratitude to the following external reviewers for their time in reviewing and providing critical feedback.

Jennifer Berthelot-Jelovic A SustainAble Production

Bill Browning Terrapin

Lisa Cohen, PhD Beth Israel Medical Center

Lisa Colicchio CBRE
Mary Davidge Google

Jason Garay Cancer Care Ontario

Chad Groshart Atelier Ten

Kevin Hall, PhDNational Institutes of HealthSamer HattarJohns Hopkins University

Beth Heider Skanska Hormos Janssens Interface

Caroline Karmann UC Berkeley, Center for the Built Environment

Thomas Knittel HOK

Jonathan Little, PhD UBC, School of Health and Exercise Sciences

Nadav Malin Building Green

Timothy McAuley, PhD Consulting for Health, Air, Nature and a Greener Environment

Robert OexmanSleep to Live InstituteLisa PettersonSERA ArchitectsRichard PiacentiniPhipps Conservatory

Dave Pogue CBRE

Christopher Pollock Cerami Associates

Kirsten Ritchie Gensler

Keith Roach, MD Weill-Cornell Medical College

Andrew Rundle, DrPH Columbia University, Mailman School of Public Health

Charles Salter CM Salter

Megan Schwarzman, MD

University of California, Berkeley

Susie See WSP Flack + Kurtz

Thomas Sheridan, ScD Massachussets Institute of Technology

Eric Soloday Integral Group

Katherine von Stackelberg, ScD Harvard, School of Public Health

Ellen Tohn Tohn Environmental
Ted Van Der Linden DPR Construction
Kathy Wardle Perkins and Will

Lauren Yarmuth YR&G
Peter Yost Building Green

Technical Development Subject Matter Experts U.S. Green Building Council

Certification Review Subject Matter Experts Green Building Certification Institute

# **Appendix H: Concept & Feature References**

The following pages list the sources used for statistics and other material in the descriptions for the Concepts and Features in the WELL Building Standard.

### Air

Joshi SM. The Sick Building Syndrome. 2008. Indian Journal of Occupational and Environmental Medicine, Volume 12, Issue 2, pp. 61-64.

Abdullahi KL, Delgado-Saborit JM, Harrison RM. Emissions and Indoor Concentrations of Particulate Matter and its Specific Chemical Components from Cooking: A Review. 2013. Atmospheric Environment, Volume 71, pp. 260-294.

- U.S. Department of Health and Human Services. Healthy People 2010: Leading Health Indicators. www.healthypeople.gov/2010/document/html/uih/uih 4.htm. Accessed April 16, 2015.
- U.S. Environmental Protection Agency. Indoor Air Facts No. 4: Sick Building Syndrome. <a href="http://www.epa.gov/iag/pdfs/sick-building-factsheet.pdf">http://www.epa.gov/iag/pdfs/sick-building-factsheet.pdf</a>. Published February 1991. Accessed April 16, 2015.
- U.S. Environmental Protection Agency. An Introduction to Indoor Air Quality (IAQ): Volatile Organic Compounds (VOCs). <a href="http://www.epa.gov/iag/voc.html">http://www.epa.gov/iag/voc.html</a>. Updated July 9, 2012. Accessed April 16, 2015.
- U.S. Environmental Protection Agency. National Ambient Air Quality Standards. 40 CFR Part 50. <a href="https://www.epa.gov/criteria-air-pollutants/naags-table">https://www.epa.gov/criteria-air-pollutants/naags-table</a>. Revised October 2011. Updated December 14, 2012. Accessed September 16, 2014.
- U.S. Environmental Protection Agency. Exposure Factors Handbook: 2011 Edition. EPA/600/R-090/052F. Published September 2011.

World Health Organization. 7 Million Premature Deaths Annually Linked to Air Pollution. http://www.who.int/mediacentre/news/releases/2014/air-pollution/en/. Accessed April 16, 2015.

### 01 Air quality standards

U.S. Environmental Protection Agency. Indoor Air Pollution: An Introduction for Health Professionals. <a href="http://www.epa.gov/iag/pubs/hpquide.html">http://www.epa.gov/iag/pubs/hpquide.html</a>. Updated July 3, 2012. Accessed April 22, 2015.

### 02 Smoking ban

American Lung Association. What's in a Cigarette? <a href="http://www.lung.org/stop-smoking/about-smoking/facts-figures/whats-in-a-cigarette.html">http://www.lung.org/stop-smoking/about-smoking/facts-figures/whats-in-a-cigarette.html</a>. Accessed February 11, 2015.

Jamal A, Agaku IT, O'Connor E, King BA, Kenemer JB, et al. Current Cigarette Smoking Among Adults—United States, 2005-2013. 2014. Morbidity and Mortality Weekly Report, Volume 63, pp. 1108-1112.

U.S. Environmental Protection Agency. Indoor Air Pollution: An Introduction for Health Professionals. <a href="http://www.epa.gov/iag/pubs/hpquide.html">http://www.epa.gov/iag/pubs/hpquide.html</a>. Updated July 3, 2012. Accessed April 22, 2015.

### 03 Ventilation effectiveness

U.S. Environmental Protection Agency. Make Your House a Healthy Home. EPA-908-K-10-001. January 2012. <a href="http://www2.epa.gov/sites/production/files/2014-05/documents/healthy-homes-brochure-english.pdf">http://www2.epa.gov/sites/production/files/2014-05/documents/healthy-homes-brochure-english.pdf</a>. Accessed May 19, 2015.

#### 04 VOC reduction

McGwin G, Lienert J, Kennedy JI. Formaldehyde Exposure and Asthma in Children: A Systematic Review. 2010. Environmental Health Perspectives, Volume 118, pp. 313-317.

Krzyzanowski M, Quackenboss JJ, Lebowitz MD. Chronic Respiratory Effects of Indoor Formaldehyde Exposure. 1990. Environmental Research, Volume 52, pp. 117-125.

International Agency for Research on Cancer. IARC Monographs: Chemical Agents and Related Occupations. Volume 100F. 2012. WHO Press, Geneva.

U.S. Environmental Protection Agency. Benzene. <a href="http://www.epa.gov/ttnatw01/hlthef/benzene.html">http://www.epa.gov/ttnatw01/hlthef/benzene.html</a>. Updated October18, 2013. Accessed April 22, 2015.

U.S. Environmental Protection Agency. An Introduction to Indoor Air Quality (IAQ): Volatile Organic Compounds (VOCs). <a href="http://www.epa.gov/iag/voc.html">http://www.epa.gov/iag/voc.html</a>. Updated July 9, 2012. Accessed April 16, 2015.

#### 05 Air filtration

Pope CA, Burnet RT, Thun MJ, Calle EE, Krewski D, et al. Lung Cancer, Cardiopulmonary Mortality, and Long-term Exposure to Fine Particulate Air Pollution. 2002. Journal of the American Medical Association, Volume 287, pp. 1132-1141

Kunzli N, Jerrett M, Mack WJ, Beckerman B, LaBree L, et al. Ambient Air Pollution and Atherosclerosis in Los Angeles. 2005. Environmental Health Perspectives, Volume 113, pp. 201-206.

Chen LH, Knutsen SF, Shavlik D, Beeson WL, Petersen F, et al. The Association Between Fatal Coronary Heart Disease and Ambient Particulate Air Pollution: Are Females at Greater Risk? 2005. Environmental Health Perspectives, Volume 113, pp. 1723-1729.

#### 06 Microbe and mold control

U.S. Environmental Protection Agency. Chapter 1: Introduction to Molds. <a href="http://www.epa.gov/mold/moldcourse/chapter1.html">http://www.epa.gov/mold/moldcourse/chapter1.html</a>. Updated March 8, 2012. Accessed April 22, 2015.

#### 09 Cleaning protocol

U.S. Environmental Protection Agency. An Introduction to Indoor Air Quality (IAQ): Volatile Organic Compounds (VOCs). http://www.epa.gov/iag/voc.html. Updated July 9, 2012. Accessed April 16, 2015.

U.S. Environmental Protection Agency. Indoor Air Facts No. 4: Sick Building Syndrome. <a href="http://www.epa.gov/iaq/pdfs/sick building factsheet.pdf">http://www.epa.gov/iaq/pdfs/sick building factsheet.pdf</a>. Published February 1991. Accessed April 16, 2015.

#### 10 Pesticide management

Gilliom J, Barbash JE, Crawford CG, Hamilton PA, Martin JD, et al. Pesticides in the Nation's Streams and Ground Water, 1992-2001. U.S. Geological Survey Circular 1291,172 p.

U.S. Environmental Protection Agency. Atrazine. Chemical Summary. <a href="http://www.epa.gov/teach/chem\_summ/Atrazine\_summary.pdf">http://www.epa.gov/teach/chem\_summ/Atrazine\_summary.pdf</a>. Updated April 24, 2007. Accessed April 21, 2015.

U.S. Environmental Protection Agency. Basic Information about Atrazine in Drinking Water. <a href="http://water.epa.gov/drink/contaminants/basicinformation/atrazine.cfm#eight">http://water.epa.gov/drink/contaminants/basicinformation/atrazine.cfm#eight</a>. Updated September 17, 2013. Accessed April 22, 2015.

U.S. Environmental Protection Agency. Basic Information about Glyphosate in Drinking Water. <a href="http://water.epa.gov/drink/contaminants/basicinformation/glyphosate.cfm">http://water.epa.gov/drink/contaminants/basicinformation/glyphosate.cfm</a>. Updated February 9, 2014. Accessed April 22, 2015.

#### 11 Fundamental material safety

U.S. Environmental Protection Agency. Asbestos. <a href="http://www.epa.gov/airtoxics/hlthef/asbestos.html">http://www.epa.gov/airtoxics/hlthef/asbestos.html</a>. Updated October 18, 2013. Accessed April 22, 2015.

U.S. Environmental Protection Agency. America's Children and the Environment, Third Edition (ACE3) – Polychlorinated Biphenyls (PCBs). <a href="http://www.epa.gov/ace/pdfs/Biomonitoring-PCBs.pdf">http://www.epa.gov/ace/pdfs/Biomonitoring-PCBs.pdf</a>. 2013. Accessed April 22, 2015.

U.S. Environmental Protection Agency. Lead Compounds. <a href="http://www.epa.gov/ttnatw01/hlthef/lead.html">http://www.epa.gov/ttnatw01/hlthef/lead.html</a>. Updated October 18, 2013. Accessed April 22, 2015.

### 13 Air flush

Rutgers Center for Green Buildings. New Jersey Green Building Manual: Building Flush. <a href="http://greenmanual.rutgers.edu/newcommercial/strategies/buildingflush.pdf">http://greenmanual.rutgers.edu/newcommercial/strategies/buildingflush.pdf</a>. Updated May 17, 2011. Accessed April 22, 2015.

#### 16 Humidity control

Centers for Disease Control and Prevention. Workplace Safety & Health Topics: Handling Irradiated Mail. <a href="http://www.cdc.gov/niosh/topics/irr-mail/opm-letter.html">http://www.cdc.gov/niosh/topics/irr-mail/opm-letter.html</a>. Updated October 5, 2012. Accessed May 1, 2015.

Parthasarathy S, Maddalena RL, Russell ML, Apte MG. Effect of Temperature and Humidity on Formaldehyde Emissions in Temporary Housing Units. 2011. Journal of the Air Waste Management Association, Volume 61, pp. 689-695.

U.S. Environmental Protection Agency. Chapter 1: Introduction to Molds. <a href="http://www.epa.gov/mold/moldcourse/chapter1.html">http://www.epa.gov/mold/moldcourse/chapter1.html</a>. Updated March 8, 2012. Accessed April 22, 2015.

U.S. Environmental Protection Agency. Indoor Air Pollution: An Introduction for Health Professionals. http://www.epa.gov/iag/pubs/hpquide.html. Updated July 3, 2012. Accessed April 22, 2015.

World Health Organization. Guidelines for Indoor Air Quality – Selected Pollutants. Geneva: World Health Organization; 2010: 141-142.

#### 17 Direct source ventilation

U.S. Environmental Protection Agency. Chapter 1: Introduction to Molds. <a href="http://www.epa.gov/mold/moldcourse/chapter1.html">http://www.epa.gov/mold/moldcourse/chapter1.html</a>. Updated March 8, 2012. Accessed April 22, 2015.

U.S. Environmental Protection Agency. Health Effects: Ground Level Ozone. <a href="http://www.epa.gov/groundlevelozone/health.html">http://www.epa.gov/groundlevelozone/health.html</a>. Updated November 26, 2014. Accessed April 22, 2015.

U.S. Environmental Protection Agency. An Introduction to Indoor Air Quality (IAQ): Volatile Organic Compounds (VOCs). <a href="http://www.epa.gov/iag/voc.html">http://www.epa.gov/iag/voc.html</a>. Updated July 9, 2012. Accessed April 16, 2015.

### 19 Operable windows

Agency for Toxic Substances and Disease Registry. Public Health Statement: Formaldehyde. Atlanta: United States Department of Health and Human Services, 2008.

#### 22 Pest control

Asthma and Allergy Foundation of America. Cockroach Allergy. <a href="http://www.aafa.org/display.cfm?id=9&sub=22">http://www.aafa.org/display.cfm?id=9&sub=22</a> &cont=312. Updated 2011. Accessed April 22, 2015.

U.S. Environmental Protection Agency. Cockroaches and Schools. <a href="http://www2.epa.gov/managing-pests-schools/cockroaches-and-schools">http://www2.epa.gov/managing-pests-schools/cockroaches-and-schools</a>. Updated April 28, 2015. Accessed May 1, 2015.

### 24 Combustion minimization

Consumer Product Safety Commission. Carbon Monoxide Questions and Answers. <a href="http://www.cpsc.gov/en/Safety-Education/Safety-Education-Centers/Carbon-Monoxide-Information-Centers/Carbon-Monoxide-Questions-and-Answers-/">http://www.cpsc.gov/en/Safety-Education/Safety-Education-Centers/Carbon-Monoxide-Information-Centers/Carbon-Monoxide-Questions-and-Answers-/</a>. Updated 2014. Accessed April 22, 2015.

Blumenthal I. Carbon Monoxide Poisoning. 2001. Journal of the Royal Society of Medicine, Volume 94, pp. 270-272.

#### 25 Toxic material reduction

Agency for Toxic Substances and Disease Registry. ToxFAQs for Polybrominated Diphenyl Ethers (PBDEs). <a href="http://www.atsdr.cdc.gov/toxfags/tf.asp?id=900&tid=94">http://www.atsdr.cdc.gov/toxfags/tf.asp?id=900&tid=94</a>. Updated March 25, 2014. Accessed April 22, 2015.

### 26 Enhanced material safety

U.S. Environmental Protection Agency. Indoor Air Facts No. 4: Sick Building Syndrome. http://www.epa.gov/iag/pdfs/sick\_building\_factsheet.pdf. Published February 1991. Accessed April 16, 2015.

### 27 Antimicrobial activity for surfaces

Sawan SP, Shalon T, Subramanyam S, Yurkovetskiy A. U.S. 5849311 A Patent. Contact-killing Non-leaching Antimicrobial Materials. <a href="http://www.google.com/patents/US5849311">http://www.google.com/patents/US5849311</a>. Updated October 1996. Accessed April 22, 2015

### Water

Agency for Toxic Substances and Disease Registry. Toxicological Profile for Bromoform and Dibromochloromethanes. August 2005. U.S. Department of Health and Human Services, Atlanta, GA.

Delaware Health and Social Services Division of Public Health. Haloacetic Acids. <a href="http://dhss.delaware.gov/dhss/dph/files/haloaceacfaq.pdf">http://dhss.delaware.gov/dhss/dph/files/haloaceacfaq.pdf</a>. Updated January 2015. Accessed April 22, 2015.

Shotyk W, Krachler M. Contamination of Bottled Waters with Antimony Leaching from Polyethylene Terephthalate (PET) Increases Upon Storage. 2007. Environmental Science and Technology, Volume 41, pp. 1560-1563.

Olson E. What's on Tap: Grading Drinking Water in U.S. Cities. 2003. Natural Resources Defense Council. Washington, D.C.

Panel on Dietary Reference Intakes for Electrolytes and Water. Dietary Reference Intakes for Water, Potassium, Sodium, Chloride, and Sulfate. 2005. Institute of Medicine, Washington, D.C.

New Zealand Ministry of Health. Datasheet Index 2013 Guidelines for Drinking-water Quality Management Part 2.2: Chemical and Physical Determinands Organic Chemicals. 2013.

Better Health Channel. Water - A Vital Nutrient.

http://www.betterhealth.vic.gov.au/bhcv2/bhcarticles.nsf/pages/water a vital nutrient?open. State Government of Victoria. Updated February 9, 2015. Accessed April 22, 2015.

- U.S. Environmental Protection Agency. National Primary Drinking Water Regulations. EPA 816-F-09-004. Published May 2009. Washington, D.C.
- U.S. Environmental Protection Agency. Water on Tap: What You Need to Know. Washington, D.C.: Environmental Protection Agency; 2009. EPA 816-K-09-002.
- U.S. Environmental Protection Agency. Basic Information about Disinfection Byproducts in Drinking Water: Total Trihalomethanes, Haloacetic Acids, Bromate, and Chlorite.

http://water.epa.gov/drink/contaminants/basicinformation/disinfectionbyproducts.cfm. Updated December 13, 2013. Accessed April 22, 2015.

U.S. Geological Society. The Water in You. <a href="http://water.usgs.gov/edu/propertyyou.html">http://water.usgs.gov/edu/propertyyou.html</a>. U.S. Department of the Interior. Updated March 17, 2014. Accessed April 22, 2015.

World Health Organization. Facts and Figures on Water Quality and Health. http://www.who.int/water\_sanitation\_health/facts\_figures/en/. 2015. Accessed April 22, 2015.

#### 30 Fundamental water quality

Olson E. What's on Tap: Grading Drinking Water in U.S. Cities. 2003. Natural Resources Defense Council. Washington, D.C.

Herson DS, Marshall DR, Victoreen HT. Bacterial Persistence in the Distribution System. 1984. Journal of the American Water Works Association, Volume 76, pp. 309-322.

Olson BH. Bacterial Colonization of Mortar-lined and Galvanized Iron Water Distribution Mains. 1981. AWWA National Conference, Denver, CO.

Dvorak B, Skipton I, Sharon O. Drinking Water Treatment: An Overview. Institute of Agriculture and Natural Resources at the University of Nebraska. August 2014, Lincoln, NE.

U.S. Environmental Protection Agency. National Primary Drinking Water Regulations. EPA 816-F-09-004. Published May 2009. Washington, D.C.

#### 31 Inorganic contaminants

U.S. Environmental Protection Agency. Basic Information About Lead in Drinking Water. <a href="http://water.epa.gov/drink/contaminants/basicinformation/lead.cfm">http://water.epa.gov/drink/contaminants/basicinformation/lead.cfm</a>. Updated February 5, 2014. Accessed May 1, 2015.

U.S. Environmental Protection Agency. Basic Information About Mercury (Inorganic) in Drinking Water. <a href="http://water.epa.gov/drink/contaminants/basicinformation/mercury.cfm">http://water.epa.gov/drink/contaminants/basicinformation/mercury.cfm</a>. Updated February 5, 2014. Accessed May 1, 2015.

### 32 Organic contaminants

Agency for Toxic Substances and Disease Registry. Toxicological Profile for Vinyl Chloride. July 2006. U.S. Department of Health and Human Services, Atlanta, GA.

Agency for Toxic Substances and Disease Registry. Public Health Statement – Polychlorinated Biphenyls. November 2000. U.S. Department of Health and Human Services, Atlanta, GA.

U.S. Environmental Protection Agency. National Primary Drinking Water Regulations. EPA 816-F-09-004. Published May 2009. Washington, D.C.

#### 33 Agricultural contaminants

Environmental Working Group. National Drinking Water Database 2,4-D. <a href="http://www.ewg.org/tap-water/chemical-contaminants/24-D/2105/">http://www.ewg.org/tap-water/chemical-contaminants/24-D/2105/</a>. Updated 2011. Accessed April 21, 2015.

Mizota K, Ueda H. Endocrine Disrupting Chemical Atrazine Causes Degranulation through Gq/11 Protein-coupled Neurosteroid Receptor in Mast Cells. 2005. Toxicological Sciences, Volume 90, pp. 362-368.

Gilliom J, Barbash JE, Crawford CG, Hamilton PA, Martin JD, et al. Pesticides in the Nation's Streams and Ground Water, 1992-2001. U.S. Geological Survey Circular 1291,172 p.

U.S. Environmental Protection Agency. Basic Information about Atrazine in Drinking Water. <a href="http://water.epa.gov/drink/contaminants/basicinformation/atrazine.cfm#eight">http://water.epa.gov/drink/contaminants/basicinformation/atrazine.cfm#eight</a>. Updated September 17, 2013. Accessed April 22, 2015.

U.S. Environmental Protection Agency. Basic Information about 2,4-D (2,4-Dichlorophenoxyacetic Acid) in Drinking Water. ;http://water.epa.gov/drink/contaminants/basicinformation/2-4-d-2-4-dichlorophenoxyacetic-acid.cfm#eight . Updated December 13, 2013. Accessed April 22, 2015.

U.S. Environmental Protection Agency. National Primary Drinking Water Regulations. EPA 816-F-09-004. Published May 2009. Washington, D.C.

U.S. Environmental Protection Agency. Basic Information about Glyphosate in Drinking Water. <a href="http://water.epa.gov/drink/contaminants/basicinformation/glyphosate.cfm">http://water.epa.gov/drink/contaminants/basicinformation/glyphosate.cfm</a>. Updated February 9, 2014. Accessed April 22, 2015.

#### 34 Public water additives

Centers for Disease Control and Prevention and the American Dental Association. Nature's Way to Prevent Tooth Decay: Water Fluoridation. 2006.

Villanueva CM, Cantor KP, Grimalt JO, Malats N, Silverman D, et al. Bladder Cancer and Exposure to Water Disinfection By-products through Ingestion, Bathing, Showering and Swimming in Pools. 2006. American Journal of Epidemiology, Volume 165, pp. 148-156.

Olson E. What's on Tap: Grading Drinking Water in U.S. Cities. 2003. Natural Resources Defense Council. Washington, D.C.

U.S. Environmental Protection Agency. National Primary Drinking Water Regulations. EPA 816-F-09-004. Published May 2009. Washington, D.C.

U.S. Environmental Protection Agency. Basic Information about Disinfectants in Drinking Water: Chloramine, Chlorine, and Chlorine Dioxide. <a href="http://water.epa.gov/drink/contaminants/basicinformation/disinfectants.cfm">http://water.epa.gov/drink/contaminants/basicinformation/disinfectants.cfm</a>. Updated December 13, 2013. Accessed April 28, 2015.

World Health Organization. Trihalomethanes in Drinking-Water. 2004. Geneva, Switzerland.

#### 37 Drinking water promotion

Medline Plus. Dehydration. <a href="http://www.nlm.nih.gov/medlineplus/ency/article/000982.htm">http://www.nlm.nih.gov/medlineplus/ency/article/000982.htm</a>. Updated April 9, 2015. Accessed April 21, 2015.

## **Nourishment**

Centers for Disease Control and Prevention. State Indicator Report on Fruits and Vegetables, 2013. 2013. Department of Health and Human Services, Atlanta, GA.

Hanks AS, Just DR, Wansink B. Smarter Lunchrooms Can Address New School Lunchroom Guidelines and Childhood Obesity. 2013. The Journal of Pediatrics, Volume 162, Issue 4, pp. 867-869.

Harvard T.H. Chan School of Public Health. Toxic Food Environment: How Our Surroundings Influence What We Eat. <a href="http://www.hsph.harvard.edu/obesity-prevention-source/obesity-causes/food-environment-and-obesity">http://www.hsph.harvard.edu/obesity-prevention-source/obesity-causes/food-environment-and-obesity</a>. Accessed April 20, 2015.

Micha R, Wallace SK, Mozaffarian D. Red and Processed Meat Consumption and Risk of Incident Coronary Heart Disease, Stroke, and Diabetes Mellitus. 2010. Circulation, Volume 121, pp. 2271-2283.

Lustig RH, Schmidt LA, Brindis CD. The Toxic Truth About Sugar. 2012. Nature, Volume 482, pp. 27-29.

Ogden CL, Kit BK, Carroll MD, Park S. Consumption of Sugar Drinks in the United States, 2005–2008. NCHS Data Brief. http://www.cdc.gov/nchs/data/databriefs/db71.pdf. Accessed April 17, 2015.

Ogden CL, Carroll MD, Kit BK, Flegal KM. Prevalence of Childhood and Adult Obesity in the United States, 2011-2012. 2014. The Journal of the American Medical Association, Volume 11, Issue 8, pp. 806-814.

Malik VS, Popkin BM, Bray GA, Despres JP, Willett WC, et al. Sugar-sweetened Beverages and Risk of Metabolic Syndrome and Type 2 Diabetes: A Meta-Analysis. 2010. Diabetes Care, Volume 33, Issue 11, pp. 2477-2483.

Sayon-Orea C, Martinez-Gonzalez MA, Gea A, Alonso A, Pimenta AM, et al. Baseline Consumption and Changes in Sugar-sweetened Beverage Consumption and the Incidence of Hypertension: The SUN Project. 2014. Clinical Nutrition, November 22. http://www.ncbi.nlm.nih.gov/pubmed/25481680. Accessed April 20, 2015.

Bernabe E, Vehkalahti MM, Sheiham A, Aromaa A, Suominen AL. Sugar-sweetened Beverages and Dental Caries in Adults: A 4-year Prospective Study. 2014. Journal of Dentistry, Volume 42, Issue 8, pp. 952-958.

Guo X, Park Y, Freedman ND, Sinha R, Hollenbeck AR, et al. Sweetened Beverages, Coffee, and Tea and Depression Risk Among Older U.S. Adults. 2014. PLoS One, Volume 9, Issue 4, e94715. <a href="http://www.ncbi.nlm.nih.gov/pubmed/24743309">http://www.ncbi.nlm.nih.gov/pubmed/24743309</a>. Accessed April 20, 2015.

Krebs-Smith SM, Guenther PM, Subar AF, Kirkpatrick SI, Dodd K. Americans Do Not Meet Federal Dietary Recommendations. 2010. The Journal of Nutrition, Volume 140, Issue 10, pp. 1832-1838.

Lajous M, Bijon A, Fagherazzi G, Rossignol E, Boutron-Ruault MS, et al. Processed and Unprocessed Red Meat Consumption and Hypertension in Women. 2014. American Journal of Clinical Nutrition, Volume 100, Issue 3, pp. 948-952.

Chan DS, Lau R, Aune D, Vieira R, Greenwood DC, et al. Red and Processed Meat and Colorectal Cancer Incidence: Meta-analysis of Prospective Studies. 2011. PLoS One, Volume 6, Issue 6, e20456. <a href="http://www.ncbi.nlm.nih.gov/pubmed/21674008">http://www.ncbi.nlm.nih.gov/pubmed/21674008</a>. Accessed April 20, 2015.

Bao PP, Shu XO, Xheng Y, Cai H, Ruan ZX, et al. Fruit, Vegetable, and Animal Food Intake and Breast Cancer Risk by Hormone Receptor Status. 2012. Nutrition and Cancer, Volume 64, Issue 6, pp. 806-819.

Cooper AJ, Forouhi NG, Ye Z, Buijsse B, Arriola L, et al. Fruit and Vegetable Intake and Type 2 Diabetes: EPIC-InterAct Prospective Study and Meta-analysis. 2012. European Journal of Clinical Nutrition, Volume 66, Issue 10, pp. 1082-1092.

Wang X, Ouyang Y, Liu J, Zhu M, Zhao G, et al. Fruit and Vegetable Consumption and Mortality from all Causes, Cardiovascular Disease, and Cancer: Systematic Review and Dose-response Meta-analysis of Prospective Cohort Studies. 2014. British Medical Journal, Volume 349, g4490. <a href="http://www.bmj.com/content/349/bmj.g4490">http://www.bmj.com/content/349/bmj.g4490</a>. Accessed April 20, 2015.

Kaluza J, Akesson A, Wolk A. Processed and Unprocessed Red Meat Consumption and Risk of Heart Failure: Prospective Study of Men. 2014. Circulation: Heart Failure, Volume 7, Issue 4, pp. 552-557.

Institute of Medicine. Food Marketing to Children and Youth: Threat or Opportunity? Editors: McGinnis MJ, Appleton Gootman J, Kraak VI. 2006. The National Academies Press, Washington, D.C.

USDA Economic Research Service. Food Availability (Per Capita) Data System. <a href="http://www.ers.usda.gov/data-products/food-availability-(per-capita)-data-system/.aspx#26705">http://www.ers.usda.gov/data-products/food-availability-(per-capita)-data-system/.aspx#26705</a>. Accessed April 17, 2015.

World Health Organization. Obesity and Overweight: Fact Sheet N°311. 2015. http://www.who.int/mediacentre/factsheets/fs311/en/. Updated January 2015. Accessed April 20, 2015.

World Health Organization. The World Health Report 2002: Reducing Risks, Promoting Healthy Life. 2002. <a href="http://www.who.int/whr/2002/en/whr02">http://www.who.int/whr/2002/en/whr02</a> en.pdf. Accessed April 20, 2015.

World Health Organization. Unhealthy Diets and Physical Inactivity. NMH Factsheet June 2009. http://www.who.int/nmh/publications/fact\_sheet\_diet\_en.pdf. Created June 2009. Accessed May 5, 2015.

#### 38 Fruits and vegetables

Produce for Better Health Foundation. State of the Plate: 2010 Study on America's Consumption of Fruits and Vegetables. 2010. <a href="http://www.pbhfoundation.org/pdfs/about/res/pbh">http://www.pbhfoundation.org/pdfs/about/res/pbh</a> res/stateplate.pdf. Accessed April 20, 2015.

U.S. Department of Agriculture and U.S. Department of Health and Human Services. Dietary Guidelines for Americans, 2010. 7th Edition, December 2010. U.S. Government Printing Office, Washington, D.C.

World Health Organization. Promoting Fruit and Vegetable Consumption Around the World: Information Sheet. <a href="http://www.who.int/dietphysicalactivity/fruit/en/index2.html">http://www.who.int/dietphysicalactivity/fruit/en/index2.html</a>. Accessed April 20, 2015.

World Health Organization. The World Health Report 2002: Reducing Risks, Promoting Healthy Life. 2002. <a href="http://www.who.int/whr/2002/en/whr02">http://www.who.int/whr/2002/en/whr02</a> en.pdf. Accessed April 20, 2015.

#### 39 Processed foods

American Heart Assocation. Added Sugars.

http://www.heart.org/HEARTORG/GettingHealthy/NutritionCenter/HealthyDietGoals/Added-Sugars\_UCM\_305858\_Article.jsp. Updated November 19, 2014. Accessed April 20, 2015.

Centers for Disease Control and Prevention. The CDC Guide to Strategies for Reducing the Consumption of Sugar-sweetened Beverages. March 2010.

Johnson RK, Appel LJ, Brands M, Howard BV, Lefevre M, et al. Dietary Sugars Intake and Cardiovascular Health: A Scientific Statement from the American Heart Association. 2009. Circulation, Volume 120, Issue 11, pp. 1011-1020.

Malik VS, Popkin BM, Bray GA, Despres JP, Willett WC, et al. Sugar-sweetened Beverages and Risk of Metabolic Syndrome and Type 2 Diabetes: A Meta-Analysis. 2010. Diabetes Care, Volume 33, Issue 11, pp. 2477-2483.

Sayon-Orea C, Martinez-Gonzalez MA, Gea A, Alonso A, Pimenta AM, et al. Baseline Consumption and Changes in Sugar-sweetened Beverage Consumption and the Incidence of Hypertension: The SUN Project. 2014. Clinical Nutrition, November 22. <a href="http://www.ncbi.nlm.nih.gov/pubmed/25481680">http://www.ncbi.nlm.nih.gov/pubmed/25481680</a>. Accessed April 20, 2015.

### 40 Food allergies

Food Allergy Research & Education. Food Allergy Facts and Statistics for the U.S. <a href="http://www.foodallergy.org/document.doc?id=194">http://www.foodallergy.org/document.doc?id=194</a>. Accessed April 20, 2015.

USDA Food Safety and Inspection Service. Food Safety Information: Allergies and Food Safety.

http://www.fsis.usda.gov/wps/wcm/connect/1e98f24c-d616-443f-8490-

f7372476d558/Allergies and Food Safety.pdf?MOD=AJPERES. Published July 2011. Accessed April 20, 2015.

#### 41 Hand washing

Food and Drug Administration. Food Code: 2013 Recommendations of the United States Public Health Service Food and Drug Administration. PB2013-110462. Published 2013.

Zapka CA, et al. Bacterial Hand Contamination and Transfer after Use of Contaminated Bulk-Soap-Refillable Dispensers. 2011. Applied and Environmental Microbiology, Volume 77, Issue 9, pp. 2898-2904.

Chattman M, Maxwell SL, and Gerba CP. Occurrence of heterotrophic and coliform bacteria in liquid hand soaps from bulk refillable dispensers in public facilities. 2011. The Journal of Environmental Health, Volume 73, Issue 7, pp. 26-29.

Huang C, Ma W, Stack S. The Hygienic Efficacy of Different Hand-drying Methods: A Review of the Evidence. 2012. Mayo Clinic Proceedings, Volume 87, Issue 8, pp. 791-798.

Lorenz LA, et al. Evaluation and remediation of bulk soap dispensers for biofilm. 2012. The Journal of Bioadhesion and Biofilm Research, Volume 28, Issue 1, pp. 99-109.

#### 43 Artificial ingredients

National Institute of Allergy and Infectious Diseases. Is it Food Allergy or Food Intolerance? <a href="http://www.niaid.nih.gov/topics/foodallergy/understanding/pages/foodintolerance.aspx#lactose">http://www.niaid.nih.gov/topics/foodallergy/understanding/pages/foodintolerance.aspx#lactose</a>. Updated December 2, 2010. Accessed April 20, 2015.

### 45 Food advertising

Federal Trade Commission. Marketing Food to Children and Adolescents, A Review of Industry Expenditures, Activities, and Self-regulation: A Report to Congress. Published July 2008.

The International Association of Consumer Food Organizations. Broadcasting Bad Health: Why Food Marketing to Children Needs to Be Controlled. A Report by the International Association of Consumer Food Organizations for the WHO Consultation on a Global Strategy on Diet and Nutrition.

https://cspinet.org/reports/codex/foodmarketingreport.pdf. Published July 2003. Accessed April 20, 2015.

### 46 Safe food preparation materials

Centers for Disease Control and Prevention. Biomonitoring Summary Bisphenol A. CAS No. 80-05-7. National Biomonitoring Program. 2013. <a href="http://www.cdc.gov/biomonitoring/BisphenolA BiomonitoringSummary.html">http://www.cdc.gov/biomonitoring/BisphenolA BiomonitoringSummary.html</a>. Accessed May 19, 2015.

Food and Drug Administration. Update on Bisphenol A for Use in Food Contact Applications. <a href="http://www.fda.gov/NewsEvents/PublicHealthFocus/ucm064437.htm">http://www.fda.gov/NewsEvents/PublicHealthFocus/ucm064437.htm</a>. 2014. Updated January 6. 2015. Accessed May 1. 2015.

#### 47 Serving sizes

Wansink B, Van Ittersum K. The Visual Illusions of Food: Why Plates, Bowls, and Spoons Can Bias Consumption Volume. 2006. The Journal of the Federation of American Societies for Experimental Biology, Volume 20, A618. <a href="http://www.fasebj.org/cgi/content/meeting-abstract/20/4/A618-c">http://www.fasebj.org/cgi/content/meeting-abstract/20/4/A618-c</a>. Accessed April 20, 2015.

Giblin C. The Perils of Large Plates: Waist, Waste, and Wallet. Cornell University Food and Brand Lab. http://foodpsychology.cornell.edu/outreach/large-plates.html. Accessed April 20, 2015.

Rolls BJ. Dietary Strategies for Weight Management. 2012. Nestle Nutrition Institute Workshop Series, Volume 73, pp. 37-48.

National Heart, Lung, and Blood Institute. What Causes Overweight and Obesity? <a href="http://www.nhlbi.nih.gov/health/health-topics/topics/obe/causes">http://www.nhlbi.nih.gov/health/health-topics/topics/obe/causes</a>. Updated July 13, 2012. Accessed April 20, 2015.

### 49 Responsible food production

Smith-Spangler C, Brandeau ML, Hunter GE, Bavinger JC, Pearson M, et al. Are Organic Foods Safer or Healthier than Conventional Alternatives?: A Systematic Review. 2012. Annals of Internal Medicine, Volume 157, Issue 5, pp. 348-366.

Baranski M, Srednicka-Tober D, Volakakis N, Seal C, Sanderson R, et al. Higher Antioxidant and Lower Cadmium Concentrations and Lower Incidence of Pesticide Residues in Organically Grown Crops: A Systematic Literature Review and Meta-analyses. 2014. British Journal of Nutrition, Volume 112, Issue 5, pp. 794-811.

### 51 Food production

Castro DC, Samuels M, Harman AE. Growing Healthy Kids: A Community Garden-based Obesity Prevention Program. 2013. American Journal of Preventive Medicine, Volume 44, pp. S193-199.

Zick CD, Smith KR, Kowaleski-Jones L, Uno C, Merrill BJ. Harvesting More than Vegetables: The Potential Weight Control Benefits of Community Gardening. 2013. American Journal of Public Health, Volume 103, Issue 6, pp. 1110-1115.

Sommerfeld AJ, Waliczek TM, Zajicek JM. Growing Minds: Evaluating the Effect of Gardening on Quality of Life and Physical Activity Level of Older Adults. 2010. HortTechnology, Volume 20, Issue 4, pp. 705-710.

## 52 Mindful eating

Robinson E, Aveyard P, Daley A, Jolly K, Lewis A, et al. Eating Attentively: A Systematic Review and Meta-analysis of the Effect of Food Intake Memory and Awareness on Eating. 2013. American Journal of Clinical Nutrition, Volume 97, Issue 4, pp. 728-742.

# Light

Berson DM, Dunn FA, Takao M. Phototransduction by Retinal Ganglion Cells that Set the Circadian Clock. 2002. Science, Volume 295, pp. 1070-3.

Bowmaker JK, Dartnall HJA. Visual Pigments of Rods and Cones in a Human Retina. 1980. The Journal of Physiology, Volume 298, pp. 501-11.

Duffy JF, Czeisler CA. Effect of Light on Human Circadian Physiology. 2009. Sleep Medicine Clinics, Volume 4, Issue 2, pp. 165-77.

Hattar S, Liao H-W, Takao M, Berson DM, Yau K-W. Melanopsin-containing Retinal Ganglion Cells: Architecture, Projections, and Intrinsic Photosensitivity. 2002. Science, Volume 295, pp. 1065-70.

American National Standards Institute and Illuminating Engineering Society of North America. American National Standard

Practice for Office Lighting. New York, NY: Illuminating Engineering Society of North America; 2012. RP-1-12.

Illuminating Engineering Society of North America. Light + Design: A Guide to Designing Quality Lighting for People and Buildings. New York, NY: Illuminating Engineering Society of North America, 2008. DG-18-08.

### http://www.darksky.org/wp-content/uploads/bsk-pdf-manager/16 MLO FINAL JUNE2011.pdf

Institute of Medicine Committee on Sleep Medicine and Research. In: Colten HR and Altevogt BM, eds. Sleep Disorders and Sleep Deprivation: An Unmet Public Health Problem. 2006. National Academies Press, Washington, D.C.

Ko CH, Takahashi JS. Molecular Components of the Mammalian Circadian Clock. 2006. Human Molecular Genetics, Volume 18, Issue 2, pp. R271-R277.

LeGates TA, Fernandez DC, Hattar S. Light as a Central Modulator of Circadian Rhythms, Sleep and Affect. 2014. Nature Reviews Neuroscience, Volume 15, pp. 443-54.

Lucas RJ, Peirson SN, Berson DM, Brown TM, Cooper HM, et al. Measuring and Using Light in the Melanopsin Age. 2014. Trends in Neuroscience, Volume 31, Issue 1, pp. 1-9.

Mistlberger RE, Skene DJ. Nonphotic Entrainment in Humans? 2005. Journal of Biological Rhythms, Volume 20, pp. 339-52.

Rollag MD, Berson DM, Provencio I. Melanopsin, Ganglion-cell Photoreceptors, and Mammalian Photoentrainment. 2003. Journal of Biological Rhythms, Volume 18, Issue 3, pp. 227-34.

Schubert EF. Human Eye Sensitivity and Photometric Quantities. Light-Emitting Diodes. 2nd ed. 2006. Cambridge University Press, New York, NY, pp. 275-91.

### 53 Visual lighting design

U.S. General Services Administration (GSA). Facilities Standards for the Public Buildings Service. March 2014, Washington, D.C., pp. 135-136.

licht.de. licht.wissen 04: Office Lighting: Motivating and Efficient. Frankfurt; 2014: 35.

Schubert EF. Human Eye Sensitivity and Photometric Quantities. Light-Emitting Diodes. 2nd ed. 2006. Cambridge University Press, New York, NY, pp. 275-91.

#### 54 Circadian lighting design

Duffy JF, Czeisler CA. Effect of Light on Human Circadian Physiology. 2009. Sleep Medicine Clinics, Volume 4, Issue 2, pp. 165-77.

Ko CH, Takahashi JS. Molecular Components of the Mammalian Circadian Clock. 2006. Human Molecular Genetics, Volume 18, Issue 2, pp. R271-R277.

Lucas RJ, Peirson SN, Berson DM, Brown TM, Cooper HM, et al. Measuring and Using Light in the Melanopsin Age. 2014. Trends in Neuroscience, Volume 31, Issue 1, pp. 1-9.

Mistlberger RE, Skene DJ. Nonphotic Entrainment in Humans? 2005. Journal of Biological Rhythms, Volume 20, pp. 339-52.

### 55 Electric light glare control

Mainster MA, Turner PL. Glare's Causes, Consequences, and Clinical Challenges after a Century of Ophthalmic Study. 2012. American Journal of Ophthalmology, Volume 153, Issue 4, pp. 587-593.

licht.de. licht.wissen 04: Office Lighting: Motivating and Efficient. Frankfurt; 2014: 35.

Luckiesh M, Holladay LL. Glare and Visibility: A Resume of the Results Obtained in Investigations of Visual and Lighting Conditions Involving These Factors. 1925. Transactions, pp. 221-247.

#### 56 Solar glare control

Mainster MA, Turner PL. Glare's Causes, Consequences, and Clinical Challenges after a Century of Ophthalmic Study. 2012. American Journal of Ophthalmology, Volume 153, Issue 4, pp. 587-593.

licht.de. licht.wissen 04: Office Lighting: Motivating and Efficient. Frankfurt; 2014: 35.

### 57 Low-glare workstation design

licht.de. licht.wissen 04: Office Lighting: Motivating and Efficient. Frankfurt; 2014: 35.

### 58 Color quality

Eye Lighting International. R9 Color Rendering Value. 2015. <a href="http://www.eyelighting.com/resources/lighting-technology-education/general-lighting-basics/r9-color-rendering-value/">http://www.eyelighting.com/resources/lighting-technology-education/general-lighting-basics/r9-color-rendering-value/</a>. Accessed April 22, 2015.

Gardner EP, Johnson KO. Sensory Coding. In: Kandel, ER, Schwartz, JH, Jessell, TM, et al, eds. Principles of Neural Science. 5th Edition, 2013. McGraw Hill Medical, New York, NY.

### 59 Surface design

Duffy JF, Czeisler CA. Effect of Light on Human Circadian Physiology. 2009. Sleep Medicine Clinics, Volume 4, Issue 2, pp. 165-77.

### 61 Right to light

Beauchemin KM, Hays P. Sunny Hospital Rooms Expedite Recovery from Severe and Refractory Depressions. 1996. Journal of Affective Disorders, Volume 40, Issue 1-2, pp. 49-51.

Beauchemin KM, Hays P. Dying in the Dark: Sunshine, Gender and Outcomes in Myocardial Infarction. 1998. Journal of the Royal Society of Medicine, Volume 91, Issue 7, pp. 352-354.

Boubekri M, Cheung IN, Reid KJ, Wang C, Zee PC. Impact of Windows and Daylight Exposure on Overall Health and Sleep Quality of Office Workers – A Case-control Pilot Study. 2014. Journal of Clinical Sleep Medicine, Volume 10, Issue 6, pp. 603-11.

### 62 Daylight modeling

Wright Jr KP, McHill AW, Birks BR, Griffin BR, Rusterholz T, et al. Entrainment of the Human Circadian Clock to the Natural Light-dark Cycle. 2013. Current Biology, Volume 23, Issue 16, p.2013 1554-8.

#### 63 Daylighting fenestration

Edwards L, Torcellini P. National Renewable Energy Laboratory. A Literature Review of the Effects of Natural Light on Building Occupants. 2002. http://www.nrel.gov/docs/fy02osti/30769.pdf. Accessed April 20, 2015.

## <u>Fitness</u>

Centers for Disease Control and Prevention. Glossary of Terms. <a href="http://www.cdc.gov/physicalactivity/everyone/glossary/index.html">http://www.cdc.gov/physicalactivity/everyone/glossary/index.html</a>. Accessed April 17, 2015.

Wen CP, Wu X. Stressing Harms of Physical Inactivity to Promote Exercise. 2012. The Lancet, Volume 380, pp. 192-193.

Lee IM, Shoroma EJ, Lobelo F, Puska P, Blair SN, et al. Effect of Physical Inactivity on Major Non-communicable Diseases Worldwide: An Analysis of Burden of Disease and Life Expectancy. 2012. Lancet, Volume 380, pp. 219-229.

Troiano RP, Berrigan D, Dodd KW, Masse LC, Tilert T, et al. Physical Activity in the United States Measured by Accelerometer. 2008. Medicine & Sciences in Sports & Exercise, Volume 40, Issue 1, pp. 181-188

Haskell WL, Lee I-M, Pate RR, Powell KE, Blair SN, et al. Physical Activity and Public Health: Updated Recommendation for Adults From the American College of Sports Medicine and the American Heart Association. 2007. Circulation, Volume 116, pp. 1081-1093.

U.S. Department of Health and Human Services. 2008 Physical Activity Guidelines for Americans. 2008. Washington, D.C.

U.S. Environmental Protection Agency. Report to Congress on Indoor Air Quality: Volume 2. EPA/400/1-89/001C. 1989, Washington, D.C.

World Health Organization. Unhealthy Diets and Physical Inactivity. NMH Factsheet June 2009. http://www.who.int/nmh/publications/fact\_sheet\_diet\_en.pdf. Created June 2009. Accessed May 5, 2015.

World Health Organization. Global Strategy on Diet, Physical Activity and Health. <a href="http://www.who.int/dietphysicalactivity/pa/en/">http://www.who.int/dietphysicalactivity/pa/en/</a>. Accessed April 17, 2015.

World Health Organization. Physical Activity. http://www.who.int/topics/physical\_activity/en/. Accessed April 17, 2015.

World Health Organization. Health and Development Through Physical Activity and Sport. 2003. http://whqlibdoc.who.int/hg/2003/WHO\_NMH\_NPH\_PAH\_03.2.pdf. Accessed April 17, 2015.

#### 64 Interior fitness circulation

Boreham C, Kennedy RA, Murphy MH, Tully M, Wallace WF, et al. Training Effects of Short Bouts of Stair Climbing on Cardiorespiratory Fitness, Blood Lipids, and Homocysteine in Sedentary Young Women. British Journal of Sports Medicine, Volume 29, Issue 9, pp. 590-593.

Lee IM, Paffenbarger RS Jr. Physical Activity and Stroke Incidence: The Harvard Alumni Health Study. 1998. Stroke, Volume 29, Issue 10, pp. 2049-2054.

### 65 Activity incentive programs

Centers for Disease Control and Prevention. Physical Activity and Health. <a href="http://www.cdc.gov/physicalactivity/everyone/health/index.html?scid=cs-284">http://www.cdc.gov/physicalactivity/everyone/health/index.html?scid=cs-284</a>. Updated February 16, 2011. Accessed April 21, 2015.

Centers for Disease Control and Prevention. Steps to Wellness: A Guide to Implementing the 2008 Physical Activity Guidelines for Americans in the Workplace. 2012. U.S. Department of Health and Human Services, Atlanta, GA.

Woodcock J, Franco OH, Orsini N, Roberts I. Non-vigorous Physical Activity and All-cause Mortality: Systematic Review and Meta-analysis of Cohort Studies. 2011. International Journal of Epidemiology, Volume 40, Issue 1, pp. 121-138.

Schumacher J, Utley J, Sutton L, Horton T, Hamer T, et al. Boosting Workplace Stair Utilization: A Study of Incremental Reinforcement. 2013. Rehabilitation Psychology, Volume 58, Issue 1, pp. 81-86.

#### 66 Structured fitness opportunities

Christensen J, Faber A, Ekner D, Overgaard K, Holtermann A, et al. Diet, Physical Exercise and Cognitive Behavioral Training as a Combined Workplace Based Intervention to Reduce Body Weight and Increase Physical Capacity in Health Care Workers – A Randomized Controlled Trial. 2011. BMC Public Health, Volume 11, pp 671. <a href="http://www.ncbi.nlm.nih.gov/pmc/articles/PMC3175468">http://www.ncbi.nlm.nih.gov/pmc/articles/PMC3175468</a>. Accessed April 21, 2015.

Zavanela P, Crewther BT, Lodo L, Floringo AA, Miyabara EH, et al. Health and Fitness Benefits of a Resistance Training Intervention Performed in the Workplace. 2012. Journal of Strength and Conditioning Resource, Volume 26, Issue 3, pp. 811-817.

### 67 Exterior active design

Frank LD, Andresen MA, Schmid TL. Obesity Relationships With Community Design, Physical Activity, and Time Spent in Cars. 2004. American Journal of Preventive Medicine, Volume 27, Issue 2, pp. 87–96.

Ewing R, Cervero R. Travel and the Built Environment. 2010. Journal of the American Planning Association, Volume 76, Issue 3, pp. 265-294.

New York City Departments of Design and Construction, Health and Mental Hygiene, Transportation, City Planning. Active Design Guidelines: Promoting Physical Activity and Health in Design. Published 2010: 4-7; 34; 43; 72-76; 85-87.

#### 68 Physical activity spaces

Emmons K, Linnan LA, Shadel WG, Marcus B, Abrams DB. The Working Healthy Project: A Worksite Health-promotion Trial Targeting Physical Activity, Diet, and Smoking. 1999. Journal of Occupational and Environmental Medicine, Vol. 41, Issue 7, pp. 545-555.

Gordon-Larsen P, Nelson MC, Page P, Popkin BM. Inequality in the Built Environment Underlies Key Health Disparities in Physical Activity and Obesity. 2005. Pediatrics, Volume 117, Issue 2, pp. 417-424.

### 69 Active transportation support

Blackford K, Jancey J, Howat P, Ledger M, Lee AH. Office-based Physical Activity and Nutrition Intervention: Barriers, Enablers, and Preferred Strategies for Workplace Obesity Prevention, Perth, Western Australia, 2012. 2013. Preventing Chronic Disease, Volume 10, pp. 130029. <a href="http://dx.doi.org/10.5888/pcd10.130029">http://dx.doi.org/10.5888/pcd10.130029</a>. Accessed April 21, 2015.

Millett C, Agrawal S, Sullivan R, Vaz M, Kurpad A, et al. Associations Between Active Travel to Work and Overweight, Hypertension, and Diabetes in India: A Cross-sectional Study. 2013. PLoS Medicine, Volume 10, Issue 6, e1001459. <a href="http://journals.plos.org/plosmedicine/article?id=10.1371/journal.pmed.1001459">http://journals.plos.org/plosmedicine/article?id=10.1371/journal.pmed.1001459</a>. Accessed April 28, 2015.

New York City Departments of Design and Construction, Health and Mental Hygiene, Transportation, City Planning. Active Design Guidelines: Promoting Physical Activity and Health in Design. Published 2010: 4-7; 34; 43; 72-76; 85-87.

#### 70 Fitness equipment

U.S. Department of Health and Human Services. 2008 Physical Activity Guidelines for Americans. 2008. Washington, D.C.

### 71 Active furnishings

Thorp A, Owen N, Neuhaus M, Dunstan DW. Sedentary Behaviors and Subsequent Health Outcomes in Adults: A Systematic Review of Longitudinal Studies, 1996-2011. 2011. American Journal of Preventive Medicine, Volume 41, Issue 2, pp. 207-215.

Thorp A, Kingwell BA, Owen N, Dunstan DW. Breaking Up Workplace Sitting Time with Intermittent Standing Bouts Improves Fatigue and Musculoskeletal Discomfort in Overweight/Obese Office Workers. 2014. Occupational and Environmental Medicine, Volume 71, Issue 11, pp. 765-771.

Schmid D, Leitzmann M. Television Viewing and Time Spent Sedentary in Relation to Cancer Risk: A Meta-Analysis. 2014. Journal of the National Cancer Institute, Volume 106, Issue 7, dju098. http://jnci.oxfordjournals.org/content/106/7/dju098.full? ga=1.42982689.5272358. Accessed April 21, 2015.

Buckley JP, Mellor DD, Morris M, Joseph F. Standing-based Office Work Shows Encouraging Signs of Attenuating Post-prandial Glycaemic Excursion. 2014. Occupational and Environmental Medicine, Volume 71, Issue 2, pp. 109-111.

Owen N, Sparling PB, Healy GN, Dunstan DW, Matthews CE. Sedentary Behavior: Emerging Evidence for a New Health Risk. 2010, Mayo Clinic Proceedings, Volume 85, Issue 12, pp. 1138-1141.

Katzmarzyk P, Lee I-M. Sedentary Behaviour and Life Expectancy in the USA: A Cause-deleted Life Table Analysis. 2012. BMJ Open, Volume 2, e000828. http://bmiopen.bmj.com/content/2/4/e000828.full. Accessed April 28, 2015.

# Comfort

ASHRAE. Standard 55: Thermal Environmental Conditions for Human Occupancy, Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers; 2013: 4; 8-13.

U.S. General Services Administration Center for Workplace Strategy Public Buildings Service. Sound Matters: How to Achieve Acoustic Comfort in the Contemporary Office. Washington, D.C.: 2012: 11, 29, 32, 33, 36.

Huizenga C, Abbaszadeh S, Zagreus L, Arens E. Air Quality and Thermal Comfort in Office Buildings: Results of a Large Indoor Environmental Quality Survey. 2006. Proceedings of Healthy Buildings, Volume 3, pp. 393-397.

Robertson JT. The Rape of the Spine. 1993. Surgical Neurology, Volume 39, pp. 5-12.

Murray CJL, Vos T, Lozano R, Naghavi M, Flaxman AD, et al. Disability-adjused Life Years (DALYs) for 291 Diseases and Injuries in 21 Regions, 1990-2010: A Systematic Analysis for the Global Burden of Disease Study 2010. 2013. The Lancet, Volume 381, pp. 628.

U.S. Department of Labor, Bureau of Labor Statistics. Nonfatal Occupational Injuries and Illnesses Requiring Days Away from Work, 2013. USDL-14-2246. 2014.

U.S. Department of Labor, Occupational Safety and Health Administration. Ergonomics: The Study of Work. OSHA 3125. 2000.

#### 73 Ergonomics: visual and physical

National Institute for Occupational Safety and Health. Musculoskeletal Disorders and Workplace Factors. 1997. U.S. Department of Health and Human Services, Washington, D.C.

#### 74 Exterior noise intrusion

Jakovljevic B, Paunovic K, Belojevic G. Road-traffic Noise and Factors Influencing Noise Annoyance in an Urban Population. 2008. Environment International, Volume 35, Issue 3, pp. 552-556.

Elmenhorst EM, Elmenhorst D, Wenzel J, Quehl J, Mueller U, et al. Effects of Nocturnal Aircraft Noise on Cognitive Performance in the Following Morning: Dose-Response Relationships in Laboratory and Field. 2010. International Archives of Occupational and Environmental Health, Volume 83, pp. 743-751.

Jarup L, Babisch W, Houthuijs D, Pershagen G, Katsouyanni K, et al. Hypertension and Exposure to Noise Near Airports: The HYENA Study. 2008. Environmental Health Perspectives, Volume 116, Issue 3 pp. 329-333.

Sørensen M, Andersen ZJ, Nordsborg RB, Jensen SS, Lillelund KG, et al. Road Traffic Noise and Incident Myocardial Infarction: A Prospective Cohort Study. 2012. PLoS One, Volume 7, Issue 6, e39283. ;www.ncbi.nlm.nih.gov/pmc/articles/PMC3380019/. Accessed April 22, 2015.

Sørensen M, Andersen ZJ, Nordsborg RB, Becker T, Tjønneland A, et al. Long-term Exposure to Road Traffic Noise and Incident Diabetes: A Cohort Study. 2013. Environmental Health Perspectives, Volume 121, pp. 217-222.

Sørensen M, Hvidberg M, Andersen ZJ, Nordsborg RB, Lillelund KG, et al. Road Traffic Noise and Stroke: A Prospective Cohort Study. 2011. European Heart Journal, Volume 32, pp. 737-744.

### 75 Internally generated noise

U.S. General Services Administration Center for Workplace Strategy Public Buildings Service. Sound Matters: How to Achieve Acoustic Comfort in the Contemporary Office. Washington, D.C.: 2012: 11, 29, 32, 33, 36.

Hedge A. The Open-plan Office: A Systematic Investigation of Employee Reactions to Their Work Environment. 1982. Environment and Behaviour, Volume 14, pp. 519-542.

Banbury SP, Berry DC. Office Noise and Employee Concentration: Identifying Causes of Disruption and Potential Improvements. 2005. Ergonomics, Volume 48, pp. 25-37.

Perham N, Hodgetts H, Banbury S. Mental Arithmetic and Non-speech Office Noise: An Exploration of Interference-by-Content. 2013. Noise & Health, Volume 15, pp. 73-78.

Kaarlela-Tuomaala A, Helenius R, Keskinen E, Hongisto V. Effects of Acoustic Environment on Work in Private Office Rooms and Open-plan Offices – Longitudinal Study During Relocation. 2009. Ergonomics, Volume 52, pp. 1423-1444.

#### 76 Thermal comfort

Fisk WJ, Black D, Brunner G. Benefits and Costs of Improved IEQ in U.S. Offices. 2011. Indoor Air Journal, Volume 21, pp. 357-367.

Wargocki P, Wyon DP. The Effects of Moderately Raised Classroom Temperatures and Classroom Ventilation Rate on the Performance of Schoolwork by Children. 2007. HVAC&R Research, Volume 13, pp. 280-286.

Arens E, Zhang H. The Skin's Role in Human Thermoregulation and Comfort. From Thermal and Moisture Transport in Fibrous Materials. 2006. University of California Berkeley, Center for the Built Environment; Berkeley, CA.

### 77 Olfactory comfort

Schiffman SS, Williams CM. Science of Odor as a Potential Health Issue. 2005. Journal of Environmental Quality, Volume 34, Issue 1, pp. 129-138.

### 78 Reverberation time

Blomkvist V, Eriksen CA, Theorell T, Ulrich R, Rasmanis G. Acoustics and Psychosocial Environment in Intensive Coronary Care. 2005. Occupational and Environmental Medicine, Volume 62, Issue 3, e1. <a href="http://oem.bmj.com/content/62/3/e1">http://oem.bmj.com/content/62/3/e1</a>. Accessed April 22, 2015.

#### 79 Sound masking

U.S. General Services Administration Center for Workplace Strategy Public Buildings Service. Sound Matters: How to Achieve Acoustic Comfort in the Contemporary Office. Washington, D.C.: 2012: 11, 29, 32, 33, 36.

Jensen KL, Arens E, Zagreus L. Acoustical Quality in Office Workstations, as Assessed by Occupant Surveys. 2005. Proceedings, Indoor Air, September 4-9, Beijing, China.

Loewen LJ, Suedfeld P. Cognitive and Arousal Effects of Masking Office Noise. 1992. Environment and Behavior, Volume 24, pp. 381-395.

### 80 Sound reducing surfaces

Blomkvist V, Eriksen CA, Theorell T, Ulrich R, Rasmanis G. Acoustics and Psychosocial Environment in Intensive Coronary Care. 2005. Occupational and Environmental Medicine, Volume 62, Issue 3, e1. http://oem.bmj.com/content/62/3/e1. Accessed April 22, 2015.

Katz JD. Noise in the Operating Room. 2014. Anesthesiology, Volume 121, pp. 894-898.

#### 83 Radiant thermal comfort

Kim KW, Olesen BW. Radiant Heating and Cooling Systems. ASHRAE Journal, Volume 57, Issue 2, pp. 28-37.

### Mind

American Counseling Association. Is Stress Affecting Your Health? <a href="http://www.counseling.org/knowledge-center/article-view/counseling-corner/2008/03/10/is-stress-affecting-your-health-">http://www.counseling.org/knowledge-center/article-view/counseling-corner/2008/03/10/is-stress-affecting-your-health-</a>. Published March 10, 2008. Accessed April 16, 2015.

Young, SN. How to Increase Serotonin in the Human Brain Without Drugs. Journal of Psychiatry and Neuroscience, Volume 32, Issue 4, pp. 394-399.

Mayer EA. The Neurobiology of Stress and Gastrointestinal Disease. 2000. Gut, Volume 47, pp. 861-869.

Chandola T, Brunner E, Marmot M. Chronic Stress at Work and the Metabolic Syndrome: Prospective Study. 2006. British Medical Journal, Volume 332, pp. 521-525.

Steptoe A, Kivimaki M. Stress and Cardiovascular Disease. 2012. Nature Reviews Cardiology, Volume 9, Issue 6, pp. 360-370.

Sapolsky RM. Why Zebras Don't Get Ulcers. Holt Paperbacks, 2004. p. 560.

Kessler RC, Berglund PA, Demler O, Jin R, Walters EE. Lifetime Prevalence and Age-of-Onset Distributions of DSM-IV Disorders in the National Comorbidity Survey Replication (NCS-R). 2005. Archives of General Psychiatry, Volume 62, Issue 6, pp. 593-602.

Whiteford HA, Degenhardt L, Rehm J, Baxter AJ, Ferrari AJ, et al. Global Burden of Disease Attributable to Mental and Substance Use Disorders: Findings from the Global Burden of Disease Study 2010. 2013. The Lancet, Volume 382, pp. 1575-1586.

Walker ER, McGee RE, Druss BG. Mortality in Mental Disorders and Global Disease Burden Implications: A Systematic Review and Meta-analysis. 2015. JAMA Psychiatry, Volume 72, Issue 4, pp. 334-341.

Johns Hopkins Medicine. Depression and Heart Disease.

http://www.hopkinsmedicine.org/heart\_vascular\_institute/clinical\_services/centers\_excellence/womens\_cardiovascular\_healt h\_center/patient\_information/health\_topics/depression\_heart\_disease.html. Accessed April 16, 2015.

National Institute of Mental Health. Major Depression Among Adults.

http://www.nimh.nih.gov/health/statistics/prevalence/major-depression-among-adults.shtml. Accessed April 16, 2015.

#### 84 Health and wellness awareness

National Academy of Sciences. Health Literacy: A Prescription to End Confusion. <a href="https://www.iom.edu/~/media/Files/Report%20Files/2004/Health-Literacy-A-Prescription-to-End-Confusion/healthliteracyfinal.pdf">https://www.iom.edu/~/media/Files/Report%20Files/2004/Health-Literacy-A-Prescription-to-End-Confusion/healthliteracyfinal.pdf</a>. Published April 2004. Accessed April 22, 2015.

U.S. Agency for Healthcare Research and Quality. Health Literacy Interventions and Outcomes: An Updated Systematic Review. Rockville, MD: Department of Health and Human Services, 2011.

#### 86 Post-occupancy surveys

Sapolsky RM. Why Zebras Don't Get Ulcers. Holt Paperbacks, 2004. p. 560.

#### 88 Biophilia I - qualitative

Ulrich RS. View Through a Window May Influence Recovery from Surgery. 1984. Science, Volume 224, pp. 420-421.

Ulrich RS. Effects of Healthcare Environmental Design on Medical Outcomes. Proceedings of the Second International Conference on Design and Health. Stockholm, Sweden: Svensk Byggtjanst, 49-59.

#### 89 Adaptable spaces

Lee SY, Brand JL. Effects of Control over Office Workspace on Perceptions of the Work Environment and Work Outcomes. 2005. Journal of Environmental Psychology, Volume 25, pp. 323-333.

#### 90 Healthy sleep policy

Centers for Disease Control and Prevention. Insufficient Sleep is a Public Health Epidemic. <a href="http://www.cdc.gov/features/dssleep/">http://www.cdc.gov/features/dssleep/</a>. Updated January 13, 2014. Accessed April 22, 2015.

Lyytikainen O, Rahkonen O, Lahelma E, Lallukka T. Association of Sleep Duration with Weight and Weight Gain: A Prospective Follow-up Study. 2011. Journal of Sleep Research, Volume 20, Issue 2, pp. 298-302.

Barber LK, Munz DC. Consistent-sufficient Sleep Predicts Improvements in Self-regulatory Performance and Psychological Strain. 2010. Stress and Health, Volume 27, pp. 314-324.

Institute of Medicine Committee on Sleep Medicine and Research. In: Colten HR and Altevogt BM, eds. Sleep Disorders and Sleep Deprivation: An Unmet Public Health Problem. 2006. National Academies Press, Washington, D.C.

#### 91 Business travel

Striker J, Dimberg L, Liese BH. Stress and Business Travel: Individual, Managerial, and Corporate Concerns. 2000. Journal of Organizational Excellence, Volume 20, pp. 3-10.

### 92 Building health policy

Centers for Disease Control and Prevention. Workplace Health Promotion. http://www.cdc.gov/workplacehealthpromotion/businesscase/benefits/, Updated October 23, 2013. Accessed April

22, 15.

Baicker K, Taubman SL, Allen HL, Bernstein M, Gruber JH, et al. The Oregon Experiment – Effects of Medicaid on Clinical Outcomes. 2013. New England Journal of Medicine, Volume 368, pp. 1713-1722.

#### 93 Workplace family support

Halpern DF. How Time-flexible Work Policies can Reduce Stress, Improve Health and Save Money. 2005. Stress and Health, Volume 21, pp. 157-168.

### 94 Self-monitoring

Community Preventive Services Task Force. Technology-supported Multicomponent Coaching or Counseling Interventions to Reduce Weight and Maintain Weight Loss.

http://www.thecommunityguide.org/obesity/TechnologicalCoaching.html. Updated December 9, 2013. Accessed April 24, 2015.

National Heart, Lung, and Blood Institute. The Practical Guide: Identification, Evaluation, and Treatment of Overweight and Obesity in Adults. <a href="http://www.nhlbi.nih.gov/files/docs/guidelines/prctgd-c.pdf">http://www.nhlbi.nih.gov/files/docs/guidelines/prctgd-c.pdf</a>. Published 2000. Accessed April 24, 2015.

#### 95 Stress and addiction treatment

The National Academies. Health and Behavior: The Interplay of Biological, Behavioral, and Societal Influences. 2001. National Academies Press, Washington, D.C.

#### 96 Altruism

Clary EG, Snyder M. The Motivations to Volunteer: Theoretical and Practical Considerations. 1999. Current Directions in Psychological Science, Volume 8, pp. 156-159.

Mental Health Foundation. Altruism. <a href="http://www.mentalhealth.org.uk/help-information/mental-health-a-z/A/altruisim/">http://www.mentalhealth.org.uk/help-information/mental-health-a-z/A/altruisim/</a>. Accessed April 22, 2015.

### 98 Organizational transparency

Kivimaki M, Ferrie JE, Head J, Shipley MJ, Vahtera J, et al. Organisational Justice and Change in Justice as Predictors of Employee Health: The Whitehall II Study. 2004. Journal of Epidemiology and Community Health, Volume 58, pp. 931-937.

### 99 Beauty and design II

Gesler W, Bell M, Curtis S, Hubbard P, Francis S. Therapy by Design: Evaluating the UK Hospital Building Program. 2004. Health and Place, Volume 10, pp. 117-128.

### 100 Biophilia II - quantitative

Ulrich RS. Effects of Healthcare Environmental Design on Medical Outcomes. Proceedings of the Second International Conference on Design and Health. Stockholm, Sweden: Svensk Byggtjanst, 49-59.

# Appendix I: Core & Shell Scope

WELL Core and Shell Certified projects integrate fundamental WELL features into the base building design and operation, which creates an incentive for future tenants seeking to support the health and productivity of their occupants. It also enables future tenants to more easily pursue WELL Certification for their interior spaces.

Core and Shell Certification includes the areas of the building controlled by the owner, including common spaces, such as lobbies and elevator banks, as well as any areas of the interior buildout managed by the project owner. Depending on the developer's scope, Core and Shell projects can receive Optimizations for complying with all parts of a WELL feature determined to be not applicable (see the WELL applicability matrix in the Introduction to the WELL Building Standard).

For further clarity, the following document outlines applicability determinations for Core and Shell projects.

- ·Entire Building: These features are required to be met throughout the entire building, in both tenant and owner-occupied spaces. For features which are intended to impact all occupants, such as amenity and common spaces, Core and Shell projects should use the expected building occupancy or the default occupancy of 250 ft²/person (23 m²/person).
- •Extent of Developer Buildout: These features are required to be met in all common areas, spaces under owner control, and all portions of the interior buildout managed by the project owner.
- •Extent of Developer Buildout with Capacity for Tenant Achievement: These features are required to be met in all spaces included in the developer buildout and require that the building systems in place have capacity to allow tenants to implement the feature requirements within their leased space.
- Extent of Developer Buildout and Confirmed Tenant Support: These features are required to be met in all spaces included in the developer buildout and require the building owner to provide tenants with full support to meet the feature requirements. This may include providing tenants fiscal allowance to implement the feature. Additional documentation may be required in these cases, depending on the type of support provided. Lease or sales agreements that leave the cost of implementation to the tenant do not qualify.
- ·Spaces under Owner Control with Tenant Education: These policy-based features are required to be met for the staff operating the Core and Shell building or employed by the project owner and working in the building (full time and part time). Additionally, they require the project owner to provide education to tenants related to the benefits and implementation the programs described in the feature.
- ·Common Areas and Spaces under Owner Control: These features are required to be met in common areas and spaces under building owner control.
- ·Spaces Under Owner Control: These features are required to be met only in spaces that are used by the staff operating the Core and Shell building or employed by the project owner and working in the building.

AIR	Scope	
FEATURE 01: AIR QUALITY STANDARDS		
PART 1: Standards for Volatile Substances	common areas and spaces under owner control	PRE
PART 2: Standards for Particulate Matter and Inorganic Gases	common areas and spaces under owner control	PRE
PART 3: Radon	common areas and spaces under owner control	PRE

AIR	Scope	
FEATURE 02: SMOKING BAN		
PART 1: Indoor Smoking Ban	entire building	PRE
PART 2: Outdoor Smoking Ban	entire building	PRE
FEATURE 03: VENTILATION EFFECTIVENESS	3	
PART 1: Ventilation Design	extent of developer buildout with capacity for tenant achievement	PRE
PART 2: Demand Controlled Ventilation	extent of developer buildout with capacity for tenant achievement	PRE
FEATURE 04: VOC REDUCTION		
PART 1: Interior Paints and Coatings	extent of developer buildout	PRE
PART 2: Interior Adhesives and Sealants	extent of developer buildout	PRE
PART 3: Flooring	extent of developer buildout	PRE
PART 4: Insulation	extent of developer buildout	PRE
PART 5: Furniture and Furnishings	extent of developer buildout	PRE
FEATURE 05: AIR FILTRATION		
PART 1: Filter Accommodation	extent of developer buildout with capacity for tenant achievement	PRE
PART 2: Particle Filtration	extent of developer buildout with capacity for tenant achievement	PRE
PART 3: Air Filtration Maintenance	extent of developer buildout with capacity for tenant achievement	PRE
FEATURE 06: MICROBE AND MOLD CONTRO	OL	
PART 1: Cooling Coil Mold Reduction	extent of developer buildout with capacity for tenant achievement	PRE
PART 2: Mold Inspections	common areas and spaces under owner control	PRE
FEATURE 07: CONSTRUCTION POLLUTION I	MANAGEMENT	
PART 1: Duct Protection	extent of developer buildout	PRE
PART 2: Filter Replacement	extent of developer buildout	PRE
PART 3: Moisture Absorption Management	extent of developer buildout	PRE
PART 4: Dust Containment and Removal	extent of developer buildout	PRE
FEATURE 08: HEALTHY ENTRANCE		
PART 1: Entryway Walk-Off Systems	entire building	PRE
PART 2: Entryway Air Seal	entire building	PRE
FEATURE 09: CLEANING PROTOCOL		
PART 1: Cleaning Plan for Occupied Spaces	extent of developer buildout and confirmed tenant support	N/A
FEATURE 10: PESTICIDE MANAGEMENT		
PART 1: Pesticide Use	entire building	PRE

AIR	Scope	
FEATURE 11: FUNDAMENTAL MATERIAL SA	AFETY	
PART 1: Asbestos and Lead Restriction	extent of developer buildout	PRE
PART 2: Lead Abatement	entire building	PRE
PART 3: Asbestos Abatement	entire building	PRE
PART 4: Polychlorinated Biphenyl Abatement	entire building	PRE
PART 5: Mercury Limitation	extent of developer buildout	PRE
FEATURE 12: MOISTURE MANAGEMENT		
PART 1: Exterior Liquid Water Management	entire building	PRE
PART 2: Interior Liquid Water Management	extent of developer buildout	PRE
PART 3: Condensation Management	extent of developer buildout	PRE
PART 4: Material Selection and Protection	extent of developer buildout	PRE
FEATURE 13: AIR FLUSH		
PART 1: Air Flush	entire building	N/A
FEATURE 14: AIR INFILTRATION MANAGEM		
PART 1: Air Leakage Testing	entire building	OPT
FEATURE 15: INCREASED VENTILATION		
PART 1: Increased Outdoor Air Supply	extent of developer buildout with capacity for tenant achievement	OPT
FEATURE 16: HUMIDITY CONTROL	and the facilities of	NI/A
PART 1: Relative Humidity	entire building	N/A
FEATURE 17: DIRECT SOURCE VENTILATION PART 1: Pollution Isolation and Exhaust	extent of developer buildout with capacity for tenant achievement	OPT
		<u> </u>
FEATURE 18: AIR QUALITY MONITORING A PART 1: Indoor Air Monitoring	extent of developer buildout	N/A
PART 2: Air Data Record Keeping and Response	extent of developer buildout	N/A
PART 3: Environmental Measures Display	extent of developer buildout	N/A
FEATURE 19: OPERABLE WINDOWS		
PART 1: Full Control	entire building	OPT
PART 2: Outdoor Air Measurement	entire building	OPT
PART 3: Window Operation Management	entire building	OPT
FEATURE 20: OUTDOOR AIR SYSTEMS		
PART 1: Dedicated Outdoor Air Systems	entire building	OPT

AIR	Scope	
FEATURE 21: DISPLACEMENT VENTILATION		
PART 1: Displacement Ventilation Design and Application	entire building	N/A
PART 2: System Performance	entire building	N/A
FEATURE 22: PEST CONTROL		
PART 1: Pest Reduction	extent of developer buildout and confirmed tenant support	N/A
PART 2: Pest Inspection	entire building	N/A
FEATURE 23: ADVANCED AIR PURIFICATION		
PART 1: Carbon Filtration	extent of developer buildout with capacity for tenant achievement	OPT
PART 2: Air Sanitization	extent of developer buildout with capacity for tenant achievement	OPT
PART 3: Air Quality Maintenance	extent of developer buildout with capacity for tenant achievement	OPT
FEATURE 24: COMBUSTION MINIMIZATION		
PART 1: Appliance and Heater Combustion Ban	entire building	OPT
PART 2: Low-Emission Combustion Sources	entire building	OPT
PART 3: Engine Exhaust Reduction	entire building	OPT
PART 4: Construction Equipment	entire building	OPT
FEATURE 25: TOXIC MATERIAL REDUCTION		
PART 1: Perfluorinated Compound Limitation	extent of developer buildout	N/A
PART 2: Flame Retardant Limitation	extent of developer buildout	N/A
PART 3: Phthalate (Plasticizers) Limitation	extent of developer buildout	N/A
PART 4: Isocyanate-Based Polyurethane Limitation	extent of developer buildout	N/A
PART 5: Urea-Formaldehyde Restriction	extent of developer buildout	N/A
FEATURE 26: ENHANCED MATERIAL SAFETY		
PART 1: Precautionary Material Selection	extent of developer buildout	N/A
FEATURE 27: ANTIMICROBIAL ACTIVITY FOR	SURFACES	
PART 1: High-Touch Surfaces	extent of developer buildout	N/A
FEATURE 28: CLEANABLE ENVIRONMENT		
PART 1: Material Properties	extent of developer buildout	N/A
PART 2: Cleanability	extent of developer buildout	N/A
FEATURE 29: CLEANING EQUIPMENT		
PART 1: Equipment and Cleaning Agents	extent of developer buildout and confirmed tenant support	N/A
PART 2: Chemical Storage	extent of developer buildout and confirmed tenant support	N/A

WATER	Scope	
FEATURE 30: FUNDAMENTAL WATER QUALITY		
PART 1: Sediment	extent of developer buildout and confirmed tenant support	PRE
PART 2: Microorganisms	extent of developer buildout and confirmed tenant support	PRE
FEATURE 31: INORGANIC CONTAMINANTS		
PART 1: Dissolved Metals	extent of developer buildout and confirmed tenant support	PRE
FEATURE 32: ORGANIC CONTAMINANTS		
PART 1: Organic Pollutants	extent of developer buildout and confirmed tenant support	PRE
FEATURE 33: AGRICULTURAL CONTAMINANTS		
PART 1: Herbicides and Pesticides	extent of developer buildout and confirmed tenant support	PRE
PART 2: Fertilizers	extent of developer buildout and confirmed tenant support	PRE
FEATURE 34: PUBLIC WATER ADDITIVES		
PART 1: Disinfectants	extent of developer buildout and confirmed tenant support	PRE
PART 2: Disinfectant Byproducts	extent of developer buildout and confirmed tenant support	PRE
PART 3: Fluoride	extent of developer buildout and confirmed tenant support	PRE
FEATURE 35: PERIODIC WATER QUALITY TESTIN	NG	
PART 1: Quarterly Testing	extent of developer buildout	N/A
PART 2: Water Data Record Keeping and Response	extent of developer buildout	N/A
FEATURE 36: WATER TREATMENT		
PART 1: Organic Chemical Removal	extent of developer buildout and confirmed tenant support	OPT
PART 2: Sediment Filter	extent of developer buildout and confirmed tenant support	OPT
PART 3: Microbial Elimination	extent of developer buildout and confirmed tenant support	OPT
PART 4: Water Quality Maintenance	extent of developer buildout and confirmed tenant support	OPT
PART 5: Legionella Control	entire building	OPT
FEATURE 37: DRINKING WATER PROMOTION		
PART 1: Drinking Water Taste Properties	extent of developer buildout and confirmed tenant support	OPT
NOURISHMENT	Scope	
FEATURE 38: FRUITS AND VEGETABLES		
PART 1: Fruit and Vegetable Variety	common areas and spaces under owner control	N/A
PART 2: Fruit and Vegetable Promotion	common areas and spaces under owner control	N/A
FEATURE 39: PROCESSED FOODS		
PART 1: Refined Ingredient Restrictions	common areas and spaces under owner control	PRE
PART 2: Trans Fat Ban	common areas and spaces under owner control	PRE

NOURISHMENT	Scope	
FEATURE 40: FOOD ALLERGIES		
PART 1: Food Allergy Labeling	common areas and spaces under owner control	PRE
FEATURE 41: HAND WASHING		
PART 1: Hand Washing Supplies	extent of developer buildout	N/A
PART 2: Contamination Reduction	extent of developer buildout	N/A
PART 3: Sink Dimensions	extent of developer buildout	N/A
FEATURE 42: FOOD CONTAMINATION		
PART 1: Cold Storage	common areas and spaces under owner control	N/A
FEATURE 43: ARTIFICIAL INGREDIENTS		
PART 1: Artificial Substance Labeling	common areas and spaces under owner control	OPT
FEATURE 44: NUTRITIONAL INFORMATION		
PART 1: Detailed Nutritional Information	common areas and spaces under owner control	OPT
FEATURE 45: FOOD ADVERTISING		OPT
PART 1: Advertising and Environmental Cues	common areas and spaces under owner control	OPT
PART 2: Nutritional Messaging	common areas and spaces under owner control	OPT
FEATURE 46: SAFE FOOD PREPARATION MATERIA		N1/A
PART 1: Cooking Material	common areas and spaces under owner control	N/A
PART 2: Cutting Surfaces	common areas and spaces under owner control	N/A
FEATURE 47: SERVING SIZES		N1/A
PART 1: Meal Sizes	common areas and spaces under owner control	N/A
PART 2: Dishware	common areas and spaces under owner control	N/A
FEATURE 48: SPECIAL DIETS		A1/A
PART 1: Food Alternatives	common areas and spaces under owner control	N/A
FEATURE 49: RESPONSIBLE FOOD PRODUCTION	common areas and spaces under owner control	N/A
PART 1: Sustainable Agriculture	·	
PART 2: Humane Agriculture	common areas and spaces under owner control	N/A
FEATURE 50: FOOD STORAGE	common areas and spaces under owner control	N/A
PART 1: Storage Capacity	common areas and spaces under owner control	IV/A
FEATURE 51: FOOD PRODUCTION  PART 1: Gardening Space	entire building	OPT
	entire building	OPT
PART 2: Planting Support	entire building	Ji i
FEATURE 52: MINDFUL EATING PART 1: Eating Spaces	entire building	OPT
	entire building	OPT
PART 2: Break Area Furnishings	entile building	OFI

LIGHT	Scope	
FEATURE 53: VISUAL LIGHTING DESIGN		
PART 1: Visual Acuity for Focus	entire building	N/A
PART 2: Brightness Management Strategies	entire building	N/A
FEATURE 54: CIRCADIAN LIGHTING DESIGN		
PART 1: Melanopic Light Intensity for Work Areas	entire building	N/A
FEATURE 55: ELECTRIC LIGHT GLARE CONTRO	L	
PART 2: Glare Minimization	extent of developer buildout	PRE
FEATURE 56: SOLAR GLARE CONTROL		
PART 1: View Window Shading	extent of developer buildout and confirmed tenant support	OPT
PART 2: Daylight Management	extent of developer buildout and confirmed tenant support	OPT
FEATURE 57: LOW-GLARE WORKSTATION DESI	IGN	
PART 1: Glare Avoidance	entire building	N/A
FEATURE 58: COLOR QUALITY		
PART 1: Color Rendering Index	entire building	N/A
FEATURE 59: SURFACE DESIGN		h1/A
PART 1: Working and Learning Area Surface Reflectivity	entire building	N/A
FEATURE 60: AUTOMATED SHADING AND DIM		
PART 1: Automated Sunlight Control	extent of developer buildout and confirmed tenant support	N/A
PART 2: Responsive Light Control	extent of developer buildout and confirmed tenant support	N/A
FEATURE 61: RIGHT TO LIGHT		
PART 1: Lease Depth	entire building	OPT
FEATURE 62: DAYLIGHT MODELING		
PART 1: Healthy Sunlight Exposure	entire building	OPT
FEATURE 63: DAYLIGHTING FENESTRATION	andra II. II II.	OPT
PART 1: Window Sizes for Working and Learning Spaces	entire building	OFT
PART 2: Window Transmittance in Working and Learning Areas	entire building	OPT
PART 3: Uniform Color Transmittance	entire building	OPT
FITNESS	Scope	
FEATURE 64: INTERIOR FITNESS CIRCULATION		
PART 1: Stair Accessibility and Promotion	entire building	PRE
PART 2: Staircase Design	entire building	PRE
PART 3: Facilitative Aesthetics	entire building	PRE

FITNESS	Scope	
FEATURE 65: ACTIVITY INCENTIVE PROGRAMS	5	
PART 1: Activity Incentive Programs	spaces under owner control with tenant education	N/A
FEATURE 66: STRUCTURED FITNESS OPPORTU	INITIES	
PART 1: Fitness Programs	entire building	N/A
PART 2: Fitness Education	entire building	N/A
FEATURE 67: EXTERIOR ACTIVE DESIGN		
PART 1: Pedestrian Amenities	entire building	OPT
PART 2: Pedestrian Promotion	entire building	OPT
PART 3: Neighborhood Connectivity	entire building	OPT
FEATURE 68: PHYSICAL ACTIVITY SPACES		
PART 1: Site Space Designation for Offices	entire building	OPT
PART 2: External Exercise Spaces	entire building	OPT
FEATURE 69: ACTIVE TRANSPORTATION SUPP	ORT	
PART 1: Bicycle Storage and Support	extent of developer buildout with confirmed tenant support	OPT
PART 2: Post Commute and Workout Facilities	extent of developer buildout with confirmed tenant support	OPT
FEATURE 70: FITNESS EQUIPMENT		
PART 1: Cardiorespiratory Exercise Equipment	entire building	OPT
PART 2: Muscle-strengthening Exercise Equipment	entire building	OPT
FEATURE 71: ACTIVE FURNISHINGS		
PART 1: Active Workstations	entire building	N/A
PART 2: Prevalent Standing Desks	entire building	N/A
COMFORT	Scope	
FEATURE 72: ACCESSIBLE DESIGN		
PART 1: Accessibility and Usability	extent of developer buildout	PRE
FEATURE 73: ERGONOMICS: VISUAL AND PHY	SICAL	
PART 1: Visual Ergonomics	entire building	N/A
PART 2: Desk Height Flexibility	entire building	N/A
PART 3: Seat Flexibility	entire building	N/A
FEATURE 74: EXTERIOR NOISE INTRUSION		
PART 1: Sound Pressure Level	entire building	PRE
FEATURE 75: INTERNALLY GENERATED NOISE	common areas and spaces under owner control	OPT
PART 2: Mechanical Equipment Sound Levels	common areas and spaces ander owner control	<u> </u>

COMFORT	Scope	
FEATURE 76: THERMAL COMFORT		
PART 1: Ventilated Thermal Environment	extent of developer buildout with capacity for tenant achievement	PRE
PART 2: Natural Thermal Adaptation	extent of developer buildout with capacity for tenant achievement	PRE
FEATURE 77: OLFACTORY COMFORT		
PART 1: Source Separation	entire building	N/A
FEATURE 78: REVERBERATION TIME		
PART 1: Reverberation Time	entire building	N/A
FEATURE 79: SOUND MASKING		
PART 1: Sound Masking Use	entire building	N/A
PART 2: Sound Masking Limits	entire building	N/A
FEATURE 80: SOUND REDUCING SURFACES		
PART 1: Ceilings	entire building	N/A
PART 2: Vertical Surfaces	entire building	N/A
FEATURE 81: SOUND BARRIERS		
PART 1: Wall Construction Specifications	entire building	N/A
PART 2: Doorway Specifications	entire building	N/A
PART 3: Wall Construction Methodology	entire building	N/A
FEATURE 82: INDIVIDUAL THERMAL CONTRO	DL	
PART 1: Free Address	entire building	N/A
PART 2: Personal Thermal Comfort Devices	entire building	N/A
FEATURE 83: RADIANT THERMAL COMFORT		
PART 1: Lobbies and Other Common Spaces	common areas and spaces under owner control only	OPT

MIND	Scope	
FEATURE 84: HEALTH AND WELLNESS AWARENESS		
PART 1: WELL Building Standard® Guide	entire building	PRE
PART 2: Health and Wellness Library	entire building	PRE
FEATURE 85: INTEGRATIVE DESIGN		
PART 1: Stakeholder Charrette	extent of developer buildout	PRE
PART 2: Development Plan	extent of developer buildout	PRE
PART 3: Stakeholder Orientation	extent of developer buildout	PRE

MIND	Scope	
FEATURE 86: POST-OCCUPANCY SURVEYS		
PART 1: Occupant Survey Content	entire building	N/A
PART 2: Information Reporting	entire building	N/A
FEATURE 87: BEAUTY AND DESIGN I		
PART 1: Beauty and Mindful Design	common areas and spaces under owner control	PRE
FEATURE 88: BIOPHILIA I - QUALITATIVE		
PART 1: Nature Incorporation	common areas and spaces under owner control	OPT
PART 2: Pattern Incorporation	common areas and spaces under owner control	OPT
PART 3: Nature Interaction	common areas and spaces under owner control	OPT
FEATURE 89: ADAPTABLE SPACES		
PART 1: Stimuli Management	spaces under owner control	N/A
PART 2: Privacy	entire building	N/A
PART 3: Space Management	entire building	N/A
PART 4: Workplace Sleep Support	spaces under owner control	N/A
FEATURE 90: HEALTHY SLEEP POLICY		
PART 1: Non-Workplace Sleep Support	spaces under owner control with tenant education	N/A
FEATURE 91: BUSINESS TRAVEL		
PART 1: Travel Policy	spaces under owner control with tenant education	N/A
FEATURE 92: BUILDING HEALTH POLICY		
PART 1: Health Benefits	spaces under owner control with tenant education	N/A
FEATURE 93: WORKPLACE FAMILY SUPPORT		
PART 1: Parental Leave	spaces under owner control with tenant education	N/A
PART 2: Employer Supported Child Care	spaces under owner control with tenant education	N/A
PART 3: Family Support	spaces under owner control with tenant education	N/A
FEATURE 94: SELF-MONITORING		
PART 1: Sensors and Wearables	spaces under owner control with tenant education	N/A
FEATURE 95: STRESS AND ADDICTION TREATME		
PART 1: Mind and Behavior Support	spaces under owner control with tenant education	N/A
PART 2: Stress Management	spaces under owner control with tenant education	N/A
FEATURE 96: ALTRUISM		
PART 1: Charitable Activities	spaces under owner control with tenant education	N/A
PART 2: Charitable Contributions	spaces under owner control with tenant education	N/A

MIND	Scope	
FEATURE 97: MATERIAL TRANSPARENCY		
PART 1: Material Information	extent of developer buildout	OPT
PART 2: Accessible Information	extent of developer buildout	OPT
FEATURE 98: ORGANIZATIONAL TRANSPARENCY		
PART 1: Transparency Program Participation	common areas and spaces under owner control	N/A
FEATURE 99: BEAUTY AND DESIGN II		
PART 1: Ceiling Height	extent of developer buildout	OPT
PART 2: Artwork	common areas and spaces under owner control	OPT
PART 3: Spatial Familiarity	common areas and spaces under owner control	OPT
FEATURE 100: BIOPHILIA II - QUANTITATIVE		
PART 1: Outdoor Biophilia	entire building	OPT
PART 3: Water Feature	entire building	OPT