

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
(Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Trinity Industries De Mexico S De R L De C V Huehuetoca Plant, Calzada De Las Marisoles Lote 1Ex-hacienda De Xalpa, Huehuetoca, Edo. De Mexico, Cp 54680, MEXICO
(Name and address of manufacturer)

2. Manufactured for DPC LEASING, 3323 SILENT SPRING DRIVE, SUGARLAND, TX, 77479, USA
(Name and address of purchaser)

3. Location of Installation NOT KNOWN
(Name and address)

4. Type Horizontal tank H0800183 N/A 875680 Rev. A H0800183 2008
(Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (Drawing No.) (National Board number) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 2004 to 2006
(Code Case numbers) (Special Service per UG-120(d)) (year) [Addenda (Date)]

6. Shell: SA-612 0.589" 0 9' 0.168" (ID) 31' 10"
(Material spec. number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) (Length overall)

7. Seams: TYPE 1 FULL 100% N/A N/A TYPE 1 SPOT 85% 4
[Long. (welded, dbl., sngl., lap, butt)] R.T. (Spot or Full) Eff. (%) (H.T. temp) Time (hr) [Girth. (welded, dbl., sngl., lap, butt)] [R.T. (spot or full)] Eff (%) No. of Courses

8. Heads: (a) Material SA-612N (b) Material _____
(Spec. no., grade) (Spec. no., grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) ENDS	0.345"	0	N/A	N/A	N/A	N/A	54.328"	N/A	Concave

If removable, bolts used (describe other fastenings) _____
(Material, spec. number, grade, size, number)

9. MAWP 250 psi 13 psi at max. temp. 125 °F 125 °F
(Internal) (External) (Internal) (External)

Min. design metal temp. 2 °F at 250 psi Hydro, pneu., or comb. test pressure HYDRO. at 325 psi

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	Number	Diameter or Size	Type	Material	Nominal Thickness	Reinforcement Material	How Attached	Location
MANWAY	1	16"	RFPF	SA-105	3.688"	INTEGRAL	UW16.1(l)	Head
FLOAT GAUGE	1	2 1/2"	CPLG	SA-105	3000#	N/A	UW16.1(y-2)	N/A
ROTARY GAUGE	1	2"	CPLG	SA-105	3000#	N/A	UW16.1(y-2)	N/A
THERMOWELL	1	3/4"	CLPG	SA-105	6000#	N/A	UW16.1(y-2)	N/A
LIQ. LVL & PRESS. GA.	1	3/4"	CPLG	SA-105	6000#	N/A	UW16.1(y-2)	N/A
VAPOR	1	2"	CPLG	SA-105	3000#	N/A	UW16.1(y-2)	N/A

Additional Nozzles - See Attached U-4...

11. Supports: Skirt NO Lugs N/A Legs N/A Other PADS AND SKID Attached WELDED TO SHELL
(Yes or no) (Number) (Number) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors, have been furnished for the following items of the report:
N/A

(Name of part, item number, Manufacturer's name and identifying stamp)

TANK, HORIZONTAL SKID STORAGE: 109.346"OD x 18.000WG. TO BE USED IN A NON-CORROSIVE SERVICE. IMPACT TEST EXEMPTED PER UCS-66 (a), UCS-66 (b) AND UG-20 (f). PRESSURE RELIEF DEVICES PER UG-125.

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1, "U" Certificate of Authorization No. 21957 expires 09/13/2010
Date 03/31/2008 Co. name Trinity Industries De Mexico S De R L De C V Huehuetoca Plant Signed _____
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Trinity Industries De Mexico S De R L De C V Huehuetoca Plant at Calzada De Las Marisoles Lote 1Ex-hacienda De Xalpa, Huehuetoca, Edo. De Mexico, Cp 54680, MEXICO
undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province TX, the and employed by OneBeacon America Insurance Co. of Lynn, MA and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
Date 03/31/2008 Signed _____ Commissions 12606A, TX1722
(Authorized Inspector) (National Board (incl. endorsements), State, Province and number)

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
 As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII,

1. Manufactured and certified by Trinity Industries De Mexico S De R L De C V Huehuetoca Plant, Calzada De Las Marisoles Lote 1 Ex-hacienda De Xalpa, Huehuetoca, Edo. De Mexico, Cp 54680, MEXICO
(Name and address of Manufacturer)

2. Manufactured for DPC LEASING, 3323 SILENT SPRING DRIVE, SUGARLAND, TX, 77479, USA
(Name and address of Purchaser)

3. Location of Installation NOT KNOWN
(Name and address)

4. Type Horizontal tank N/A H0800183
(Horizontal, vertical, or sphere) (Tank, separator, heat exh., etc.) (Manufacturer's serial number)

N/A 875680 Rev. A H0800183 2008
(CRN) (drawing no.) (National Board number) (Year built)

Additional nozzles, inspection and safety valve openings:

Additional nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Mat'l.	Nom. Thk.	Reinforcement Mat'l.	How Attached	Location
LIQUID OUT	1	3"	CPLG	SA-105	6000#	N/A	UW16.1(y-2)	N/A
FILL	1	2"	CPLG	SA-105	3000#	N/A	UW16.1(y-2)	N/A
DRAIN	1	2"	CPLG	SA-105	3000#	N/A	UW16.1(z-1)	N/A
RELIEF	2	2"	CPLG	SA-105	3000#	N/A	UW16.1(z-1)	N/A
SPARE	2	3/4"	CPLG	SA-105	6000#	N/A	UW16.1(y-2)	N/A

Certificate of Authorization: Type "U" No. 21957 Expires 09/13/2010

Date 03/31/2008 Name Trinity Industries De Mexico S De R L De C V Huehuetoca Plant
(Manufacturer) Signed [Signature]
(Representative)

Date 03/31/2008 Name [Signature] Commissions: 12606A, TX1722
(Authorized Inspector) (National Board (incl. endorsements), State, Province and number)