

Energy Management Connected Components Building Block - Powermonitor 1000



Allen-Bradley

Quick Start



Allen-Bradley • Rockwell Software

**Rockwell
Automation**

Important User Information

Solid state equipment has operational characteristics differing from those of electromechanical equipment. Safety Guidelines for the Application, Installation and Maintenance of Solid State Controls (publication [SGI-1.1](#) available from your local Rockwell Automation sales office or online at <http://www.rockwellautomation.com/literature/>) describes some important differences between solid state equipment and hard-wired electromechanical devices. Because of this difference, and also because of the wide variety of uses for solid state equipment, all persons responsible for applying this equipment must satisfy themselves that each intended application of this equipment is acceptable.

In no event will Rockwell Automation, Inc. be responsible or liable for indirect or consequential damages resulting from the use or application of this equipment.

The examples and diagrams in this manual are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Rockwell Automation, Inc. cannot assume responsibility or liability for actual use based on the examples and diagrams.

No patent liability is assumed by Rockwell Automation, Inc. with respect to use of information, circuits, equipment, or software described in this manual.

Reproduction of the contents of this manual, in whole or in part, without written permission of Rockwell Automation, Inc., is prohibited.

Throughout this manual, when necessary, we use notes to make you aware of safety considerations.

WARNING



Identifies information about practices or circumstances that can cause an explosion in a hazardous environment, which may lead to personal injury or death, property damage, or economic loss.

IMPORTANT

Identifies information that is critical for successful application and understanding of the product.

ATTENTION



Identifies information about practices or circumstances that can lead to personal injury or death, property damage, or economic loss. Attentions help you identify a hazard, avoid a hazard, and recognize the consequence

SHOCK HAZARD



Labels may be on or inside the equipment, for example, a drive or motor, to alert people that dangerous voltage may be present.

BURN HAZARD



Labels may be on or inside the equipment, for example, a drive or motor, to alert people that surfaces may reach dangerous temperatures.

Rockwell Automation, Allen-Bradley, Rockwell Software, Powermonitor 1000, Powermonitor 3000, PanelView Component, ControlLogix, RSLogix 500, RSEnergyMetrix, RSLinx Classic, RSPower, and TechConnect are either trademarks or registered trademarks of Rockwell Automation, Inc.

Trademarks not belonging to Rockwell Automation are property of their respective companies.

Follow the path below to complete your connected components building block.

Connected Components
Building Blocks, publication
[CC-QS001](#)

[Chapter 1 Powermonitor 1000 Device Configuration](#)

The screenshot shows the 'Powermonitor 1000 Utility Page' in a Microsoft Internet Explorer browser. The page title is 'Power and Energy Management Solutions' by Rockwell Automation. The main content area is titled 'Ethernet Configuration' and contains a table with the following data:

Element	Item Name	Value
0	Password Range 0 to 9999	192
2	IP Address Byte b (xxx.bbb.xxx.xxx) Range 0 to 255	168
3	IP Address Byte c (xxx.xxx.ccc.xxx) Range 0 to 255	1
4	IP Address Byte d (xxx.xxx.xxx.ddd) Range 0 to 255	7

[Chapter 2 System Validation and Application Tips](#)

The screenshot shows the 'Device Setup' window. On the left is a tree view of the system hierarchy, including 'System Status', 'Groups', 'Devices', and 'Efficient Industries Plant 1'. The 'Boiler House' device is selected. The right pane shows the 'Device Setup' configuration for the 'Boiler House' device, which is a 'Powermonitor 1000 (EM3) on EtherNet/IP'. The configuration includes the following fields:

- Device Information:**
 - Device Configuration:**
 - Device Viewer:**
 - ☒ Enable device
 - ☒ Enable real-time logging
 - ☒ Enable auto data repopulation
 - Parent group:** --Electricity
 - Device class:** Powermonitor 1000 (EM3) on EtherNet/IP
 - Name:** Boiler House
 - Notes:** (empty text area)
 - Time zone:** (GMT-06:00) Central Time (US & Canada)
 - Time sync:** Daily
 - Device password:** *****

Notes:

Preface	Introduction	7
	Conventions Used in This Manual	8
	Additional Resources.	9
	Chapter 1	
Powermonitor 1000 Device Configuration	Introduction	11
	Before You Begin	11
	What You Need	12
	Follow These Steps	12
	Configure a Powermonitor 1000 Device	13
	Additional Resources.	19
	Chapter 2	
System Validation and Application Tips	Introduction	21
	Before You Begin	21
	What You Need	21
	Follow These Steps	22
	Powermonitor 1000 Device to PanelView Component Configuration	23
	Powermonitor 1000 Device to RSEnergyMetrix Software Configuration	25
	Configure Communication Drivers	26
	Configure a Powermonitor 1000 Device	28
	Copy Devices	30
	Creating Electric Meters in RSEnergyMetrix Software.	31
	Additional Resources.	36
	Appendix A	
Frequently Asked Questions	Introduction	37

Notes:

Introduction

This quick start is designed to provide a way to implement and use a connected component for energy management. To assist in the design and installation of your system, application files and other information are provided on the Connected Components Building Blocks Overview CD, publication CC-QR001. The CD provides bills of materials (BOM), CAD drawings for panel layout and wiring, control programs, Human Machine Interface (HMI) screens, and more. With these tools and the built-in best-practices design, the system designer is free to focus on the design of their machine control and not on design overhead tasks. The beginning of each chapter contains the following information. Read these sections carefully before beginning work in each chapter:

- **Before You Begin** - This section lists the steps that must be completed and decisions that must be made before starting that chapter. The chapters in this quick start do not have to be completed in the order in which they appear, but this section defines the minimum amount of preparation required before completing the current chapter.
- **What You Need** - This section lists the tools that are required to complete the steps in the current chapter. This includes, but is not limited to, hardware and software.
- **Follow These Steps** - This illustrates the steps in the current chapter and identifies which steps are required to complete the examples.

Use this Energy Management Connected Components Building Block Quick Start in conjunction with the Connected Components Building Blocks Quick Start, publication [CC-QS001](#).

Refer to Additional Resources on [page 9](#) for a listing of quick starts.

Conventions Used in This Manual

This manual uses these conventions.

Convention	Meaning	Example
Check or uncheck	To activate or deactivate a checkbox.	Check Disable Keying.
Click	Click the left mouse button once while the cursor is positioned on object or selection.	Click Browse.
Select	Using the mouse to highlight a specific option.	Select the New Module folder.
Enter	What you type.	Enter your choice.
>	Use this symbol to indicate the sub-menu name.	Choose File > Menu > Options.

Additional Resources

Resource	Description
Connected Components Building Blocks Quick Start, publication CC-QS001	Provides information on how to select products and gain access to panel and wiring information.
Connected Component Building Blocks Overview CD, publication CC-QR001	Provides files for the Connected Component Building Blocks.
MicroLogix 1400 Programmable Controllers User Manual, publication 1766-UM001	Provides information on using the MicroLogix 1400 programmable controller.
MicroLogix 1400 Programmable Controllers Installation Instructions, publication 1766-IN001	Provides information on installing the MicroLogix 1400 programmable controller.
MicroLogix 1400 Programmable Controllers Instruction Set Reference Manual, publication 1766-RM001	Provides information on using the MicroLogix 1400 programmable controller RSLogix 500 instruction set.
http://www.ab.com	Provides access to the Allen-Bradley website.
Powermonitor 1000 User Manual, publication 1408-UM001	Provides information for using the Powermonitor 1000 device.
Powermonitor 1000 Installation Instructions, publication 1408-IN001	Provides information for installing the Powermonitor 1000 device.
PanelView Component Operator Terminals User Manual, publication 2711C-UM001	Provides information on using the PanelView Component HMI terminals.
PanelView Component Installation Instructions, publication 2711C-IN001	Provides installation information for the PanelView Component terminal.
REnergyMetrix Getting Results Guide, publication ENEMTX-GR001	Provides information about using REnergyMetrix software.
Current Transformer Selection Matrix, publication 1411-SG001	Provides a selection matrix for choosing your current transformer.
http://www.rockwellautomation.com/knowledgebase	Provides access to self-service support.
http://www.rockwellautomation.com/components/connected	Provides access to the Connected Components website.

Notes:

Powermonitor 1000 Device Configuration

Introduction

In this chapter, you will learn to configure a Powermonitor 1000 device.

For other configuration parameters such as, Wiring Mode WYE, Delta, Potential/Current Transformer ratios, Demand periods, and advanced configuration, you need to consult these Powermonitor 1000 publications:

- Bulletin 1408 Powermonitor 1000 User Manual, publication [1408-UM001](#)
- Powermonitor 1000 Unit Installation Instructions, publication [1408-IN001](#)

Before You Begin

- Review the Energy Management Connected Component Building Blocks common folder to review important background information regarding your Powermonitor device and software package
- Select hardware and wire devices. Refer to the Powermonitor 1000 Unit Installation Instructions, publication [1408-IN001](#), for reference.


What You Need

- Powermonitor 1000 device
- PanelView Component HMI terminal
- RSLogix 500 and RSEnergyMetrix software
- Current transformers and potential transformers, if required (refer to the Powermonitor 1000 User Manual, publication [1408-UM001](#))
- Product manuals
 - Bulletin 1408 Powermonitor 1000 User Manual, publication [1408-UM001](#)
 - Powermonitor 1000 Unit Installation Instructions, publication [1408-IN001](#)
 - PanelView Component User Manual, publication [2711C-UM001](#)

Follow These Steps

Follow these paths to configure the Powermonitor device and PanelView Component device in your energy system.

Configure a Powermonitor 1000 Device



Configure a Powermonitor 1000 Device

This section shows you how to configure parameters of a Powermonitor 1000 device by using its internal Display and Configuration web page. Certain settings are needed for the Powermonitor 1000 device to meter accurately, communicate correctly, and work with RSEnergyMetrix software properly. You will set the network configuration, Voltage mode, PT and CT ratios, demand values, and the date and time. Your application may require additional configuration.

TIP

Network configuration is provided for the Powermonitor 1000 device on the Ethernet network. For other communication options, refer to the Powermonitor 1000 Unit Installation Instructions, publication [1408-IN001](#).


Follow these steps to configure Powermonitor 1000 device parameters.

1. Launch the Internet browser on your computer.
2. In the Address field, type the IP address of your Powermonitor 1000 device.

The default IP address is 192.168.254.xxx, where xxx is the unit's ID. The default address simplifies the task of making the initial connection to the unit from a personal computer.

**TIP**


You can check the IP address of the Powermonitor 1000 device from its display or by using RSLinx Classic software and configuring an EtherNet/IP driver.



Configure RS-485

Follow these steps to configure RS-485 in a Powermonitor 1000 device.

1. Choose Configure Options > Communication > RS-485 Communications to access the RS-485 Configuration page.



2. Enter the default password of 0 or another valid password to access Edit mode.
3. Enter the following parameter values in the RS-485 Configuration table.

This configuration is used for a PanelView Component 3-inch application.


- PM1000 Protocol - DH485
- Serial Delay - 5 ms
- Baud Rate - 19200
- Serial Address - 1
- Serial Data Format - 8-1-E
- Intercharacter Timeout - 0

RS485 Configuration		
Element	Item Name	Value
0	Password Range 0 to 9999	
1	Protocol Setting 0 = DF1 Half Duplex Slave 1 = DF1 Full Duplex 2 = Modbus RTU Slave 3 = Auto Sense 4 = DH485	
2	Serial Delay (ms) Range 1 to 15	
3	Baud Rate 0 = 1200 1 = 2400 2 = 4800 3 = 9600 4 = 19200 5 = 38400 6 = 57600	
4	DF1/Modbus/DH485 Address Range 1 to 247 for DF1/Modbus 0-31 for DH485	
5	Data Format 0 = No parity, 8 data, 1 stop 1 = Odd parity, 8 data, 1 stop 2 = Even parity, 8 data, 1 stop Only 2 for DH485	
6	Intercharacter Timeout (ms) 0 = 3.5 characters Range 0 to 6553 (ms)	
7	Maximum Node Address Range 1-31	
8	Reserved Range 0	

Configure the EtherNet/IP Address

Follow these steps to configure the EtherNet/IP address of a Powermonitor 1000 device.

1. Choose Configure Options> Communication > Ethernet Communications to access the Ethernet Configuration page.



2. Enter the default password of 0 or another valid password to access Edit mode.

TIP

The password appears as asterisks (*). If you don't know the password, call Rockwell Automation technical support for assistance.

3. Enter appropriate values in the IP Address Byte fields.

For this example, the IP address is 10.10.10.1 for the first Powermonitor 1000 device.

Ethernet Configuration		
Element	Item Name	Value
0	Password Range 0 to 9999	
1	IP Address Byte a (aaa.xxx.xxx.xxx) Range 0 to 255	10
2	IP Address Byte b (xxx.bbb.xxx.xxx) Range 0 to 255	10
3	IP Address Byte c (xxx.xxx.ccc.xxx) Range 0 to 255	10
4	IP Address Byte d (xxx.xxx.xxx.ddd) Range 0 to 255	01
5	Subnet Mask Byte a Range 0 to 255	255
6	Subnet Mask Byte b Range 0 to 255	255
7	Subnet Mask Byte c Range 0 to 255	255

4. Enter the Subnet Mask and Gateway IP addresses as required.
5. Click Submit to send the parameter changes to the Powermonitor 1000 device.

TIP

You will lose communication to the Powermonitor 1000 device. You must enter the new IP address in the Address field of your web browser to re-establish communication with the device.


6. Browse to the new IP address from your web browser.

The IP address is shown on the default LCD display screen.

Configure Analog Inputs

Follow these steps to configure the Voltage mode, PT ratios, and CT ratios for the Powermonitor 1000 device. The Analog Input Set-up Parameters table on [page 17](#) shows the analog input parameters and example settings.

- 1. From the Configure Options menu, choose Analog Input to display the Analog Input Configuration page.



- 2. Enter the default password of 0 or another valid password to access Edit mode.

TIP

The password appears as asterisks (*). If you don't know the password, call Rockwell Automation technical support for assistance.

Analog Input Configuration		
Element	Item Name	Value
0	Password Range 0 to 9999	•
1	Voltage Mode 0 = Direct Delta 1 = Open Delta 2 = Wye 3 = Single Phase 4 = Demo 5 = 1PT1CT-LL 6 = 1PT1CT-LN	2
2	PT Primary Range 1 to 50000	480
3	PT Secondary Range 1 to 600	480
4	CT Primary Range 5 to 50000	600

- 3. Enter the value of the Voltage Mode you are using.
- 4. Set elements 2, 3, and 4 to configure the PT and CT parameters.
- 5. Click Submit to send the parameter changes to the Powermonitor 1000 device.

Analog Input Set-up Parameters

Parameter	Range	Default	Example Settings
Password	0...9999	0	0
Voltage Mode	0...6 0 = Direct Delta 1 = Open Delta 2 = Wye 3 = Single Phase 4 = Demo, simulated results 5 = 1PT1CT-LL 6 = 1PT1CT-LN	2	2
PT Primary	1.0...50,000	480	480
PT Secondary	5.00...50,000	480	480
CT Primary	5.00...50,000	5	600
System PF Setting	0 = Lead (-97...89) 1 = High (-85...98) 2 = Low (-52...-95)	2 = Low	2

Configure Advanced Device Parameters

Follow these steps to configure advanced demand parameters for the Powermonitor 1000 device. These settings include demand source, demand period length, and the number of demand periods to average for the demand calculation. The Advanced Device Configuration Parameters table on [page 18](#) shows the demand parameters and example settings.

- From the Configure Options menu, choose Advanced to access the Advanced Configuration page.

- Enter the default password of 0 or another valid password to access Edit mode.

TIP

The password appears as asterisks (*). If you don't know the password, call Rockwell Automation technical support for assistance.

14	Demand Source 0 = Internal Timer 1 = Status Input 2 2 = Controller Command 3 = Ethernet Broadcast	0
15	Demand Period Length (minutes) Range 0 to 99	15
16	Number of Demand Periods Range 1 to 15	1

- Set appropriate values for the demand parameters (elements 14, 15, and 16).

For this example, accept the default parameters as shown.

- Click Submit to send the parameter changes to the Powermonitor 1000 device.

Advanced Device Configuration Parameters

Parameter	Range	Default	Example Settings
Password	0...9999	0	0
Demand Source	0...3 0 = Internal Timer 1 = Status Input 2 2 = Controller Command 3 = Ethernet Demand Broadcast	0	0
Demand Period Length	0...99 min	15 min	15
Number of Demand Periods	1...15	1	1
Forced Demand Sync Delay	0...90 s	10	
Demand Broadcast Master Select	0...1	0	
Broadcast Port Number (Ethernet Setup)	300...400	300	

Configure the Date and Time

Follow these steps to configure the date and time for the Powermonitor 1000 device. The Date and Time Set-up Parameters table on [page 19](#) shows the date and time parameters, and example settings.

- From the Configure Options menu, choose Date and Time to access the Date and Time Configuration page.

Power and Energy Management Solutions
Meeting the Changing Demands for Power and Energy Management
Powermonitor 1000 Display and Configuration

Allen-Bradley
Display and Configuration Menu
Home
Display Metering Information
Display Status
Execute Commands
Configure Options
Catalog Number Breakdown
Go To ab.com

Analog Input
Date and Time
Advanced
User Configurable Table
Communication

Element	Item Name	Value
0	Password Range 0 to 9999	
1	New Password Range 0 to 9999	
	Metering Result Averaging OFF = 0 ON = 1	
3	Log Status Input Changes NO = 0 YES = 1	

2. Enter the default password of 0 or another valid password to access Edit mode.

TIP

The password appears as asterisks (*). If you don't know the password, call Rockwell Automation technical support for assistance.

3. Configure the date and time parameters accordingly.
4. Click Submit to send the parameter changes to the Powermonitor 1000 device.

Date and Time Configuration		
Element	Item Name	Value
0	Password Range 0 to 9999	0
1	Date: Year Range 2001 to 2100	2009
2	Date: Month Range 1 to 12	8
3	Date: Day Range 1 to 31	31
4	Time: Hour Range 0 to 23	7
5	Time: Minute Range 0 to 59	44
6	Time: Seconds Range 0 to 59	39
7	Time: Hundredths Range 0 to 99	46

Submit

Refresh

Date and Time Set-up Parameters

Parameter	Range	Default	Example Settings
Password	0...9999	0	0
Date: Year	2001...2100	2005	
Date: Month	1...12	1	
Date: Day	1...31	0	
Time: Hour	0...23	0	
Time: Minute	0...59	0	
Time: Seconds	0...59	0	
Time: Hundreths	0...59	0	

TIP

For a full Powermonitor 1000 LCD screen display and configuration map, see pages 30...32 of the Powermonitor 1000 Installation Instructions, publication [1408-IN001](#).

Additional Resources

Refer to [page 9](#) for a listing of product and information resources.

Notes:

System Validation and Application Tips

Introduction

In this chapter, you will configure the communication of your application. You will learn how to:

- connect a Powermonitor 1000 device to a PanelView Component terminal.
- configure RSEnergyMetrix software to properly log your Powermonitor 1000 device data.

Before You Begin


- Review the PanelView Component User Manual, publication [2711C-UM001](#)
- Optional - Install RSEnergyMetrix software (Review the RSEnergyMetrix User and Installation Manual, publication [ENEMTX-GR001](#))
- Configure Powermonitor 1000 devices, refer to [Chapter 1](#)
- Configure the PanelView Component terminal

What You Need

- Personal computer with Internet access for launching and using RSEnergyMetrix software
- RSEnergyMetrix CD, catalog number 9307-ENEMTXCD
- RSEnergyMetrix online help and Getting Results Guide, publication [ENEMTX-GR001](#)
- USB flash drive (for loading the PanelView application)

Follow These Steps

Follow these steps to verify that communication is occurring between your devices.



Powermonitor 1000 Device to PanelView Component Configuration

Loading Powermonitor 1000 Standalone Application to a PanelView Component Terminal


Follow these steps to download the Powermonitor 1000 device preconfigured PanelView Component project to 3 inch touch terminal.

1. Power up the PanelView Component 3 inch terminal and Powermonitor 1000 device.

TIP

The PanelView Component terminal is powered with a 24V DC supply. The PanelView Component HMI power wiring is illustrated in the Connected Building Block CD.

2. Verify that the PanelView Component terminal is connected to the Powermonitor 1000 device over the RS-485 network.



TIP

Powermonitor 1000 firmware revision 2.13 or later is supported. The Powermonitor 1000 device can be updated by using the ControlFlash utility. The latest upgrade can be obtained from <http://www.ab.com/PEMS/downloads.html>.

3. Verify that the Powermonitor 1000 device is configured properly for the RS-485 network.

This configuration was done on [page 14](#).

- PM1000 Protocol - DH485
- Serial Delay - 5 ms
- Baud Rate - 19200
- Serial Address - 1
- Serial Data Format - 8-1-E
- Intercharacter Timeout - 0
- Maximum Node Address - 4

4. Copy the PanelView Component application 'PM1000_C300.cha' from the Component Building Block CD to the root of the USB flash drive.
5. Plug the USB drive into the PanelView Component terminal.

The USB connection is on the back side of PanelView C300 terminal.

TIP

The application was developed for a PanelView Component touch-screen terminal only.

To transfer the application to a PanelView Component HMI, see the PanelView Component Quick Start, publication [CC-QS001](#).

Go to Config > File Manager > Source (USB) > Selected PM1000_C300.cha file, and copy it to the internal memory of the PanelView Component HMI.

6. Configure the Screensaver/Start-up application as desired from the PanelView Component HMI settings, then run the Powermonitor 1000 application file.
7. Verify that the PanelView Component terminal is reading data from the Powermonitor 1000 device.

TIP

The RS-485 TX/RX status indicators should be blinking on the Powermonitor 1000 device.


Compare the metering values from the Powermonitor 1000 LCD display or web page against the PanelView Component terminal. The start-up screen has Average Line-to-Line Voltage, Average Line Current, and Total Real Power values. Make sure that there are no asterisks '**' on the PanelView Component screen.

An asterisk '**' indicates:

- a communication error.
- the value has more significant digits than HMI applications.

This flowchart shows the PanelView Component terminal screen navigation.

PanelView Component C300 Screens Quick Navigation for Powermonitor 1000 Device



Powermonitor 1000 Device to RSEnergyMetrix Software Configuration

Overview of Devices

Devices are physical entities that RSEnergyMetrix software communicates with over a network. Setting up a device in RSEnergyMetrix software establishes communication and creates database definitions for the device.

Devices may be directly connected to the server over a network if the RSEnergyMetrix server is also on the network through an appropriate network interface and you have configured the appropriate RSLinx Classic device drivers. Devices routed through a ControlLogix gateway or RSLinx Classic gateway are also considered directly connected devices.

Device Classes

RSEnergyMetrix software uses device classes to determine how to interact with a particular device. The device class includes the device family, communication type, and specifies whether the device has a clock that can be synchronized. The device classes covered in this quick start include a Powermonitor 1000 device.

For a complete list of device classes, refer to:

- RSEnergyMetrix Getting Results Guide, publication [ENEMTX-GR001](#).
- RSEnergyMetrix Online Help provided with RSEnergyMetrix software.


Configure Communication Drivers

Before setting up devices, you need to configure the drivers required for communication. This example uses the RSLinx Classic Ethernet driver for the Powermonitor 1000 device.


Configure the RSLinx Ethernet Driver

Follow these steps to configure the RSLinx Classic Ethernet driver.


1. Open RSLinx Classic software by clicking its icon in the Windows system tray (SysTray).



2. From the Communications menu, choose Configure Drivers.




3. From the Available Driver Types pull-down menu, choose Ethernet Devices.




4. Click Add New.

5. Click OK to accept the default driver AB_ETH-1.



6. Enter the IP address of your first device (station).
7. Click Add New to enter the IP address for each additional device you want to add, then click OK.
8. Click OK when done entering IP addresses.
9. Click Close to exit the Configure Drivers dialog box.




Configure a Powermonitor 1000 Device

Follow these steps to configure a Powermonitor 1000 device.

1. Expand the Devices folder on the System tab.

2. Navigate to and select the appropriate group or domain.

In this example, select the Electricity group under the Engineering subdomain.



3. Click the Add a device link.

4. From the Parent group pull-down menu, choose a subdomain or group.

For this example, choose Electricity.

5. Check the boxes as shown.

The checkboxes vary by device type.

If the device will not be connected during configuration, clear the Enable device checkbox to avoid timeout errors.

6. From the Device class pull-down menu, choose a device.

For this example, choose Powermonitor 1000 (EM3) on EtherNet/IP.

7. Enter a name for the device.


For this example, enter Boiler House.

8. Enter the Time zone and Time sync interval.

Devices with internal clocks may be time-synched, such as Powermonitor devices and controllers.

9. Enter the communication path to the device.

For this example, the communication path to the first Powermonitor 1000 EM3 device is AB_ETH-1\10.10.10.1.



The 'Device Communications' window shows the following settings:

- Communications path: AB_ETH-1\10.10.10.1
- Comm. timeout (seconds): 5
- Comm. retries: 2
- Max. messages: 1
- ☐ Enable comm. loss alarm

10. Modify other communication settings as needed.


For details, refer to the RSEnergyMetrix software help.

11. Click Save.



The 'Add Device' dialog box contains two buttons: 'Save' and 'Cancel'.

The Boiler House device appears under Electricity.



12. If the device is connected to the network, click Test Connection to verify communication with the device.




If you see 'connection failed', try again. If the test times out, check that you entered the correct communication path in [step 9](#) and that the device is online. Try to access the Powermonitor device's web page or try to ping it from the RSEnergyMetrix server.

Copy Devices

Follow these steps to create additional devices by using the copy function. For the Efficient Industries Plant 1 example, you will use the copy function to create five remaining Powermonitor 1000 devices (Power House, Production 1, Production 2, Shipping/Receiving/DC, MCC2).

1. Select an existing device, and then click Copy.


For this example, select the Boiler House device.




2. Change the name of the copied device.

For this example, replace 'Copy of Boiler House' with 'Power House'.

3. Change the Communication path to match the device for this example.
4. If the device will not be connected during configuration, clear the Enable device checkbox to avoid timeout errors.
5. Click Save.



The Power House device appears under Electricity.




6. For this example, repeat [step 1](#) through [step 5](#) to copy the remaining Powermonitor 1000 devices.

Change the name and communication path to each device as shown in the table. Note that all devices fall under the Electricity parent group except for the MCC 2 device that is under Fuels.


Parent Group	Name	Communication Path
Electricity	Production 1	AB_ETH-1\10.10.10.3
Electricity	Production 2	AB_ETH-1\10.10.10.4
Electricity	Shipping/Receiving/DC	AB_ETH-1\10.10.10.5
Fuels	MCC 2	AB_ETH-1\10.10.10.6

Six Powermonitor 1000 devices and one Powermonitor 3000 device appear under the appropriate groups.



Creating Electric Meters in RSEnergyMetrix Software

You will now create meters for Powermonitor 1000 devices and assign tags to those meters.



Create a Powermonitor 1000 Electric Meter

Follow these steps to create a Powermonitor 1000 electric meter.

1. Click the Meters tab.

2. Navigate to and select a group to assign the meter.

For this example, select Electricity under the Engineering subdomain.

3. Click the Meters tab on the right.

4. Click the [Add a new meter](#) link.

5. Select the Parent group.

For this example, select Electricity.

6. From the Type pull-down menu, choose the meter type.

For this example, choose Electric.

7. From the Device pull-down menu, choose the device associated with the meter.


For this example, choose Boiler House.

8. Enter a meter name.

For this example, enter Boiler House Meter.

9. Click Save.

10. Confirm the meter was created in the correct group.




Add a Meter

Save Cancel

Meter Information

Parent group	--Electricity	Assigned to Group Electricity (100)
Type	Electric	
Device	Boiler House	
Name	Boiler House Meter	
Notes		
Time zone	(GMT-06:00) Central Time (US & Canada)	




Assign Meter Tags to a Powermonitor 1000 Electric Meter

You will now assign tags to a Powermonitor 1000 electric meter. For this example, Real Energy Net, Reactive Energy Net, and Real Power Demand are assigned to the Boiler House Meter.

1. Select the meter to assign tags.

For this example, select Boiler House Meter.



2. Click the Meter Setup tab.
3. Click the Add a new meter tag link.

Domain/Meter: Engineering/Electricity/Boiler House Meter
 Meter type: Electric Device class: Powermonitor 1000 (EM3)

Meter Setup

Edit Add Copy Delete

Meter Information

Type: Electric Assigned to Groups (Contribution factor %): Electricity (100)
 Device: Boiler House
 Name: Boiler House Meter
 Notes:
 Time zone: (GMT-06:00) Central Time (US & Canada)

Meter Tags

ID	Type	Name	Units	Log Rate	Address
Add a new meter tag					

4. Verify that the Meter tag type is Device.
5. From the Meter tag type pull-down menu, choose Real Energy Net.

For a Powermonitor device, the rest of the settings are autofilled.

Do not change these autofill values. Changing the values may prevent logging of the tag or cause incorrect data to be logged.

The log rate is set to the default log rate of the meter's assigned group. It is typically the utility demand interval rate.

Refer to the RSEnergyMetrix software help before changing the log rate or maximum consumption per hour.

6. Click Save.

Add a Meter Tag

Save Cancel

Meter tag type: Device
 Real Energy Net

Meter tag name: Real Energy Net
 Value type: Real Energy Net
 Log rate: 15
 Number of demand periods: 1
 Address: 16:8
 Tag format: Powermonitor 1000 Double Float
 Unit: kWh
 Number of decimals to display: 1
 Scale: 1
 Offset: 0
 Log delta reading: ☐
 Rollover value: 1000000000
 Trend log parameter: 9
 Max consumption per hour:

7. Click Add when the screen refreshes.



8. Repeat [step 4](#) through [step 7](#) to add the remaining tags:
- Reactive Energy Net
 - Real Power Demand

These are typical tags for electric meters.

9. When done, click the [Return to meter screens](#) link or the meter tag.



The tags just entered appear on the Meter Setup tab.

Domain/Meter: Engineering/Electricity/Boiler House Meter
 Meter type: Electric Device class: Powermonitor 1000 (EM3)

[Return to meter screens](#)

Meter Tag Setup

Edit Add Delete

Meter Setup

Edit Add Copy Delete

Meter Information

Type: Electric
 Device: Boiler House
 Name: Boiler House Meter
 Notes:
 Time zone: (GMT-06:00) Central Time (US & Canada)

Assigned to Groups (Contribution factor %)
 Electricity (100)

ID	Type	Name	Units	Log Rate	Address	
4	Device	Real Energy Net	kWh	15 minutes	16.8	View
5	Device	Reactive Energy Net	kVARh	15 minutes	16.14	View
6	Device	Real Power Demand	KW	15 minutes	17.0	View

For this example, these tags appear.

10. Click the Meter Data tab to verify that the meter data is being logged.

The data will not appear until the next logging interval has occurred.

Another way to check the data is to return to the Meter Setup tab and click the [Read device tags](#) link just above the list of meter tags.

You can click Current Date/Time to refresh the data.

Domain/Meter: Engineering/Electricity/Boiler House _Meter
 Meter type: Electric

Meter Data Trend Calendar Trend Meter Setup

Time zone: (GMT-05:00) Eastern Time (US & Canada)

Date/Time: 8/26/2009 2:53 PM [Get Data](#) [Current Date/Time](#)

< Page > [Enter Data](#)


15-Min Auto Data

Date/Time	Reactive Energy Net (kVARh)	Real Energy Net (kWh)	Real Power Demand (kW)
8/26/2009 2:45:00 PM	295999.9	987213.4	516.5
8/26/2009 2:30:00 PM	295963.4	987084.3	526.9
8/26/2009 2:15:00 PM	295923.4	986952.6	537.7
8/26/2009 2:00:00 PM	295885.5	986818.1	544.6
8/26/2009 1:45:00 PM	295847.8	986682	519.7
8/26/2009 1:30:00 PM	295809	986552.1	508.8
8/26/2009 1:15:00 PM	295769.6	986424.9	550.4

Copy Meters and Tags


Meters with the same device class and tags can be copied. It's a real time saver to create the first meter and its tags, then use the copy function to create the rest of the meters.

For this example, the Powermonitor 1000 electric meters all use the Real Energy Net, Reactive Energy Net, and Real Power Demand tags. You will copy the Boiler House meter and tags to create the Power House, Production 1, Production 2, and Shipping/Receiving/DC electric meters. The tags are copied with the meter.



1. Select the meter to copy.

For this example, select Boiler House under the Electricity group.



2. Click the Meter Setup tab.

3. Click Copy.

A copy of the meter is created under the selected group with the name 'Copy of Boiler House Meter'.

Domain/Meter: Engineering/Electricity/Boiler House _Meter
Meter type: Electric

Meter Data | Trend | Calendar Trend | **Meter Setup**

Meter Setup

Edit | Add | **Copy** | Delete

Meter Information

Type	Electric	Assigned to Groups (Contribution factor %)	Electricity (100)
Device	None		
Name	Boiler House _Meter		
Notes			
Time zone	(GMT-05:00) Eastern Time (US & Canada)		

Meter Tags

ID	Type	Name	Units	Log Rate	Address	
44	Derived	Real Energy Net	kWh	15 minutes		View
45	Derived	Real Power Demand	kW	15 minutes		View
49	Derived	Reactive Energy Net	KVARh	15 minutes		View

[Add a new meter tag](#)

4. Change the device to Power House.
5. Change the meter name to Power House Meter.
6. Click Save.

The copied meter and its tags are created under the Electricity group with the new name.

Domain/Meter: Engineering/Electricity/Copy of Boiler House Meter
 Meter type: Electric Device class: Powermonitor 1000 (EM3)

Meter Data Trend Calendar Trend **Meter Setup**

Edit Meter

Save Cancel

Meter Information

Type	Electric	Assigned to Groups (Contribut
Device	Power House	Electricity (100)
Name	Power House Meter	
Notes		
Time zone	(GMT-08:00) Central Time (US & Canada)	

7. Repeat [step 1](#) through [step 6](#), copy the rest of the Powermonitor 1000 electric meters.

The Real Energy Net, Reactive Energy Net, and Real Power Demand tags are automatically copied with each device.


8. Change the device name and meter name as shown in the table.

Meter	Parent Group	Device	Name
Production 1	Electricity	Production 1	Production 1 Meter
Production 2	Electricity	Production 2	Production 2 Meter
Shipping/Receiving/DC	Electricity	Shipping/Receiving/DC	Shipping/Receiving/DC Meter

For this example, the electric meter listing looks like this.

TIP

Remember that the device class must be the same in the source and copied meters, otherwise the meter tag addressing will be incorrect in the copied meter.



Additional Resources

Refer to [page 9](#) for a listing of product and information resources.

Frequently Asked Questions

Introduction

This appendix provides some frequently asked questions regarding using a Powermonitor 1000 device and a PanelView Component HMI terminal.

1. When I click the Navigation links in the PanelView Component HMI, why does it **not** bring up the correct display?
A: Calibrate the touch screen on your PanelView Component HMI. Detailed instructions to re-calibrate the touch screen can be found in the PanelView Component HMI User Manual, publication [2711C-UM001](#). (Reference [page 9](#).)
2. What does 'Data Access Error for Alias...' mean? When I see this error message, my terminal does not refresh and the data fields are filled with ' * '?
A: Answer: Check the communication media (RS-485 cable). Verify proper wiring, and communication protocol settings on both your PanelView Component HMI and Powermonitor 1000 device.
3. I do not like the PanelView Component navigation. Can I show other metering parameters on the start-up screen?
A: The PanelView Component navigation is designed with the layout as described in this quick start. To customize the application, you can use the PanelView Component emulator to add on or modify the application. Reference the PanelView Component Building Block documentation for application development.
4. How can I change the Powermonitor 1000 configuration from the PanelView Component display?
A: The PanelView Component application is for viewing metering information only. To change the Powermonitor 1000 configuration, use the web page of the product or the built-in Powermonitor 1000 LCD display.

You can also customize the PanelView Component HMI. See Question 3.

- 5.** I see some of the data for the metering parameters, but it shows ‘ * ‘ on the least significant digit. What is causing that?
- A:** The metering parameter in the PanelView Component application is programmed with a fixed number of digits. Your data value is outside of the fixed digits. You need to customize the PanelView Component application for your specific situation.

Rockwell Automation Support

Rockwell Automation provides technical information on the Web to assist you in using its products. At <http://www.rockwellautomation.com/support/>, you can find technical manuals, a knowledge base of FAQs, technical and application notes, sample code and links to software service packs, and a MySupport feature that you can customize to make the best use of these tools.

For an additional level of technical phone support for installation, configuration, and troubleshooting, we offer TechConnect support programs. For more information, contact your local distributor or Rockwell Automation representative, or visit <http://www.rockwellautomation.com/support/>.

Installation Assistance

If you experience an anomaly within the first 24 hours of installation, review the information that is contained in this manual.

You can contact Customer Support for initial help in getting your product up and running.

United States or Canada	1.440.646.3434
Outside United States or Canada	Use the Worldwide Locator at http://www.rockwellautomation.com/support/americas/phone_en.html , or contact your local Rockwell Automation representative.

New Product Satisfaction Return

Rockwell Automation tests all of its products to ensure that they are fully operational when shipped from the manufacturing facility. However, if your product is not functioning and needs to be returned, follow these procedures.

United States	Contact your distributor. You must provide a Customer Support case number (call the phone number above to obtain one) to your distributor to complete the return process.
Outside United States	Please contact your local Rockwell Automation representative for the return procedure.

Documentation Feedback

Your comments will help us serve your documentation needs better. If you have any suggestions on how to improve this document, complete this form, publication [RA-DU002](#), available at <http://www.rockwellautomation.com/literature/>.

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846