



The Trellis™ Power Insight Application

Installer/User Guide

The information contained in this document is subject to change without notice and may not be suitable for all applications. While every precaution has been taken to ensure the accuracy and completeness of this document, Vertiv assumes no responsibility and disclaims all liability for damages resulting from use of this information or for any errors or omissions. Refer to other local practices or building codes as applicable for the correct methods, tools, and materials to be used in performing procedures not specifically described in this document.

The products covered by this instruction manual are manufactured and/or sold by Vertiv. This document is the property of Vertiv and contains confidential and proprietary information owned by Vertiv. Any copying, use or disclosure of it without the written permission of Vertiv is strictly prohibited.

Names of companies and products are trademarks or registered trademarks of the respective companies. Any questions regarding usage of trademark names should be directed to the original manufacturer.

Technical Support Site

If you encounter any installation or operational issues with your product, check the pertinent section of this manual to see if the issue can be resolved by following outlined procedures.

Visit <https://www.vertiv.com/en-asia/support/> for additional assistance.

Table of Contents

1 Software introduction	1
1.1 Overview	1
2 Installation of the software	3
2.1 Installation Requirements	3
2.1.1 Hardware	3
2.1.2 Software	3
2.2 Software Download	4
2.2.1 Account Registration	4
2.2.2 Download	8
2.3 Software Installation	10
2.3.1 Trellis™ Power Insight Installation	10
2.3.1.1 Steps to install the application on the Windows operating system	10
2.3.1.2 Steps to install the application on a Linux operating system	13
2.3.2 Trellis™ Automation Agent Installation	16
2.3.2.1 Steps to install Trellis™ Automation Agent on the Windows server side	16
2.3.2.2 Steps to install Trellis Automation™ Agent on the Linux server side	17
2.4. Software Uninstall	18
2.4.1 Trellis Power Insight uninstall	18
2.4.1.1 To uninstall from a Windows operating system	18
2.4.1.2 To uninstall from a Linux operating system	18
2.4.2 Trellis™ Automation Agent uninstall	19
2.4.2.1 Windows server side uninstall setup	19
3 Software Login and Main Interface	21
3.1. Software login	21
3.1.1. User registration	21
3.1.2. User login	24
3.2. User Interface	25
4 Add UPS, rPDU	27
4.1 Overview	27
4.2 Get started quickly	27
4.2.1. Quick deployment steps	27
4.2.2. Example	27
4.3. Detailed Features	33

4.3.1.Add a device UPS.....	33
5 Device monitoring	35
5.1 Overview.....	35
5.1.1 Function Module.....	35
5.2 Get started quickly.....	35
5.2.1 Quick Deployment Steps.....	35
5.2.2.Example.....	35
5.3 Detailed Features.....	36
5.3.1.Dashboard.....	36
5.3.2.Device List.....	36
5.3.3 Device Metrics.....	41
5.3.4 Device details.....	42
5.3.5.Alarm Notifications.....	44
6 Alarm Management.....	45
6.1 Overview.....	45
6.2 Get started quickly.....	45
6.3 Detailed features.....	47
7 Alarm Notification	53
7.1 Overview.....	53
7.1.1 Functional Module.....	53
7.2 Get started quickly.....	53
7.2.1 Quick Deployment Steps.....	53
7.2.2 Example.....	53
7.3 Detailed Features.....	57
7.3.1 Contacts settings.....	57
7.3.2 Email and SMS notification settings.....	60
7.3.3.Action settings.....	61
7.3.4 Action sets settings.....	63
7.3.5 Automation Rules settings.....	65
7.3.6Alarm notification trigger logic.....	66
8 Communication Profile	67
8.1 Overview.....	67
8.1.1 Function Module.....	67
8.2 Get started quickly.....	67
8.2.1 Quick Deployment Steps.....	67

8.2.2 Example.....	67
8.3 Detailed features.....	68
8.3.1 List of communication profile configurations.....	68
8.3.2 New communication profile configuration	69
8.3.3 Device List.....	71
9 Server Shutdown Profile	73
9.1 Overview.....	73
9.1.1 Function Module.....	73
9.2 Get started quickly.....	73
9.2.1 Quick Deployment Steps.....	73
9.2.2 Example.....	73
9.3 Detailed Features	76
9.3.1 Server List	76
9.3.2 New Servers.....	76
9.3.3 List of server shutdown profiles.....	79
9.3.4 New server shutdown configuration	79
9.3.5 Alarm trigger server shutdown process.....	81
10 System Settings	83
10.1 Overview	83
10.1.1 Function Module.....	83
10.2 Get started quickly.....	83
10.2.1 Quick Deployment Steps.....	83
10.2.2 Example	83
10.3 Detailed Features.....	86
10.3.1 Events.....	86
10.3.2 System Settings.....	87
10.3.3 System Health.....	88
10.3.4 Trust Store.....	89
11 Common Troubleshooting	91

This page is intentionally left blank.

1 Software introduction

1.1 Overview

The *Trellis*™ Power Insight application is a web browser-based monitoring tool dedicated for UPS, PDU power infrastructure devices, and provides a central location to view power status, alarms and trends. It supports up to 100 critical power infrastructure devices.

1.2 Function

Trellis™ Power insight 2.3 and further versions have the following features and benefits:

- Alarm notifications via email, SMS and on-screen icons
- Shutdown protection for individual and virtual servers
- Auto discovery of devices
- Access to each UPS and rPDU web interface
- Alarm views with data that can be sorted or filtered
- Summary data of individual devices
- Redundant device support
- Dashboard views of key data points such as capacity load percentage, output current, battery percentage charge and battery time remaining
- Sequential server shutdown function to extend runtime for the most critical loads

This page is intentionally left blank.

2 Installation of the software

2.1 Installation Requirements

2.1.1 Hardware

Trellis™ Power Insight Hardware Requirements:

Minimum Configuration

- CPU: 4 core
- Memory: 8 GB
- Hard drive: 256 GB of free disk space/minimum usage space.

Recommended Configuration

- CPU: 8 core
- Memory: 8 GB
- Hard drive: 2T Available Disk Space/Recommended 2T Space Justification Description, storage data space required to run for one year, and historical data retention.

2.1.2 Software

Trellis™ Power Insight Supported 64-bit operating system:

- Microsoft® Windows® 7 and 10
- Microsoft® Windows Server® 2012 R2 and 2016
- Red Hat® Enterprise Linux® 7.1 (With graphical user interface)

Trellis™ Power Insight Supported Browsers:

- Google Chrome™ 55 or above (desktop and tablet)
- Microsoft® Edge 38 or above (desktop)
- Internet Explorer® 11 (desktop)
- Firefox® 51 or above (desktop)

Trellis™ Automation Agent Supported operating systems (for server shutdown):

- Microsoft® Windows® 7, 8.1 and 10
- Microsoft® Windows Server® 2008 R2, 2012 R2 and 2016
- Microsoft® Hyper-V Server® 2012 R2 and 2016
- Red Hat® Enterprise Linux® 6.7, 6.9 and 7.1 - 7.4

NOTE: The shutdown function also supports virtual machines:

1. VMWare ESXi 5.5, 6.0 and 6.5, But there is no need to install Trellis™ Automation Agent.

2. Hyper-V and Red Hat operating systems only support 64-bit systems.

2.2 Software Download

The following sections provide information on how to register an official account and download the Trellis™ Automation Agent and *Trellis™* Power Insight software.


2.2.1 Account Registration

If you do not have a Vertiv™ account, register on the official website of Vertiv. The latest version of the software cannot be downloaded until registration is complete.

Sign-up Steps:

1. From a web browser, navigate to www.vertiv.com and click “Support”.
2. Click “Software/Firmware Updates” > click “Software Product Downloads” > jump to a new page:

Figure 2-1



3. Find “Trellis™ Power Insight Software Downloads on the page and click. The following page is displayed.

Figure 2-2

SOFTWARE AND FIRMWARE

Trellis™ Power Insight a complimentary web-based software designed to monitor up to 100 Vertiv™ UPSs and rPDUs.

To successfully install the latest version of the application you must:

- Register on Vertiv™ software downloads portal
- Download and install the *Trellis™ Power Insight*

ATTENTION: To upgrade the *Trellis™ Power Insight*, please read the all instructions linked below.

Users with version 2.1 only MUST FOLLOW ALL UPGRADE INSTRUCTIONS outlined in the: [Power Insight User Guide](#), section 2.5 page 8.

Users with version 2.0 or lower will need to uninstall their current version of Power Insight and reinstall Power Insight 2.2.

[Register](#) [Log in](#)

Latest Releases

Product	Notes	Release Version and Date	Download
<i>Trellis™ Power Insight Application</i>		v2.2.1 March 21, 2019	Release Notes
	Installer (Windows)	v2.2.1 March 21, 2019	Power Insight 2.2.1 Windows.zip
	Installer (Linux)	v2.2.1 March 21, 2019	Power Insight 2.2.1 Linux.zip
<i>Trellis™ Automation Agent (Linux Shutdown)</i>		- October 05, 2018	trellis-automation-agent-installer-1.10.0-linux.ta MD5 Checksum
<i>Trellis™ Automation Agent (Windows Shutdown)</i>		- October 05, 2018	trellis-automation-agent-installer-1.10.0-windows. MD5 Checksum
<i>Trellis™ Automation Agent (Windows x86 Shutdown)</i>		- October 05, 2018	trellis-automation-agent-installer-1.10.0-windows_ MD5 Checksum

4. Click on the object and a pop-up window requesting for login details is displayed.

Figure 2-3

SOFTWARE AND FIRMWARE

Trellis™ Power Insight a complimentary web-based software designed to monitor up to 100 Vertiv™ UPSs and rPDUs.

To successfully install the latest version of the application you must:

- Register on Vertiv™ software downloads portal
- Download and install the *Trellis™* Power Insight

ATTENTION: To upgrade the *Trellis™* Power Insight, please read the all instructions linked below.



Users with version 2.1 only MUST FOLLOW ALL UPGRADE INSTRUCTIONS outlined in the: [Power Insight User Guide](#), section 2.5 page 8.

Users with version 2.0 or lower will need to uninstall their current version of Power Insight and reinstall Power Insight 2.2.

[Register](#) [Log in](#)

Log in.

Please login to verify your access to Software files.

	<input type="text" value="User name"/>
	<input type="password" value="Password"/>

LOG IN

WARNING: Your account will be locked after 5 incorrect login attempts. Please Click "Forgotten Username or Password" to recover your credentials, if needed.

[Forgotten Username or Password?](#)

[Create an Account](#)

5. Click “Register” in the upper right corner. The browser pops up a new window named as “Register” as shown below.

Figure 2-4

[Register](#) [Log in](#)

Create an Account for Infrastructure Management Software Downloads

User name *	Password *	
<input type="text" value="Enter user name"/>	<input type="password" value="Enter password"/>	

Confirm password *	
<input type="password" value="Confirm password"/>	

Email address *

Title	First Name *	Last Name *
<input type="text" value="please-select"/>	<input type="text" value="Enter first name"/>	<input type="text" value="Enter last name"/>

Company *

Language	Country *
<input type="text" value="English"/>	<input type="text" value="please-select"/>

Address *

City *	US State *	Postal Code *
<input type="text" value="Enter city"/>	<input type="text" value="please-select"/>	<input type="text" value="Enter postal code"/>

Telephone *	Fax Number
<input type="text" value="Enter telephone"/>	<input type="text"/>


Fill in the required fields (fields marked by red asterisk are mandatory) and click “I agree to the Terms of Use” and then click “Create Account”. The mailbox verification page is displayed.

6. Access the email address provided during the registration process and obtain the activation code from “Welcome to Vertiv Software Downloads” email.
7. Enter the activation code in the Code field and click “Submit”.
8. Registration is complete.

2.2.2 Download

1. Access the page of Section 4 according to the registration process mentioned in [section 2.2.1](#).

Figure 2-5



2. Click “Log in” in the upper right corner. A new window will pop up in the browser as shown below.

Figure 2-6

Hi, [chaotec123]
Latest Releases [Log off](#)

Log in.

Please login to verify your access to Software files.

👤

The user name field is required.

🔒

The password field is required.

LOG IN

WARNING: Your account will be locked after 5 incorrect login attempts. Please Click "Forgotten Username or Password" to recover your credentials, if needed.

[Forgotten Username or Password?](#)

[Create an Account](#)

- After entering the previously registered username and password, click the “LOG IN” button. Go to the download page, see figure as shown below.

Figure 2-7

Hi, [chaotec123]
click on UserName to manage account
[Log off](#)

Latest Releases

Product	Notes	Release Version and Date	Download
<hr/>			
Trellis™ Power Insight Application		v2.21 March 21, 2019	Release Notes
	Installer (Windows)	v2.21 March 21, 2019	Power Insight 2.21 Windows.zip
	Installer (Linux)	v2.21 March 21, 2019	Power Insight 2.21 Linux.zip
	Trellis™ Automation Agent (Linux Shutdown)	- October 05, 2018	trellis-automation-agent-installer-1.10.0-linux.ta MD5 Checksum
	Trellis™ Automation Agent (Windows Shutdown)	- October 05, 2018	trellis-automation-agent-installer-1.10.0-windows. MD5 Checksum
	Trellis™ Automation Agent (Windows x86 Shutdown)	- October 05, 2018	trellis-automation-agent-installer-1.10.0-windows_ MD5 Checksum

- Depending on the operating system that Power Insight needs to install, if the Windows operating system chooses to click Power Insight 2.3.0 Windows.zip, if the Linux operating system selects “Power Insight 2.3.0 Linux.zip”. At the same time according to Automation Agent to install the server system, if the 64-bit Windows operating system selects click “trellis-automation-agent-installer-1.10.0-windows.zip”, if it is 32-bit Windows operating system select click “trellis-automation-agent-installer-1.10.0-windows_x86.zip”. If the Linux operating system chooses to click “trellis-automation-agent-installer-1.10.0-linux.tar.gz”.
- Wait until the download is completed.

2.3 Software Installation

2.3.1 Trellis™ Power Insight Installation

2.3.1.1 Steps to install the application on the Windows operating system

NOTE: You must be logged in as a local administrator.


1. Go to the folder where Power Insight 2.3.0 Windows.zip is located.
2. Double-click on the Trellispowerinsightinstaller.exe file in the compressed file.
3. Select the preferred language from the drop-down list and click OK.

Figure 2-8




4. Click Next on the introduction screen.

Figure 2-9



5. Click the checkbox to accept the license agreement and click Next.
6. Select the radio button for a typical installation. If you select a typical installation, proceed to [Step 9](#).
- Or -
Select the radio button for customize installation and click Next.

Figure 2-10



7. Select the installation location and click Next.
8. Select the location of the data catalog and click Next.
9. Select the shortcut folder and click Next.
10. Select the parameters and click Next.

Figure 2-11





Table 2-1 Default parameter window values

Parameter	Description	Default value
Database port	The default port used by the database. Ensure that the selected port is not in use.	27017
Database admin	Administrator of the database	mtpadmin
Database admin password	The administrator's password. It is highly recommended to change this password.	admin
Database users	Owner of the database	mtpuser
Database user password	The password of the database owner. It is highly recommended to change this password.	Password
Application service port	The port on which the service runs. Ensure that the selected port is not in use.	8443

Note: If there is a port error, you will be prompted to change the port.


11. Click the “install” button in the pre-installation summary window.

Figure 2-12



12. Once installed, click Done. Shortcuts are added to the location selected during the installation process.

Figure 2-13



2.3.1.2 Steps to install the application on a Linux operating system

NOTE: You must have permissions to install the program.

1. Go to the folder where Power Insight 2.3.0 Windows.tar.gz is located.
2. Extract the installer from the “tar.gz” file.
3. Open the terminal window.
4. Navigate to the directory where the file is copied.
5. If you log in to the console as a root user, enter “./trellispowerinsightinstaller.bin”.
- Or-
If you have Superuser (SUDO) privileges, enter “sudo ./trellispowerinsightinstaller.bin”.
6. If you are logged in to the Graphical User Interface (GUI) as a root user, enter “./trellispowerinsightinstaller.bin -i GUI”. - Or-
If you have SUDO privileges, enter “sudo ./trellispowerinsightinstaller.bin -i GUI” to run the GUI installer.

Note: For the installation steps of the graphical user interface, please refer to the “Installation Steps on Windows Operating System” section. The following installation steps are based on the terminal window installation.

7. Install the dependencies and press enter key.

Figure 2-14

```
[chaotec@localhost Downloads]$ sudo ./vertiv-powerinsight-installer.bin
Preparing to install
Extracting the JRE from the installer archive...
Unpacking the JRE...
Extracting the installation resources from the installer archive...
Configuring the installer for this system's environment...

Launching installer...

=====
TrellisPowerInsight                               (created with InstallAnywhere)
=====

Preparing CONSOLE Mode Installation...

=====
Introduction
-----

Welcome to the Trellis™ Power Insight v2.3.0.0 Setup wizard.

This installer will guide you through the steps required to install the
product on your computer.

It is strongly recommended that you quit all programs before continuing with
this installation.

Respond to each prompt to proceed to the next step in the installation.
If you want to change something on a previous step, type 'back'.
You may cancel this installation at any time by typing 'quit'.

PRESS <ENTER> TO CONTINUE:
```

8. Read the End User License Agreement (EULA) and eventually enter “Y” to accept the license terms.

Figure 2-15

```
=====
License agreement
-----

Installation and use of Trellis™ Power Insight requires acceptance of the
following license agreement:

TRELLIS(TM) APPLICATION FRAMEWORK Software
End-User License Agreement

The Trellis(TM) Application Framework and the associated Application Modules
and Symbols (the "SOFTWARE PRODUCT") from Vertiv ("Vertiv") are licensed as
set forth in this EULA.
IMPORTANT: READ CAREFULLY - THIS EULA IS A LEGAL AGREEMENT BETWEEN THE COMPANY
YOU REPRESENT AND Vertiv (OR, YOU IF YOU ARE AN INDIVIDUAL END USER, THIS IS
AN AGREEMENT BETWEEN YOU AND Vertiv) FOR THE SOFTWARE PRODUCT IDENTIFIED
ABOVE, WHICH PRODUCT INCLUDES COMPUTER SOFTWARE AND MAY INCLUDE ASSOCIATED
MEDIA, PRINTED MATERIALS, AND ONLINE OR ELECTRONIC DOCUMENTATION (THE
"SOFTWARE PRODUCT"). BY CLICKING THE ACCEPT BUTTON OR BY INSTALLING OR
OTHERWISE USING THE SOFTWARE PRODUCT, YOU AGREE TO BE BOUND BY THE TERMS OF
THIS EULA. IF YOU DO NOT AGREE TO THE TERMS OF THIS EULA, THEN DO NOT INSTALL
OR USE THE SOFTWARE PRODUCT. INSTEAD, YOU MAY, IF YOU ARE THE ORIGINAL
PURCHASER OF THE SOFTWARE PRODUCT, RETURN THE UNOPENED SOFTWARE PACKET(S) AND
ANY ACCOMPANYING WRITTEN MATERIALS TO THE PLACE OF PURCHASE FOR A FULL REFUND.

1. License Grant. Subject to the payment of the applicable license fees, and
subject to the terms and conditions of this EULA, Vertiv hereby grants you the
following nonexclusive, nontransferable, nonsublicensable rights:

1.1. Single Instance License. You may install and use one instance of the

PRESS <ENTER> TO CONTINUE: █
```

9. Select the installation type. If you select a typical installation, enter “1”, press Enter key, and skip to step 9. - Or- If you choose a custom installation, enter “2” and press enter key.

Figure 2-16

```

=====
Installation type
-----

Select 'Typical' for a prompt free installation

Select 'Custom' to change default parameters

->1- Typical
   2- Custom

ENTER THE NUMBER FOR YOUR CHOICE, OR PRESS <ENTER> TO ACCEPT THE DEFAULT: █

```

10. Enter the location of the program installation directory and press “enter” key.
11. Enter the location of the data storage directory and press “enter” key.
12. Select the shortcut folder and press enter.
13. Enter the user/group, enter the username, press the “enter” key, then enter the group name, press the “enter” key.
14. Select the parameters, enter the relevant parameters, the specific parameters meaning refer to the “Default parameter values” table in the [section 2.3.1.1](#).
15. After confirming the installation path again, press “enter” key to start installation.

Figure 2-17

```

=====
Ready to install
-----

Ready to install Trellis™ Power Insight onto your system at the following
location:

  /opt/trellispowerinsight

PRESS <ENTER> TO INSTALL: █

```

Note: If there is a port error, you will be prompted to change the port.

16. After installation is complete, press enter.

Note: A `"/var/opt/trellisappmgr"` directory will be created during installation. The log files are stored in this directory.

Table 2-2 Default parameter window value

Number of parameters	Say Ming	Default value
Database port	The default port used by the database. Ensure that the selected port is not in use.	27017
Database administrator	Administrator of the database	mtpadmin
Database administrator password	The administrator's password. It is highly recommended that you change this password.	admin
Database users	Owner of the database	mtpuser
Database user password	The password of the database owner. It is highly recommended that you change this password.	Password
Application service port	The port on which the service runs. Ensure that the selected port is not in use.	8443

16. Click the installation window to begin the installation process.

NOTE: If there is a port error, you will be prompted to change the port.

17. After installation is complete, press enter.

Note: A `"/var/opt/trellisappmgr"` directory will be created during installation. The log files are stored in this directory.

2.3.2 Trellis™ Automation Agent Installation

Trellis™ Automation Agent is an application that accepts the *Trellis™* Power Insight shutdown command. To enable Server Shutdown, *Trellis™* Automation Agent must be installed on the server.

2.3.2.1 Steps to install *Trellis™* Automation Agent on the Windows server side

1. Sign into the server with administrative rights.
2. Find the downloaded installation package and unzip the file. Double-click `trellis-automation-agent-install.exe`.
3. Under the new window that pops up, select English and Chinese. For English, enter 1 and press "Enter" key.

Note: If it is Microsoft® Windows Server® or Microsoft® Hyper-V Server® operating system, after logging in, navigate to the installation file directory, enter `"trellis-automation-agent-install.exe"`, and press "Enter".

4. Read the End User License Agreement (EULA) and eventually enter "Y" to accept the license terms.

Figure 2-18

```
[chaotec@localhost Downloads]$ sudo ./vertiv-powerinsight-Installer.bin
Preparing to install
Extracting the JRE from the installer archive...
Unpacking the JRE...
Extracting the installation resources from the installer archive...
Configuring the installer for this system's environment...

Launching installer...

=====
TrellisPowerInsight                               (created with InstallAnywhere)
=====

Preparing CONSOLE Mode Installation...

=====
Introduction
-----

Welcome to the Trellis™ Power Insight v2.3.0.0 Setup wizard.

This installer will guide you through the steps required to install the
product on your computer.

It is strongly recommended that you quit all programs before continuing with
this installation.

Respond to each prompt to proceed to the next step in the installation.
If you want to change something on a previous step, type 'back'.
You may cancel this installation at any time by typing 'quit'.

PRESS <ENTER> TO CONTINUE:
```

5. Select the location of program installation directory and press “Enter” key.
6. Create an account name and password.

NOTE: The password length must be between 8-32 characters. This password will be used when the server selects a new communication rule.

7. Enter the port address and press “Enter” key.
8. Press “Enter” key to install Trellis™ Automation Agent.

2.3.2.2 Steps to install Trellis Automation™ Agent on the Linux server side

1. Sign-in to the server with administrative rights.
2. Find the downloaded installation package and unzip the file. If you log in to the console as a root user, enter “./trellis-automation-agent-install.bin”.
 - Or-
 - If you have SUDO privileges, enter “sudo ./trellis-automation-agent-install.bin”.
3. Under the new window that pops up, select both English and Chinese. Enter 1 for English and For Chinese, Enter 2.
4. Read the End User License Agreement (EULA) and eventually enter “Y” to accept the license terms.
5. Select the location of program installation directory and press “Enter” key.
6. Create an account name and password.

NOTE: The password length must be between 8-32 characters. This password will be used when the server selects a new communication rule.

7. Enter the port address and press “Enter” key.
8. Press “Enter” key to install Trellis™ Automation Agent.


2.4. Software Uninstall

2.4.1 Trellis Power Insight uninstall

2.4.1.1 To uninstall from a Windows operating system

9. Run Control Panel - Programs and Features.
10. Find Trellis Power Insight in the list of programs. Run the uninstall.
11. Click “Next”.
12. In the “Get User Input” window, if you keep the original data, click “Next”.
 - Or-
 - If you don't need to keep the data, click “Yes” and click “Next”.

Figure 2-23



13. Click Done when the process is completed.

2.4.1.2 To uninstall from a Linux operating system

1. If you are logged in to the console as a root user, enter “/<installdir>/_installation/trellisappmgruninstall”.
2. On the Delete Data window, press Enter to accept the default (No).
 - or-
 - Enter “1” (Yes) to delete the data.

Figure 2-24

```

=====
Delete data?
-----

In addition to deleting Trellis™ Power Insight
would you like to delete the data folder and all its content?

    1- Yes
   ->2- No

ENTER THE NUMBER FOR YOUR CHOICE, OR PRESS <ENTER> TO ACCEPT THE DEFAULT: |

```

3. Press “Enter” key to wait for the uninstall to complete.


2.4.2 Trellis™ Automation Agent uninstall

2.4.2.1 Windows server side uninstall setup

4. Log in to the remote server and run Control Panel- Programs and Features.
5. Find “Trellis AutomationAgent” in the list of programs. Run the uninstall.

Note: If it is Microsoft® Windows Server® or Microsoft® Hyper-V Server® operating system, after logging in, navigate to the installation file directory, enter “TrellisAutomationAgentUninstall.exe”, and press “Enter” key.

Figure 2-25



```

TrellisAutomationAgentUninstall.exe
=====
TrellisAutomationAgent                <created with InstallAnywhere>
=====

Preparing CONSOLE Mode Uninstallation...

=====
Uninstall Trellis Automation Agent
=====

About to uninstall...
Trellis Automation Agent

This will remove features installed by InstallAnywhere. It will not remove
files and folders created after the installation.

PRESS <ENTER> TO CONTINUE:

```

6. Press “Enter” key to continue and wait until uninstallation is complete.

2.5.2.2 Linux server side uninstall setup

1. Log in to the Linux server as a root user.
2. Enter the terminal, enter “/<install dir>/_installation/TrellisAutomationAgentUninstall” and press the “enter” key to run the uninstallation program.
3. Wait until uninstallation is completed.

3 Software Login and Main Interface

3.1. Software login

3.1.1. User registration

If visiting *Trellis™* Power Insight for the first time, you need to register an administrator user and password.

Sign up Steps:


1. Open a web browser on your local computer and enter "https://localhost:SERVICE_PORT." where the service port is the service port number, such as 8443.

In this example, the address is "https://localhost:8443".

- Or-

On the computer in which the application is installed, double-click the Trellis™ Power Insight Console shortcut icon.

Figure 3-1



2. To login on a remote computer, enter "https:// <remote IP address>: <service port>"; where the <remote IP address> is the IP address for the installation of Trellis™ Power Insight, and the <service port> is the service port number, for example, 8443.
3. Enter the email address you want to receive the alert notification, and then click Continue.

Figure 3-2



NOTE: The email address entered only receives alert notifications and not your account name. The default account name for the application is "admin". In addition to the default email address, users can also add different e-mail addresses to the system to receive alert notifications, specifically referring to the "other address book settings" in the "7.3.1 Contacts Settings" section.

4. Create a new password, enter the Password and Confirm Password fields. Click Continue.

Figure 3-3



NOTE: Passwords must be between 10 and 128 characters long and contain at least one capital letter, one lowercase letter, and one number.

5. Select the configuration. If you need to configure your email server in advance, click Configure the server.

- Or -

Click Skip and go to step 7.

NOTE: If the e-mail server is not configured at this time, you can also complete the configuration by accessing to the "7.3.2 email and SMS notification settings to complete the configuration".

6. Enter the IP address or host name of the e-mail server in the E-Mail Host field. Enter the email port number (the default is 25), email server account name, and password in the appropriate field. Click the Use TLS slider to enable secure communication. When complete, click Continue.

NOTE: The Use TLS button is enabled by default. When enabled, an email server account name and password is required. When disabled, an email server account name and password is not required.

Figure 3-4




7. To start the initial sign-in process from scratch, click Start Over.

- Or -

Click Continue in the next window. Complete the registration.

Figure 3-5



3.1.2. User login

You can log in once you're registered.

Sign in Steps:

1. Open a web browser on your local computer and enter "https://localhost:SERVICE_PORT." where the <service port> is the service port number, such as 8443. In this example, the address is "https://localhost:8443".

- Or-


On the computer on which the application is installed, double-click the Trellis™ Power Insight Console shortcut icon.

Figure 3-6



2. To login on a remote computer, enter "https:// <remote IP address>: <service port>"; where the <remote IP address> is the IP address for the installation of Trellis™ Power Insight, and the <service port> is the service port number, for example, 8443.
3. Enter your username (admin by default) and password, and then click Sign in. Complete your sign-in.

Figure 3-7




3.2. User Interface

The user interface contains several areas that help you manage the devices being monitored by the Trellis™ Power Insight application. The pivot bar and context menu on the left contain items that provide access to devices, alarm information, discovery configurations and administrative tools. The pivot bar and context menu can be expanded or collapsed using the menu icon at the top of the window.

Alarm notifications on the top right corner of the window are activated when SNMP traps are triggered from the device. The Profile icon, also on the top right corner of the window, is used to sign-out, set profile information and access help topics. Use the icons on the toolbar to customize each window or complete tasks.

Icons that allow you to customize the content information are static and appear on the toolbar when you access the window. Icons that allow you to complete tasks can be accessed in two ways. You can select a row in the table to view and use the available icons on the toolbar or select the vertical ellipsis icon in the row to access the same icons. In the following sections, you will be guided to select the vertical ellipsis icon to access these icons.

Figure 3-8



Number	Name	Description
1	Pivot Bar	Provides access to the Devices (devices on a network icon), Alarms (bells icon), Monitoring (heart monitor icon), Automation (process arrows icon), Administration (gear icon) and App Manager (grid icon) context menus.
2	Context menu	Provide a list of options for the selected icon in the pivot bar.
3	Extended menu icon	Expands or collapses options bars and context menus.
4	Alarm notifications	Incremental alarm notifications for warning and critical alarms.
5	Profile menu	System and user tools such as help, password reset, application and email settings for the current user.
6	Toolbar	Contains icons that allow you to perform various functions for a selected row or an entire table.

Number	Name	Description
7	Table	Details concerning the menu item selected. Each row contains a vertical ellipsis icon at the right end that expands to display functions that can be performed on the row.
8	Vertical ellipsis icon	Contains the function icons that allow you to edit, delete and run a configuration or view details.
9	Administration	Contains context menu items: <ul style="list-style-type: none"> • Event • Notification settings • System settings • User-defined properties • <i>Trellis™ System Health</i> • Address Book Contacts • Trust Store
10	Monitoring	Contains context menu items: <ul style="list-style-type: none"> • Discovery Configurations • Discovered Devices • Communication Profiles • Server Shutdown Profiles
12	Alarm	Contains context menu items: <ul style="list-style-type: none"> • Alarms • Active Alarms • Alarm History • Automation • Actions • Action Sets • Automation Rules
13	Devices	Contains context menu items: <ul style="list-style-type: none"> • Dashboard • UPS • rPDU

4 Add UPS, rPDU

4.1 Overview

The first step in running Power Insight is to add the UPS or rPDU that needs to be monitored to the device list, and when you're done, real-time data and alert information for your device is available.

4.2 Get started quickly

4.2.1. Quick deployment steps

Adding a UPS or PDU can be done in two modes:

1. Add manually
2. Search Add

4.2.2.Example

1. Add UPS manually




Select Device List in the level 1 menu  and to add a device that is UPS, click “UPSs” in the secondary menu. The page as shown below is displayed.

Figure 4-1




Click on the “+” sign in the upper right corner to go to the device configuration page.

Figure 4-2



Fill in the name of the device, manufacturer model (i.e. UPS model), monitoring configuration (communication card model), IPV4 address (IP address of the communication card) and other relevant parameters, click the next step into the communication profile page. (For specific parameters refer to the [4.3.1 section](#)).

Figure 4-3



In the communication profile page, choose communication profile from existing configuration, generally select SNMPv2, other parameters will be filled in accordingly. Then click “Save” and the entire UPS manual addition process is complete. (For specific parameters refer to the [4.3.1 section](#)).

Note: Additionally, to configure SNMP on the Power Insight, also configure SNMP on the communication card side and add the IP address of the server installed by Power Insight to the SNMP white list of the communication card. Similarly, pay attention to reading communication words and writing communication words to be consistent.

Add pDU manually




Select Device List in the level 1 menu , and if you need to add a device that is PDU, click “PDUs” in the level 2 menu. The page looks as shown below is displayed.

Figure 4-4




Click on the “+” sign in the upper right corner to go to the device Information page

Figure 4-5



Fill in the name of the device, manufacturer model (i.e. PDU model), monitoring configuration (communication card model), IPV4 address (IP address of the communication card) and other relevant parameters, click the next step into the communication profile page. (For specific parameters refer to the [4.3.1 section](#)).

Figure 4-6




In the communication file page, choose communication profile from existing configuration, generally select SNMPv2, other parameters will be filled in accordingly. Then click Save, the entire PDU manual lying process is complete. (For specific parameters refer to the [4.3.1 section](#))

Note: Additionally, to configure SNMP on the Power Insight, also configure SNMP on the acquisition card side and add the IP address of the server installed by Power Insight to the SNMP white list of the acquisition card while taking care to keep the word read and write consistent.

Auto discovery configuration


Select Monitoring  in the level 1 menu and click Discovery Configuration in the secondary menu. The page as shown is displayed.

Figure 4-1



Click on the “+” sign in the upper right corner, and the “Add device search configuration” below window will pop up.


Figure 4-8



Fill in the configuration name, network address type (IPv4 or IPv6), IP start address, IP end address 4 parameters, click “Save and run.” (Specific parameters may refer to the [4.3. Detailed Features](#)).


When the run is over, the state turns green. Refer below image.

Figure 4-9




Click on the green icon and the pop-up window shows the number of devices searched for to communicate:

Figure 4-10




If the number of monitorable devices is greater than one, click “Discovered Devices” in the level 2 (secondary) menu which displays specific communicable devices. Click the ellipsis “⋮” on the right side of the “firmware version” and click on “Monitor”.

Figure 4-11



If there is no problem, a green window pops up in the lower right corner to indicate that the device was added successfully.

Figure 4-12




Note: Additionally, to configure SNMP on the Power Insight, also configure SNMP on the acquisition card side and add the IP address of the server installed by Power Insight to the SNMP white list of the acquisition card while taking care to keep the word read and write consistent.

4.3. Detailed Features

4.3.1. Add a device UPS


Click on the first-level menu to select “Monitor”, click on “Discovery Configuration” in the secondary menu, then click on the “+” sign in the upper right corner, enter the add device UPS page, enter the following information: name (UPS name, user-customizable), manufacturer-model (actual UPS model), monitoring configuration (UPS communication card model), address (UPS IP address), description (device description, information, cannot be filled in). When you’re done, click “Next”.

Figure 4-13




For rPDUs, in addition to the above parameters, Properties section is added. Users can enter: rack (rack name, not filled), feed (feed phase A or B, cannot be filled).

Figure 4-14



Go to the second page of Add UPS and enter the following information: Select the device communication profile (which contains all the default communication profile options), the communication profile name (the name of the communication profile, which the user can customize), the protocol (SNMP protocol type, V1, V2, V3), the port (communication port, default is 161), read community (SNMP's read operation password), write community (SNMP's write operation password), time out (no response time for the operation, if the time is exceeded, the same operation will be re-performed), retries (time-out retry), enable for discovery (used for device search). When you're done, click "Save".

Figure 4-15



5 Device monitoring

5.1 Overview




After adding UPSs or PDUs they can be monitored. The Power Insight interface helps to monitor device's power parameter information (input, output, load, etc.) and environmental parameter information (temperature). If a device is not added, refer to [chapter 4](#).

5.1.1 Function Module

- Status panel
- List on devices
- Device real-time signal
- Device details
- Alert Notice

5.2 Get started quickly

5.2.1 Quick Deployment Steps

1. Ref. [4.2.1](#).
2. Quickly monitor entrances:
 - Click on the , then click **Status panel** to browse the global device status statistics.
 - Click on the , then click **UPS list** and browse the asset information and some real-time signals for all UPS devices.
 - Click on , and then click on the **PDU**, enter the PDU list and browse through the asset information and some real-time signals for all PDU devices.
 - In the list of UPS or PDU, click the button on the right side of the list and select the device details in the list, click on the pop-up box to view the device's detailed assets.
 - In the list of UPS or PDU, click the button on the right side of the list and select the device's live signal in the pop-up box to monitor the device's detailed real-time status.

5.2.2. Example

Refer [4.2.2 section](#).


5.3 Detailed Features

5.3.1. Dashboard

Each time you log in, you have an at-a-glance overview of all the devices monitored by the application via the Dashboard. Click on the list of devices in the level one directory will enter the dashboard interface by default. Dashboard (shown in Figure 5-1)

It displays status of all UPS devices on the left half portion and status of all rPDU devices on the right half portion. Above the UPS or PDU icon indicates the total number of devices that are currently monitored by the application, and below the icon indicates the number of devices in various states. The UPS device status are further divided by its mode of operation and number of alarms its generating such as “In alarm”(UPS devices with one or more active alarms), “In bypass” (number of devices that are receiving power directly from an electric utility, bypassing the UPS), “Offline” (UPS devices that are not sending data to the application), and “Battery mode” (Number of devices that are receiving power from a UPS not receiving power from an electric utility). The PDU device status are further divided by important alarms such as “In Warning” (number of rPDU devices with one or more active warnings), In Critical (number of rPDU devices with one or more critical warnings), and Offload (rPDU devices that are not sending data to the application). The pie chart on the left is a summary of the state of the device: it shows green when all devices are online and in a normal state, it shows red-green pie chart in proportion when there is an abnormal state of the devices.

Figure 5-1



Each category shown on the System Status panel is a link that directs you to a Device List window that only displays the devices in that category.

5.3.2. Device List


Select the Devices icon to access the Device List window. This window allows you to add or access devices monitored by the application. The Device List window contains the following information for each monitored power supply:

NOTE: Some categories are hidden by default. To view all categories, click the Columns Icon.

The UPS list has the following twelve columns as shown in [Figure 5-2](#).

1. Check the box: You can use this to select the device when you perform batch operations on the device.
2. Status: The real-time status of the device is displayed by icon, there are three kinds of status: normal, alarm, and offline.
3. Device name
4. Category: Product category
5. Model: Product-specific model
6. Firmware version: Firmware version of the UPS
7. Address: IP address of UPS communication card
8. Battery: UPS battery state, with three lines of information: battery remaining available time, battery drain status, percentage of remaining charge
9. Temperature: divided into degrees Celsius and Fahrenheit
10. Output: divided into three lines: output frequency, output current, output voltage
11. Output mode: Characterizes the state in which the output of UPS is in, there are four types: Normal, Off, Bypass Mode, and Battery Mode. Bypass mode indicates direct use of power supply, and battery mode indicates that UPS is powered by battery.
12. Drop-down selection box: After clicking, three selection items will pop up, device detailed information, device real-time signal, and delete. You can jump to device detailed information, device real-time signal, and delete device, respectively.

Figure 5-2




	STATUS	DEVICE NAME	CATEGORY	MODEL	FIRMWARE VERSION	ADDRESS	BATTERY	TEMPERATURE	OUTPUT	OUTPUT MODE
		ITA-123	RACK_UPS	ITA		10.169.42.1...				
		GXT5-90	RACK_UPS	GXT5	1.3.0.0	10.169.42.90	508 MIN REMAINING FULLY CHARGED 100 %	26 °C 78.8 °F	49.9Hz 0.2A 229.7V	Normal

The rPDU list has the following twelve columns:

1. Check the box: You can use this to select the device when you perform batch operations on the device.
2. Status: The real-time status of the device is displayed by icon, there are three kinds of status: normal, alarm, and offline.
3. Device name
4. Category: Product category
5. Model: Product-specific model
6. Firmware version: Firmware version of the rPDU
7. Address: IP address of rPDU communication card
8. Rack
9. Feed
10. Total energy
11. Total power
12. Drop-down selection box: After clicking, three selection items will pop up, device detailed information, device real-time signal, and delete. You can jump to device detailed information, device real-time signal, and delete device, respectively.

Common list of operations:

Search for a device: As shown in Figure 5.2, there is a search “” button in the upper right corner of the list. Click the button to display or hide the search bar. By entering information in the search bar, such as GXT5, you can filter the items in the list against the keyword GXT5 and filter out the item that contains GXT5 information. Search information supported by different lists is inconsistent. For example, the UPS list only supports searching the device names, categories, models, firmware versions, and addresses.





Column Hide: As shown in [Figure 5-3](#), clicking on the button in the upper right corner of the list  will bring up a drop-down box that lists columns that can be hidden. Click the drop-down box option to show or hide the column.  Indicates that the column is being  displayed, indicates that the column is hidden.

Figure 5-3



Item filtering: As shown in Figure 5-4, there is a filter button in the upper right corner of the list and click to display or hide the filter options bar (shown in the top left of Figure 5-4). There are two single drop-down boxes in the list options bar for selecting grouping and status. Selecting a grouping can help you group list items, as shown in Figure 5-4. In addition to selecting grouping, the other drop-down boxes are used to filter the properties of list items. As shown in Figure 5.5, the device is filtered for status properties, and only devices whose status is offline are displayed.

Figure 5-4






Figure 5-5




Batch operation: Click on the check box on the left side of the list, by selecting multiple items, the action button will appear on top of the list where the gray icons can only operate for a single item in the list and the ungrayed icon can perform the batch operation of the corresponding selected device, For example, click “🗑️” can delete the devices in bulk.

Figure 5-6



Sorting the list: Hovering an item in the list header, if there is no “🚫” icon prohibiting operation, you can sort the list by clicking the table header. The ascending arrow represents the positive sequence, and the descending arrow represents the reverse sequence, as shown in Figure 5.7, which is to sort in the forward direction based on the device name. The sorting algorithm varies depending on the data format of the column in which the header is clicked, in general, the string uses a dictionary order, the numbers are sorted from small to large, and the normal status on the top.


Figure 5-7


5.3.3 Device Metrics



In the list of UPS or PDU, click the “⋮” button on the right side of the list and select the device metrics in the pop-up box to enter the device metrics page. The Device Metrics window contains the metrics information of the selected device from the last eight hours.

Figure 5.6 shows device metrics window page of the UPS GXT5-90 UPS. The device metrics interface consists of two blocks. The top block shows the output current and the output voltage line chart for the last 8 hours. Hover the mouse on to the line chart there pops up the dialogue box to see the output current or output voltage at a specific moment. Below the chart, you can view detailed information of the device, and mouse movement on the grouping allows you to switch groups. The upper left corner of the window page shows the time stamp for the data acquisition. The number of groups and the number of data metrics within each group will vary depending on the type of device and the model of the device.

Figure 5-8




5.3.4 Device details

In the list of UPS or PDU, click the “” button on the right side of the list and select the device details in the pop-up box to enter the device details page. This window displays detailed information about the device and allows you to access the device’s web interface and the Summary tab. It also displays the servers powered by the UPS. The title shows the device name and device status, and the icon “” represents the device status is healthy.


The configuration and function of the servers powered by UPS will be described in detail in [section 9.3.1](#). The summary tab displays the device description, product line, firmware version, model name, serial number, address, and communication profile information.

Figure 5-9



Click the edit button under summary tab to edit the name and description of the device, as shown in [Figure 5-10](#).

Figure 5-10



5.3.5. Alarm Notifications



On the device details or device metrics page, click on the “alarm notifications” in the secondary directory to enter the alarm notifications interface, as shown in Figure 5.11. Alarm Notifications is a read-only window that displays which of the device alarms will trigger an email or SMS text. The e-mail and SMS columns in the list indicate whether the alert is currently allowed to send an email or text message as per rules defined in the Actions and Automated rules, the symbol  which represents that it has been allowed. Using the search feature, you can also filter alarms based on their severity and locate a specific alarm in the list.

Figure 5-11



6 Alarm Management

6.1 Overview

Alarms are the main functional modules for monitoring alarms throughout the Power Insight platform and obtaining alarm information, and users can obtain the active alarms and alarm history in the alarm module and can export the alarm list so that the user can grasp the alarm status of the equipment under the site.

6.1.1 Function Module

The Alarm includes the following function modules, each of which is detailed in this manual under [section 6.3](#)

1. Active alarm
2. Alarm history

6.2 Get started quickly

6.2.1 Quick deployment steps

To ensure that you can view the alert information, you need to:


1. View the alarm list
2. View the alarm history

6.2.2 Examples

Active Alarms

As shown in Figure 6.1, Selecting the Alarms icon provides access to the Active Alarms by default, and the severity, source address, device name, alarm name, start time, confirm time, confirm by and amount of notes appear in the active alarm list. Alarm list according to the support list of searches, filtering, column hiding functions, can refer to [5.3.2](#) universal list operation. The Active Alarms window (as shown in [Figure 6-1](#)) displays alarms that have not been cleared. Each alarm has a severity of either warning or critical, represented by an exclamation point in a yellow triangle or an x in a red circle, respectively. There's also an Information severity, represented by an "i" inside of a circle. The toolbar allows you to filter the alarm list. You can choose to display alarms from a specific time period and group them based on certain criteria. You can also retrieve the most current alarm notification using the Reload icon located on the toolbar and store notes on any alarm on the Alarm Details window.


Figure 6-1



View alert details

As shown in Figure 6-2, on the active alarm or alarm history page, click the “” button on the right side of a warning line and click to see the details.

Figure 6-2



Note: When alarm data is not available, “No data” appears on the alarm list. The purpose of the alarm confirmation button is not to end the alarm, but to stop the alarm notification. It is not allowed to end the alarm manually, only by the alarm device itself, to determine that the trigger condition for alarm is no longer present and thus automatically end an alarm.

Export alerts



As shown in [Figure 6-3](#), on the alarm list page, click the “” button in the upper right corner, enter the file name to export, select the type of an alarm, the date range, alarm severity, and the properties to export. Click the Save button.

Figure 6-3



After the export is successful, you can prompt for the export success in the lower right corner. Click to view the exports and enter the list of export records, and then click on the download button of the file you want to export, you can successfully download the exported record. The contents of the file after download are shown in [Figure 6.4](#). The header field contained in the file is consistent with the selection in [Figure 6-3](#).

6.3 Detailed features

6.3.1 Active Alarms



Select the level one menu the “” alarm icon to open the active alarm window page. The Active Alarms window (as shown in [Figure 6.4](#)) displays alarms that have not been cleared. Each alarm has a severity of either warning or critical, represented by an exclamation point in a yellow triangle or an x in a red circle, respectively. There’s also an Information severity, represented by an “i” inside of a circle. The toolbar allows you to filter the alarm list. You can choose to display alarms from a specific time period and group them based on certain criteria. You can also retrieve the most current alarm notification using the Reload icon located on the toolbar and store notes on any alarm on the Alarm Details window.

Figure 6-4




Note: When an alarm is not available, “No alarm” appears on the list. The search button in the table is orange by default, the search box is displayed by default, when you click the Search Button, the button turns black and the search box is hidden. The last time the search button was saved is saved.

6.3.2 Alarm History

Click “🔔” icon in the level one directory and select alarm history. The Alarm History window contains a list of cleared and historical alarms. The window displays details about each alarm, including the time cleared, the duration of the alarm and its severity. Additional alarm details are stored on the Alarm Details window, which is accessed by clicking View details. The Alarm Details window allows you to add notes to the alarm and view the action history.

Figure 6-5



6.3.3 View Alarm Details

There are two ways to view alert details:

1. As shown in [Figure 6-6](#), on the active alarms or alarm history page, click the “⋮” button on the right side of a warning line and click to view the details.
2. As shown in [Figure 6-7](#), click a warning in the left multi-select box, and on the top of search box will show a row selected, click the “👁️” button on the right to see the view details.

Figure 6-6





Figure 6-7



The alert details page, in addition to the properties displayed in the alarm list, also includes the add alarm notes, action history, and status records.

6.3.4 Alarm Notes




On the alarm details page, click on the notes tab page below, enter the relevant notes in the input box, and then click the “Add Note” button. Adding a successful note appears in the list of notes below, and you can click  to Edit Notes and Click  to delete Notes.


Figure 6-8



6.3.5 Action History

On the alert details page, click on the Action history Tab page below to show a history of the action. Refer to [Chapter 7](#) for the configuration of actions and automation rules.


Figure 6-9



6.3.6 Alert Status Record

On the alert details page, click on the note Tab page below to display the status record of the alarm (information such as when the alarm was generated, and the alarm ended).


Figure 6-10



6.3.7 Export alerts

On the alarms list page, click the button in the upper right corner, enter the export file name, select the type of alarm to export, the date range, the severity of an alarm, and the properties to export. Click the “Save” button.

Figure 6-11



After the export is successful, you can prompt for the export success in the bottom right corner. Click to view the Alarm exports (Figure 6-12) and enter the list of export records, and then click on the download button of the file you want to export, you can successfully download the exported record.

The contents of the file after download are shown in Figure 6-13. The header field contained in the file is consistent with the selection in Figure 6.6.

Figure 6-12




Figure 6-13

	A	B	C	D	E	F	G
1	Severity	Device Name	Alarm Name	Start Time	Confirm Time	Confirm By	Source Address
2	Critical	PDU-Test	Device Communication Lost	2020/05/19 16:13:33			10.169.104.192
3							

7 Alarm Notification

7.1 Overview

Alarms generated by the monitoring system needs to be notified to the user by mail and text message. This chapter describes how to set up these two notification methods.

7.1.1 Functional Module

The following functional modules are set for the alarm notification. For detailed introduction of each function module, please refer to [7.3 Detailed Functions](#) in this manual:

1. Email and SMS notification settings
2. Action settings
3. Action sets settings
4. Automation rules settings

7.2 Get started quickly

7.2.1 Quick Deployment Steps

Follow the below steps to setup the alarm notification:


1. Set up contacts
2. Configure the email server connection and SMS modem connection respectively
3. Set the action
4. Configure the action sets
5. Set automation rules

7.2.2 Example

Set up contact information

Click on the “admin” drop-down box in the upper right corner, and then click on the “User Profile” option. Click the edit option to enter the email address and phone number of your admin account. Refer to section [7.3.1](#) for detailed functions that can be configured with contacts.

Figure 7-1



Mail and SMS server configuration




Click on  icon, then click on the “Notification Settings” menu to enter the notification settings page, click on edit icon  in the email server connection configuration to fill the required fields, as shown in [Figure 7-2](#). click on edit icon  in the SMS modem configuration to fill the required fields, as shown in [Figure 7-3](#).

Figure 7-2






Figure 7-3



Set the action


1. Click on “🔔” icon, then click on the “Actions” to enter the Actions settings page, as shown in Figure 7-4. Click the ⋮ button on the right to edit the default email notification action or the default SMS notification action.

Figure 7-4



2. Go to the action configuration interface, as shown in Figure 7-5. Check the user admin to accept the email notification after click Save. The same way into the default SMS notification action editing interface, check the user admin to accept the SMS notification after click Save.

Figure 7-5



Configure action sets





Click on “” icon, and then click on the “Action sets” to go to the Action sets page. Click the “” button on the right to enter the Default action set editing interface, and then click on “” button brings up Add actions to set interface, as shown in [Figure 7-6](#). Add the default SMS notification action to the default action type.

Figure 7-6



Set automation rules




Click on “” icon, then click on the “Automation rules” to enter the Automation rules interface. Click the “” button on the right to enter the edit rules interface, and then select any device check box of the device and select any alarm check box of the alarm and click Save.

Figure 7-7



The quick deployment of the alarm notification is completed, and if power insight finds a new alert, it sends a text message to the admin configured phone number, as well as to the admin configured mailbox.


7.3 Detailed Features

7.3.1 Contacts settings

Contacts settings for admin account

Click on the “admin” drop-down box in the upper right corner, and then click on the “User Profile” option as shown in [Figure 7-8](#).

Figure 7-8






Enter the user profile editing interface, click the button  in the contact information, you can edit the email address, of admin, and save the phone number, click “” the drop-down button to select different countries.

Figure 7-9



Other Contacts settings






Click on “”, then click on the “Address book contacts” to enter the address book contacts page, click “” button to select edit or delete the contacts that you have added. For the general operation of the address book contacts list, please refer to [5.3.2 common List of Operations](#). All the lists in this chapter can be used for general list operation, which will not be repeated later.


Figure 7-10



In the [Figure 7-10](#), Click on “” plus symbol to enter the new contacts interface, as shown in [Figure 7-11](#). New contacts require first name, last name, contact email, and contact phone (optional). Click on symbol “” on the contact E-mails


section will pop-up Add contact E-mail window. After entering the email address click Add to add the contact email.

Figure 7-11





When you click on plus button “+” on the contact phone numbers section as shown in [Figure 7-11](#), the Add contact phone number box pops up as shown in [Figure 7.12](#) where you enter your phone type, phone number, and move slide button to activate/deactivate SMS notification, then click ADD button. After adding a phone number and email ID, click the Save button.

Figure 7-12




Note: A single contact can add multiple email slots and phone numbers. After you've added your contact email and phone number, remember to click the Save button in the contact information add interface. When you add a contact to an action's address book, all the contact's email addresses are notified if the action is to send a message. If the action is to send a text message, the contact's mobile phone number will only accept the text message if the number that initiates the SMS notification.


7.3.2 Email and SMS notification settings

Click on “” icon, then click Notification Settings menu to enter the notification settings page, click edit icon “” to configure the email server connection, as shown in Figure 7.13. Enter following information to configure the e-mail server: the host (the host IP address where the mail server is located), the port (mail server process port number), the user (the user set by the mail server), the password (password set by the mail server), use authentication, use TLS protocol, sender's mailbox (the sender address needed when the mail server sends the mail), and reply mailbox (the email address used by the mail server to accept the external mail). After the mail server configuration is configured, it is recommended to send a test email first, and then click “Save” configuration after test s successful.

Note: The user and password are not the username and password used by the host to log on, but the username and password configured by the mail server process on the host. The mail server configuration in Power Insight needs to be consistent with the parameters configured by the mail server process on the remote host. The use of authentication and the TLS protocol can enhance the security of the mail server, but the configuration of Power Insight is not effective until configuration modifications are made synchronously by the mail server process on the remote host.


Figure 7-13



In the Notification Settings interface, click the edit icon “” to configure SMS modem connection information as shown in Figure 7-14. Users need to select the following information: port (try to select the recommended port), port rate, data bit, parity code, stop bit. Before saving the configuration, it is recommended that the user to send a text message to ensure that the configuration is correct.

Note: Before you configure a SMS modem, you need to connect the SMS modem (Etek TD-8411) to the host installed by Power Insight, and then install the drivers and initialize configuration for the SMS modem. Power Insight’s SMS modem configuration should be as consistent as possible with the SMS modem initial configuration.

Figure 7-14



7.3.3. Action settings



1. Click on bell icon , then click on the Actions menu to enter the actions page, as shown in [Figure 7-15](#). The system creates the default email notification action and the default SMS notification action by default. Click the button “⋮” on the right to select edit, delete, and copy existing actions. Action role: The action that the system needs to perform when an alarm is triggered.


Figure 7-15



- Click on add icon “+” to enter the create Action interface, as shown in Figure 7-16. Enter the following information: name, action type (send a text message or email), description (optional), and recipient. The recipient can select an admin user, or the contact that the user adds to the contacts. Users can select multiple recipients.

Note: Recipient information varies with the choice of action type, and when you select the type to send a message, only the users and contacts who have configured the email address are displayed in the recipient list. The same is true of the type of text message that is sent.


Figure 7-16



As shown in Figure 7-17, Scroll down to configure the “Action Delay” (default 5 seconds, representing the delay time of action start), Retry (the number of repeated notifications when the alarm is not acknowledged), the retry interval. You can view the content of preset notifications for alarm notification input including: alarm name, device name, alarm severity, start time, end time. Scroll down to configure whether to enable end of alarm notification, and then click Save.

Note: After an alarm triggers an action, if the alarm is completed by the system within the time of the operation delay, the action will be cancelled.

Figure 7-17



7.3.4 Action sets settings





1. Click on the “” icon, then click “Action sets” to enter the Action sets page. The Action Sets context menu item allows you to group actions and configure their execution when an alarm condition is met. For example, you can group an email and SMS text notification to be sent at the same time or one after the other when an alarm is triggered. The system creates a default action sets by default, and the default action combination contains only the default message notification action. Click the “” button on the right to edit, delete, and copy the action sets.

Figure 7-18




2. Click “” to enter the New Action set interface, where the action set configuration requires the name, description, execution strategy (serial or parallel), and action list. If the selected execution strategy is serial, you also need to choose whether to continue to execute the next action when an action fails to execute.

Note: Serial execution strategy: The actions in the group are arranged in a queue order, and the actions in the queue are executed in sequence. Next action can be continued only when the execution of the previous action ends.


Note: Parallel execution strategy: All actions are started simultaneously, in no particular order.

Figure 7-19




Click the add “+” icon on Action set Actions panel popup the add actions to set window, as shown in [Figure 7-20](#). Select the actions to add to the action set and click ADD.

Figure 7-20



After you add an action to the action set actions list, you can adjust the order of the actions in the action list, as shown in [Figure 7-21](#). ^ v ^ v The four buttons represent move up, down, move to the top, and move to the bottom. Finally, remember to click Save.

Figure 7-21



7.3.5 Automation Rules settings





Click on “” icon, then click on the Automation rules menu to enter the Automation rules page, as shown in [Figure 7-22](#). The Trellis™ Power Insight application allows you to create automation rules to map action sets to an alarm. Automation rules tell the system what actions to execute when alarms are triggered. In the default Alarm Notification automation rule, any alarm on any device will trigger the Default Alarm Notification Action Set. Configure which devices which alarms can trigger which action combinations. Click the button  on the right to select edit, delete, and copy existing automation rules.


Figure 7-22



Click the  icon in [Figure 7-22](#) to enter the new rule interface, as shown in [Figure 7-23](#). Then enter the automation rules name, description, and Select the action set from the Action Set To Execute drop-down list. Finally, Select the devices to which the automated rule will be applied and Select the alarms to activate the automated rule and click SAVE.

Note: Select the device can select any device, select the alarm can also select any alarm, so that all current devices and alarms will be selected, and the new equipment will be automatically selected in the future. In this configuration, then, all alarms for all devices trigger the configuration-bound action combination. The alarm list will only show the alarm supported by the added device. Both the device list and the alarm list can be searched for list, and the alarm list can also be filtered according to the alarm severity.

Figure 7-23



7.3.6 Alarm notification trigger logic

When you complete the configuration from 7.3.1 to 7.3.5, software can trigger an alarm notification. If the output of UPS123 has an off alarm, the trigger process is as follows:

1. First check whether the existing automation rules has UPS123 selected in the device list, and at the same time check the alarm list that contain the output off alarm, if so, then execute automation rules.
2. The action set is executed, and all actions in the action sets are executed according to the execution strategy of the action set.
3. When performing an action, if the type of action is to send a text message, the text message is sent to the configured contact person in the action according to the text message content configuration in the action configuration.

8 Communication Profile

8.1 Overview

Communication profiles define how and through what methods the application communicates with devices. The *Trellis™* Power Insight application allows you to search for saved profiles and view devices that are associated with the profile you created.

8.1.1 Function Module

Communication profile configuration contains the following function modules, refer to this manual section 8.3 detailed functions for detailed information of each function module.

Communication profile configuration list

1. New communication profile
2. List of devices

8.2 Get started quickly

8.2.1 Quick Deployment Steps

The quick deployment steps for communication profile configuration are as follows:

1. New server communication configuration.

8.2.2 Example

Because the communication protocols used by the existing UPS and PDU are both SNMP V1 or SNMP V2, and the communication configurations of SNMP V1 and SNMP V2, the system has been created by default. Therefore, the communication profile of the UPS and PDU need not be considered in a rapid deployment, only the communication parameter configuration that is created for the server.

Before you can create a server communication configuration, you need to install the server shutdown agent on the server refer to [chapter 2](#).






Click on the monitoring icon “” then click Communication Profiles to enter the communication profile configuration. Click add icon “” on the communication profile configuration page to enter the new profile window, select the communication type such as windows/ VMWareESXi / Linux / Hyperos based on the server operating system, as shown in [Figure 8-2](#). After entering the communication profile name, port (the port number used by the shutdown agent installed on the server, the default is 3029, no change is required), the login name (the remote login name set by the server shutdown agent), the password (the remote login password set by the server shutdown agent), ignore the SSL authentication (because communication with the server shutdown agent temporarily does not support SSL authentication, so the user will be checked this option). After entering the above information and click Save, the deployment of the communication profile configuration is complete.

Figure 8-1




8.3 Detailed features


8.3.1 List of communication profile configurations

Click on the monitoring icon “” then click Communication profile Configuration to enter the communication profile configuration page, as shown in Figure 8.2. Click “” the button on the right to select to edit, delete, or browse the list of devices configured with that communication profile. The system has three communication profile configurations by default: SNMPv1, SNMPv2, Liebert SNMP. The list also supports common list of operations refer to [section 5.3.2](#) for more details, which are not repeated later in this chapter.

Note: Communication configuration SNMPv1 is a communication configuration that uses the protocol SNMPv1 and the default read and write communication word (public, private). Communication configuration SNMPv2 and Liebert SNMP are both SNMPv2 protocols, but communication configuration SNMPv2 reads and writes the communication words are private, respectively, and Liebert SNMP’s read and write communication words are Liebert EM.



Figure 8-2


8.3.2 New communication profile configuration

In [Figure 8-2](#), click  to enter the new profile configuration interface.

1. New communication profile configuration for SNMP protocol supported devices.


SNMPv1 or SNMPv2

Click on the monitoring icon  then click Communication Profile Configuration to enter the communication profile configuration page. Click on the add icon  to enter the new profile configuration interface, select the communication type SNMPv1 or SNMPv2, then the interface in [Figure 8.3](#) appears.



After entering the communication profile name, port, read community, write community, time out (trying to establish an SNMP connection, in seconds), retries (the number of retries after the connection failed), click Save.

You can also choose to set timeouts and retries specifically for device searches. Because device search requires efficiency and performance, specific default timeouts and retries are typically used. Here you can override the default device search configuration by clicking on enable discovery and then entering a customized timeout (seconds) and retries, click save.

Figure 8-3




SNMPv3

Click on the monitoring icon “” then click Communication Profile Configuration to enter the communication profile configuration page. Click on the add icon “” to enter the new profile configuration interface, select the communication type Is SNMPv3, then the interface appears as shown in [Figure 8-4](#).

The input configuration of SNMPv3 in Power Insight needs to be the same as the configuration of SNMPv3 of the connected device. At the same time, there are three levels of security: no authentication and no encryption, authorization and no encryption, and authorization & encryption. selecting a different level of security requires different security information to enter.



Currently, few devices connected to Power Insight use SNMPv3, so it is generally not necessary to create an SNMPv3 communication configuration.

Figure 8-4




2. New server communication profile configuration

Before you can add a server communication profile configuration, you need to install the server shutdown agent on the server refer to [chapter 2](#).



Click on the monitoring icon “” then click Communication Profile Configuration to enter the communication profile configuration page. Click on add icon “” to enter the new profile configuration interface, select the communication type such as windows/ VMWareESXi / Linux / Hyperos based on the server operating system, as shown in [Figure 8-5](#). After entering the communication profile name, port (the port number used by the shutdown agent installed on the server, the default is 3029, no change is required), the login name (the remote login name set by the server shutdown agent), the password (the remote login password set by the server shutdown agent), ignore the SSL authentication (because communication with the server shutdown agent temporarily does not support SSL authentication, so the user will be checked this option). After entering the above information and click Save, the deployment of the communication profile configuration is complete.

Note: The information in the server communication profile configuration needs to be consistent with the parameter configuration of the server shutdown agent installed by the server, otherwise the configuration doesn't work.

Figure 8-5



8.3.3 Device List

Click monitoring icon “”, then click the communication profile configuration to enter the communication profile configuration page, and finally click “” icon located on the right side of the device list pops up the window and click the Devices.

If the communication profile configuration to which the device list belongs is the configuration of the SNMP protocol, the interface shown in [Figure 8-6](#) pops up. The list of devices for the SNMP protocol is divided into two-tab pages: all discovered devices, monitored devices, and showing all IP devices that use this communication configuration. Usually we only need to care about the monitored device. For the source of the device information here, please see the automatic device discovery and manual device addition in [Chapter 4](#). If you remove a device from the list of devices, Power Insight will completely delete all information about the device.

If the communication configuration to which the device list belongs is the server communication configuration, the interface shown in [Figure 8-7](#) pops up. The interface shows which communication configurations are used on servers added to Power Insight. For the server information source, please refer to [Chapter 9](#) to add a server.

Figure 8-6





Figure 8-7



9 Server Shutdown Profile

9.1 Overview

When an alarm is received and an automated rule is applied, the application begins the designated action you set up. When the designated action is a server shutdown, the application looks for the servers powered by the UPS or rPDU and begins the server shutdown process. Server Shutdown profiles indicate for the servers which alarms and delay timers will be used to trigger a shutdown. For example, you can arrange for the servers powered by a UPS with a Load on Battery alarm to shut down later than those powered by a UPS that have a Low Battery alarm. You can also create profiles that shut down critical servers sooner than non-critical servers. The Trellis™ Power Insight application contains a default shutdown profile with three alarms to trigger a server shutdown. You can set the timer for the shutdown process to complete for each triggered alarm via the Server Shutdown Profile context menu item.

Each server can have only one Server Shutdown Profile and the profile should include all alarms that cause a shutdown from all UPSs and rPDUs that power the server.

9.1.1 Function Module

Server shutdown profile management include the following functional modules, each of which is detailed in this manual in the [section 9.3.3](#).

1. List of servers
2. New servers
3. List of server shutdown profiles
4. New server shutdown profiles

9.2 Get started quickly

9.2.1. Quick Deployment Steps

The quick deployment steps for server and shutdown management are as follows:

1. Add a new server and bind the shutdown configuration.

9.2.2 Example





If you want to add a server powered by ITA2-UPS now, Click on device icon “”, then click on the UPSs list. By clicking “” button on the far right of the ITA2-UPS list item, a small window pops up and click on the device details to enter device information where you can see the list of servers powered by UPS, click the add icon “” button in the list to open the new server page, as shown in [Figure 9-1](#), enter the server name, select the operating system type (windows / VMWare ESXi / Linux / Hyperos), enter the IP address and click next.

Figure 9-1



Then go to the second page, as shown in [Figure 9-2](#), to configure the server communication profile. Here you can choose an existing communication profile, or you can create a new communication profile on this interface. Refer to [8.3.2 section](#) explains detailed steps to configure communication profile. After the configuration of the communication, it is recommended to test the connection first, and then click Next after success. If you select whether this device is associated with another device, go to the interface shown in [Figure 9-3](#), select a different UPS or PDU device, and click Next. This allows you to connect the new server to other devices at the same time.

Figure 9-2






Figure 9-3



Go to the next step, binding the server shutdown configuration, as shown in [Figure 9-4](#). The system will help you select the default shutdown configuration by default. The default shutdown configuration contains three alarms that trigger a server to shut down: the load is battery-powered, the battery power is low, and the battery is discharged. If you need to execute a shutdown script when the server shuts down, you can browse and import shut down script from the local computer, and then click Save. After saving successfully, return to the list of servers powered by UPS. At the same time, the load of ITA2-UPS uses battery power supply, low battery power, battery discharge alarm can also trigger the server to shut down.




Figure 9-4



9.3 Detailed Features


9.3.1. Server List

Currently, *Trellis™* Power Insight does not specifically manage servers, and all server lists are based on a list of servers powered by a device. There are currently two lists: a list of servers powered by UPS and a list of servers powered by the rPDU. The structure of the two is the same. Next, take the list of servers powered by UPS as an example.


Click on device icon “”, then click on the UPSs list. By clicking “” button on the far right of the UPS list item, a small window pops up and click on the device details to enter device information where you can see the list of servers powered by UPS, as shown in [Figure 9-5](#). You can see that the server My Computer has been added. And the list contains system type, device name, address, and powered by (there may be multiple devices connected to the same server). Click on “” button right side of the list to edit and delete the server.

The server lists can also be used for common list of operations, for more details, refer to chapter 5.3.2, common list of operations. The common list of operations in this chapter are no longer repeated.

Figure 9-5




9.3.2 New Servers

Click the add icon “” button in [Figure 9-5](#) to enter the new server page, as shown in [Figure 9-6](#), Enter the server name, select the operating system type (windows/VMWare ESXi/Linux/Hyperv(via OS), enter the IP address and click next.

Note: If you select an operating system type that is VMWare, the server cannot and a shutdown script configuration for subsequent use because VMWare does not currently support shutdown scripts.

Figure 9-6



Then go to the second page, as shown in [Figure 9-2](#), to configure the server communication profile. Here you can choose an existing communication profile, or you can create a new communication profile on this interface. Refer to [8.3.2 section](#) explains detailed steps to configure communication profile. After the configuration of the communication, it is recommended to test the connection first, and then click Next after success. If you select whether this device is associated with another device, go to the interface shown in [Figure 9-3](#), select a different UPS or PDU device, and click Next. This allows you to connect the new server to other devices at the same time.

Figure 9-7






Figure 9-8



Go to the next step, binding the server shutdown configuration, as shown in [Figure 9-9](#). The system will help you select the default shutdown configuration by default. The default shutdown configuration contains three alarms that trigger a server to shut down: the load is battery-powered, the battery power is low, and the battery is discharged. You can also select New in the Select Server Shutdown configuration. This allows the new server shutdown configuration in this interface and binds to the current server by default. For details of the new server shutdown configuration, please refer to [9.3.4](#).

If you need to execute a shutdown script when the server shuts down, you can browse the shutdown script from local computer and import it, and then click Save. After saving successfully, return to the list of servers powered by UPS. At the same time, some alerts for UPS can also trigger the server to shut down and execute the script that you specified before shutting down.

Figure 9-9



9.3.3 List of server shutdown profiles



Click on monitoring icon  then click on the Server Shutdown Profiles to enter Server shutdown profiles page, as shown in [Figure 9-10](#). The system creates a default shutdown configuration by default. This configuration only binds three alarms: the load uses battery power, the battery is low, and the battery is discharged. And the default delay for the alarm is 30 seconds. Click on icon “⋮” button right side of the list to edit and delete the server shutdown configuration.


Figure 9-10



9.3.4 New server shutdown configuration


Click the add “+” button in [Figure 9-10](#) to enter the new interface of the server shutdown configuration, as shown in [Figure 9-11](#). Enter the name and description of the server shutdown configuration, and then the newly added server shutdown configuration is divided into the alarm configuration and the associated server.

Alarm configuration

As shown on the alarm tab page in [Figure 9-11](#), the alarm configuration shows all the alarms supported in Power Insight in the form of a list. Users can enable or disable the alarm by clicking . When some alarm is enabled, if the server is bound to the server shutdown configuration, and the connected power supply device triggers an alarm, and the server will be shut down. After enabling certain alarms, shutdown delay can be edited. The battery discharge alarm in [Figure 9.11](#) is enabled, and the default shutdown delay is 30 seconds, after which the shutdown delay can be modified. The maximum shutdown delay is 8 hours. The effect of shutdown delay: When an alarm is triggered, the server shutdown is delayed for a period of time.

Note: After the alarm is triggered, during the shutdown countdown, if the alarm is ended by the system, the shutdown countdown is canceled, and the server will not be shut down.

Figure 9-11




Associated Server

As shown in Figure 9-12, the server lists all the servers in the current system, showing the name, address, shutdown profile (the shutdown configuration file currently bound to the server). Click the association button in the last column of the list to associate or untie the server for the list item with the current server shutdown configuration. Click Associate all servers or untie all servers with the current shutdown configuration.

Note: After you configure an alarm and associated server, remember to click the save button for the changes to take effect. When you click the association button to untie it, the shutdown file bound to the server will be restored to its previous state. (empty before unbound).

Figure 9-12



9.3.5 Alarm trigger server shutdown process

If the battery discharge alarm for UPS123 is triggered, the server shutdown process is as follows:

1. Find all the servers that UPS123 is connected to and the shutdown configurations together they bind.
2. Check that battery discharge alarms are enabled in the server's shutdown configuration.
3. If step 2 is established, the countdown is made to the shutdown delay of the battery discharge warning in the server shutdown configuration. The server shuts down at the end of the countdown. If the battery discharge alarm for UPS123 is ended by the system during the countdown, the shutdown process is ended, and no shutdown is carried out.

Note: The server shutdown process includes: shutdown delay countdown, execution of shutdown script, execution of server shutdown. If more than one UPS is connected to the same server, the server will trigger the shutdown process only if all UPS is in an alert state and the active alert is enabled in the server's shutdown configuration. In the above case, the server will shut down only if the server shutdown process triggered by at least one alert in all UPS has completed the countdown.

This page is intentionally left blank.

10 System Settings

10.1 Overview

System settings are where *Trellis™* Power Insight to view all event records, configure notification messages, text messages, security settings, user-defined properties, system diagnostics, contacts, and trust certificates.

10.1.1 Function Module

The system settings include the following functional modules:

1. Event
2. Notification settings
3. System settings
4. User-defined properties
5. Trellis System health
6. Address book contacts
7. Trust store

10.2 Get started quickly

10.2.1 Quick Deployment Steps

1. List of events
2. System settings
3. System health
4. Trust store

10.2.2 Example

1. List of events




Click on Administration icon  , then click “Events” in the secondary menu. A list of all user actions and device actions is displayed on the following page: (specific parameters reference [10.3.1](#)).

Figure 10-1



Click on “Details” on the right of “Source Name” to see the specific information of the operation.

Figure 10-2



2. System Settings




Click on Administration icon “”, then click System Settings in the secondary menu displays session timeout configuration as shown in [Figure 10-3](#) (Specific parameter stake [10.3.2](#)).

Figure 10-3




Click on the “” symbol in the upper right corner to edit the time. Save after editing to take effect.

3. System Health

Click on Administration icon “”, then click Trellis system Health in the secondary menu. Some of the statuses of the server situated by Power Insight are displayed on the following page: (specific parameters reference [10.3.3](#)).

Figure 10-4



4. Trust Store



Click on Administration icon “10.3.3).

Figure 10-5




10.3 Detailed Features

10.3.1 Events

Click on Administration icon “

The *Trellis™* Power Insight application records each action or event that occurs in the application. Events are grouped in categories that identify each event with a time/date stamp. They are categorized as Audit Events, Device Events, System Events, System Events-Administration, Authentication and User Profile Events and Application Level Events. Each event has a severity level of informational, warning or critical. You can also add or remove columns, filter to show only the events that are important to you and retrieve detailed information about each event listed under the link in the Details column.

Figure 10-6


10.3.2 System Settings


The application's system settings are used to configure the login session timeout in minutes for the application. Changes to reduce or extend the amount of time a user can remain logged in to the system are applied after the next log in.

To set a session timeout:

1. Click the Administration icon and click System Settings.
2. Click the Edit icon on the upper right corner of the window.
3. Enter the number of minutes in the Session Timeout field and click SAVE.

Note: Session timeouts range from 1 to 1440 minutes.


Figure 10-7



10.3.3 System Health

The *Trellis™* System Health window displays a visual dashboard illustrating how the host system running the *Trellis™* Power Insight application is functioning. This window provides information on how many requests per second are being filtered through the computer. It also displays the number of processors in the computer and the total accumulated time the computer has run without interruption.

Figure 10-8



10.3.4 Trust Store

The Trust Store allows you to add, delete or review security certificates. The content includes a list of the current certificates and provides each certificates' type, size, date of validation and date it is added to the application.


To add a security certificate:

1. Click the Administration icon and click Trust Store.
2. Click the Add icon and enter the name of the certificate in the Name field.
3. Click Browse, select a certificate file and click Add Certificate.

To delete a security certificate:

1. Click the Administration icon and click Trust Store.
2. Locate the contact information, click the vertical ellipsis icon in the same row and click Delete.
3. In the Confirmation window, click DELETE.

Figure 10-9



This page is intentionally left blank.

11 Common Troubleshooting

Number	Description	Reason	Solution
1	Uninstallation of <i>Trellis™</i> Power Insight is fails in Windows	A Power Insight uninstall failure causes program files and database files to remain on disk.	<ol style="list-style-type: none"> 1. Enable Windows to “show hidden files and folders” function. 2. Delete the Power Insight program folder with the default path of C:\program Files\TrellisPowerInsight. 3. Delete the Power Insight database folder with the default path is C:\Users\Default\AppData\Local\TrellisPowerInsight. 4. Delete the Power Insight registry folder with the path is c:\Program Files\Zero G Registry.
2	After updating Windows 10, <i>Trellis™</i> Intelligence Engine data is lost.	If postgresQL's default data directory is C:\Users\Default will be overwritten by C:\Users\default.migrated in the process of updating Windows 10.	<ol style="list-style-type: none"> 1. Log in as a Windows user with administrative privileges 2. Find \HKEY_LOCAL_MACHINE\SYSTEM\CurrentControl-Set\Services\postgresql-x64-9.5 Register entry 3. Click “ImagePath” to change the default data directory to C:\Users\Default 4. Restart the following services in “Services”: <ol style="list-style-type: none"> 1) postgresql-x64-9.5 2) TRELLIS Intelligence Engine MSS Engine Service 3) Trellis Application Framework
3	<i>Trellis™</i> Power Insight Linux version failed to install under Red Hat (7.5, 7.6 or 7.7 repository).	The installation package for the Power Insight Linux version does not contain related third-party dependencies.	<ol style="list-style-type: none"> 1. Power Insight is connected to the World Wide Web when installed, and third-party library files are automatically downloaded when installed. 2. First install the following dependencies in various ways: <ol style="list-style-type: none"> 1) net-tools. 2) psmisc. 3) log4cpp. 4) jsoncpp. 5) net-snmp. 6) Openssl. 7) Postgresql. 8) postgresql-contrib. 9) postgresql-server. 10) libpqxx. 11) glibmm24. <p>After that install.</p>
4	<i>The remote Trellis™ Automation Agent installation is completed and was unable to communicate with Trellis™ Power Insight.</i>	Windows or Linux Firewall turns off the communication port 3029 by default (used by <i>Trellis™</i> Automation Agent).	Turn off the firewall or open the 3029 port of the remote computer.

This page is intentionally left blank.

Connect with Vertiv on Social Media



<https://www.facebook.com/vertiv/>



<https://www.instagram.com/vertiv/>



<https://www.linkedin.com/company/vertiv/>



<https://www.twitter.com/vertiv/>

