

DEPARTMENT OF HEALTH AND HUMAN SERVICES FOOD AND DRUG ADMINISTRATION					
DISTRICT ADDRESS AND PHONE NUMBER One Montvale Avenue Stoneham, MA 02180 (781) 587-7500 Fax: (781) 587-7556		DATE(S) OF INSPECTION 2/6/2018-2/27/2018* FEI NUMBER 3004483427			
NAME AND TITLE OF INDIVIDUAL TO WHOM REPORT ISSUED Hilary Thibault, Pharmacist in Charge					
FIRM NAME Lynnfield Drug, Inc. dba Freedom Fertility Pharmacy		STREET ADDRESS 12 Kent Way, Suite 120F			
CITY, STATE, ZIP CODE, COUNTRY Byfield, MA 01922-1221		TYPE ESTABLISHMENT INSPECTED Producer of Non-Sterile and Sterile Products			
This document lists observations made by the FDA representative(s) during the inspection of your facility. They are inspectional observations, and do not represent a final Agency determination regarding your compliance. If you have an objection regarding an observation, or have implemented, or plan to implement, corrective action in response to an observation, you may discuss the objection or action with the FDA representative(s) during the inspection or submit this information to FDA at the address above. If you have any questions, please contact FDA at the phone number and address above.					
DURING AN INSPECTION OF YOUR FIRM I OBSERVED: OBSERVATION 1 Disinfecting agents and cleaning pads and cleaning wipes used in the ISO 5 classified aseptic processing areas were not sterile. Specifically, your firm cleans the interior of the ISO-5 classified (b) (4) located within your sterile cleanroom suite using (b) (4) prior to the aseptic production of drug products. Your firm uses non-sterile wipes (b) (4) wipes) to perform this cleaning process. There has been no assessment related to the use of non-sterile wipes in the ISO-5 classified area where aseptic processing occurs.					
OBSERVATION 2 You had inadequate HEPA filter airflow over the area to which sterile product was exposed. Specifically, on April 12, 2017, your firm performed an air pattern analysis (smoke study) of the sterile cleanroom suite and ISO-5 classified areas. The smoke studies conducted within the ISO-5 classified areas were inadequate as the smoke used was faint and intermittent. The ISO-5 classified areas were not					
SEE REVERSE OF THIS PAGE		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;"> EMPLOYEE(S) SIGNATURE John P Mistler, Investigator </td> <td style="padding: 5px; text-align: center;"> DATE ISSUED 2/27/2018 </td> </tr> </table> John P Mistler Investigator Signed By: 2001294055 Date Signed: 02-27-2018 08:44:58 X		EMPLOYEE(S) SIGNATURE John P Mistler, Investigator	DATE ISSUED 2/27/2018
EMPLOYEE(S) SIGNATURE John P Mistler, Investigator	DATE ISSUED 2/27/2018				
FORM FDA 483 (09/08) PREVIOUS EDITION OBSOLETE PAGE 1 OF 2 PAGES					

DEPARTMENT OF HEALTH AND HUMAN SERVICES FOOD AND DRUG ADMINISTRATION			
DISTRICT ADDRESS AND PHONE NUMBER One Montvale Avenue Stoneham, MA 02180 (781) 587-7500 Fax: (781) 587-7556		DATE(S) OF INSPECTION 2/6/2018-2/27/2018*	
		FEI NUMBER 3004483427	
NAME AND TITLE OF INDIVIDUAL TO WHOM REPORT ISSUED Hilary Thibault, Pharmacist in Charge			
FIRM NAME Lynnfield Drug, Inc. dba Freedom Fertility Pharmacy		STREET ADDRESS 12 Kent Way, Suite 120F	
CITY, STATE, ZIP CODE, COUNTRY Byfield, MA 01922-1221		TYPE ESTABLISHMENT INSPECTED Producer of Non-Sterile and Sterile Products	
certified under dynamic conditions and unidirectional airflow was not verified under operational conditions. The smoke studies did not include the transfer of starting components and materials into the ISO-5 classified areas, transfer of in-process products into a sterile (b) (4) or transfer of product into final container closure.			
*DATES OF INSPECTION 2/06/2018(Tue), 2/08/2018(Thu), 2/09/2018(Fri), 2/12/2018(Mon), 2/13/2018(Tue), 2/15/2018(Thu), 2/21/2018(Wed), 2/27/2018(Tue)			
SEE REVERSE OF THIS PAGE	EMPLOYEE(S) SIGNATURE John P Mistler, Investigator		DATE ISSUED 2/27/2018
	John P Mistler Investigator Signed By: 2001294085 Date Signed: 02-27-2018 08:44:58 X		
FORM FDA 483 (09/08)		PREVIOUS EDITION OBSOLETE	PAGE 2 OF 2 PAGES

INSPECTIONAL OBSERVATIONS