



Certificate of Compliance

Certificate: 70128984

Master Contract: 179014 (LR 80849)

Project: 70128984

Date Issued: 2017-04-26

Issued to: Schneider Electric Industries S A S
Power Business Unit / FLV
Electropole/EYBENS
31 rue Pierre Mendes France
Grenoble Cedex, 38050
FRANCE
Attention: Christophe Chabert

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ronald Tateishi*
Ronald Tateishi

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breakers, Types C60BP and C60BPR, ratings as follows:

1-pole: 0.5 to 63A, 240V ac max, 60V dc max; 0.5 to 35A, 277V ac max.

2-pole: 0.5 to 25A, 125V dc max; 0.5 to 35A, 480Y/277V ac max; 0.5A to 63A, 240V ac max.

3-pole: 0.5 to 35A, 480Y/277V ac max, 0.5A to 63A, 240V ac max.

Notes:

1. These circuit breakers are suitable for use with copper conductors only.



Certificate: 70128984

Master Contract: 179014 (LR 80849)

Project: 70128984

Date Issued: 2017-04-26

2. These circuit breakers may be marked with interrupting ratings in maximum RMS Symmetrical Amperes as follows:

Voltages		Ratings	
		0.5A up to 35A	40 up to 63A
120V 1P	AC	14 kA	10 kA
240V 1P	AC	14 kA	10 kA
277V 1P	AC	10 kA	-
240V 2P&3P	AC	14 kA	10 kA
480Y/277V 2P&3P	AC	10 kA	-
60V 1P	DC	10 kA	10 kA
125V 2P	DC	10 kA*	-

*Ratings 0.5 up to 25A

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 70128984

Master Contract: 179014 (LR 80849)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70128984	2017-04-26	Original Certification.