

Emerson Climate Technologies GmbH
 Am Borsigturm 31
 D-13507 Berlin

EU DECLARATION OF CONFORMITY

We hereby declare under our sole responsibility that the following products

AMI-1 followed by MM, SM, FM or SS 1)	AMI-2 S 1)	AMI-3 S 1)	MIA 1)	MIA 1) - FLR (for R290)	CIA 1)
--	-------------------	-------------------	---------------	-----------------------------------	---------------

1) followed by number indicates size of fitting in inches or in millimeters

comply with the basic requirements of following **EU Directives**:

- Pressure Equipment Directive 2014/68/EU**

Fluid Group 2 according to PED ²⁾		Fluid Group 1 according to PED ²⁾	
DN ≤ 32	DN > 32	DN ≤ 25	DN > 25
Above listed products are designed and manufactured in accordance with the sound engineering practice (Article 4.3) of a Member State and shall not bear the CE mark.	Above listed pressure equipment comply with the requirements of the Pressure Equipment Directive 2014/68/EU.	Above listed products are designed and manufactured in accordance with the sound engineering practice (Article 4.3) of a Member State and shall not bear the CE mark.	Above listed pressure equipment comply with the requirements of the Pressure Equipment Directive 2014/68/EU.
Conformity assessment: not applicable	Conformity assessment: Category I – Modul A (Internal production control)	Conformity assessment: not applicable	Conformity assessment: Category I – Modul A (Internal production control)

2) for the full list of refrigerants see Operating Instructions

Applied harmonized standards:

EN 378-2: 2016 Refrigerating systems and heat pumps - Safety and environmental requirements. Parts 2: Design, construction, testing, marking and documentation.

EN 12178: 2016 Refrigerating systems and heat pumps – Liquid level indicating devices – Requirements, testing and marking.

Signed for and on behalf of Emerson Climate Technologies GmbH:



Matthew Irons (Vice-President Engineering)
 Aachen, June 01, 2020