

ValveLink™ Mobile Software



ValveLink Mobile software lets you configure, calibrate, and troubleshoot FIELDVUE™ DVC6200, DVC6200f, DVC2000, DVC6000, and DVC6000f digital valve controllers using Emerson's AMS Trex™ Device Communicator or an Emerson Field Communicator. See the table below for hardware requirements. Diagnostic and configuration data collected using ValveLink Mobile software can be transferred to ValveLink Solo, ValveLink SNAP-ON™, ValveLink DTM, or ValveLink PLUG-IN for PRM® applications to be analyzed and archived.

Hardware Requirements

AMS Trex Device Communicator	The HART® or FOUNDATION™ Fieldbus communicator needs to be licensed for ValveLink Mobile software and licensed for HART or Fieldbus communications. Upgrade studio is required to be installed to use the Trex communicator file transfer utility to create export files, which can be imported into ValveLink software.
475 Field Communicator	Easy Upgrade option and System Software Version 3.8 are required to install ValveLink Mobile 6.1. Requires Bluetooth® or an IrDA® interface on the PC to transfer data files. To transfer data files using Bluetooth, the Field Communicator must be ordered with the Bluetooth option. Both HART and FOUNDATION™ fieldbus communications are supported.
Note: 475 Field Communicators are no longer available for sale and software updates will not be supported after October 2020.	



AMS Trex Device Communicator



475 Field Communicator

Installation

AMS Trex Device Communicator

ValveLink Mobile is automatically installed and unlocked when the device is registered and ValveLink Mobile is licensed.

Field Communicator

ValveLink Mobile 6.1 on Field Communicators v 3.8 or 3.9 must be updated using the Card Updater Utility found in [Easy Upgrade for the 475 Field Communicator](#) (available at [Emerson Handheld Communicators Support](#)).

Connecting to the Digital Valve Controller

The Trex communicator or Field Communicator may be connected to the loop wiring or directly


to the digital valve controller. To connect directly to the digital valve controller, attach the clip-on wires to the Loop + and - terminals located in the digital valve controller terminal box.

Launching ValveLink Mobile Software

Select the ValveLink Mobile icon from the main menu to launch the software. Select HART or FOUNDATION Fieldbus communications to start a session.

Establishing a Connection

With ValveLink Mobile software, you can navigate through the menu structure without being connected to a device. This can be used to explore the menu structure, review diagnostic data, or transfer diagnostic data files to a PC while off-line.




Home Screen

Select the Fieldbus or HART **Connect** icon from the home screen to communicate with a field instrument.

Navigation Tips

List controls are scrolled with grab-and-drag input as shown in the list control navigation screen shot.

Once you find a variable that you want to change, you can hit the selection button (>). The selection button may not be visible if you are not connected to a device. Parameters that cannot be changed will have a  symbol next to the selection button. This will usually happen when the instrument mode is In Service for HART devices or AUTO for fieldbus devices.





List Control Navigation

The command bar located at the bottom of the screen has two soft keys. The left Done soft key is used to go back one screen. The right soft key displays instrument mode (In Service, Out of Service, or Not Connected for HART devices; AUTO, MAN, OOS, or Not Connected for fieldbus devices). Select this key to change the instrument mode.

Most tasks will display a green highlighted bar to indicate that the task has completed successfully. For off-line diagnostic tests, wait for the green **Completed** highlight to appear on the graph before moving on to the next task.

Graph Controls


Graphs are displayed in real time or statically after a test has completed. Graph areas can be zoomed in by dragging a selection rectangle around the desired region of interest. Axes can be translated by grabbing the scale and sliding it to the desired position. Zooming and translation are shown in the figure below. To return back to the default view, tap the graph.

**Graph Zoom and Translate Controls****Graph Crosshairs and Coordinates**

When graphs are being drawn in real time, you can zoom in on the data or translate the axes. When this occurs, updates to the display will be paused but data will continue to be collected in the background. Tap the graph to restart the real time display.

Crosshairs can be displayed by selecting the directional pad (up, down, left, right arrows) "Enter" or Checkmark key until the crosshairs appear. Crosshairs can be moved by grabbing and dragging any point on the screen. X-Y coordinates are displayed in the lower right corner. To clear the crosshairs, press the directional pad "Enter" or Checkmark key again.

PD graphs can display up to four variables on two graphs. The second graph can be viewed by grabbing a graph anywhere except the y-axis scale and sliding the display up or down. Alternatively, graphs can be moved by pressing the up or down directional pad arrow keys.


**PD Real Time Graphs**

ValveLink Mobile File Transfer on AMS Trex Device Communicator

Connect your Trex communicator to the PC you wish to export the files to with the USB connection.


Note

Ensure ValveLink Mobile software is closed and will not be accessed for the entirety of this transfer.




Transfer ValveLink Mobile Dataset

Navigate to Trex File Transfer Utility on the PC.



Note

Upgrade Studio must be installed from the Trex installation CD before you can transfer files from the Trex.



Click the Transfer button next to ValveLink Mobile Dataset.


These .exp files can then be individually imported into ValveLink software.

Note


This process does not delete the files from the Trex communicator. Files must be deleted from the ValveLink Mobile application, at Utilities > Data Set Explorer.

AMS Trex Powering the Loop


1. From the main menu, click on Connect.




2. During the connect stage, select the top right button (of the bottom four) to power the device.



3. In the Communication Settings page select the > button for the Provide Power from Trex option.



4. On the Power Settings page select either Power Positioner with 4mA, 20mA, or other mA value for HART devices (shown below), or Yes for Fieldbus devices.



5. If you select Power Positioner other mA value, you will be asked to enter a mA value between 4.00 and 20.00 with the keypad. Once you've entered your value, click OK to return to the previous page.

Current

12.00 mA Del

Enter a value between 4.00 and 20.00.

1 2 3

4 5 6

7 8 9

• 0 +/-

Cancel OK

6. Click OK to return to the initial Connect page.

Communication Settings

Mode Analog >

Multidrop Address 0 >

Power Settings

Provide Power from Trex Yes >

Current 12.00 mA >

Power will be checked and enabled on connect

Cancel OK

7. Click Connect to connect and begin powering your device.

Click Connect to start

Power will be provided to the valve when connect is pressed. Warning! The valve may move when power is enabled!

☐ Read Only Analog / 12.00 mA

Done Connect

8. Information will load on the screen. Once the process completes, you should see a green bar indicating you've successfully connected to the device. Click Done to return to the main menu.

Hardware Revision:

HART Revision:

Device ID:

HART Tag:

Long Tag:

Instrument Mode:

Instrument Level:

Relay Type:


Last Calibration Date:

Connect task completed


☐ Read Only Analog / 12.00 mA

Done Connect

9. If connected to a HART device, your main menu will now have a Power icon.



10. Click on the Power icon to adjust the current provided to your device.

**Note**

The Device Communicator Plus Communication Module is required to power the loop through ValveLink Mobile.

Menu Structure



CONNECT

Connect is the starting place for establishing communications with a FIELDVUE instrument. Select Connect to access valve tag, last calibration date, and other relevant connection information. For fieldbus devices, the instrument must be at a permanent address to connect and change parameters.



SETUP



Setup Wizard

Use the Setup Wizard to guide you through initial instrument setup and calibration. All fields must be filled in before you can select **Apply** to download settings to the instrument. The instrument mode must be **Out of Service (HART)** or **MAN (fieldbus)** before the Setup Wizard can download parameters to the instrument.



Initial Setup

Fundamental instrument parameters, such as Zero Power Condition. Once these have been established, they generally do not need to be changed.




Tuning

Parameters for tuning travel and pressure servo controllers.



Response

Parameters for configuring rate limits, input filter time constant, and input characteristic.



Travel / Pressure Control

Parameters for configuring cutoffs, travel limits, and pressure fallback.



Alerts

Parameters for enabling alerts and setting alert thresholds. Alert states can be viewed using **Status**.



SIS (HART)

Parameters for configuring and enabling SIS Tier (Safety Instrumented Systems) alerts, values, and diagnostics (Partial Stroke Test).



FST / PST (Fieldbus)

Parameters for configuring and enabling PST Tier (Partial Stroke Test) alerts, values, and diagnostics (Partial Stroke Test)



Detailed Setup



Engineering Units

Use Engineering Units to set instrument units. The display of operational parameters in ValveLink Mobile will be consistent with units configured in the instrument.



Write Protection

Used to enable or disable Write Protection in the instrument. When enabled, Write Protection prevents configuration and calibration changes to the instrument.



Save Detailed Setup

Save Detailed Setup is used to save a record of all device parameters. Saved data can be viewed in Data Set Explorer.



Spec Sheet

Reference list detailing valve body, actuator, and trim construction. Used to provide context for diagnostics.



CALIBRATION



Auto Travel Cal

Auto Travel provides guided procedures for calibrating travel control and pressure fallback.




Manual Travel Cal

Manual Travel provides guided procedures for manually calibrating travel feedback. Parameters for pressure fallback can be manually set in Detailed Setup.



Partial Stroke Cal

Partial Stroke Calibration provides a routine to set the Partial Stroke Test parameters.



Travel Sensor Adjust

This routine allows for adjusting the magnetic array to ensure it is in the appropriate position for a full travel range reading.



SOV Calibration

Solenoid Valve Test calibration initiates a routine to configure SOV Test parameters.



STATUS

- Monitor Tab** Displays operating parameters, such as input current, travel, and supply pressure.
- Alerts Tab** Summarizes instrument alert states:
-  Alert ON
 -  Alert not enabled
 -  Alert OFF
 -  Alert not read
- Device Info Tab** Shows tag, firmware revision, device ID, etc.
- Save Data Tab** Save status monitor information. Results can be viewed in Data Set Explorer or transferred to desktop computer using Wireless File Transfer.



DIAGNOSTICS



Total Scan

Pressure versus travel, travel versus time, and pressure versus time graphs are available using Total Scan. This is an off-line test that must be run with the instrument mode **Out of Service** (HART) or **MAN** (fieldbus). Total Scan tests are used to estimate friction, bench set, and seat load.



Step Response



Stroking Time

Response to target set point values of 0%, 100%, and 0%. Used to estimate the time required to fully open and fully close a valve.

**25% Step Study**

Dynamic response to target set point values of 0%, 25%, 50%, 75%, 100%, 75%, 50%, 25%, and 0%. Used to check linearity.

**Large Step Study**

10%, 20%, ..., 80% steps from a baseline of 10%. Used to assess stability of valves with complex accessory configurations.

**Performance Step Test**

Bidirectional steps with amplitudes of 0.25%, 0.5%, 1%, 2%, 5%, and 10%. Used to estimate valve dead band and dynamic response.

**PD One Button**

Preconfigured, on-line diagnostic tests for identifying faults. Must be run with the instrument mode set In Service.

**PD Traces**

Real time traces of any device variable. Must be run with the instrument mode In Service for HART devices. PD traces can be run in MAN or AUTO for fieldbus devices. PD Traces are especially useful for tracking down limit cycles or other atypical behavior.

**Partial Stroke**

Run the Partial Stroke Test and analyze the data during and after the test.

**LCP Utilities**

Tools to view and test the Local Control Panel.

**Upload Diagnostics (Fieldbus)**

Read diagnostics stored on the device and upload to ValveLink Mobile.



UTILITIES



Data Set Explorer

Select Data Set Explorer to view all diagnostic data by tag.



Wireless File Transfer (475 Field Communicator only)

Wireless File Transfer combines selected tag data into a single *VLMobile.exp* file that can be transferred to a desktop computer using IrDA or Bluetooth and imported into ValveLink.

Most desktop Bluetooth software will guide you through the file transfer process. However, If you have the Microsoft Bluetooth software stack on your desktop, you will need to enable file transfer services before you can send a file. To do this, right mouse click on the Bluetooth logo in your icon tray and select *Receive a File* before transferring data. If the desktop software requires a passcode, use **0000** (all zeros).



Fieldbus Tools



Set Device Address

Used to define a permanent or temporary address for the instrument. Device parameters can only be changed when the device is at a permanent address. Use a temporary address to initialize an address on a host system.



Set Device Tag

Sets device tag.



Set Output Block

Used to define an analog or discrete set point source.



Restart

Reboots the microprocessor. This function does not change device parameters.



Device List

Scans and displays all device tags and addresses on a segment. The device list can be displayed without being connected to a specific instrument.



Block Modes

Displays resource, transducer, AO, and DO block modes.



HART Tools



Toggle Burst Mode

Select Toggle Burst Mode to temporarily disable burst communications. This will improve speed and reduce communication errors.



HART Revision

If supported, HART Revision can be used to set HART 5 or HART 7 communications protocol in the instrument.



Instrument Family

For DVC6200 instruments, select DVC6000 for devices with a potentiometer feedback sensor or DVC6200 for devices with a magnetic array feedback sensor.



Instrument Level StepUp

Instrument Level StepUp is used to change the diagnostic tier in the instrument with a device specific 15 digit code.



About

About displays standard software identification information.



STROKE VALVE

Stroke Valve is a routine for moving a valve to 0%, 25%, 50%, 75%, and 100% lifts or by jogging the valve up or down in 2% increments from any starting point.



TREX POWERING THE LOOP (HART)

If you are connected via the AMS Trex and providing power to a HART device, you can adjust the current and monitor voltage.

Neither Emerson, Emerson Automation Solutions, nor any of their affiliated entities assumes responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use, and maintenance of any product remains solely with the purchaser and end user.

Fisher, ValveLink, FIELDVUE, and SNAP-ON are marks owned by one of the companies in the Emerson Automation Solutions business division of Emerson Electric Co. Emerson Automation Solutions, Emerson, and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Automation Solutions

Marshalltown, Iowa 50158 USA

Sorocaba, 18087 Brazil

Cernay, 68700 France

Dubai, United Arab Emirates

Singapore 128461 Singapore

www.Fisher.com

