


Rosemount™ 8800D Series Vortex Flowmeter Safety Manual for Safety Instrumented Systems (SIS)



Contents

| | | |
|------------------|--|-----------|
| Chapter 1 | Before you begin..... | 5 |
| | 1.1 Emerson Flow customer service..... | 5 |
| | 1.2 About this document..... | 5 |
| | 1.3 Related documents..... | 6 |
| | 1.4 Terms and definitions..... | 6 |
| | 1.5 Skill level requirement..... | 8 |
| | 1.6 Documentation and standards..... | 8 |
| Chapter 2 | Installation and commissioning..... | 9 |
| | 2.1 Identification of SIS certified transmitter..... | 9 |
| | 2.2 Set up the flowmeter..... | 11 |
| | 2.3 Enable transmitter write protection..... | 12 |
| | 2.4 Set failure mode..... | 13 |
| | 2.5 Flow simulation diagnostic..... | 15 |
| | 2.6 Replace equipment..... | 16 |
| Chapter 3 | Proof tests..... | 17 |
| | 3.1 Proof test requirement..... | 17 |
| | 3.2 Repair and replacement..... | 17 |
| | 3.3 Notification of failures..... | 17 |
| | 3.4 Proof test interval..... | 17 |
| | 3.5 Tools required..... | 17 |
| | 3.6 Proof test options..... | 18 |
| | 3.7 Partial proof test..... | 18 |
| | 3.8 Comprehensive proof test..... | 19 |
| | 3.9 SIS example..... | 20 |
| Chapter 4 | Operating Constraints..... | 25 |
| | 4.1 Reverse flow..... | 25 |
| | 4.2 Reliability data..... | 25 |
| | 4.3 Report failures..... | 25 |

1 Before you begin

1.1 Emerson Flow customer service

Email:

- Worldwide: flow.support@emerson.com
- Asia-Pacific: APflow.support@emerson.com

Telephone:

| North and South America | | Europe and Middle East | | Asia Pacific | |
|-------------------------|---------------------|--------------------------|---------------------|--------------|------------------|
| United States | 800 522 6277 | U.K. | 0870 240 1978 | Australia | 800 158 727 |
| Canada | +1 303 527 5200 | The Netherlands | +31 (0) 704 136 666 | New Zealand | 099 128 804 |
| Mexico | +41 (0) 41 7686 111 | France | 0800 917 901 | India | 800 440 1468 |
| Argentina | +54 11 4837 7000 | Germany | 0800 182 5347 | Pakistan | 888 550 2682 |
| Brazil | +55 15 3413 8000 | Italy | 8008 77334 | China | +86 21 2892 9000 |
| Venezuela | +58 26 1731 3446 | Central & Eastern Europe | +41 (0) 41 7686 111 | Japan | +81 3 5769 6803 |
| | | Russia/CIS | +7 495 995 9559 | South Korea | +82 2 3438 4600 |
| | | Egypt | 0800 000 0015 | Singapore | +65 6 777 8211 |
| | | Oman | 800 70101 | Thailand | 001 800 441 6426 |
| | | Qatar | 431 0044 | Malaysia | 800 814 008 |
| | | Kuwait | 663 299 01 | | |
| | | South Africa | 800 991 390 | | |
| | | Saudi Arabia | 800 844 9564 | | |
| | | UAE | 800 0444 0684 | | |

1.2 About this document

This document provides information about how to install, commission, and proof test the Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeter to comply with Safety Instrumented Systems (SIS) requirements.

The information in this document assumes that users understand:

- Basic flowmeter installation, configuration, and maintenance concepts and procedures
- Safety Instrumented System (SIS) operations, including bypass procedures, flowmeter maintenance, and company Management of Change procedures
- All corporate, local government, and national government safety standards and requirements that guard against injuries or death

1.3 Related documents

You can find all product documentation via the Rosemount product documentation DVD shipped with the product or at www.emerson.com/vortex. For more information, see any of the following documents:

- *Rosemount™ 8800D Series Vortex Flow Meter Product Data Sheet*
- *Rosemount™ 8800D Series Vortex Flow Meter Quick Start Guide*
- *Rosemount™ 8800D Series Vortex Flow Meter Reference Manual*
- Report No. ROS 06/03-34 R001; FMEDA report for Rosemount 8800D Vortex Flow Meter Prepared for Emerson by exida.com LLC

1.4 Terms and definitions

| | |
|----------------------------------|---|
| BPCS | Basic Process Control System |
| λ_{DU} | Dangerous Undetected |
| λ_{DD} | Dangerous Detected |
| λ_{SU} | Safe Undetected |
| λ_{SD} | Safe Detected |
| CPT | Comprehensive Proof Test |
| Diagnostic Coverage | [DC] Percentage of detectable faults |
| Diagnostic Test Interval | Time during which all internal diagnostics are carried out at least once. |
| Fail-safe state | Failure that causes the device to go to the defined fail-safe state without a demand from the process. |
| Fail dangerous | Failure that deviates the process signal or the actual output by more than the safety deviation specification, drifts away from the user defined threshold (Trip Point) and that leaves the output within the active scale. |
| FIT | Failure In Time per billion hours |
| Fail Dangerous Detected | Failure that is dangerous but is detected. |
| Fail Dangerous Undetected | Failure that is dangerous and that is not detected. |
| Fail No Effect | Failure of a component that is part of the safety function but that has no effect on the safety function. |
| Fail Safe | Failure that causes the output to go to the defined fail-safe state without an input from the process. |
| FMEDA | Failure Modes, Effects and Diagnostic Analysis |

| | |
|-------------------------------|--|
| HART® | Highway Addressable Remote Transducer |
| HFT | Hardware Fault Tolerance as defined by 61508-2 7.4.4.1.1 |
| High demand mode | The safety function is only performed on demand, in order to transfer the EUC (Equipment Under Control) into a specified safe state, and where the frequency of demands is greater than one per year (IEC 61508-4). |
| Low demand mode | The safety function is only performed on demand, in order to transfer the EUC into a specified safe state, and where the frequency of demands is no greater than one per year (IEC 61508-4). |
| PFD_{AVG} | Average Probability of Failure on Demand |
| PFH | Probability of dangerous failure per hour. |
| PPT | Partial Proof Test |
| Random Integrity | The SIL limit imposed by the architectural constraints that must be met for each element. |
| Safety Demand Interval | The expected time between safety demands. |
| Systematic Capability | A measure (expressed on a scale of SC 1 to SC 4) of the confidence that the systematic safety integrity of an element meets the requirements of the specified SIL, in respect of the specified element safety function, when the element is applied in accordance with the instructions specified in the compliant item safety manual for the element as per 61508-4 |
| SFF | Safe Failure Fraction |
| SIF | Safety Instrumented Function |
| SIL | Safety Integrity Level - a discrete level (one out of four) for specifying the safety integrity requirements of the safety instrumented functions to be allocated to the safety instrumented systems. SIL 4 has the highest level of safety integrity, and SIL 1 has the lowest level. |
| SIS | Safety Instrumented System (SIS) - an instrumented system used to implement one or more safety instrumented functions. An SIS is composed of any combination of sensors, logic solvers, and final elements. |
| Type B device | Complex device using controllers or programmable logic, as defined by the standard IEC 61508. |

1.5 Skill level requirement

System design, installation and commissioning, and repair and maintenance shall be carried out by suitably qualified personnel.

1.6 Documentation and standards

This section lists the documentation and standards referred to by this safety manual.

| Documents | Purpose of documents |
|------------------------------------|--|
| IEC 61508-2: 2010 | <i>Functional Safety of Electrical/Electronic/Programmable Electronic Safety-Related Systems</i> |
| IEC 61511 (ANSI/ISA 84.00.01-2004) | <i>Functional safety - Safety instrumented systems for the process industry sector</i> |
| ROS 06/03-34 R001 | <i>FMEDA Report Version V1, Revision R1, or later, for the Rosemount 8800D Series Vortex Flowmeter</i> |
| 00813-0100-4004 | <i>Rosemount™ 8800D Series Vortex Flow Meter Product Data Sheet</i> |
| 00809-0100-4004 | <i>Rosemount™ 8800D Series Vortex Flow Meter Reference Manual</i> |
| 00825-0100-4004 | <i>Rosemount™ 8800D Series Vortex Flow Meter Quick Start Guide</i> |

2 Installation and commissioning

Use this chapter to install and commission the Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeter. The safety certified output of the Rosemount 8800D is the 4–20 mA output. This output provides a signal proportional to process flow, between low flow cutoff and the Upper Range Value (URV). Detected faults are indicated by an offscale output (see [Set failure mode](#)). The safety logic solver should be configured to detect offscale output levels. While the pulse output may be used, it is not a safety certified output. Devices ordered without SI option may not be certified per IEC 61508.

2.1 Identification of SIS certified transmitter

IEC 61508 relevant requirements

The Rosemount 8800D is certified per the relevant requirements of IEC 61508.

| | |
|-----------------------|---|
| Systematic capability | Safety Integrity Level (SIL) 3 capable |
| Random capability | <p>Low Demand:</p> <ul style="list-style-type: none"> Type B element SIL 2 capable @ HFT\geq0 (single transmitter) SIL 3 capable @ HFT\geq1 (multiple single transmitters i.e. dual, 2 single or quad flow meter minimum) <p>High Demand:</p> <ul style="list-style-type: none"> Type B element SIL 2 or 3 capable @ HFT\geq1 (multiple single transmitters i.e. dual, 2 single or quad flow meter minimum) |

Failure rates per IEC 61508 in FIT

Table 2-1: Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeter

| Failure categories | λ_{SD} | λ_{SU} | λ_{DD} | λ_{DU} |
|--------------------|----------------|----------------|----------------|----------------|
| Low Flow Trip | 0 | 76 | 387 | 74 |
| High Flow Trip | 0 | 32 | 387 | 119 |

SIS-certified versions

All Rosemount 8800D Vortex Flowmeters must be identified as safety certified before installing into SIS systems.

To identify a safety certified Rosemount 8800D Vortex with single or dual flow meter, requirements 1 and 2, or requirements 2 and 3 must be satisfied. The requirements are:

8800 Single and Dual meters

1. Verify the option code "SI" in the model code. The SI code will appear somewhere after the 16th character of the model code (after the required fields.) Note that the

optional options, including SI, can appear in any order and be valid. Please refer to A of Figure 2-1.


- For example: 8800D.....SI

2. Verify 4-20mA marking on the transmitter housing nameplate. Please refer to B of Figure 2-1.
3. Confirm firmware revision is one of the revisions listed in Table 2-2.

Note

Software version information may be verified in the device from the Field Communicator: Overview → Device Information → Revision Number.

Figure 2-1: Example of transmitter nameplate for Single or Dual meters



- A. SI option code
- B. 4-20mA Output

To identify a safety certified transmitters with in an 88800D Quad Vortex Flowmeter, requirements 1 and 2, or requirements 2 and 3 must be satisfied. The requirements are:

8800 Quad meters

1. SI[X] option code to be present in respects to the transmitter in question. Please refer to A of Figure 2-2 for location of transmitter number. Confirm model string contains SI[X], where X is the transmitter number, option code for the indicated transmitter. Please refer to B of Figure 2-2 for location of SI[X] option code(s). The SI[X] code will appear somewhere after the 26th character of the model code (after the required fields). Note that the optional options, including SI[X], can appear in any order and be valid
 - For example: 8800DQ.....SI1SI2SI3

Note

In this example, Transmitter 4 may not be safety certified.

2. Verify 4-20mA marking on the transmitter housing nameplate. Please refer to C of Figure 2-2.
3. Confirm firmware revision is one of the revisions listed in Table 2-2.

Figure 2-2: Example of Quad transmitter nameplate



- A. Transmitter number
- B. SI option code
- C. 4–20mA Output

Table 2-2: Rosemount 8800D SIS revisions and versions

| Device | Display tag | Safety certified version combinations | | |
|----------------|----------------------|---------------------------------------|---|---|
| | | 1 | 2 | 3 |
| 8800D firmware | Universal revision | 5 | 5 | 7 |
| | Transmitter revision | 2 | 3 | 2 |
| | Software revision | 8 | 4 | 4 |
| 8800D hardware | Hardware revision | 1 | 2 | 2 |

Safety precautions

Prior to making any changes to the flowmeter, such as changing the configuration or replacing the transmitter hardware or sensor:

- Take appropriate action to avoid a false trip by electronically bypassing the safety logic solver.
- Prior to placing the meter online and removing the bypass from the safety logic solver, verify the transmitter configuration and all safety parameters per [Set up the flowmeter](#).

Important

Ensure alternate means are in place to maintain the process in a safe state.

2.2 Set up the flowmeter

Use the following procedure to make sure the flowmeter is installed and configured for SIS applications.

You can use ProLinkIII software, AMS Device Manager, or the Field Communicator to verify, or configure these settings. For more information, see the product reference manual.

The flowmeter does not require special installation other than the standard installation procedures in the reference manual.

Note

Transmitter output is not safety-rated during the following: Configuration changes, loop test mode, simulation mode, multidrop operation, temperature compensation of the process fluid, SMART fluid diagnostics, saturated steam or mass flow with temperature and/or pressure compensation. Alternative means should be used to ensure process safety during configuration and maintenance activities.

1. Verify that the software revision running is one of the revisions listed in [Table 2-2](#).

| | |
|----------------------|---|
| ProLink III Software | Device Tools → Device Information → Software Revision |
|----------------------|---|

2. Verify all safety parameters.
 - a. Verify that all appropriate flow calibration parameters are set (Reference K-Factor, Process Fluid, Fixed Process Temperature, Fixed Process Density).
 - b. Verify that the Lower Range Value (LRV) and the Upper Range Value (URV) for the 4-20 mA output is configured


2.3 Enable transmitter write protection

Write-protection helps protect the transmitter against accidental changes to configuration. When the transmitter is write-protected, no changes to the transmitter configuration will be accepted.

Tip

Write protecting the transmitter prevents accidental changes to configuration. It does not prevent normal operational use. You can always disable write protection, perform any required configuration changes, then re-enable write protection.

The SECURITY jumper enables write protection.

- If the jumper is in the ON position, write protection is enabled.
- If the jumper is in the OFF position, write protection is disabled.
 1. If you are in a hazardous area, power down the transmitter.
 2.  **WARNING**
Never remove the transmitter housing cover in a hazardous area when the transmitter is powered up. Failure to follow these instructions may result in an explosion.

Remove the transmitter housing cover (opposite of the terminal block).
 3. Move the two-pin SECURITY jumper to the ON position.
The location of the security switch depends upon whether or not the transmitter has the (M5) optional display.

Figure 2-3: SECURITY jumper location without M5 optional display





Figure 2-4: SECURITY jumper location with M5 optional display



4. Replace the transmitter housing cover.
5. Power up the transmitter.

2.4 Set failure mode

As part of normal operations, the flowmeter continuously runs a self-diagnostic routine. If the routine detects an internal failure, the failure mode setting determines whether the flowmeter output is driven to a low or high alarm level.

The failure mode setting is controlled by the ALARM jumper, which is set at the factory per the CDS (Configuration Data Sheet); the default setting is HI.

- If the ALARM jumper is in the HI position, the flowmeter output will be driven to a high alarm level in the event of a failure.
- If the ALARM jumper is in the LOW position, the flowmeter output will be driven to a low alarm level in the event of a failure.

Note

For exact alarm values, see the product reference manual.

1. If you are in a hazardous area, power down the transmitter.
2. **⚠ WARNING**
Never remove the transmitter housing cover in a hazardous area when the transmitter is powered up. Failure to follow these instructions may result in an explosion.

Remove the transmitter housing cover (opposite of the terminal block).

3. Move the two-pin ALARM jumper to the HI or LOW position, as desired.
The location of the ALARM jumper depends upon whether or not the transmitter has the (M5) optional display.

Figure 2-5: ALARM jumper location without (M5) optional display





Figure 2-6: ALARM jumper location with (M5) optional display



4. Replace the transmitter housing cover.
5. Power up the transmitter.

2.5 Flow simulation diagnostic

Performing an internal flow simulation ensures the current calibration state of the transmitter by carrying out a verification of the electronics board stack to indicate the health of the various components on the board stack. Failure may indicate a need to replace the electronics. Every transmitter comes with internal flow simulation capabilities.

Note

For the Flow Simulation Function to operate, Primary Variable must be set to Velocity Flow, Volume Flow, or Mass Flow and the write protection must be disabled (see [Enable transmitter write protection](#)).

1. Ensure that the write protection is disabled (see [Enable transmitter write protection](#)).
2. Read the calculated Shedding Frequency at URV.

| | |
|----------------------|--|
| ProLink III Software | Device Tools → Configuration → Process Measurement → Signal Processing |
|----------------------|--|

3. Navigate to **Flow Simulation**.

| | |
|----------------------|--|
| ProLink III Software | Device Tools → Diagnostics → Testing → Flow Simulation |
|----------------------|--|

4. Select **Internal Flow Simulation, Fixed Flow, Percent of Range** and enter 50% flow.
5. Verify that flow rate output is 50% of full scale and Frequency is 1/2 of calculated Frequency at URV.
 - a. If the flow rate output is 50% of full scale, the electronics are working properly.
 - b. If the flow rate output is not 50% of full scale, see the troubleshooting information in the product reference manual.

Note

(Optional): Verify shedding frequency from internal signal generator is the same as displayed on handheld communicator, ProLink III, or AMS Device Manager. This can be accomplished by connecting a device such as a Fluke multi-meter with frequency measurement capability to the test points behind the display labeled "TP1" and Ground (using the universal ground symbol). Connect the positive lead of the digital multi-meter to TP1 and the negative lead to the Ground lug. The frequencies should match to a plant specified tolerance that is no less than the tolerance of the device used to read the frequency.

- If the shedding frequency is 50% of full scale, the electronics are working properly.
- If the shedding frequency is not 50% of full scale, see the troubleshooting information in the product reference manual.

6. Exit simulation by selecting **Normal Flow Measurement** or **Exit**.
7. Enable write protection (see [Enable transmitter write protection](#)).

2.6 Replace equipment

If you need to replace hardware, purchase all spare parts from Emerson. You cannot use user-supplied components on any Rosemount printed circuit assemblies.

1. Replace the hardware by contacting your local Emerson or Emerson affiliated sales representative to obtain the correct part number.

Use the product reference manual or quick start guide for proper maintenance guidelines.

2. Verify the transmitter configuration and all safety parameters (see [Set up the flowmeter](#)).
3. Enable write protection (see [Enable transmitter write protection](#)).
4. Set the failure mode (see [Set failure mode](#).)

3 Proof tests

3.1 Proof test requirement

During operation, an SIF must be proof tested. The objective of proof testing is to detect failures within the equipment in the SIF that are not detected by any automatic diagnostics of the system. Undetected failures that prevent the SIF from performing its function are the main concern.

Periodic proof tests shall take place at the frequency (or interval) defined by the SIL verification calculation. The proof-tests must be performed more frequently than or as frequently as specified in the SIL verification calculation in order to maintain the required safety integrity of the overall SIF.

Results from periodic proof tests shall be recorded and periodically reviewed.

3.2 Repair and replacement

Repair procedures in the product reference manual must be followed.

3.3 Notification of failures

In case of malfunction of the system or SIF, the Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeter shall be put out of operation and the process shall be kept in a safe state by other measures.

Emerson must be informed when the Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeter is required to be replaced due to failure. The occurred failure shall be documented and reported to Emerson using the contact details on the back page of this functional safety manual. This is an important part of Emerson SIS management process.

3.4 Proof test interval

The time intervals for proof testing are defined by the SIL verification calculation (subject to the PFD_{AVG}). The proof tests must be performed more frequently than or as frequently as specified in the SIL verification calculation in order to maintain the required safety integrity of the overall SIF.

Results from periodic proof tests shall be recorded and periodically reviewed. For the specification of customer requirements required to fulfil this SIS requirement, please see IEC-61511.

3.5 Tools required

- HART host or Field Communicator
- mA meter

3.6 Proof test options

The flowmeter has two proof tests you can use to detect failures. Proof tests can be performed using ProLink III software or the Field Communicator.

Table 3-1: Proof test options

| Device | Proof test | Description | DU failure detection |
|--------|---------------|---|---|
| 8800D | Partial | <ul style="list-style-type: none"> • Low/High alarm checks • Visual inspection of flow meter • Single point reasonability check or internal flow simulation at 2 points • Checking for alarms • Checking configuration | High flow trip: 85% Low flow trip: 77% |
| | Comprehensive | <ul style="list-style-type: none"> • Low/High alarm checks • Visual inspection of flow meter • 3 to 5-point calibration check using reference standard • Checking for alarms • Checking configuration | High flow trip: 94% Low flow trip: 92% |

3.7 Partial proof test

The partial proof test is recommended for all Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeters.

This procedure assumes that you are familiar with plant procedures. For details on how to do any of the following steps, see the product reference manual.

1. Take appropriate action to avoid a false trip by electronically bypassing the safety Programmable Logic Controller (PLC).
2. Inspect flowmeter for any leaks, visible damage or contamination.
3. Verify that the transmitter does not indicate alarms or warnings using HART host or LCD.
4. Cycle power and use HART communications to retrieve any diagnostics and take appropriate action.
5. Disable write protection (see [Enable transmitter write protection](#)).
6. Using the Loop Test function, send a HART command to the transmitter to go to the high alarm current output and verify that the analog current reaches that value.
 - Loop Test can be found at **Service Tools** → **Simulate** → **Analog Output** → **Loop Test**.
 - High alarm and low alarm levels can be found in the product reference manual.

This step tests for compliance voltage problems, such as low voltage on the loop power supply, or increased wiring resistance.

7. Send a HART command to the transmitter to go to the low alarm current output and verify that the analog current reaches that value.

This step tests for possible failures related to quiescent current.

8. Exit fixed current mode.
9. Compare the process flow with the Low Flow Cutoff, and do one of the following:

| Option | Description |
|---|---|
| Process flow greater than Low Flow Cutoff | Confirm measured flow compares reasonably to an independent measurement. |
| Process flow less than Low Flow Cutoff | Check output at 2 points using internal flow simulation, with at least one point between LFC and URV. |

10. Verify all safety-critical configuration parameters (see [Set up the flowmeter](#)).
11. Enable write-protection (see [Enable transmitter write protection](#)).
12. Remove the bypass and otherwise restore normal operation.
13. Document the results of this proof test as part of your plant safety management procedures.

3.8 Comprehensive proof test

The comprehensive proof test is recommended for all Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeters.

This procedure assumes that you are familiar with plant procedures. For details on how to do any of the following steps, see the product reference manual.

1. Take appropriate action to avoid a false trip by electronically bypassing the safety Programmable Logic Controller (PLC).
2. Inspect flow meter for any leaks, visible damage or contamination.
3. Verify that the transmitter does not indicate alarms or warnings using HART host or LCD.
4. Cycle power and use HART communications to retrieve any diagnostics and take appropriate action.
5. Disable write protection (see [Enable transmitter write protection](#)).
6. Using the Loop Test function, send a HART command to the transmitter to go to the high alarm current output and verify that the analog current reaches that value.
 - Loop Test can be found at **Service Tools** → **Simulate** → **Analog Output** → **Loop Test**.
 - High alarm and low alarm levels can be found in the product reference manual.

This step tests for compliance voltage problems, such as low voltage on the loop power supply, or increased wiring resistance.

7. Send a HART command to the transmitter to go to the low alarm current output and verify that the analog current reaches that value.

This step tests for possible failures related to quiescent current.

8. Exit fixed current mode.
9. Perform a 3 to 5-point calibration check of the transmitter and flowmeter against a reference standard.
10. Verify all safety-critical configuration parameters (see [Set up the flowmeter](#)).
11. Enable write-protection (see [Enable transmitter write protection](#)).
12. Remove the bypass and otherwise restore normal operation.
13. Document the results of this proof test as part of your plant safety management procedures.


3.9 SIS example

The following figures illustrate the indicative benefits of using a combination of comprehensive and partial proof tests to manage the level of risk associated with a particular SIS Installation. [Figure 3-1](#) shows a typical 1oo1 safety system configuration. [Figure 3-2](#) through [Figure 3-5](#) illustrate the benefit of implementing a combination of comprehensive and partial proof tests on the system's PFD.

Note


It is assumed that the sensor typically contributes ~30% to the systems SIL 2 PFD budget, with the logic solver and actuator the remaining ~70%.

Figure 3-1: Single use 1oo1 (1 out of 1) for SIL 2 low demand (SIL 2@HFT=0)




- A. Sensor (Rosemount 8800D)
- B. Logic solver
- C. Actuator

Figure 3-2: PFD and PFD average of system when no proof testing applied




- A. PFD (Probability of failure on demand)
- B. Mission time (years)
- C. PFD_{AVG} (average probability of failure on demand)
- D. Predicted PFD

Figure 3-3: Unit subjected to either no proof test or a comprehensive proof test every 5 years




- A. PFD (Probability of failure on demand)
- B. Mission time (years)
- C. PFD_{AVG} (average probability of failure on demand)
- D. Predicted PFD
- E. Predicted PFD + CPT (comprehensive proof test)

Figure 3-4: Unit subjected to a partial proof test every year and a comprehensive proof test every 3 years



- A. PFD (Probability of failure on demand)
- B. Mission time (years)
- C. PFD_{AVG} (average probability of failure on demand)
- D. Predicted PFD + PPT (partial proof test) + CPT (comprehensive proof test)

Figure 3-5: Unit subjected to a partial proof-test every year and a comprehensive proof test every 5 years



- A. PFD (Probability of failure on demand)
- B. Mission time (years)
- C. PFD_{AVG} (average probability of failure on demand)
- D. Predicted PFD + PPT (partial proof test) + CPT (comprehensive proof test)

4 Operating Constraints

4.1 Reverse flow

Use appropriate means to ensure only zero or forward flow through the meter, as indicated by the arrow on the meter body. Reverse flow operation may result in erroneous non-zero flow indication.

4.2 Reliability data

The Rosemount 8800D Series SIL 2/3 Capable Vortex Flowmeter:

- Has a specified safety deviation of 2%. Internal component failures are listed in the device failure rate if they will cause an on-scale error of 2% or greater.
- Reports an internal failure within 30 minutes of fault occurrence – worst case scenario.
- Generates a valid signal within 6 seconds plus configured damping response of a power-on startup.

FMEDA report

The Failure Mode, Effects, and Diagnostics Analysis (FMEDA) report is used to calculate the failure rate. A FMEDA report for a Vortex Flow Meter with a Rosemount 8800D transmitter contains:

- All failure rates and failure modes
- Common cause factors for applications with redundant devices that should be included in reliability calculations
- The expected lifetime of your flowmeter and transmitter, as the reliability calculations are valid only for the lifetime of the equipment

Obtain a FMEDA report at www.emerson.com/vortex.

Environmental and application limits

See the product data sheet for environmental and application limits.

Using the flowmeter or transmitter outside environmental or application limits invalidates the reliability data in the FMEDA report.

4.3 Report failures

If you have detected any failures that compromise safety, contact the Flow Solutions Group Product Safety Officer.

Contact the Product Safety Officer through the Flow Solutions Group customer service. Customer service is available 24 hours a day, seven days a week. Contact information is located at the front of this manual.



00809-0200-4004
Rev. AC
2020

Emerson Automation Solutions USA

7070 Winchester Circle
Boulder, Colorado USA 80301
T +1 303-527-5200
T +1 800-522-6277
F +1 303-530-8459
www.emerson.com

Emerson Automation Solutions Asia

1 Pandan Crescent
Singapore 128461
Republic of Singapore
T +65 6363-7766
F +65 6770-8003

Emerson Automation Solutions Europe

Neonstraat 1
6718 WX Ede
The Netherlands
T +31 (0) 70 413 6666
F +31 (0) 318 495 556
www.micromotion.nl

Emerson Automation Solutions United Kingdom

Emerson Process Management Limited
Horsfield Way
Bredbury Industrial Estate
Stockport SK6 2SU U.K.
T +44 0870 240 1978
F +44 0800 966 181

©2020 Rosemount, Inc. All rights reserved.

The Emerson and Rosemount logos are trademarks and service marks of Emerson Electric Co. All other marks are property of their respective owners.

ROSEMOUNT™

