UN 38.3 Lithium Battery Test Summary

Cell, Battery or Product Model Number

Item Number:

Item Name: Li-ion Battery AHB682828HPA 3.8V 530mAh 2.1Wh

Cell, battery, or product manufacturer's contact information

Name: Kunshan SYNergy ScienTech Co.,Ltd

Address: No.688, Nanhe Road, Economic&Technical Development Zone, Kunshan, Jiangsu

KunShan City:

State: Jiangsu ZIP: 215300

Country: China

Telephone: +86-512-57710688 hmsong@synst.com.cn Website: http://www.synst.com.cn

Test Laboratory

Name: The laboratory for UN38.3 of Kunshan SYNergy ScienTech Co., Ltd

Address: 688# Nanhe Road Kunshan

City: KunShan State: Jiangsu

ZIP: 215300 Country: China

Telephone: +86-0512-57710688-3411

E-mail: alice@synst.com.cn

Website: http://www.synst.com.cn

Cell or Battery Description					
Cell or Battery: Battery					Physical Description (dimensions, appearance):
Cell or Battery Type: AHB682828HPA					
Watt-hour rating or Lithium Content: 2.1Wh					Silvery aluminum-plastics shell
Completed Cell or Battery Weight: Approx. 10g					
Unique Test Report ID Number: UN18120304					Date of test report: 2018-12-04~2019-01-03
List of Tests Completed:					
Yes	No		Pass	Fail	Additional Comments (or indicate compliance with other standards, e.g., Underwriters Laboratory):
Yes		Test T.1: Altitude simulation	Pass		Not Applicable
Yes		Test T.2: Thermal test	Pass		
Yes		Test T.3: Vibration	Pass		Reference to assembled battery testing requirements, if applicable (i.e., 38.3.3 (f) and 38.3.3 (g)).
Yes		Test T.4: Shock	Pass		Not Applicable
Yes		Test T.5: External short circuit	Pass		
Yes		Test T.6: Impact/Crush	Pass		Reference to the revised edition of the Manual of Tests and Criteria used and to amendments thereto, if any:
Yes		Test T.7: Overcharge	Pass		Sixth Edition
Yes		Test T.8: Forced discharge	Pass		

Signature with name and title of signatory as an indication of the validity of information provided:

in 12 1/2 Caporatory Engineer

