

CC 1396-CPD-0062 1396-CPR-0077 FTZU 13 ATEX 0046 FTZU 14 ATEX 0127X

DECLARATION OF PERFORMANCE

According to Regulation (EU) No 305/2011 of the European Parliament and of the Council Number of the declaration: DoP28_PKIS_H_EN

1. Unique identification code of the product	PKIS-EI90S, PKIS-EI120S, PKIS3G,
	PKIS90-Ex, PKIS120-Ex, PKIS3G-Ex
2. Туре	Rectangular fire damper
3. Intended use of the construction product	Fire closure for HVaC ductworks for the compartmentization
4. Name, registered trade name and contact address of the manufacturer	IMOS-Systemair 90043, Kalinkovo 146, Slovakia
5. Where applicable, name and contact address of the authorized representative	
6. System of assessment and verification of constancy of performance of the construction	system 1
product	
7. Harmonized product standard, test standard, classification standard	EN 15 650, EN 1366-2, EN 13 501-3
8. Identification number of the notified body	1396
Name and adress of the notified person	FIRES s.r.o. Osloboditeľov 282, 059 35 Batizovce
Which performed in system 1:	determination of the product type on the basis of type testing (including sampling) and descriptive documentation of the production initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control
and issued certificate of constancy of performance	CE 1396-CPD-0062 CE 1396-CPR-0077
Identification number and name of the notified person for ATEX certification	1026 Fyzikálně technický zkušební ústav Ostrava–Radvanice,CZ
Which examinated type of the round and rectangular fire damper for the explosive environment according to	Council Directive 94/9/EC and EN 13463-1:2009
With marking	⟨€x⟩ 2/- G B
Number of the EC-Type examination certificate	FTZU 13 ATEX 0046, FTZU 14 ATEX 0127X
9. Declared performance	

product name	dimension range (mm)	certificates No.	picture	product type	fire resistivity	ting		Installation - tested at underpressure (Pa)				
TechSpec. InstalMain.			F			suppor constru	wet	dry	soft crossing	installation kit	on a wall	out of a wall
	100x100 13 up to 800x600 FTZU	CE 1396-CPR-0077 FTZU14ATEX0127X		PKIS3G PKIS3G-Ex ^{atex}	El60(ve ho i ↔ o)S	ve	500	300	300	500	300 ^{W, P}	300 ^{W, P}
			1			ho	500		300			
					El90(ve ho $i \leftrightarrow o)S$	ve	500	300	300	500	300 ^{W, P}	300 ^{W, P}
rectangular fire damper TPI-28 PP-28						ho	500		300			
					EI120(ve ho $i \leftrightarrow o)S$	ve	500			500	300i→o [,] W,P	300i←o ^{.w, p}
						ho	500					
	800 < W ≤ 1200 &100 ≤ H ≤ 300 13	CE 1396-CPR-0077		PKIS3GA without ATEX	El60(ve ho i ↔ o)S	ve	300				300 ^p	300 ^p
						ho						
						ve	300				300 ^p	300 ^p
					ho							
	W>800 and/or H>600 up to 1600x1000	d/or H>600 000x1000 CC 1396-CPD-0062 FTZU13ATEX0046		PKIS-EI90S MULTI PKIS90-Ex ATEX PKIS-EI120S	El90(ve ho $i \leftrightarrow o$)S	ve	300	300			300 w	300 w
						ho	300					
	100x100 up to		41	PKIS120-Ex ATEX	EI120(ve ho i ↔ o)S	ve	300					
	1500x1000 GOST	С-SK.ПБ01.В.01805		PK-I-S-EI90S GOST PK-I-S-EI120S GOST		ho	300					
RIGID/FLEXIBLE WALL ONLY RIGID WALL/CEILING		-	ONLY IN/ON THE DUCT									

ATEX When ordering the ATEX fire damper use codes with Ex such as PKIS3G-Ex or PKIS90-Ex ... All ATEX fire dampers are designated a class of explosion proof (E) II 2/- G IIB

MULTI Multi-installation is possible: two dampers beside each other or one above the other, or four dampers - always with a horizontal axis of the blade

P Installation on/out of a wall with Promatect boards insulation for lower ceiling with resistivity EI30/45/60/90/S

^w Installation on/out of a wall with mineral wool

Modulated fire dampers (the activation mechanism DV9-T-SR on page 10 in TPI-28) are manufactured: PKIS3G with H ≥ 160 mm.

ACCORDING TO EN 15650 EACH FIRE DAMPER MUST BE INSTALLED ACCORDINGLY INSTALLATION INSTRUCTIONS PROVIDED BY THE MANUFACTURER! For dimensions of 100 × 100 up to 800 × 600 mm certificate number FTZU 14 ATEX 0127

For dimensions W>800 and/or H>600 mm up to 1600 x 1000 mm certificate number FTZU 13 ATEX 0046

Explosion-proof certified according to the EC Directive. 94/9/EC and the standards EN 13 463, Part 1

Supporting construction	Standard according to tab. 3 – 5 in EN 1366-2
Direction of the blade axis	Wet and dry vertical / all installation methods horizontal
Fire resistance:	passed
maintenance of the cross section (under E) / integrity E / insulation I / smoke leakage S /	
mechanical stability (under E) / cross section (under E)	

Nominal activation conditions/sensitivity:	passed
- sensing element load bearing capacity	
- sensing element response temperature	
Response delay (resp. time)	passed
- closure time	
Operational reliability:	passed
- cycling motorized	10200 cycles
- cycling manual	50 cycles
Durability of operational reliability:	passed
open and closing cycle	
Durability of response delay:	passed
sensing element response temperature and load bearing capacity	
Tightness class according to EN 1751:	
-casing	standardly B on demand C
-blade	standardly 2 on demand 3
Actuating mechanism:	Manual
	Electromagnet 24V AC/DC/ 230 V AC in impulse/interruption connection
	Servomotor 24V AC/DC/230 V AC

Declared performance table and texts in italic are new against version G of the Declaration of Performance.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. Signed for and on behalf of the manufacturer by:

Kalinkovo the 10th November 2015

Ing. Ondrej Ertl CSc., technical director:

I CONFIRM THAT THIS TRANSLATION IS IDENTICAL TO THE ATTACHED ENGLISH ORIGINAL

date:....

translator: firm, position: signature: first name last name:.....