

# **Certificate of Compliance**

Certificate:	1015065	Master Contract:	178267
Project:	80007826	Date Issued:	2019-07-10
Issued To:	Hawke International A Division of Hubbell Limited Oxford St W Ashton-Under-Lyne, Lancashire, OL7 0NA United Kingdom		

Attention: Andy Tindall

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: Jimmy Solanki Jimmy Solanki



#### PRODUCTS

#### CLASS - C441805 - CABLE Hardware - For Hazardous Locations

Class I, Div.2 Groups ABCD; Class II Div. 2, Groups EFG; Class III Ex db IIC Gb, Ex eb IIC Gb -60 °C < Ta <80°C or -60°C < Ta < 100 °C ; IP 66

Series	Size (Os to F)	Oversized G, H,J	Operating Temp
501/414	Yes	No	-60 °C to 100°C
501/421	Yes	Yes	-60 °C to 100°C
501/421 2K	2K	No	-60 °C to 100°C
501/421 R	Os to C2 size only	No	-60 °C to 100°C
501/423	Yes	Yes	-60 °C to 100°C
501/453 Dedicated	Yes	Yes	-60 °C to 100°C



**Certificate:** 1015065 **Project:** 80007826 Master Contract: 178267 Date Issued: 2019-07-10

501/453 RAC	Yes	No	-60 °C to 100°C
501/453 RAC - X	Yes	No	-60 °C to 100°C
501/453 UNIV	Yes	No	-60 °C to 80°C
501/453 UNIV-X	Yes	No	60 °C to 80°C

NOTES:

- 1. Cable Gland Connectors' Material may be brass, nickel plated brass, aluminium or stainless steel.
- 2. Additional marking denoting trade size, and manufacturer information will be included.
- 3. These cable glands are designed for use with unarmoured or appropriate Steel Tape Armour (STA), Steel Wire Armour (SWA), and appropriate braided cable. These cables must be with extruded sealing (solid polymeric) completely surrounding the 'core' (insulation and conductor), allowing for no holes or ventilation through the inner jacket or along the cores.
- 4. The Hawke 501/4 series cable gland connectors, when used in Class I Division 2 Classified areas, are not suitable to be interfaced with an explosion proof enclosure containing arcing and sparking devices, unless installed in conjunction with an approved explosion proof sealing fitting. The installation shall be as per Canadian Electric Code C22.1-18.
- 5. These gland are also suitable for use with Certified Marine Shipboard armored/ unarmored cables constructed to CSA Std 245 and IEEE45/IEC600092-353 Standards, or certified equivalent), for use on Shipboards and Offshore Rigs/ platforms.
- 6. Must comply with Canadian Electrical Code and National Electric Code requirements for threaded entries.
- 7. Cable glands must be used with an appropriate cable, as per the manufacturer's specifications, to maintain integrity of the installation.
- 8. For Ex e applications a sealing washer or thread sealant may be required between the enclosure and the gland to maintain the IP rating of the enclosure.
- 9. All glands (exception 501/421R range) when used with unarmored or braided cables are only suitable for use with fixed apparatus, the cable must be effectively clamped and cleated elsewhere, to be noted in Installation Instructions.

#### CLASS - C441885 - CABLE-Hardware For Hazardous Locations-Certified to U.S. Standards

Class I, Zone 1,AEx eb IIC Gb Zone 21, AEx tb IIIC Db ; -60 °C< Ta< 80°C or -60°C< Ta <100 °C; IP 66 "HAWKE" Cable Glands

Series	Size (Os to F)	Oversized G, H,J	Operating Temp
501/414	Yes	No	-60 °C to 100°C
501/421	Yes	Yes	-60 °C to 100°C
501/421 2K	2K	No	-60 °C to 100°C
501/421 R	Os to C2 size only	No	-60 °C to 100°C
501/423	Yes	Yes	-60 °C to 100°C
501/453 Dedicated	Yes	Yes	-60 °C to 100°C



**Certificate:** 1015065 **Project:** 80007826 Master Contract: 178267 Date Issued: 2019-07-10

501/453 RAC	Yes	No	-60 °C to 100°C
501/453 RAC-X	Yes	No	-60 °C to 100°C
501/453 UNIV	Yes	No	-60 °C to 80°C
501/453 UNIV-X	Yes	No	60 °C to 80°C

NOTES:

- 1. Cable Gland Connectors' Material may be brass, nickel plated brass, aluminum or stainless steel.
- 2. Additional marking denoting trade size, and manufacturer information will be included.
- 3. These cable glands are designed for use with unarmoured or appropriate Steel Tape Armour (STA), Steel Wire Armour (SWA), and appropriate braided cable. These cables must be with extruded sealing (solid polymeric) completely surrounding the 'core' (insulation and conductor), allowing for no holes or ventilation through the inner jacket or along the cores.
- 4. These gland are also suitable for use with Certified Marine Shipboard armored/unarmored cables constructed to CSA Std 245 and IEEE45/IEC600092-353 Standards, or certified equivalent), for use on Shipboards and Offshore Rigs/ platforms.
- 5. Must comply with Canadian Electrical Code and National Electric Code requirements for threaded entries.
- 6. Cable glands must be used with an appropriate cable, as per themanufacturer's specifications, to maintain integrity of the installation.
- 7. For Ex e applications a sealing washer or thread sealant may be required between the enclosure and the gland to maintain the IP rating of the enclosure.
- 8. All glands (exception 501/421R range)when used with unarmored or braided cables are only suitable for use with fixed apparatus, the cable must be effectively clamped and cleated elsewhere, to be noted in Installation Instructions.

~~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	
CSA Standard C22.2 No 0-10	General Requirements - Canadian Electrical Code Part II
CSA Standard C22.2 No 174-18	Cables and Cable Glands for Use in Hazardous Locations For
	Reference.)
CSA Standard C22.2 No 60079-0-15	Electrical apparatus for explosive gas atmospheres. PART 0: General
	requirements.
CSA Standard C22.2 No 60079-1-16	Electrical apparatus for explosive gas atmospheres. PART 1:
	Construction and verification test of flameproof enclosures of
	electrical apparatus.
CSA Standard C22.2 No 60079-7-16	Electrical apparatus for explosive gas atmospheres.
	Part 7: Increased Safety 'e'.
CSA Standard C22.2 No 60079-31-15	Explosive atmospheres Part 31: Dust ignition protection by enclosure
	"t"
UL514B (6 <sup>th</sup> Edition)	Conduit, Tubing and Cable Fittings
UL1203 (4 <sup>th</sup> Edition)	Outlet boxes and fitting for Use in Hazardous (Classified) Locations.
	Fourth Edition
UL 2225(4 <sup>th</sup> Edition)	Cables and Cable Glands for Use in Hazardous Locations
	·

#### **APPLICABLE REQUIREMENTS**



UL60079-0 ( 6 <sup>th</sup> Edition)	Electrical apparatus for explosive gas atmospheres. PART 0: General requirements
UL60079-7 (5 <sup>th</sup> Edition)	Electrical apparatus for explosive gas atmospheres. Part 7: Increased Safety 'e'.
UL 60079-31 (2 <sup>nd</sup> Edition)	Explosive Atmospheres Part 31 Dust ignition protection by enclosure "t"

#### **MARKINGS**

The manufacturer is required to apply the following markings:

• Products shall be marked with the markings specified by the particular product standard.

• Products certified for Canada shall have all Caution and Warning markings in both English and French. Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Nameplate adhesive label material approval information:

- 1. Submittor's name, trademark, or the CSA file number (adjacent the CSA Mark).
- 2. Model designation,
- 3. Thread form and Trade size.
- 4. The symbol Ex and the symbol for each Level of Protection used;
- 5. The symbol of the Group;
- 6. The equipment Protection Level;
- 7. The name or mark of the certificate issuer and the certificate reference in the following form; the last two figures of the year of the certificate followed by ......
- 8. Hazardous Location Designation: e.g. Class I, Div. 2, Groups A, B, C and D.....(Only for Canada)
- 9. The cCSA Mark:





**Certificate:** 1015065 **Project:** 80007826 Master Contract: 178267 Date Issued: 2019-07-10

10. The CSAus Mark :



- 11. Enclosure rating IP66.
- 12. Operating Temperature -60 °C < Ta <  $80^{\circ}$ C or - $60^{\circ}$ C < Ta <  $100^{\circ}$ C

Note: Gland shall be provided with and assembled in accordance with Manufacturers instruction sheet AI 300.

#### METHOD OF MARKING:

The marking shall be permanent such as cast, etched or engraved



## Supplement to Certificate of Compliance

Certificate: 1015065 (078713\_0\_000)

Master Contract: 178267

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

### **Product Certification History**

Project	Date	Description
80007826	2019-07-10	Update certificate 1015065 to remove the Marking of Class I Div. 2, Class II, Div. 2 for US, as per the Certification Notice No.27 Dated October 22, 2016. Also the AEx d IIC Marking for US has been removed.
70133468	2017-07-07	Add new construction Series 501/453 Univ X and 501/453 RAC-X Update the certificate 1015065 to include assessment to the later standards as justified by existing documentation
70036583	2015-06-26	Update report 1015065 to remove supplementary Gland Assembly note.
2489847	2013-02-15	Update report 1015065 to include North American Class/Div ratings, Temperature ratings and expand series model offering