

## **Declaration of Performance**

According to Construction Product Regulation EU No. 305/2011 No. 429534-4

Unique identification code of the product-type	ArenaMatch Utility AMU208		
2. Identification of the product	ArenaMatch Utility AMU208		
3. Intended use	Fire detection and fire alarm systems installed in and around buildings		
Name, registered trade name or trade mark and contact address of the manufacturer	Bose Corporation The Mountain Framingham, MA 01701 USA		
5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks in art. 12 (2)	N/A		
System of assessment and verification of constancy of performance of the construction products:	System 1		
7. Performance of the notified body as required in the harmonised standards	UL INTERNATIONAL (UK) LTD. (ID 0843) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued certificate of constancy of performance/certificate of conformity.		
Number of issued certificate of constancy of performance/certificate of conformity	00843-CPR-0543	•	
8. European Technical Assessment	No technical assessment has been issued.		
9. Declared performance	All requirements including all Essential Characteristics and the		
	corresponding performance for the intended use or uses indicated in item 3 have been determined as described in hEN mentioned in the following table		
Essential characteristics	Performance	Harmonized technical specification EN 54-24: April 2008	
Performance under fire condition	Pass	4.2, 5.2, 5.3, 5.4, 5.5	
Operational reliability	Pass	4.3, 4.4, 4.5, 5.6, 5.18	
Durability of operational reliability:	Pass	5.7, 5.8, 5.9	
Darability of operational reliability.	1 433	0.1, 0.0, 0.0	



	1			
temperature resistance				
Durability of operational reliability:	Pass	5.10, 5.11, 5.12		
humidity resistance				
Durability of operational reliability:	Pass	5.13		
corrosion resistance				
Durability of operational reliability:	Pass	5.15, 5.16, 5.17		
impact and vibration resistance				
10. The performance of the product identified in points 1 and 2 is in conformity with the declared				
performance in point 9. This declaration of performance is issued under the sole responsibility of the				
manufactured identified in point 4.				
City, Date	Name, Signature			
Bose Corporation				
The Mountain	Poh Poh Ha			
Framingham, MA 01701				
USA	Porton			
		Constant of the Constant of th		
2020-7-16	PohPoh Gan			
	Manager, Complianc	e Assurance Engineering		