

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160728-E310130  
**Report Reference** E310130-20160726  
**Issue Date** 2016-JULY-28

**Issued to:** COOPER CAPRI SAS  
36 RUE DES FONTENILS  
41600 NOUAN LE FUZELIER FRANCE

**This is to certify that  
representative samples of**

CABLE SEALING FITTINGS FOR USE IN HAZARDOUS  
LOCATIONS

Please see addendum

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

Standard No. UL 2225, Cables and Cable-Fittings for Use in  
Hazardous (Classified) Locations. Standard No. UL 514B,  
CONDUIT, TUBING, AND CABLE FITTINGS.

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160728-E310130  
**Report Reference** E310130-20160726  
**Issue Date** 2016-JULY-28


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL - Cable Sealing Fitting Models ADE-6FC, followed by No. 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16 or 17. For use in Class I, Division 1, Groups A, B, C and D Hazardous Locations. For use with cable type ITC-HL and Cooper Crouse-Hinds Type TSC sealing compound. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive, for vertical or horizontal mounting.

USL - Cable Sealing Fitting Models ADE-6FC, followed by No. 5, 6, 7, 8 or 9. For use in Class I, Division 1, Groups A, B, C and D Hazardous Locations. For use with cable type TC-ER-HL and Cooper Crouse-Hinds Type TSC sealing compound. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive, for vertical or horizontal mounting.

USL - Cable Sealing Fitting Models ADE-1FC, followed by No. 4, 5, 6, 7, 8 or 9. For use in Class I, Division 1, Groups A, B, C and D Hazardous Locations. For use with cable type TC-ER-HL and Cooper Crouse-Hinds Type TSC sealing compound. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive, for vertical or horizontal mounting.

USL - Cable Sealing Fitting Models ADE-1FC and ADE-6FC, followed by No. 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, or 17;. For use in Class I, Division 2, Groups A, B, C and D Hazardous Locations. For use with for use with cable types TC, TC-ER, TC-ER-HL, PLTC, PLTC-ER, ITC, ITC-ER, ITC-HL, MV, and Cooper Crouse-Hinds Type TSC sealing compound. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive, for vertical or horizontal mounting.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

