



A P P R O V A L S ®

## Certificate of Suitability

\*Addendum\*

**Certificate No.:** SAA181339

**Date of Issue:** 10 October 2019

**Class Description:** Non-Declared

**Product Description:** Battery Inverter

Additional Models	Trade Name	Rating
MultiPlus-II 48/3000/35-32 GX	Victron Energy	DC: 48Vdc, Charge/discharge 35/75A Max Grid: 187-250V ~ 50/60Hz 32A Output: 230V ~ 50Hz, 16A charging, 11A discharging, 3000VA/2400W
MultiPlus-II 48/5000/70-50	Victron Energy	DC: 48Vdc, Charge/discharge 70/120A Max Grid: 187-250V ~ 50/60Hz 50A Output: 230V ~ 50Hz, 18A charging, 19A discharging, 5000VA/4000W

A handwritten signature in black ink, appearing to be 'M. ...', positioned above a horizontal line.

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd confirms that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)



Issued: 10-10-19 181339/3